OhioEPA
State of Ohio Environmental Protection Agency

01

PERMIT TO OPERATE AN AIR CONTAMINANT SOURCE

Date of Issuance 03/03/95 Application No. 15760008060001

Effective Date 03/03/95 Permit Fee $000

This document constitutes issuance to:

WATER POLLUTION CONTROL CENTER
5530 CENTRAL AVE S E
CANTON OHIO 44707

of a permit to operate for:

GASOLINE/FUEL DISPENSING FACILITY W/ VB-1 & SUB F
GASOLINE DISPENSING FACILITY

The following terms and conditions are hereby expressly incorporated into this permit to operate:

1. This permit to operate shall be effective until 03/03/98
You will be contacted approximately six months prior to this date regarding the renewal of this permit. If you are not contacted, please write to the appropriate Ohio EPA field office.
2. The above-described source is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.
3. Prior to any modification of this source, as defined in rule 3745-31-01 of the Ohio Administrative Code (OAC), a permit to install must be granted by the Ohio EPA pursuant to OAC Chapter 3745-31.
4. The Director of the Ohio EPA or an authorized representative may, subject to the safety requirements of the permit holder, enter upon the premises of this source at any time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit.
5. A permit fee in the amount specified above must be remitted within 15 days from the issuance date of this permit.
6. Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA field office must be notified in writing of any transfer of this permit.
7. This source and any associated air pollution control system(s) shall be maintained regularly in accordance with good engineering practices in order to minimize air contaminant emissions. Any malfunction of this source or any associated air pollution control system(s) shall be reported immediately to the appropriate Ohio EPA field office in accordance with OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this source.
8. Any unauthorized or emergency release of an air contaminant from this source which, due to the toxic or hazardous nature of the material, may pose a threat to public health, or otherwise endanger the safety or welfare of the public, shall be reported immediately to the appropriate Ohio EPA field office (during normal business hours) or to the Ohio EPA's Emergency Response Group (1-800-282-9378). (Additional reporting may be required pursuant to the federal Comprehensive Environmental Response, Compensation, and Liability Act.)
9. The appropriate Ohio EPA field office is:
AIR POLLUTION CNTRL DIV. CANTON CITY HEALTH DEPT.
CITY HALL 420 MARKET AVE. NORTH
CANTON, OH 44702-1544 (216)-489-3385
10. ☐ If this term and condition is checked, the permit holder is subject to the attached special terms and conditions.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Donald R Schregardus
Director

EPA 3834
Revised 9-90

APPLICATION NUMBER : **15 76 00 0806 G001**

FACILITY NAME : **WATER POLLUTION CONTROL CENTER**

EQUIPMENT DESCRIPTION : **GASOLINE DISPENSING FACILITY W/ VB-1 & SUB F**

COMPANY ID : **GASOLINE DISPENSING FACILITY**

SPECIAL TERMS AND CONDITIONS

1. **Applicable State Regulation(s)**

The following rules of the Ohio Administrative Code establish the applicable emission limitations and/or control requirements for this source:

3745-21-09 (R)
3745-31-05
3745-35-02

(This condition in no way limits the applicability of other requirements of the Ohio Administrative Code to this source.)

2. **Allowable Mass Emission Limitation(s) and/or Control Requirements**

The allowable mass emission limitation(s) and/or control requirements for the operation(s), equipment and/or property identified below are specified in the following table:

Operation(s), Equipment and/or Property	Allowable Mass Emission Emission Limitation(s) and/or Control Requirements
GASOLINE/FUEL DISPENSING FACILITY WITH VB-1 INCLUDING RELATED STORAGE TANKS OF CAPACITY 1,000 GALLONS (GASOLINE), 1,000 GALLONS (DIESEL), AND 600 GALLONS (KEROSENE)	0.5 TPY OC SEE FOLLOWING SPECIAL TERMS AND CONDITIONS

3. This source shall be serviced by a Stage I vapor balance system. The vapor balance system shall be designed and operated to route at least 90% by weight of the organic compounds in the displaced vapors from the storage tanks to the delivery vessel and shall be equipped with a means to prevent the discharge into the atmosphere of displaced vapors from an unconnected vapor line. This shall be used at all times when filling the tanks.

4. The transfer of gasoline from a delivery vessel to a stationary storage tank shall be conducted by use of submerged fill into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank.

5. This facility shall be serviced by a bulk gasoline plant or terminal that is in compliance with OAC Rule 3745-21-09(P) or (Q), respectively.

6. There shall be no leaks in the vapor and liquid lines during the transfer of gasoline.

7. All fill caps shall be "in place" and clamped during normal storage conditions.

8. The gasoline dispensing facility shall repair within fifteen (15) days any leaks from the vapor balance system which is employed to meet the requirements of Paragraph (A)(3) of OAC Rule 3745-31-05 or Paragraph (R)(1) of OAC Rule 3745-21-09 when such leaks are equal to or greater than 100% of the lower explosive limit of propane, as determined under Paragraph (K) of OAC Rule 3745-21-10.

9. Any diesel and/or kerosene dispensing operation identified within this permit consists of the transfer of diesel and/or kerosene from a delivery vessel to a stationary storage tank through the use of submerged filling into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank.