



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

11/15/02

CERTIFIED MAIL

RE: Final Chapter 3745-35 Permit To Operate

G001 (GDF) GDF

North Canton Schools Bus Garage (15-76-17-1560)

Ray Nist
525 Seventh Street NE
North Canton, OH 44720

RECEIVED

DEC - 2 2002

Dear Ray Nist:

CANTON CITY HEALTH DEPT.
AIR POLLUTION DIVISION

The enclosed Permit(s) to Operate allow you to operate the described emissions unit(s) in the manner indicated in the Permit(s). Because each permit contains several terms and conditions, I urge you to read them carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Review Appeals Commission within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. It is also requested by the Director that a copy of the appeal be served upon the Environmental Enforcement Section of the Office of the Attorney General. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
236 East Town Street
Room 300
Columbus, Ohio 43215

If you have any questions, please contact the Canton Division of Air Pollution Control at (330) 489-3385.

Very truly yours,

Michael W. Ahern

Michael W. Ahern, Supervisor
Field Operations and Permit Section
Division of Air Pollution Control

cc: Canton Division of Air Pollution Control



State of Ohio Environmental Protection Agency

Final Permit To Operate An Emissions Unit

Effective Date: 11/15/02

Expiration Date: 11/15/07

This document constitutes issuance to:

Facility ID: 15-76-17-1560
North Canton Schools Bus Garage
387 Pershing Street NE
North canton, OH 44720

of a permit to operate for:

G001 (GDF)
GDF

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your permit:

Canton Division of Air Pollution Control
420 Market Avnue N.
Canton, OH 44702-1544
(330) 489-3385

This permit is granted subject to the conditions attached hereto.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Christopher Jones
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an

authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

Canton Division of Air Pollution Control
420 Market Avenue N.
Canton, OH 44702-1544
(330) 489-3385

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Part II: Special Terms and Conditions

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
G001 - Gasoline Dispensing Facility 3,000 gallon gasoline storage tank and 10,000 gallon diesel storage tank.	OAC rule 3745-31-05(A)(3) PTI 15-01494	The volatile organic compound (VOC) emissions shall not exceed 0.65 ton/year. Best Available Technology (BAT) is Stage I vapor control - 90% control efficiency for VOC for gasoline storage tanks and submerged fill for gasoline and diesel storage tanks.
	OAC rule 3745-21-09(R)	See section B.1. below Exempt because throughput is less than 120,000 gallon/year.

2. Additional Terms and Conditions

None

B. Operational Restrictions

1. The permittee shall comply with the following operational restrictions for the Stage I vapor control system:
 - a. the vapor balance system shall be kept in good working order and shall be used at all times during the transfer of gasoline;
 - b. there shall be no leaks in the delivery vessel pressure/vacuum relief valves and hatch covers;
 - c. there shall be no leaks in the vapor lines or liquid lines during the transfer of gasoline;
 - d. the transfer of gasoline from a delivery vessel to a stationary storage tank shall be conducted by use of submerged fill into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank;
 - e. all fill caps shall be "in place" and clamped during normal storage conditions; and
 - f. the permittee shall repair within 15 days any leak from the vapor balance system or vapor control system, which is employed to meet the requirements of paragraph (R)(1) of OAC rule 3745-21-09, when such leak is equal to or greater than 100 percent of the lower explosive limit of propane, as determined under paragraph (K) of OAC rule 3745-21-10.

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain records of the results of any leak checks, including, at a minimum, the following information:
 - a. date of inspection;
 - b. findings (may indicate no leaks discovered or location, nature, severity of each leak).
 - c. leak determination method;
 - d. corrective action (date each leak repaired and reasons for any repair interval in excess of 15 calendar days); and
 - e. inspector's name and signature.
2. The permittee shall maintain records of the annual gasoline throughput for the facility and determine the annual VOC emission rate. (See section E.1.a, which explains how to calculate annual VOC emissions).

D. Reporting Requirements

1. Any leak from the vapor balance system or vapor control system that is not repaired within 15 days after identification shall be reported to the Canton local air agency within 30 days after the repair is completed.
2. Any leak from the vapor balance system or vapor control system that is not repaired within 15 days after identification shall be reported to the Canton local air agency within 30 days after the repair is completed.

E. Testing Requirements

1. Compliance with the annual volatile organic compound (VOC) emission limit in Section A.1 of these terms and conditions shall be calculated as the sum of the VOC emissions from all gasoline storage tank filling and dispensing operations, and, if applicable, diesel, kerosene, and used oil tank filling operations at the gasoline dispensing facility (unless otherwise exempted pursuant to OAC rule 3745-31-03). This calculation shall be based on the actual gasoline, diesel, kerosene, and used oil throughputs for the facility using the calculation factors below.

- 1.a Emissions Limitation:
0.65 ton VOC/year.

Applicable Compliance Method:

Multiply the appropriate emission factor below by the gallons of gasoline, diesel, kerosene, or used oil dispensed per year and divide by 2,000 lbs/ton. Repeat this calculation for each material dispensed at the facility and sum the results to yield the total annual VOC emission rate.

(Emission rates (factors) are expressed in pounds (lbs) of organic compounds per 1,000 gallons of gasoline throughput. Emission factors are for VOC as well as total organic compound (OC) emissions because the methane and ethane content of gas is negligible.)

- i. Since this gasoline dispensing facility has submerged tank filling with Stage I vapor control for gasoline storage tanks, the emission factor for gasoline storage tank filling and dispensing operations = 13.0 lbs VOC/1,000 gallons. (Gasoline emission factors are from USEPA publication AP-42, Fifth Edition, table 5.2-7).
- ii. The emission factor for diesel, kerosene, and used oil tank filling operations when the facility has submerged tank filling = 0.027 lb VOC/1,000 gallons. (This emission factor is the SCC emission factor for transfer operations from diesel storage tanks. It is assumed that the same emission factor applies to kerosene and used oil transfer operations.)

F. Miscellaneous Requirements

None