John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

12/4/2013

Certified Mail

No	TOXIC REVIEW
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
No	MACT/GACT
No	NSPS
No	NESHAPS
No	NETTING
No	MODELING SUBMITTED
No	SYNTHETIC MINOR TO AVOID TITLE V
No	FEDERALLY ENFORCABLE PTIO (FEPTIO)
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Mr. Steve Hilton
CSA AMERICA, INC.
8501 E PLEASANT VALLEY RD
Cleveland, OH 44131-5575

RE: FINALAIR POLLUTION PERMIT-TO-INSTALL AND OPERATE
Facility ID: 1318278206
Permit Number: P0115442
Permit Type: Renewal
County: Cuyahoga

Dear Permit Holder:

Enclosed please find a final Ohio Environmental Protection Agency (EPA) Air Pollution Permit-to-Install and Operate (PTIO) which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully. In this letter you will find the information on the following topics:

- **How to appeal this permit**
- **How to save money, reduce pollution and reduce energy consumption**
- **How to give us feedback on your permitting experience**
- **How to get an electronic copy of your permit**

How to appeal this permit

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of $70.00, made payable to “Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General’s Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
77 South High Street, 17th Floor
Columbus, OH 43215

How to save money, reduce pollution and reduce energy consumption

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: www.ohioairquality.org/clean_air

How to give us feedback on your permitting experience

Please complete a survey at www.epa.ohio.gov/survey.aspx and give us feedback on your permitting experience. We value your opinion.

How to get an electronic copy of your permit

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Search for Permits" link under the Permitting topic on the Programs tab.

If you have any questions, please contact Cleveland Division of Air Quality at (216)664-2297or the Office of Compliance Assistance and Pollution Prevention at (614) 644-3469.

Sincerely,

Michael W. Ahern

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: CDAQ

FINAL

Division of Air Pollution Control
Permit-to-Install and Operate
for
CSA AMERICA, INC.

Facility ID:	1318278206
Permit Number:	P0115442
Permit Type:	Renewal
Issued:	12/4/2013
Effective:	12/4/2013
Expiration:	12/4/2023

Division of Air Pollution Control
Permit-to-Install and Operate
for
CSA AMERICA, INC.

Table of Contents

Authorization 1

A. Standard Terms and Conditions 3

1. What does this permit-to-install and operate ("PTIO") allow me to do? 4
2. Who is responsible for complying with this permit? 4
3. What records must I keep under this permit? 4
4. What are my permit fees and when do I pay them? 4
5. When does my PTIO expire, and when do I need to submit my renewal application? 4
6. What happens to this permit if my project is delayed or I do not install or modify my source? 5
7. What reports must I submit under this permit? 5
8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit? 5
9. What are my obligations when I perform scheduled maintenance on air pollution control equipment? 5
10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report? 6
11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located? 6
12. What happens if one or more emissions units operated under this permit is/are shut down permanently? 6
13. Can I transfer this permit to a new owner or operator? 7
14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"? 7
15. What happens if a portion of this permit is determined to be invalid? 7

B. Facility-Wide Terms and Conditions 8

C. Emissions Unit Terms and Conditions 10

1. P001, Test Cell One 11

Authorization

Facility ID:	1318278206
Application Number(s):	A0048830
Permit Number:	P0115442
Permit Description:	PTIO renewal for a Natural Gas Fired Water Heater Safety Certification Laboratory Test Cell #1 controlled by a thermal oxidizer.
Permit Type:	Renewal
Permit Fee:	$0.00
Issue Date:	12/4/2013
Effective Date:	12/4/2013
Expiration Date:	12/4/2023

Permit Evaluation Report (PER) Annual Date: Apr 1 - Mar 31, Due May 15

This document constitutes issuance to:

CSA AMERICA, INC.
8501 E PLEASANT VALLEY RD
Cleveland, OH 44131-5575

of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page.

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Cleveland Division of Air Quality
2nd Floor
75 ErieviewPlaza
Cleveland, OH 44114
(216)664-2297

The above named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s))listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Scott J. Nally
Director

Authorization (continued)

Permit Number: P0115442
Permit Description: PTIO renewal for a Natural Gas Fired Water Heater Safety Certification Laboratory Test Cell #1 controlled by a thermal oxidizer.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	**P001**
Company Equipment ID:	Test Cell One
Superseded Permit Number:	13-03557
General Permit Category and Type:	Not Applicable

A. Standard Terms and Conditions

1. What does this permit-to-install and operate ("PTIO") allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

PTIO fee.This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11, or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

Annual emissions fee.Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is

very important that you submit a complete renewal permit application (postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended by up to 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective, and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.

10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the [DO/LAA] in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction, but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. “Shut down” means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as beingpermanently shut down without first applying for and obtaining a permit pursuantto OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, you must follow the procedures in OAC Chapter 3745-31, including notifying Ohio EPA or the local air agency of the change in ownership or operator. Any transferee of this permit must assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.

B. Facility-Wide Terms and Conditions

1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

   a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

      (1) None.

   b) For the purpose of a permit-to-operate document, the facility-wide terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

      (1) None.

C. Emissions Unit Terms and Conditions

1. P001, Test Cell One

Operations, Property and/or Equipment Description:

Natural Gas Fired Water Heater Safety Certification Laboratory Test Cell #1 controlled by a thermal oxidizer.

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 13-3557, issued 11/30/2006)	Organic compound (OC) emissions shall not exceed 6.15 lbs/hour and 7.3 tons/year or an overall VOC reduction of 85% shall be achieved for this emissions unit. Visible particulate emissions shall not exceed 5% opacity as a six-minute average from the stack serving this emissions unit. See c)(1) and c)(2) below.
b.	OAC rule 3745-17-07(A)(1)	The visible emissions requirement of this rule is less stringent than the requirements established by OAC rule 3745-31-05(A)(3).

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
c.	OAC rule 3745-114-01	See g)(1) below.

(2) Additional Terms and Conditions

a. The OC emissions from the test cell shall be vented to the thermal oxidizer that shall meet the operational, monitoring, and recordkeeping requirements of this permit, when this emissions unit is in operation.

b. The permittee shall operate a flame arrester into the inlet of the thermal oxidizer.

c. The thermal oxidizer process stream has been designed so that the hydrocarbon concentration at the inlet of the oxidizer does not exceed 25% of the lower explosive limits of the gasoline being processed, in accordance with NFPA standards. The permittee shall ensure that these levels are not exceeded at all times when actively venting the test cell.

d. The permittee shall operate a flame ionization detector-type hydrocarbon analyzer (FIDHCA) to measure and record the hydrocarbon concentration inside of the test chamber during each test on a continuous basis.

e. Provisions for Handling Sudden and Violent Ignition of Gasoline Vapors: There is a chance that the tests performed in the cell may cause a sudden and violent ignition of gasoline vapors inside of the test chamber. The chamber should be designed to withstand such an ignition.

c) Operational Restrictions

(1) The permittee shall operate an interlocking device which does not allow the test cell to actively vent unless the thermal oxidizer temperature is maintained at no less than the average temperature during which most recent emissions test demonstrated that the emissions unit was in compliance, which is at no less than 1,400 degrees Fahrenheit.

(2) The permittee shall not actively vent the test cell without the benefit of the thermal oxidizer.

d) Monitoring and/or Recordkeeping Requirements

(1) In order to maintain compliance with the applicable emission limitation(s) contained in this permit, the acceptable combustion temperature within the thermal oxidizer, during any period of time when the emissions unit controlled by the thermal oxidizer is in operation, shall not be less than 1,400 degrees Fahrenheit.

(2) The permittee shall properly operate, and maintain a continuous temperature monitor and recorder that measures and records the combustion temperature within the thermal oxidizer when the emissions unit is in operation, including periods of startup and shutdown. Units shall be in degrees Fahrenheit. The accuracy for each thermocouple,

monitor, and recorder shall be guaranteed by the manufacturer to be within ±1 percent of the temperature being measured or ± 5 degrees Fahrenheit, whichever is greater. The temperature monitor and recorder shall be installed, calibrated, operated, and maintained in accordance with the manufacturer's recommendations, instructions, and the operating manuals, within any modifications deemed necessary by the permittee. The permittee shall collect and record the following information each day the emissions unit is in operation:

a. all 3-hour blocks of time, when the emissions unit controlled by the thermal oxidizer was in operation, during which the average combustion temperature within the thermal oxidizer was more than 50 degrees Fahrenheit below the average temperature during the most recent performance test that demonstrated the emissions unit was in compliance and;

b. a log or record of the operating time for the capture (collection) system, thermal oxidizer, monitoring equipment, and the associated emissions unit.

(3) The permittee shall collect and record the following information each day for this emissions unit:

a. the permittee shall maintain daily records of the afterburner combustion temperature, in degrees Fahrenheit when the test cell was actively venting;

b. a log of the downtime for the capture (collection) system, control device, and monitoring equipment, when the associated emissions unit was actively venting;

c. the dates and periods of time the test cell was actively vented without the benefit of the thermal oxidizer;

d. the test periods of time and gasoline (i.e., amount used minus the amount collected) per test and on a daily basis; and

e. maintain mass balance records of the gasoline consumed, estimated losses of OC emissions, determined in accordance with f)(1)a. of this permit, and the number of failed units during the reporting period. The capture and control efficiency shall be determined from the most recent performance test that demonstrated compliance.

(4) Whenever the monitored combustion chamber temperature within the thermal oxidizer deviates from the range or limit established in accordance with this permit, the permittee shall promptly investigate the cause of the deviation. The permittee shall maintain records of the following information for each investigation:

a. the date and time the deviation began;

b. the magnitude of the deviation at that time;

c. the date the investigation was conducted;

d. the name(s) of the personnel who conducted the investigation; and

e. the findings and recommendations.

In response to each required investigation to determine the cause of a deviation, the permittee shall take prompt corrective action to bring the operation of the control equipment within the acceptable range/limit specified in this permit, unless the permittee determined that the corrective action is not necessary and documents the reasons for that determination and the date and time the deviation ended. The permittee shall maintain records of the following information for each correction action taken:

f. a description of the corrective action;

g. the date corrective action was completed;

h. the date and time the deviation ended;

i. the total period of time (in minutes) during which there was a deviation;

j. the temperature readings immediately after the corrective action was implemented; and

k. the name(s) of the personnel who performed the work.

Investigation and records required by this paragraph do not eliminate the need to comply with the requirements of OAC rule 3745-15-06 if it is determined that a malfunction has occurred.

The temperature range/limit is effective for the duration of this permit, unless revisions are requested by the permittee and approved in writing by the Cleveland Division of Air Quality (Cleveland DAQ). The permittee may request revisions to the permitted temperature range/limit based upon information obtained during future performance tests that demonstrate compliance with the allowable emission rate(s) for the controlled pollutant(s). In addition, approved revisions to the temperature range/limit will not constitute a relaxation of the monitoring requirements of this permit and may be incorporated into this permit by means of a minor permit modification.

e) Reporting Requirements

(1) The permittee shall submit an annual Permit Evaluation Report (PER) to the Ohio EPA District Office or Local Air Agency by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve months for each air contaminant source identified in this permit. It is recommended that the PER is submitted electronically through the Ohio EPA's "e-Business Center: Air Services" although PERs can be submitted via U.S. postal service or can be hand delivered.

(2) The permittee shall identify in the annual permit evaluation report the following information concerning the operations of the thermal oxidizer during the 12-month reporting period for this emissions unit:

a. an identification of each hour during which the average controlled organic compound emissions from the gasoline usage exceeded 6.15 pounds per hour, and the actual average controlled organic compound emissions for each such hour;

b. each period of time (start time and date, and end time and date) when the average combustion temperature within the thermal oxidizer was below the minimum temperature;

c. any period of time (start time and date, and end time and date) when the emissions unit was in operation and the process emissions were not vented to the thermal oxidizer.

d. each incident of deviation described in “a”, “b”, or “c” (above) where a prompt investigation was not conducted;

e. each incident of deviation described in “a”, “b”, or “c” where prompt corrective action, that would bring the emissions unit into compliance, and/or the temperature within the thermal oxidizer into compliance with the acceptable range, was determined to be necessary are was not take; and

f. each incident of deviation described in “a”, “b”, or “c” where proper records were not maintained for the investigation and/or the above corrective action(s), as identified in the monitoring and recordkeeping requirements of this permit.

(3) The reports required by this permit may be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal; or they may be mailed as a hard copy to the appropriate district office or local air agency.

f) Testing Requirements

(1) Compliance with the Emissions Limitations and/or Control Requirements specified in b) of these terms and conditions shall be determined in accordance with the following methods:

a. <u>Emissions Limitation</u>:

OC emissions shall not exceed 6.15 lbs/hour and 7.3 tons/year or an overall emissions reduction of 85%.

<u>Applicable Compliance Method</u>:

The limit is based upon the gasoline usage per test, control of emissions by use of the thermal oxidizer, and the capture efficiency of the control device. The recordkeeping requirements and the following equations shall be used to determine compliance:

Initial Gasoline Quantity (lbs/test) - Amount Collected Post Test (lbs/test) = Gasoline usage (lbs of gasoline lost/test)

Gasoline usage (lbs of gasoline lost/test) x [1 - (overall control efficiency)] = OC emissions/test

OC emissions/test (lbs/test) + OC emissions/test (lbs/test) = OC emissions rate (lbs/day) / Testing duration (hours/day) = Average OC emission rate (lbs/hour)

The capture and control efficiencies are determined from the most recent stack test that demonstrated compliance with the allowable limit. The overall control percent reduction can be determined by multiplying the capture efficiency by the control efficiency of the oxidizer.

If required, compliance with the above pound per hour limit or the 85% overall reduction can be demonstrated through emissions testing conducted in accordance with Method 25 or 25A of 40 CFR Part 60, Appendix A.

b. Emissions Limitation:

Visible particulate emissions from the stack serving this emissions unit shall not exceed 5% opacity as a 6-minute average.

Applicable Compliance Method:

Compliance with the visible particulate emissions limitation shall be determined through visible emissions observations performed in accordance with U.S. EPA Method 9.

g) Miscellaneous Requirements

(1) Modeling to demonstrate compliance with the Toxic Air Contaminant Statute, ORC 3704.03(F)(4)(b), was not necessary because the emissions units maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a “modification” as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase above 1.0 ton per year may require the permittee to apply for an obtain a new permit to install.