

Facility ID: 0679010110 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0679010110 Emissions Unit ID: P013 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Monolithics building: batching system, mortar mixing, crushing, BEST sand system - controlled by two fabric filters	OAC 3745-31-05(A)(3) PTI # 06 - 4937	Particulate matter emissions from the fabric filter exhausts shall not exceed 0.020 grain per dry standard cubic foot of exhaust gases.
	OAC 3745-17-07(A)	The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A). Visible particulate emissions from any stack shall not exceed twenty per cent opacity, as a six-minute average, except for a period of six consecutive minutes in any sixty minutes. Visible particulate emissions shall not exceed sixty percent opacity, as a six-minute average, at any time.

2. **Additional Terms and Conditions**
 - (a) None

B. Operational Restrictions

1. None

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform daily checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stacks serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the daily check until the incident has ended. The observer may indicate that the visible emission incident was continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

D. Reporting Requirements

1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from any stack serving this emissions unit and (b) describe any corrective actions taken to minimize or eliminate the visible particulate emissions. These reports shall be submitted to the Ohio EPA Southeast District Office by January 31 and July 31 of each year and shall cover the previous 6-month period.

E. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.1. of these terms and conditions shall be determined in accordance with the following method(s):
Emissions Limitation: Particulate matter emissions from the fabric filter exhausts shall not exceed 0.020 grain per dry standard cubic foot of exhaust gases.

Applicable Compliance Method:

Compliance shall be determined in accordance with the test methods and procedures in USEPA Methods 1 through 5, which are located in 40 CFR Part 60, Appendix A. No testing is specifically required to demonstrate compliance with this limit but, if appropriate, may be requested pursuant to OAC rule 3745-15-04(A).
Emission Limitation: Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.

Applicable Compliance Method:

If required, compliance with the visible emission limitation shall be determined in accordance with the test methods and procedures in USEPA Method 9, which is located in 40 CFR Part 60, Appendix A.

F. Miscellaneous Requirements

1. None