

John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Craig W. Butler, Director

6/10/2014

Certified Mail

Facility ID: 0855100041  
Permit Number: P0114113  
County: Miami

Roger Wehrman  
Piqua Municipal Power System  
201 Hemm Ave.  
Piqua, OH 45356

RE: FINAL AIR POLLUTION CONTROL TITLE V PERMIT  
Permit Type: Renewal

Dear Permit Holder:

Enclosed is a final Ohio Environmental Protection Agency (EPA) Air Pollution Title V permit that allows you to operate the facility in the manner indicated in the permit. Because this permit may contain several conditions and restrictions, we urge you to read it carefully. In this letter you will find the information on the following topics:

- **How to appeal this permit**
- **How to save money, reduce pollution and reduce energy consumption**
- **How to give us feedback on your permitting experience**
- **How to get an electronic copy of your permit**

**How to appeal this permit**

The issuance of this Title V permit is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission  
77 South High Street, 17th Floor  
Columbus, OH 43215

## **How to save money, reduce pollution and reduce energy consumption**

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: [www.ohioairquality.org/clean\\_air](http://www.ohioairquality.org/clean_air)

## **How to give us feedback on your permitting experience**

Please complete a survey at [www.epa.ohio.gov/survey.aspx](http://www.epa.ohio.gov/survey.aspx) and give us feedback on your permitting experience. We value your opinion.

## **How to get an electronic copy of your permit**

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Division of Air Pollution Control (DAPC) Web page, [www.epa.ohio.gov/dapc](http://www.epa.ohio.gov/dapc) by clicking the "Search for Permits" link under the Permitting topic on the Programs tab.

If you have any questions regarding this permit, please contact the Regional Air Pollution Control Agency as indicated on page one of your permit.

Sincerely,



Michael W. Ahern, Manager  
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA Region 5 *Via E-Mail Notification*  
Regional Air Pollution Control Agency



**FINAL**

**Division of Air Pollution Control  
Title V Permit  
for  
Piqua Municipal Power System**

Facility ID:	0855100041
Permit Number:	P0114113
Permit Type:	Renewal
Issued:	6/10/2014
Effective:	7/1/2014
Expiration:	7/1/2019





**Division of Air Pollution Control**  
**Title V Permit**  
for  
Piqua Municipal Power System

**Table of Contents**

Authorization .....	1
A. Standard Terms and Conditions .....	2
1. Federally Enforceable Standard Terms and Conditions .....	3
2. Monitoring and Related Record Keeping and Reporting Requirements.....	3
3. Reporting of Any Exceedence of a Federally Enforceable Emission Limitation or Control Requirement Resulting From Scheduled Maintenance.....	6
4. Risk Management Plans .....	7
5. Title IV Provisions .....	7
6. Severability Clause .....	7
7. General Requirements .....	7
8. Fees.....	8
9. Marketable Permit Programs.....	8
10. Reasonably Anticipated Operating Scenarios .....	9
11. Reopening for Cause .....	9
12. Federal and State Enforceability .....	9
13. Compliance Requirements .....	9
14. Permit Shield .....	11
15. Operational Flexibility.....	11
16. Emergencies .....	12
17. Off-Permit Changes .....	12
18. Compliance Method Requirements .....	12
19. Insignificant Activities or Emissions Levels.....	13
20. Permit to Install Requirement.....	13
21. Air Pollution Nuisance .....	13
22. Permanent Shutdown of an Emissions Unit .....	13
23. Title VI Provisions .....	13
24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only .....	14
25. Records Retention Requirements Under State Law Only.....	14
26. Inspections and Information Requests .....	14
27. Scheduled Maintenance/Malfunction Reporting For State-Only Requirements.....	15
28. Permit Transfers .....	15



- 29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations ..... 15
- 30. Submitting Documents Required by this Permit ..... 16
- B. Facility-Wide Terms and Conditions..... 17
- C. Emissions Unit Terms and Conditions ..... 19
  - 1. B007, C.T. # 8..... 20



**Final Title V Permit**  
Piqua Municipal Power System  
**Permit Number:** P0114113  
**Facility ID:** 0855100041  
**Effective Date:** 7/1/2014

## Authorization

Facility ID: 0855100041  
Facility Description: electrical services  
Application Number(s): A0047222  
Permit Number: P0114113  
Permit Description: Renewal Title V permit for a #2 fuel oil-fired combustion turbine used for peaking and emergency power generation.  
Permit Type: Renewal  
Issue Date: 6/10/2014  
Effective Date: 7/1/2014  
Expiration Date: 7/1/2019  
Superseded Permit Number: P0092147

This document constitutes issuance of an OAC Chapter 3745-77 Title V permit to:

Piqua Municipal Power System  
919 South Main street  
Piqua, OH 45356-5001


Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Regional Air Pollution Control Agency  
117 South Main Street  
Dayton, OH 45422-1280  
(937)225-4435

The above named entity is hereby granted a Title V permit pursuant to Chapter 3745-77 of the Ohio Administrative Code. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. You will be sent a notice approximately 18 months prior to the expiration date regarding the renewal of this permit. If you do not receive a notice, please contact the Regional Air Pollution Control Agency. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, if a timely renewal application is submitted. A renewal application will be considered timely if it is submitted no earlier than 18 months and no later than 6 months prior to the expiration date.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

  
Craig W. Butler  
Director



**Final Title V Permit**  
Piqua Municipal Power System  
**Permit Number:** P0114113  
**Facility ID:** 0855100041  
**Effective Date:** 7/1/2014

## **A. Standard Terms and Conditions**



**1. Federally Enforceable Standard Terms and Conditions**

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
- (1) Standard Term and Condition A. 24., Reporting Requirements Related to Monitoring and Record Keeping Requirements of State-Only Enforceable Permit Terms and Conditions
  - (2) Standard Term and Condition A. 25., Records Retention Requirements for State-Only Enforceable Permit Terms and Conditions
  - (3) Standard Term and Condition A. 27., Scheduled Maintenance/Malfunction Reporting For State-Only Requirements
  - (4) Standard Term and Condition A. 29., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
  - (5) Standard Term and Condition A. 30.

*(Authority for term: ORC 3704.036(A))*

**2. Monitoring and Related Record Keeping and Reporting Requirements**

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit), the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
- (1) The date, place (as defined in the permit), and time of sampling or measurements.
  - (2) The date(s) analyses were performed.
  - (3) The company or entity that performed the analyses.
  - (4) The analytical techniques or methods used.
  - (5) The results of such analyses.
  - (6) The operating conditions existing at the time of sampling or measurement.

*(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))*

- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

*(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))*



c) The permittee shall submit required reports in the following manner:

- (1) All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:

Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted by January 31, April 30, July 31, and October 31 of each year in accordance with Standard Term and Condition A.2.c)(2) below; and each report shall cover the previous calendar quarter. An exceedance of the visible emission limitations specified in OAC rule 3745-17-07(A)(1) that is caused by a malfunction is not a violation and does not need to be reported as a deviation if the owner or operator of the affected air contaminant source or air pollution control equipment complies with the requirements of OAC rule 3745-17-07(A)(3)(c).

In accordance with OAC rule 3745-15-06, a malfunction reportable under OAC rule 3745-15-06(B) is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any submitted scheduled maintenancerequests, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

- (2) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit or, in some cases, in section B. Facility-Wide Terms and Conditions of this Title V permit), all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the



probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be submitted promptly to the Regional Air Pollution Control Agency. Except as provided below, the written reports shall be submitted by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.

These written deviation reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. Full compliance with OAC rule 3745-77-07(A)(3)(c) requires reporting of all other deviations of the federally enforceable requirements specified in the permit as required by such rule.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement satisfies the reporting requirements specified in this Standard Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy (for the deviations so reported) the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this Standard Term and Condition.

See A.29 below if no deviations occurred during the quarter.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

- (3) All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not reported in accordance with Standard Term and Condition A.2)c)(2) above shall be submitted in the following manner:

Unless otherwise specified by rule, written reports that identify deviations of the following federally enforceable requirements contained in this permit; Standard Terms and Conditions: A.3, A.4, A.5, A.7.e), A.8, A.13, A.15, A.19, A.20, A.21, and A.23 of this Title V permit, as well as any deviations from the requirements in section C. Emissions Unit Terms and Conditions of this Title V permit, and any monitoring, record keeping, and reporting requirements, which are not reported in accordance with Standard Term and Condition A.2.c)(2) above shall be submitted to the Regional Air Pollution Control Agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months. Unless otherwise specified by rule, all other deviations from federally enforceable requirements identified in this permit shall be submitted annually as part of the annual compliance certification, including deviations of federally



enforceable requirements not specifically addressed by permit or rule for the insignificant activities or emissions levels (IEU) identified in section B. Facility-Wide Terms and Conditions of this Title V permit. Annual reporting of deviations is deemed adequate to meet the deviation reporting requirements for IEUs unless otherwise specified by permit or rule.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual and annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with Standard Term and Condition A.2.c)(2) above.

If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.

*(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii) and OAC rule 3745-77-07(A)(13)(b))*

- (4) Each written report shall be signed by a Responsible Official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete." Signature by the Responsible Official may be represented by entry of the personal identification number (PIN) by the Responsible Official as part of the electronic submission process or by the scanned attestation document signed by the Responsible Official that is attached to the electronically submitted written report.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))*

- (5) Consistent with A.2.c.1. above, reports of any required monitoring and/or record keeping information required to be submitted to Ohio EPA shall be submitted to Regional Air Pollution Control Agency unless otherwise specified.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*

### **3. Reporting of Any Exceedence of a Federally Enforceable Emission Limitation or Control Requirement Resulting From Scheduled Maintenance**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in Standard Term and Condition A.2.c)(1) above.

*(Authority for term: OAC rule 3745-77-07(A)(3)(c))*



#### **4. Risk Management Plans**

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

- a) a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or
- b) as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

*(Authority for term: OAC rule 3745-77-07(A)(4))*

#### **5. Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

*(Authority for term: OAC rule 3745-77-07(A)(5))*

#### **6. Severability Clause**

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

*(Authority for term: OAC rule 3745-77-07(A)(6))*

#### **7. General Requirements**

- a) Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit except as provided pursuant to A.16 below.
- c) This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with A.11 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.



- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.
- f) Except as otherwise indicated below, this Title V permit, or permit modification, is effective for five years from the original effective date specified in the permit. In the event that this facility becomes eligible for non-title V permits, this permit shall cease to be enforceable when:
- (1) the permittee submits an approved facility-wide potential to emit analysis supporting a claim that the facility no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on the permanent shutdown and removal of one or more emissions units identified in this permit; or
  - (2) the permittee no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on obtaining restrictions on the facility-wide potential(s) to emit that are federally enforceable or legally and practically enforceable ; or
  - (3) a combination of (1) and (2) above.

The permittee shall continue to comply with all applicable OAC Chapter 3745-31 requirements for all regulated air contaminant sources once this permit ceases to be enforceable. The permittee shall comply with any residual requirements, such as quarterly deviation reports, semi-annual deviation reports, and annual compliance certifications covering the period during which this Title V permit was enforceable. All records relating to this permit must be maintained in accordance with law.

*(Authority for term: OAC rule 3745-77-01(W), OAC rule 3745-77-07(A)(3)(b)(ii), OAC rule 3745-77(A)(7))*

## **8. Fees**

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

*(Authority for term: OAC rule 3745-77-07(A)(8))*

## **9. Marketable Permit Programs**

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(9))*



**10. Reasonably Anticipated Operating Scenarios**

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these standard terms and conditions shall apply to all operating scenarios authorized in this permit.

*(Authority for term: OAC rule 3745-77-07(A)(10))*

**11. Reopening for Cause**

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a) Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b) This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c) The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d) The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

*(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))*

**12. Federal and State Enforceability**

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

*(Authority for term: OAC rule 3745-77-07(B))*

**13. Compliance Requirements**

- a) Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a Responsible



Official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.

- b) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
- (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
  - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
  - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
  - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c) The permittee shall submit progress reports to the Regional Air Pollution Control Agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
  - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d) Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the Regional Air Pollution Control Agency) and the Administrator of the U.S. EPA in the following manner and with the following content:
- (1) Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted on or before April 30th of each year during the permit term.
  - (2) Compliance certifications shall include the following:
    - a. Identification of each term or condition that is the basis of the certification. The identification may include a statement by the Responsible Official that every term and condition that is federally enforceable has been reviewed, and such terms and conditions with which there has been continuous compliance throughout the year are not separately identified.
    - b. The permittee's current compliance status.



- c. Whether compliance was continuous or intermittent consistent with A.13.d.2.a above.
  - d. The method(s) used for determining the compliance status of the source currently and over the required reporting period consistent with A.13.d.2.a above.
  - e. Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
- (3) Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

*(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))*

#### **14. Permit Shield**

- a) Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.
- b) This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

*(Authority for term: OAC rule 3745-77-07(F))*

#### **15. Operational Flexibility**

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the Regional Air Pollution Control Agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the Regional Air Pollution Control Agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

*(Authority for term: OAC rules 3745-77-07(H)(1) and (2))*



## **16. Emergencies**

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

*(Authority for term: OAC rule 3745-77-07(G))*

## **17. Off-Permit Changes**

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a) The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b) The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emissions levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c) The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d) The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e) The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit-to-install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

*(Authority for term: OAC rule 3745-77-07(I))*

## **18. Compliance Method Requirements**

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Federal Register 8314, Feb. 24, 1997), in the context of any future proceeding.

*(This term is provided for informational purposes only.)*



**19. Insignificant Activities or Emissions Levels**

Each IEU that is subject to one or more applicable requirements shall comply with those applicable requirements.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**20. Permit to Install Requirement**

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**21. Air Pollution Nuisance**

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

*(Authority for term: OAC rule 3745-77-07(A)(1))*

**22. Permanent Shutdown of an Emissions Unit**

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification from the Responsible Official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the Responsible Official that the emissions unit was permanently shut down.

After the date on which an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an "emissions unit" as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the certification and submission to Ohio EPA, to meet any Title V permit requirements applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

Unless otherwise exempted, no emissions unit identified in this permit that has been certified by the Responsible Official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.

*(Authority for term: OAC rule 3745-77-01)*

**23. Title VI Provisions**

If applicable, the permittee shall comply with the standards for recycling and reducing emissions of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:



- a) Persons operating appliances for maintenance, service, repair, or disposal must comply with the required practices specified in 40 CFR 82.156.
- b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment specified in 40 CFR 82.158.
- c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

*(Authority for term: OAC rule 3745-77-01(H)(11))*

**24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only**

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or record keeping information shall be submitted to the Regional Air Pollution Control Agency.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Regional Air Pollution Control Agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

**25. Records Retention Requirements Under State Law Only**

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

**26. Inspections and Information Requests**

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine



whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

*(Authority for term: OAC rule 3745-77-07(C))*

**27. Scheduled Maintenance/Malfunction Reporting For State-Only Requirements**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the Regional Air Pollution Control Agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

**28. Permit Transfers**

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The Regional Air Pollution Control Agency must be notified in writing of any transfer of this permit.

*(Authority for term: OAC rule 3745-77-01(C))*

**29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations**

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

- a) where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in Standard Term and Condition A.2.c)(2); or
- b) where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potential to emit; or
- c) where the company's Responsible Official has certified that an emissions unit has been permanently shut down.



**30. Submitting Documents Required by this Permit**

All applications, notifications or reports required by terms and conditions in this permit to be submitted or "reported in writing" are to be submitted to Ohio EPA through the Ohio EPA's eBusiness Center: Air Services web service ("Air Services"). Ohio EPA will accept hard copy submittals on an as-needed basis if the permittee cannot submit the required documents through the Ohio EPA eBusiness Center. In the event of an alternative hard copy submission in lieu of the eBusiness Center, the post-marked date or the date the document is delivered in person will be recognized as the date submitted. Electronic submission of applications, notifications, or reports required to be submitted to Ohio EPA fulfills the requirement to submit the required information to the Director, the Regional Air Pollution Control Agency, and/or any other individual or organization specifically identified as an additional recipient identified in this permit unless otherwise specified. Consistent with OAC rule 3745-15-03, the required application, notification or report is considered to be "submitted" on the date the submission is successful using a valid electronic signature. Signature by the Responsible Official may be represented as provided through procedures established in Air Services.



## **B. Facility-Wide Terms and Conditions**



1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:
  - a) None.
2. NO<sub>x</sub> emissions from emission unit B007 shall not exceed 561.98 tons per rolling 12-month period.
3. The permittee shall maintain monthly records of the following information for emission unit B007:
  - a) The monthly NO<sub>x</sub> emissions rate, in tons.
  - b) The rolling, 12-month summation of the NO<sub>x</sub> emissions rate, in tons.
4. The permittee shall submit quarterly deviation (excursion) reports that identify all exceedances of the rolling, 12-month NO<sub>x</sub> emissions limitation for emission unit B007.

The quarterly deviation (excursion) reports shall be submitted in accordance with the reporting requirements of the Standard Terms and Conditions of this permit.

5. Compliance with the emission limitation(s) in 2., above of these terms and conditions shall be determined in accordance with the following method(s):

- a) Emission Limitation

NO<sub>x</sub> emissions from emission unit B007 shall not exceed 561.98 tons per rolling 12-month period.

- Applicable Compliance Method

Compliance with the emissions limitation shall be based upon record keeping specified in 3 above and shall be determined by:

- (1) for B007, multiplying the No. 2 fuel oil usage for the month by the emission factor 0.88 lb NO<sub>x</sub> /mmBtu (AP-42, Table 3.1-1, 4/00), by 140 mmBtu/1000 gal and dividing by 2000 lbs/ton.



**Final Title V Permit**  
Piqua Municipal Power System  
**Permit Number:** P0114113  
**Facility ID:** 0855100041  
**Effective Date:** 7/1/2014

## **C. Emissions Unit Terms and Conditions**



**1. B007, C.T. # 8**

**Operations, Property and/or Equipment Description:**

#2 fuel oil 20 MW turbine and Stationary black start compression ignition (CI) internal combustion engine (ICE); complying with 40 CFR 63, Subpart ZZZZ Table 2d #4; and installed before 6/12/06.

- a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.
  - (1) None.
- b) Applicable Emissions Limitations and/or Control Requirements
  - (1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	40 CFR Part 63 Subpart ZZZZ (40 CFR 63.6580 to 63.6675)  In accordance with 40 CFR 63.6585, this emissions unit is a stationary internal combustion engine (ICE) subject to the National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines.	The existing black start stationary compression ignition (CI) reciprocating internal combustion engine (RICE), located at an area source for hazardous air pollutants (HAPs), shall meet the requirements of 40 CFR Part 63, Subpart ZZZZ.
b.	40 CFR 63.6603(a)  Table 2d #4 to Subpart ZZZZ	Must comply with the maintenance / operational requirements from the NESHAP for existing area source black start CI RICE.
c.	OAC rule 3745-17-11(B)(5)(a)	Internal Combustion Engine:  Particulate emissions (PE) shall not exceed 0.062 lb/MMBtu of actual heat input.
d.	OAC rule 3745-17-11(B)(4)	PE shall not exceed 0.040 lb/mmBtu actual heat input.



e.	OAC rule 3745-18-06(F)	The fuel oil shall not be calculated to exceed 0.5 lb SO <sub>2</sub> /MMBtu or the limit established in the most current version of this rule, if amended.
f.	OAC rule 3745-17-07(A)(1)	Visible particulate emissions (PE) shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

(2) Additional Terms and Conditions

- a. The permittee shall comply with the following applicable requirements identified in 40 CFR Part 63, Subpart ZZZZ:

Applicable Rule	Requirement
Applicable Tables from Part 63, Subpart ZZZZ	Compliance requirements in Table 2d #4; continuous compliance in Table 6 #9; general provision from Subpart A in Table 8.
40 CFR 63.6603(a)	Maintain compliance with operational limitations in Table 2d #4 (inspection and maintenance requirements) to Part 63 Subpart ZZZZ.
40 CFR 63.6665	Meet all of the general provisions of Subpart A, from Sections 63.1 through 63.15, that apply to the CI RICE, as identified in Table 8 to Subpart ZZZZ.

c) Operational Restrictions

- (1) This CI ICE shall only be operated for the purpose of starting up the combustion turbine(s).

[40 CFR 63.6675]

- (2) Unless meeting the requirements of 40 CFR 63.6625(i), the permittee shall change the oil and filter every 500 hours of operation or annually, whichever comes first; shall inspect the air cleaner every 1,000 hours of operation or annually, whichever comes first; and shall inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace them as necessary. A log shall be maintained for the date of each oil/filter change and inspection.

[40 CFR 63.6603], [40 CFR 63.6625(i)], and [Table 2d to Subpart ZZZZ of Part 63, #4]

- (3) The permittee shall comply with the following applicable requirements identified in 40 CFR Part 63, Subpart ZZZZ:

Applicable Rule	Requirement
40 CFR 63.6605	General duty to minimize emissions, with good air pollution control practices for minimizing emissions; and compliance required at all times.
40 CFR 63.6625(e)	Operate & maintain RICE according to mfg. instructions and develop



	a facility maintenance plan for the RICE that meets the requirements of Subpart ZZZZ Table 2d #4.
40 CFR 63.6625(h)	Minimize idle and startup time, not to exceed 30 minutes.
40 CFR 63.6625(i)	Oil analysis program, option to extend the oil change frequency.

- (4) The quality of the oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in this permit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

- (5) The permittee shall burn only No. 2 fuel oil in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(1)]

d) **Monitoring and/or Recordkeeping Requirements**

- (1) For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of the diesel oil received and the oil supplier's (or permittee's) analyses for sulfur content, in parts per million or percent by weight. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content, using the appropriate ASTM methods. These records shall be retained for a minimum of 3 years and shall be made available for inspection, if requested.

[OAC rules 3745-18-04(E), (G) and OAC rule 3745-77-07(A)(3)]

- (2) The permittee shall maintain a record of any period of time where the black start engine is operated for any purpose other than starting up a combustion turbine.

[40 CFR 63.6675]

- (3) The permittee shall comply with the following applicable requirements identified in 40 CFR Part 63, Subpart ZZZZ:

Applicable Rule	Requirement
40 CFR 63.6635	Except for monitor malfunctions, associated repairs, and required quality assurance activities, must continuously monitor that the RICE is operating. Must use all valid data (not recorded during malfunctions, repairs, or required quality assurance or control activities) in calculations used to report emissions or operating levels.
40 CFR 63.6655(a)	Keep records of: 1. each notification and report submitted to comply with Subpart ZZZZ; 2. the occurrence and duration of each malfunction of the RICE; and 3. corrective actions taken during each period of malfunction to minimize emissions and restore normal operations.
40 CFR 63.6640(a) and 40 CFR 63.6655(d)	Keep the records required in #9 of Table 6 to Subpart ZZZZ to demonstrate continuous compliance.



40 CFR 63.6655(e)(3)	Records of maintenance and inspections conducted in order to demonstrate compliance with Table 2d and to demonstrate that the RICE was operated and maintained according to the facility's maintenance plan.
OAC rule 3745-18-04(E) and (F)	Maintain records for the quality of diesel fuel burned in the CI RICE and the calculations for SO <sub>2</sub> emissions or the calculation of worst-case emissions to document compliance.
40 CFR 63.6625(h)	Maintain a record of each idle and/or startup time that exceeded 30 minutes.
40 CFR 63.6660	Records readily available and retained for at least 5 years after the date of occurrence or date of report according to 63.10(b)(1).

- (4) On each day during which the permittee burns a fuel other than No. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Authority for term: OAC rule 3745-77-07(A)(3)].

e) Reporting Requirements

- (1) Unless other arrangements have been approved by the Director, all notifications and reports shall be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal.

[Authority for term: OAC rule 3745-77-07(A)(3)]

- (2) The permittee shall identify in the annual permit evaluation report any period of time (date and number of hours) that the CI ICE was operated for any purpose other than to start up the combustion turbine(s).

[for 40 CFR 63.6675]

- (3) The permittee shall comply with the following applicable requirements identified in 40 CFR Part 63, Subpart ZZZZ:

Applicable Rule	Requirement
OAC 3745-18-06(G)	Identify in the annual permit evaluation report any period of time (date and number of hours), during the reporting period, that the quality of oil burned in this emissions unit did not meet the requirements established in this permit.
40 CFR 63.6640(b); and OAC rule 3745-15-03(B)(2) and (D)	Submit in the annual permit evaluation report each instance in which the operational requirements in Table 2d to Subpart ZZZZ were not met.
40 CFR 63.6640(e) and OAC rule 3745-15-03(B)(2) and (D)	Submit in the annual permit evaluation report each instance in which the applicable requirements in Table 8 to Subpart ZZZZ, the general provisions from Subpart A, were not met.



- (4) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than number two fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Authority for Term: OAC rule 3745-77-07(A)(3)]

f) Testing Requirements

- (1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b)(1) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission limitation

Visible PE shall not exceed 20% opacity as a 6-minute average.

Applicable Compliance Method

Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

[Authority for term: OAC rules 3745-17-03(B)(1) and 3745-77-07(C)(1)]

b. Emission limitation

PE shall not exceed 0.062 lb/mmBtu actual heat input

PE shall not exceed 0.040 lb/mmBtu actual heat input.

Applicable Compliance Method

Compliance shall be based upon an emission factor of 0.012 lb/mmBtu. This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1 (4/2000), Table 3.1-2a.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).

[Authority for term: OAC rules 3745-17-03(B)(10) and 3745-77-07(C)(1)]

c. Emission limitation

Sulfur dioxide emissions shall not exceed 0.5 lb/mmBtu actual heat input.

Applicable Compliance Method

Compliance shall be demonstrated through the record keeping requirements for the sulfur content of each shipment of diesel oil received.



**Final Title V Permit**  
Piqua Municipal Power System  
**Permit Number:** P0114113  
**Facility ID:** 0855100041  
**Effective Date:** 7/1/2014

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

[Authority for term: OAC rules 3745-18-04(F) and 3745-77-07(C)(1)].

- g) Miscellaneous Requirements
  - (1) None.