



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
CUYAHOGA COUNTY**

CERTIFIED MAIL

Street Address:

122 S. Front Street

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 13-03878

DATE: 9/27/2001

Cuyahoga Community College West Campus
Thomas Somerville
2900 Community College Avenue
Cleveland, OH 44115

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Review Appeals Commission pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed within thirty (30) days after the notice of the Directors action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: USEPA

CBAPC



**Permit To Install
Terms and Conditions**

**Issue Date: 9/27/2001
Effective Date: 9/27/2001**

FINAL PERMIT TO INSTALL 13-03878

Application Number: 13-03878
APS Premise Number: 1318455478
Permit Fee: **\$600**
Name of Facility: Cuyahoga Community College West Campus
Person to Contact: Thomas Somerville
Address: 2900 Community College Avenue
Cleveland, OH 44115

Location of proposed air contaminant source(s) [emissions unit(s)]:
**11000 Pleasant Valley Road
Parma, Ohio**

Description of proposed emissions unit(s):
Vapor corporation hot Water Boilers 1, 2, and 3 -- B001, B002, and B003.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

Part I - GENERAL TERMS AND CONDITIONS

A. Permit to Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized

representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Termination of Permit to Install

This Permit to Install shall terminate within eighteen months of the effective date of the Permit to Install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

9. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio

Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

10. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

11. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit to Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

12. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

13. Source Operation and Operating Permit Requirements After Completion of Construction

This facility is permitted to operate each source described by this Permit to Install for a period of up to one year from the date the source commenced operation. This permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within thirty (30) days after commencing operation of the emissions unit(s) covered by this permit.

Cuyahoga Community College West Campus
 PTI Application: 13-03878
 Issued: 9/27/2001

Facility ID: 1318455478

14. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

15. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit to Install fees within 30 days after the issuance of this Permit to Install.

B. Permit to Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>	<u>Change from Past Actual Emissions</u>
PE	4.05	+3.98
CO	17.00	+14.09
NO _x	20.24	+16.78

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

40 CFR 60 Subpart Dc

Operations, Property,
and/or Equipment

Applicable Rules/Requirements

B001 - Natural gas-fired hot water boiler, having a nominal heat input capacity of 15.4 mmBtu/hr. Company ID is Hot Water Boiler #1.

OAC rule 3745-31-05(A)(3)

OAC rule 3745-17-07(A)(1)

OAC rule 3745-17-10(B)(1)

OAC rule 3745-18-06(A)

OAC rule 3745-21-08(B)

OAC rule 3745-23-06(B)

Applicable Emissions
Limitations/Control Measures

The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A) and rule 3745-17-10(B)(1).

Particulate emissions (PE) shall not exceed 0.31 lb/hr and 1.35 ton PE/year.

Carbon monoxide (CO) emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Nitrogen oxide (NOx) emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

PE shall not exceed .020 lb/mmBtu of actual heat input.

Exempt pursuant to OAC rule 3745-18-06(A) when burning natural gas

See Section A.2.a. below.

See Section A.2.a. below.

See Section A.2.b. below.

2. Additional Terms and Conditions

- 2.a** The design of the emissions unit and the technology associated with the current operating practices satisfy the "best available control techniques and operating practices" and "latest available control techniques and operating practices" required pursuant to OAC rules 3745-21-08 and 3745-23-06, respectively.
- 2.b** So long as only natural gas fuel is burned, this emissions unit is not subject to the emission limits listed in 40 CFR Part 60, Subpart Dc.

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

D. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. The permittee shall submit annual reports that specify the total particulate, carbon monoxide, nitrogen oxides, organic compound and sulfur dioxide emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.

E. Testing Requirements

Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

1. Emission Limitation:
Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Methods:

If required, compliance shall be determined through visible emission observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

Emissions Unit ID: B001

2. Emission Limitation:
PE shall not exceed .020 lb/mmBtu of actual heat input, 0.31 lb/hr and 1.35 ton PE/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 1.9 lbs of particulates/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr) and dividing by the emissions unit's total heat input capacity (15.4 mmBtu/hr). Compliance with the hourly emission limitation shall be determined by multiplying 1.9 lbs of particulates/mm cu. ft. by 0.02092 mm cu. ft./hr. The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9) while firing natural gas.

3. Emission Limitation:
CO emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 84 lbs of CO/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 10 while firing natural gas.

4. Emission Limitation:
NOx emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 100 lbs of NOx/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Emissions Unit ID: B001

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 7 while firing natural gas.

12

Cuyah

PTI A

Issued: 9/27/2001

Emissions Unit ID: B001

F. Miscellaneous Requirements

None

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	
B002 - Natural gas-fired hot water boiler, having a nominal heat input capacity of 15.4 mmBtu/hr. Company ID is Hot Water Boiler #2.	OAC rule 3745-31-05(A)(3)	OAC rule 3745-21-08(B) OAC rule 3745-23-06(B) 40 CFR 60 Subpart Dc
	OAC rule 3745-17-07(A)(1)	
	OAC rule 3745-17-10(B)(1)	
	OAC rule 3745-18-06(A)	

Applicable Emissions
Limitations/Control Measures

The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A) and rule 3745-17-10(B)(1).

Particulate emissions (PE) shall not exceed 0.31 lb/hr and 1.35 ton PE/year.

Carbon monoxide (CO) emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Nitrogen oxide (NOx) emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

PE shall not exceed .020 lb/mmBtu of actual heat input.

Exempt pursuant to OAC rule 3745-18-06(A) when burning natural gas

See Section A.2.a. below.

See Section A.2.a. below.

See Section A.2.b. below.

Emissions Unit ID: B002

2. Additional Terms and Conditions

- 2.a** The permittee has satisfied the "best available control techniques and operating practices" and "latest available control techniques and operating practices" required pursuant to OAC rules 3745-21-08 and 3745-23-06, respectively, by committing to comply with the best available technology requirements.
- 2.b** So long as only natural gas fuel is burned, this emissions unit is not subject to the emission limits listed in 40 CFR Part 60, Subpart Dc.

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

D. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. The permittee shall submit annual reports that specify the total particulate, carbon monoxide, nitrogen oxides, organic compound and sulfur dioxide emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.

E. Testing Requirements

Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

1. Emission Limitation:
Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Methods:

If required, compliance shall be determined through visible emission observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

2. Emission Limitation:
PE shall not exceed .020 lb/mmBtu of actual heat input, 0.31 lb/hr and 1.35 ton PE/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 1.9 lbs of particulates/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr) and dividing by the emissions unit's total heat input capacity (15.4 mmBtu/hr). Compliance with the hourly emission limitation shall be determined by multiplying 1.9 lbs of particulates/mm cu. ft. by 0.02092 mm cu. ft./hr. The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9) while firing natural gas.

3. Emission Limitation:

CO emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 84 lbs of CO/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 10 while firing natural gas.

4. Emission Limitation:

NOx emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 100 lbs of NOx/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm

Emissions Unit ID: B002

cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 7 while firing natural gas.

F. Miscellaneous Requirements

None

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	
B003 - Natural gas-fired hot water boiler, having a nominal heat input capacity of 15.4 mmBtu/hr. Company ID is Hot Water Boiler #3.	OAC rule 3745-31-05(A)(3)	OAC rule 3745-21-08(B) OAC rule 3745-23-06(B) 40 CFR 60 Subpart Dc
	OAC rule 3745-17-07(A)(1)	
	OAC rule 3745-17-10(B)(1)	
	OAC rule 3745-18-06(A)	

Applicable Emissions
Limitations/Control Measures

The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A) and rule 3745-17-10(B)(1).

Particulate emissions (PE) shall not exceed 0.31 lb/hr and 1.35 ton PE/year.

Carbon monoxide (CO) emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Nitrogen oxide (NOx) emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

PE shall not exceed .020 lb/mmBtu of actual heat input.

Exempt pursuant to OAC rule 3745-18-06(A) when burning natural gas

See Section A.2.a. below.

See Section A.2.a. below.

See Section A.2.b. below.

2. Additional Terms and Conditions

- 2.a** The permittee has satisfied the "best available control techniques and operating practices" and "latest available control techniques and operating practices" required pursuant to OAC rules 3745-21-08 and 3745-23-06, respectively, by committing to comply with the best available technology requirements.
- 2.b** So long as only natural gas fuel is burned, this emissions unit is not subject to the emission limits listed in 40 CFR Part 60, Subpart Dc.

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

D. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. The permittee shall submit annual reports that specify the total particulate, carbon monoxide, nitrogen oxides, organic compound and sulfur dioxide emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.

E. Testing Requirements

Compliance with the emission limitation(s) in Section A.I. of these terms and conditions shall be determined in accordance with the following method(s):

1. Emission Limitation:
Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Methods:

If required, compliance shall be determined through visible emission observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC

Emissions Unit ID: B003

rule 3745-17-03(B)(1).

2. Emission Limitation:
PE shall not exceed .020 lb/mmBtu of actual heat input, 0.31 lb/hr and 1.35 ton PE/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 1.9 lbs of particulates/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr) and dividing by the emissions unit's total heat input capacity (15.4 mmBtu/hr). Compliance with the hourly emission limitation shall be determined by multiplying 1.9 lbs of particulates/mm cu. ft. by 0.02092 mm cu. ft./hr. The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9) while firing natural gas.

3. Emission Limitation:

CO emissions shall not exceed 1.29 lbs/hr and 5.67 tons CO/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 84 lbs of CO/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 10 while firing natural gas.

4. Emission Limitation:

NOx emissions shall not exceed 1.54 lbs/hr and 6.75 tons NOx/year.

Applicable Compliance Methods:

When firing natural gas, compliance shall be determined by multiplying an emission factor of 100 lbs of NOx/mm cu. ft. by the emissions unit's maximum hourly natural gas firing rate (0.0154 mm

cu. ft./hr). The emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-2 (7/98).

Compliance with the annual emission limit shall be determined by multiplying the above calculated hourly emission rate by 8,760 hours per year and multiplying the result by the conversion factor of 1.0 ton/2000 lbs.

If required, the permittee shall demonstrate compliance with the lbs/hr emission limitation in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 7 while firing natural gas.

F. Miscellaneous Requirements

None