



State of Ohio Environmental Protection Agency

P.O. Box 1049, 1800 WaterMark Dr.
Columbus, Ohio 43266-0149



Re: Permit to Install
TUSCARAWAS County
Application No. 06-2254

CERTIFIED MAIL

Richard F. Celeste
Governor

MARCH 1, 1989

DOVER MUNICIPAL POWER PLANT
MR. WILLIAM ENGLISH
116 E THIRD ST
DOVER, OHIO 44622

Dear Sir:

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager
Field Operations Section
Division of Air Pollution Control

TGR/gs

cc: US EPA
SOUTHEAST DISTRICT OFFICE

1500 MAR -6 AM 10:38
O.E.P.A.
S.E.D.O.

Permit to Install Terms and Conditions

Application No. Ø6-2254
APS Premise No. Ø679Ø1Ø146
Permit Fee: \$292.

Name of Facility: DOVER MUNICIPAL POWER PLANT

Person to Contact: MR. WILLIAM ENGLISH

Address: 116 E THIRD ST
DOVER, OHIO 44622

Location of proposed source(s): BROADWAY ST
DOVER, OHIO

Description of proposed source(s): 252 MMBH GAS FIRED TURBINE
GENERATOR.


Date of Issuance: MARCH 1, 1989

Effective Date: MARCH 1, 1989

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Director

EPA 3156

1989 MAR -6 AM 10:38
O.E.P.A.
S.E.D.O.

Substantial construction for installation must take place within eighteen months of the effective date of this permit. This deadline may be extended by up to twelve months, if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

The specified permit fee must be remitted within 15 days of the effective date of this permit to install.

The proposed source shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

EMISSION SUMMARY

The air contaminant sources listed below comprise the Permit to Install for Dover Municipal Power located in Tuscarawas County. The sources listed below shall not exceed the emission limits/control requirements contained in the following table:

<u>Ohio EPA Source No.</u>	<u>Source Identification</u>	<u>BAT Determination</u>	<u>Applicable Ohio EPA rule</u>	<u>Allowable Emissions (lb/hr, lb/MMBTU, gr/DSCF, etc.)</u>
B005	252 mmBH gas fired turbine generator	Part. - 0.020 lb/10 ⁶ BTU NO _x - 0.42 lb/10 ⁶ BTU operation - 756 hrs/yr	3745-31-05 (A)(3)	0.020 lb/10 ⁶ BTU Particulate 0.42 lb/10 ⁶ BTU NO _x

O.E.P.A.
 06-001
 APR 10 1989

SUMMARY
TOTAL NEW SOURCE EMISSIONS

<u>Pollutant</u>	<u>Tons/Year</u>
Particulate	1.34
NO _x	39.9

This condition in no way limits the applicability of any other state or federal regulation.

APPLICABILITY

This Permit to Install is applicable only to the air contaminant sources listed and does not include the installation or modification of wastewater disposal systems or solid waste disposal facilities. Separate application must be made to the Director for the installation or modification of any such wastewater disposal systems or solid waste disposal facilities.

CONSTRUCTION STATUS

The Southeast District Office, 2195 Front St., Logan, Ohio 43138 shall be notified in writing as to (a) the construction starting date (b) the construction completion date and (c) the date the facilities were placed into operation.

PERFORMANCE TEST REQUIREMENTS

The permittee shall conduct, or have conducted, performance testing on the air contaminant source(s) in accordance with procedures approved by the Agency. Two copies of the written report shall be submitted and signed by the person responsible for the test, describing the test procedures followed and the results of such tests. The Director or an Ohio EPA representative shall be allowed to witness the tests, examine testing equipment and require the acquisition or submission of data and information necessary to assure that the source operation and testing procedures provide a valid characterization of the emissions from the source and/or the performance of the control equipment.

- A. A completed Intent to Test form shall be submitted to the appropriate Ohio EPA District Office or Local Air Pollution Control Agency where the original permit application was filed. This notice shall be made thirty (30) days in advance and shall specify the source operating parameters, the proposed test procedures and the time, date, place and person(s) conducting such tests.
- B. Two copies of the test results shall be submitted within thirty (30) days after the completion of the performance test.

1989 MAR -6 AM 10:38
O.E.P.A.
S.E.D.D.

C. Tests shall be performed for the following sources and pollutants: B005 for NO_x

WASTE DISPOSAL

The owner/operator shall comply with any applicable state and federal requirements governing the storage, treatment, transport, and disposal of any waste material generated by the operation of the sources.

PERMIT TO OPERATE APPLICATION

A Permit to Operate Application and a \$15 application fee must be submitted to the appropriate field office for each source in this Permit to Install. In accordance with OAC rule 3745-35-02, the application shall be made at least ninety days prior to start-up of the source.

PUBLIC DISCLOSURE

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source are subject to public disclosure in accordance with OAC Rule 3745-49-03.

ADDITIONAL SPECIAL TERMS AND CONDITIONS

Operating Limit

This source shall not be operated for more than 756 hours in any 12 month period. Record of operating time shall be kept for each month and for each previous 12 months. This information shall be submitted to the Southeast District Office of Ohio EPA by February 15, May 15, August 15, and November 15 of each year and shall cover the data obtained during the previous calendar quarters.

1989 MAR -6 AM 10:38
O.E.P.A.
S.E.D.O.