

HAMILTON COUNTY

PUBLIC NOTICE

**ISSUANCE OF DRAFT PERMIT TO INSTALL 14-05108 FOR AN AIR CONTAMINANT SOURCE FOR
University of Cincinnati**

On 6/30/2005 the Director of the Ohio Environmental Protection Agency issued a draft action of a Permit To Install an air contaminant source for **University of Cincinnati**, located at **3001 Vine Street, Cincinnati, Ohio**.

Installation of the air contaminant source identified below may proceed upon final issuance of Permit To Install 14-05108:

Administrative Modification to permit to install 14-05108 as issued 08/15/2002; Two 14.5 MW Natural Gas/ No. 2 Fuel Oil fired Turbines with 92 MMBtu/hr duct burners; two 2 MW deisel fired IC engines.

Comments concerning this draft action, or a request for a public meeting, must be sent in writing to the address identified below no later than thirty (30) days from the date this notice is published. All inquiries concerning this draft action may be directed to the contact identified below.

Brad Miller, Hamilton County Department of Environmental Services, 250 William Howart Taft Pkwy,
Cincinnati, OH 45219-2660 [(513)946-7777]



**Permit To Install
Terms and Conditions**

**Issue Date: To be entered upon final issuance
Effective Date: To be entered upon final issuance**

DRAFT PERMIT TO INSTALL 14-05108

Application Number: 14-05108
Facility ID: 1431070849
Permit Fee: **To be entered upon final issuance**
Name of Facility: University of Cincinnati
Person to Contact: Peter Luken
Address: 210181
Cincinnati, OH 45221-0181

Location of proposed air contaminant source(s) [emissions unit(s)]:
**3001 Vine Street
Cincinnati, Ohio**

Description of proposed emissions unit(s):
Administrative Modification to permit to install 14-05108 as issued 08/15/2002; Two 14.5 MW Natural Gas/ No. 2 Fuel Oil fired Turbines with 92 MMBtu/hr duct burners; two 2 MW deisel fired IC engines.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

A. State and Federally Enforceable Permit To Install General Terms and Conditions**1. Monitoring and Related Recordkeeping and Reporting Requirements**

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.9 below if no deviations occurred during the quarter.

Issued: To be entered upon final issuance

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

Issued: To be entered upon final issuance

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees within 30 days after the issuance of this Permit To Install.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit

Issued: To be entered upon final issuance

shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit To Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete

University of Cincinnati
PTI Application: 14-05108

Facility ID: 1431070849

Issued: To be entered upon final issuance

Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

University of Cincinnati

Facility ID: 1431070849

PTI Application: 14-05108

Issued: To be entered upon final issuance

B. State Only Enforceable Permit To Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Termination of Permit To Install

This permit to install shall terminate within eighteen months of the effective date of the permit to install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

University of Cincinnati

PTI Application: 14-05108

Issued: To be entered upon final issuance

Facility ID: 1431070849

5. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

8. Construction Compliance Certification

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

University of Cincinnati
 PTI Application: 14-05108

Facility ID: 1431070849

Issued: To be entered upon final issuance

9. **Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)**

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. **Permit To Install Summary of Allowable Emissions**

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
 TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
PE/PM10	14.04
SO2	3.47
NOx	193.15
CO	23.33
VOC	5.90

University of Cincinnati

PTI Application: 14-05108

Issued: To be entered upon final issuance

Facility ID: 1431070849

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Unive|
PTI A

Emissions Unit ID: P003

Issued: To be entered upon final issuance

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
P003 - 14.5 MW combined cycle natural gas / transportation grade diesel fuel-fired combustion turbine with 98.5 mmBtu/hr natural gas-fired duct burner and CO oxidation catalyst - administrative modification.	OAC Rule 3745-31-05(A)(3)

Issued: To be entered upon final issuance

40 CFR 60, Subpart GG

40 CFR 60, Subpart Dc

OAC rule 3745-18-06(F)

OAC rule 3745-17-07(A)

OAC rule 3745-17-11(B)(4)

40 CFR Part 75

OAC rule 3745-103

OAC rule 3745-31-10
through 3745-31-20.

OAC rule 3745-31-05(C)

**Univer
PTI A**

Emissions Unit ID: P003

Issued: To be entered upon final issuance

<u>Applicable Emissions Limitations/Control Measures</u>		
See terms and conditions A.I.2.e. and A.I.2.g. through A.I.2.n.	2.07 lbs/hr; Sulfur dioxide (SO ₂) emissions shall not exceed 0.16 lb/hr;	FIRING: Nitrogen oxides (NO _x) emissions shall not exceed 25 ppmvd at 15% oxygen and 14.71 lbs/hr; and
EMISSION LIMITS DURING NORMAL OPERATION WITHOUT DUCT BURNER FIRING:	Organic compounds (OC) emissions shall not exceed 0.78 lb/hr; and Carbon monoxide (CO) emissions shall not exceed 2.84 lbs/hr.	PM10 emissions shall not exceed 0.0073 lb/mmBtu and 1.08 lbs/hr.
Particulate matter (PM) emissions shall not exceed 1.08 lbs/hr;	EMISSION LIMITS DURING BACKUP OPERATION: Particulate matter (PM) emissions shall not exceed 1.79 lbs/hr;	EMISSION LIMITS DURING NORMAL OPERATION WITH DUCT BURNER FIRING:
Sulfur dioxide (SO ₂) emissions shall not exceed 0.10 lb/hr;	Sulfur dioxide (SO ₂) emissions shall not exceed 7.54 lb/hr;	Nitrogen oxides (NO _x) emissions shall not exceed 0.10 lb/mmBtu and 24.56 lbs/hr; and
Organic compounds (OC) emissions shall not exceed 0.56 lb/hr; and	Organic compounds (OC) emissions shall not exceed 0.55 lbs/hr; and	PM10 emissions shall not exceed 0.0084 lb/mmBtu and 2.07 lbs/hr.
Carbon monoxide (CO) emissions shall not exceed 1.97 lbs/hr.	Carbon monoxide (CO) emissions shall not exceed 1.92 lbs/hr.	EMISSION LIMITS DURING BACKUP OPERATION:
EMISSION LIMITS DURING NORMAL OPERATION WITH DUCT BURNER FIRING:	The requirements of this rule include compliance with the requirements of OAC rule 3745-31-10 through 3745-31-20, OAC rule 3745-31-05(C), 40 CFR Part 60, Subpart GG and 40 CFR Part 60, Subpart Dc.	Nitrogen oxides (NO _x) emissions shall not exceed 96 ppmvd at 15% oxygen and 54.91 lbs/hr; and
Particulate matter (PM) emissions shall not exceed	EMISSION LIMITS DURING NORMAL OPERATION WITHOUT DUCT BURNER	PM10 emissions shall not exceed 0.013 lb/mmBtu and 1.79 lbs/hr.
		COMBINED EMISSIONS FROM THE TURBINE AND DUCT BURNER AT

ALL LOAD CONDITIONS,
INCLUDING
STARTUP/SHUTDOWN,
NORMAL AND BACKUP:

Nitrogen oxides (NO_x)
emissions shall not exceed
91.5 TPY*;

PM10 emissions shall not
exceed 7.0 TPY*;

Benzene emissions shall not
exceed 0.0011 TPY*;

Particulate matter (PM)
emissions shall not exceed
7.0 TPY*;

Sulfur dioxide (SO₂)
emissions shall not exceed
1.63 TPY*;

Organic compounds (OC)
emissions shall not exceed
2.82 TPY*; and

Carbon monoxide (CO)
emissions shall not exceed
11.46 TPY*.

See term A.I.2.a, A.III.13
and A.III.14.

See term A.III.16.

The emission limitation
specified by this rule is less
stringent than the emission
limitation established
pursuant to OAC rule
3745-31-05(A)(3).

The emission limitation
specified by this rule is less
stringent than the emission

limitation established pursuant to
OAC rule 3745-31-05(A)(3).

The emission limitation specified by
this rule is less stringent than the
emission limitation established
pursuant to OAC rule
3745-31-05(A)(3).

See term A.I.2.b.

See term A.I.2.b.

* Based on a rolling, 12-month
summation

Assume PM=PM10

Issued: To be entered upon final issuance**2. Additional Terms and Conditions**

- 2.a** The emissions limits based on this applicable rule are equivalent to or less stringent than the limits established pursuant to OAC rule 3745-31-05(A)(3) and OAC rule 3745-31-10 through 3745-31-20. Except as provided for in the terms and conditions in this permit, the permittee is not exempt from meeting any additional requirements of 40 CFR Part 60, Subpart GG.
- 2.b** If the permittee is subject to the requirements of 40 CFR Part 72 and 75 concerning acid rain, the permittee shall ensure that any effected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.
- 2.c** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by the use of dry low NOx burners with a 25.0 ppm NOx emission limit during normal operation, a catalytic oxidizer to control CO and VOC emissions at a destruction efficiency of at least 89 percent by weight, and limited usage of diesel fuel in the turbine and natural gas in the duct burner.
- 2.d** The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.
- 2.e** Visible particulate emissions from any stack shall not exceed 10 percent opacity, as a six-minute average except during periods of malfunction as provided in OAC rule 3745-17-07(A)(3)(c).
- 2.f** The hourly emission limitation(s) for PM, PM10, SO2 and VOC outlined in term A.I.1. are based upon the emissions unit's Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.g** "Normal Operation" shall be defined as the period when the combustion turbine achieves dry low NOx mode, burning natural gas at steady state operation, between 50 percent load (equivalent to an output of 7.25 megawatts) and full load.
- 2.h** "Backup Operation" shall be defined as the period when the combustion turbine achieves dry low NOx mode, burning diesel fuel at steady state operation, between 65 percent load (equivalent to an output of 9.425 megawatts) and full load. Duct burners shall not operate during periods of backup operation.

Emissions Unit ID: P003

- 2.i "Full Load" shall be defined as any load greater than or equal to the nominally rated maximum output of 14.5 megawatts.
- 2.j "Startup" shall be defined as the period between initial fuel light-off in the combustion turbine until the combustion turbine reaches normal or backup operations.
- 2.k "Shutdown" shall be defined as the period beginning when the combustion turbine leaves normal or backup operations until combustion has ceased.
- 2.l When burning natural gas, during startup/shutdown cycle, the following emission limits shall not be exceeded for this emission unit:

 NO_x = 57.0 lbs/ startup/shutdown cycle
 CO = 21.0 lbs/ startup/shutdown cycle
- 2.m When burning diesel fuel, during startup/shutdown cycle, the following emission limits shall not be exceeded for this emission unit:

 NO_x = 164.7 lbs/ startup/shutdown cycle
 CO = 13.6 lbs/ startup/shutdown cycle
- 2.n A startup/shutdown cycle shall not exceed a maximum total duration of 3 hours.

II. Operational Restrictions

- 1. The permittee shall only burn natural gas in the duct burner portion of this emissions unit, and except as allowed in term A.II.3 of this permit, the permittee shall only burn natural gas in the combustion turbine portion of this emission unit. The maximum sulfur content of natural gas shall not exceed 2 grains per 100 standard cubic feet.
- 2. The sulfur content of the diesel fuel used in this combustion turbine shall not exceed 0.05 percent by weight.
- 3. The maximum annual operating hours for the combustion turbine while burning diesel fuel shall not exceed 288 hours, based upon a rolling, 12-month summation of the operating hours.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the operating hours levels specified in the following table:

Month(s)	Maximum Allowable Cumulative Operating Hours
1	144
1-2	144
1-3	144

Univer

PTI A

Emissions Unit ID: P003

Issued: To be entered upon final issuance

1-4	144
1-5	144
1-6	170
1-7	195
1-8	220
1-9	245
1-10	270
1-11	288
1-12	288

After the first 12 calendar months of operation, following the issuance of this permit, compliance with the annual operating hours limitation shall be based upon a rolling, 12- month summation of the operating hours.

- The maximum annual natural gas usage for the duct burner of this emission unit shall not exceed 515 million standard cubic feet, based upon a rolling, 12-month summation of the natural gas usage figures.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the natural gas usage levels specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative Natural Gas Usage, MMscf</u>
1	71
1-2	142
1-3	213
1-4	284
1-5	355
1-6	426
1-7	497
1-8	515
1-9	515
1-10	515
1-11	515
1-12	515

After the first 12 calendar months of operation, following the issuance of this permit, compliance with the annual natural gas usage limitation shall be based upon a rolling, 12- month summation of the natural gas usage levels.

Issued: To be entered upon final issuance

5. The average combustion temperature within the oxidation catalyst, for any 3-hour block of time when the emissions unit is in operation, shall not be more than 50 degrees Fahrenheit below the average temperature during the most recent emission test that demonstrated the emissions unit was in compliance.
6. Duct burners shall not operate during backup mode operation.
7. The number of startup/shutdown cycles per year shall not exceed 180 cycles.
8. The maximum annual heat input rate to the combustion turbine of this emission unit shall not exceed 1,177,200 mmBtu, based upon a rolling, 12-month summation of the fuel usage figures. The permittee has records to demonstrate compliance with this limitation upon issuance of this permit.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain daily records of the following information:
 - a. the emissions unit's actual electrical output for each operating hour; and
 - b. for each day during which the permittee burns a fuel other than natural gas and/or diesel fuel, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
2. The permittee shall maintain monthly records of the following information for this emissions unit:
 - a. The natural gas usage rate in the combustion turbine for each month (in standard cubic feet).
 - b. The natural gas usage rate in the duct burner for each month (in standard cubic feet).
 - c. The diesel fuel usage rate in the combustion turbine for each month (in gallons).
 - d. The hours of operation of the combustion turbine.
 - e. The hours of operation of the duct burners and the fuel used during those hours of operation.
 - f. The hours of operation of the combustion turbine while burning diesel fuel.

Emissions Unit ID: P003

- g. The number of startup/shutdown cycles for each month.
- h. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of the hours of operation of the combustion turbine while burning diesel fuel.
- i. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of the natural gas usage rate in the duct burner.
- j. The monthly emission rate for NO_x, CO, SO₂, PM/PM₁₀ and VOC, in tons.
- k. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of NO_x, CO, SO₂, PM/PM₁₀ and VOC, in tons.
- l. The rolling, 12-month summation of the actual heat input rate of the combustion turbine.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative hours of operation of the combustion turbine while burning diesel fuel for each calendar month, and the cumulative natural gas usage rate in the duct burner for each calendar month.

- 3. The permittee shall maintain monthly records of the following information for this emissions unit in order to monitor compliance with the startup and shutdown emission limitations and operational restrictions:
 - a. the date and duration, in minutes, of each startup and shutdown cycle;
 - b. the emissions, in pounds, for NO_x and CO when burning natural gas for each startup and shutdown cycle; and
 - c. the emissions, in pounds, for NO_x and CO when burning diesel fuel for each startup and shutdown cycle.

The permittee shall use the continuous NO_x and CO emissions monitoring data to determine the NO_x and CO emissions for these emissions units. During any period when the NO_x and/or the CO emissions monitoring systems are not operational, the permittee shall use the appropriate missing data procedures specified in 40 CFR Part 75 to determine NO_x and CO (although 40 CFR Part 75 pertains mainly to determining NO_x and SO₂ emissions and not to determining CO emissions, the permittee may use the same procedures allowed in 40 CFR Part 75 to determine NO_x emissions to determine CO emissions) emissions or an approved data substitution protocol. The data substitution values shall not be used to demonstrate compliance with the hourly NO_x and CO emission limitations applicable during normal or backup operation of this emissions unit.

- 4. For each shipment of diesel fuel received for burning in this emissions unit, the permittee shall maintain records of the total quantity of diesel fuel received, the permittee's or diesel fuel supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission

Issued: To be entered upon final issuance

rate (in lbs/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch and the quality of the diesel fuel for those loads may be represented by a single batch analysis from the supplier.

The permittee shall collect or require the diesel fuel supplier to collect a representative grab sample for each shipment of diesel fuel that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240, D4294, D6010), or equivalent methods as approved by the Director.

5. Continuous NO_x Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous NO_x monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 6 or 40 CFR Part 75 (The permittee may use 40 CFR Part 75 continuous emissions monitoring systems (CEMS) methodology using fuel flow monitors in conjunction with CEMS data to determine NO_x mass emissions if it is done in accordance with the provisions listed 40 CFR Part 75) for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2 and Performance Specification 6 or 40 CFR Part 75 if low mass emission criteria described in 40 CFR Part 75 have been met. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, the Relative Accuracy requirements of 40 CFR Part 60, Performance Specification 6 are still required to be met, although other requirements from this performance specification may not be required. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous NO_x monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, Performance Specification 6, and 40 CFR Part

75 where applicable.

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO_x monitoring system designed to ensure continuous valid and representative readings of NO_x emissions in units of the applicable standard. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B, Section 1.3 for fuel flow monitors. The quality assurance/quality control plan and a logbook dedicated to the continuous NO_x monitoring system must be kept on site and available for inspection during regular office hours.

6. The permittee shall operate and maintain existing equipment to continuously monitor and record NO_x from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements of the appropriate sections specified in 40 CFR Part 60.13. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data for mass emissions determinations, fuel flow meters shall meet the requirements of 40 CFR Part 75, Appendix D, Sections 2.1.2 and 2.1.5.

Data necessary for mass emission calculations per 40 CFR Part 75, Appendix D shall be recorded.

The permittee shall maintain records of all data obtained by the continuous NO_x monitoring system including, but not limited to, parts per million NO_x on an instantaneous (one-minute) basis, emissions of NO_x in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

During any period when the continuous NO_x emission monitoring systems are not operational, the permittee shall use the appropriate missing data procedures specified in 40 CFR Part 75 to determine the NO_x emissions.

7. Continuous CO Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous CO monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 6, or 40 CFR Part 75 (The permittee may use 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine CO mass emissions if it is done in a manner consistent with NO_x mass emissions determinations as allowed in 40 CFR Part 75) for approval by the Ohio EPA, Central Office.

Emissions Unit ID: P003

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of the continuous CO monitoring system pursuant to ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 4A and Performance Specification 6 . If 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, the Relative Accuracy requirements of 40 CFR Part 60, Performance Specification 6 are still required to be met, although other requirements from this performance specification may not be required. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous CO monitoring system shall be granted upon determination by the Ohio EPA Central Office that the system meets all requirements of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4A and Performance Specification 6).

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous CO monitoring system designed to ensure continuous valid and representative readings of CO. The plan shall follow the requirements of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous CO monitoring system must be kept on site and available for inspection during regular office hours.

8. The permittee shall operate and maintain equipment to continuously monitor and record CO from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, fuel flow meters shall meet the requirements of 40 CFR Part 75, Appendix D, Sections 2.1.2 and 2.1.5.

Data necessary for mass emission calculations per 40 CFR Part 75, Appendix D shall be recorded.

The permittee shall maintain records of all data obtained by the continuous CO monitoring system including, but not limited to, parts per million CO on an instantaneous (one minute) basis, emissions of CO in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, annual, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

9. Continuous O₂ or CO₂ Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous O₂ monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 3 for approval by the

Emissions Unit ID: P003

Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), and 40 CFR Part 60, Appendix B, Performance Specification 3. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous O₂ monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 3.

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous O₂ monitoring system designed to ensure continuous valid and representative readings of O₂. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous O₂ monitoring system must be kept on site and available for inspection during regular office hours.

10. The permittee shall operate and maintain equipment to continuously monitor and record O₂ from this emissions unit in percent O₂. Such continuous monitoring and recording equipment shall comply with the requirements in the appropriate sections specified in 40 CFR Part 60.13

The permittee shall maintain records of all data obtained by the continuous O₂ monitoring system including, but not limited to, percent O₂ on an instantaneous (one-minute) basis, emissions of O₂ results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

11. The permittee shall maintain hourly records of the following information for this emissions unit:

in lb(s)/hr emissions rate for NO_x and CO as obtained from terms III.6. and 8, and NO_x ppmvd@15% O₂ as obtained from term A.III. 6. based upon an hourly averaging period as allowed in the appropriate sections of 40 CFR Part 60.
12. The permittee shall monitor the sulfur content and gross calorific value of the fuel being fired in the duct burner. Fuel sampling and analysis shall be conducted according to the procedures and at the frequency specified by 40 CFR Part 75, Appendix D.
13. The permittee shall monitor the sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of the monitoring shall be determined as follows:
 - a. If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.

Issued: To be entered upon final issuance

- b. If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators, or fuel vendors may develop custom fuel schedules for the determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Ohio EPA, Central Office before they can be used.
14. The permittee shall maintain documentation on the sulfur and nitrogen contents of the fuels as required in 40 CFR 60.334(b). The permittee may submit a custom fuel monitoring schedule to deviate from the sampling schedule in 40 CFR 60.334(b).
15. The permittee shall perform weekly checks, when this emissions unit is in operation, during daylight hours, and when weather conditions allow, for any visible particulate emissions from the stack/stacks serving this/these emissions unit(s). The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and,
 - e. any corrective actions taken to eliminate the visible emissions.
16. The permittee shall maintain daily records of the natural gas usage rate in the duct burner.
17. The permittee shall operate and maintain a continuous temperature monitor and recorder which measures and records the combustion temperature within the oxidation catalyst when the emissions unit is in operation. Units shall be in degrees Fahrenheit. The monitoring and recording devices shall be capable of accurately measuring the desired parameter. The temperature monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee.

The permittee shall collect and record the following information for each day:

- a. All 3-hour blocks of time during which the average combustion temperature within the

Emissions Unit ID: P003

oxidation catalyst, when the emissions unit was in operation, was more than 50 degrees Fahrenheit below the average temperature during the most recent emission test that demonstrated the emissions unit was in compliance.

- b. A log of the downtime for the capture (collection) system, control device, and monitoring equipment, when the associated emissions unit was in operation.

Issued: To be entered upon final issuance**IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas or diesel fuel was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurred.
2. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12-month operating hours limitation while burning diesel fuel in the combustion turbine and for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative operating hours levels. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).
3. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12-month actual heat input limitation to the combustion turbine; the rolling, 12-month natural gas usage limitation for the duct burner and for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative natural gas usage levels. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).
4. The permittee shall notify the Hamilton County Department of Environmental Services in writing of any record that shows a deviation of the allowable sulfur dioxide limitation specified in term A.II.2. of this permit. The notification shall include a copy of such record and shall be sent to the Hamilton County Department of Environmental Services within 45 days after the deviation occurs.
5. Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031 and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of NO_x values in excess of the applicable limits specified in 40 CFR Part 76 and any limitations specified in the terms and conditions of this permit or variance. These reports shall also contain the total NO_x emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous NO_x monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total

Emissions Unit ID: P003

operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031, the permittee shall submit a summary of the excess emission reports pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

6. Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031 and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of CO values in excess of any applicable limitation(s) specified in OAC Chapter 3745-21, 40 CFR Part 60, or any limitation(s) specified in the terms and conditions of this permit, in units of the standard. These reports shall also contain the total CO emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous CO monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031, the permittee shall submit a summary of the excess emission reports pursuant to 40 CFR Part 60.7. The

Issued: To be entered upon final issuance

summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

7. Pursuant to 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting all instances of continuous O₂ monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.
8. The permittee shall submit deviation (excursion) reports that identify any record which shows that the sulfur content of the natural gas exceeded 2 grains per standard cubic foot. These reports are due by the date described in Part I - General Terms and Conditions of this permit under section (A)(2).
9. In lieu of the excess emissions reports required under 40 CFR Part 60.334, the permittee shall submit excess emissions reports for emissions unit P003 in accordance with this permit.
10. The permittee shall submit semiannual written reports which (a) identify all weeks during which any visible particulate emissions were observed from the stack serving this emissions units and (b) if needed describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.
11. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year. The CAA, Title V Fee Emission Report (FER) required to be submitted annually by April 15 for the facility will also satisfy the emission reporting requirement of this condition.
12. This emissions unit is subject to the applicable provisions of Subpart Dc. and GG of the New Source Performance Standards (NSPS) as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60. The application and enforcement of these standards are delegated to the Ohio EPA. The requirements of 40 CFR Part 60 are also federally enforceable.

Pursuant to 40 CFR Part 60.7, the permittee is hereby advised of the requirement to report the following at the appropriate times:

- a. construction date (no later than 30 days after such date);
- b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
- c. actual start-up date (within 15 days after such date); and,
- d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P. O. Box 163669
Columbus, Ohio 43216-3669

Issued: To be entered upon final issuance

and

Hamilton County Department of Environmental Services
250 William Howard Taft Rd.
Cincinnati, Ohio 45219

13. The permittee shall submit deviation (excursion) reports which identify all 3-hour blocks of time during which the average combustion temperature within the oxidation catalyst does not comply with the temperature limitation specified in term A.II.5.
14. The permittee shall submit deviation (excursion) reports which identify all exceedances of the NO_x and CO emissions limitations for each startup/shutdown cycle as specified in term and condition A.I.2.1 and A.I.2.m.
15. The permittee shall submit deviation (excursion) reports which identify all exceedances of the number of startup/shutdown cycles limit in term A.II.7 or the startup/shutdown duration limit in term A.I.2.n.
16. Unless specified, the deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit.
 - b. The emission testing shall be conducted to demonstrate compliance with the NO_x outlet concentration, and the mass emissions limitations for NO_x,* CO, OC, PM, and visible emission limitation, and destruction efficiency for CO and OC.
 - c. The following test method(s) shall be employed to demonstrate compliance with the above emissions limitations: for NO_x, Method 20 of 40 CFR Part 60, Appendix A; for PM, Method 5 of 40 CFR Part 60, Appendix A; for visible emission limitations, Method 9,; for OC Method 25 of 40 CFR Part 60, Appendix A; and for CO Method 10 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.

Emissions Unit ID: P003

- d. The testing shall be conducted while the emissions unit is operating at or near its maximum capacity with and without duct burner firing, unless otherwise specified or approved by Ohio EPA or local air agency.
- e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Hamilton County Department of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Hamilton County Department of Environmental Services refusal to accept the results of the emission test(s).
- f. Personnel from the Hamilton County Department of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- g. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Hamilton County Department of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Hamilton County Department of Environmental Services.

* Using the test methods and procedures required under 40 CFR Part 60.335.

2. Compliance with the allowable emission limitations in section A.I.1 of this permit shall be determined according to the following methods:

- a. NOx Emission Limitations

See section A.I.1.

Applicable Compliance Method

Initial compliance with the allowable outlet concentration, and the lbs/hr emission limitations shall be demonstrated by the performance testing as described in condition V.1 and continual compliance with those limitations shall be demonstrated by the use of the CEM in condition A.III.6 based upon an hourly averaging period . Compliance with the annual emission limitation shall be determined by the record keeping required in condition A.III.2.

- b. PM Emission Limitation

See section A.I.1.

Issued: To be entered upon final issuance

Applicable Compliance Method

Compliance with the lbs/hr emission limitations shall be demonstrated by the performance testing in condition A.V.1. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

Issued: To be entered upon final issuancec. SO₂ Emission Limitation

See section A.I.1.

Applicable Compliance Method

Compliance with the hourly emission limitation shall be determined by the record keeping required in condition A.III.2,4,13,and 14. If required, the permittee shall demonstrate compliance by emission testing in accordance with approved US EPA test methods. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

d. OC Emission Limitations

See section A.I.1.

Applicable Compliance Method

Compliance with the lbs/hr limitations shall be demonstrated by the performance testing in condition A.V.1. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

e. CO Emission Limitation

See section A.I.1.

Applicable Compliance Method

Initial compliance with the lbs/hr emission limitations shall be demonstrated by the performance testing as described in condition A.V.1 and continual compliance with those limitations shall be demonstrated by the use of the CEM in condition A.III.8 based upon an hourly averaging period . Compliance with the annual emission limitation shall be determined by the record keeping required in condition III.2.

f. Emission Limitation

Visible particulate emissions from any stack shall not exceed 10 percent opacity as a six-minute average.

Applicable Compliance Method

University of Cincinnati
PTI Application: 14-05108
Issued

Facility ID: 1431070849

Emissions Unit ID: P003

Compliance with the visible emissions limitation established by this permit shall be determined by Method 9, 40 CFR Part 60 Appendix A.

Issued: To be entered upon final issuance

3. Emission Limitation:

0.05 percent sulfur by weight for the diesel fuel.

Applicable Compliance Method:

When firing diesel fuel, except as provided below, compliance with the allowable SO₂ emission limitation shall be demonstrated by documenting that the sulfur content of each shipment of diesel fuel received during a calendar month meets the limitation.

If required, the permittee shall demonstrate compliance with this emission limitation (when firing diesel fuel) in accordance with 40 CFR, Part 60, Appendix A, Method 6C.

4. Compliance with the hours of operation limitation when burning diesel fuel in the combustion turbine shall be demonstrated by the record keeping in term A.III.2.
5. Compliance with the natural gas usage limitation for the duct burner shall be demonstrated by the record keeping in term A.III.2.
6. Compliance with the emissions limitations in terms and conditions A.I.2.l. and A.I.2.m. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.3.
7. Compliance with the limitation in term and condition A.I.2.n. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.3.
8. Compliance with the operational restriction in term and condition A.II.7. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.2.g.
9. Compliance with the annual heat input operational restriction in term and condition A.II.8. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.2.l.

VI. Miscellaneous Requirements

1. The terms and conditions in this Permit to Install supersede the terms and conditions in Permit to Install 14-05108 as issued on August 15, 2002.

Univer

PTI A

Emissions Unit ID: P003

Issued: To be entered upon final issuance

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P003 - 14.5 MW combined cycle natural gas / transportation grade diesel fuel-fired combustion turbine with 98.5 mmBtu/hr natural gas-fired duct burner and CO oxidation catalyst		See term B.VI

2. Additional Terms and Conditions

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

Unive]

PTI A

Emissions Unit ID: P003

Issued: To be entered upon final issuance**VI. Miscellaneous Requirements**

1. Modeling to demonstrate compliance with the Ohio EPA's "Air Toxic Policy" was not necessary because the emissions unit's maximum annual emissions for each toxic compound will be less than 1.0 ton. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any pollutant that has a listed TLV to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
P004 - 14.5 MW combined cycle natural gas / transportation grade diesel fuel-fired combustion turbine with 98.5 mmBtu/hr natural gas-fired duct burner and CO oxidation catalyst - administrative modification	OAC Rule 3745-31-05(A)(3)

Issued: To be entered upon final issuance

OAC rule 3745-31-10
through 3745-31-20.

OAC rule 3745-17-07(A)

OAC rule 3745-17-11(B)(4)

40 CFR Part 75

OAC rule 3745-103

OAC rule 3745-31-05(C)

40 CFR 60, Subpart GG

40 CFR 60, Subpart Dc

OAC rule 3745-18-06(F)

Issued: To be entered upon final issuance

<u>Applicable Emissions</u> <u>Limitations/Control</u> <u>Measures</u>	2.07 lbs/hr;	Nitrogen oxides (NO _x) emissions shall not exceed 25 ppmvd at 15% oxygen and 14.71 lbs/hr; and
See terms and conditions A.I.2.e. and A.I.2.g. through A.I.2.n.	Sulfur dioxide (SO ₂) emissions shall not exceed 0.16 lb/hr;	PM10 emissions shall not exceed 0.0073 lb/mmBtu and 1.08 lbs/hr.
EMISSION LIMITS DURING NORMAL OPERATION WITHOUT DUCT BURNER FIRING:	Carbon monoxide (CO) emissions shall not exceed 2.84 lbs/hr.	EMISSION LIMITS DURING NORMAL OPERATION WITH DUCT BURNER FIRING:
Particulate matter (PM) emissions shall not exceed 1.08 lbs/hr;	EMISSION LIMITS DURING BACKUP OPERATION:	Nitrogen oxides (NO _x) emissions shall not exceed 0.10 lb/mmBtu and 24.56 lbs/hr; and
Sulfur dioxide (SO ₂) emissions shall not exceed 0.10 lb/hr;	Particulate matter (PM) emissions shall not exceed 1.79 lbs/hr;	PM10 emissions shall not exceed 0.0084 lb/mmBtu and 2.07 lbs/hr.
Organic compounds (OC) emissions shall not exceed 0.56 lb/hr; and	Sulfur dioxide (SO ₂) emissions shall not exceed 7.54 lb/hr;	EMISSION LIMITS DURING BACKUP OPERATION:
Carbon monoxide (CO) emissions shall not exceed 1.97 lbs/hr.	Organic compounds (OC) emissions shall not exceed 0.55 lbs/hr; and	Nitrogen oxides (NO _x) emissions shall not exceed 96 ppmvd at 15% oxygen and 54.91 lbs/hr; and
shall not exceed 1.92 lbs/hr	Carbon monoxide (CO) emissions shall not exceed 1.92 lbs/hr.	PM10 emissions shall not exceed 0.013 lb/mmBtu and 1.79 lbs/hr.
EMISSION LIMITS DURING NORMAL OPERATION WITH DUCT BURNER FIRING:	The requirements of this rule include compliance with the requirements of OAC rule 3745-31-10 through 3745-31-20, OAC rule 3745-31-05(C), 40 CFR Part 60, Subpart GG and 40 CFR Part 60, Subpart Dc.	COMBINED EMISSIONS FROM THE TURBINE AND DUCT BURNER AT ALL LOAD CONDITIONS, INCLUDING STARTUP/SHUTDOWN,
Particulate matter (PM) emissions shall not exceed	EMISSION LIMITS DURING NORMAL OPERATION WITHOUT DUCT BURNER FIRING:	

Univer

PTI A

Emissions Unit ID: P004

Issued: To be entered upon final issuance

NORMAL AND BACKUP:

Nitrogen oxides (NO_x) emissions shall not exceed 91.5 TPY*;

PM10 emissions shall not exceed 7.0 TPY*;

Benzene emissions shall not exceed 0.0011 TPY*;

Particulate matter (PM) emissions shall not exceed 7.0 TPY*;

Sulfur dioxide (SO₂) emissions shall not exceed 1.63 TPY*;

Organic compounds (OC) emissions shall not exceed 2.82 TPY*; and

Carbon monoxide (CO) emissions shall not exceed 11.46 TPY*.

See term A.I.2.a, A.III.13 and A.III.14.

See term A.III.16.

The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

The emission limitation

specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

See term A.I.2.b.

See term A.I.2.b.

* Based on a rolling, 12-month summation.

Assume PM=PM10

Emissions Unit ID: P004

2. Additional Terms and Conditions

- 2.a** The emissions limits based on this applicable rule are equivalent to or less stringent than the limits established pursuant to OAC rule 3745-31-05(A)(3) and OAC rule 3745-31-10 through 3745-31-20. Except as provided for in the terms and conditions in this permit, the permittee is not exempt from meeting any additional requirements of 40 CFR Part 60, Subpart GG.
- 2.b** If the permittee is subject to the requirements of 40 CFR Part 72 and 75 concerning acid rain, the permittee shall ensure that any effected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.
- 2.c** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by the use of dry low NOx burners with a 25.0 ppm NOx emission limit during normal operation, a catalytic oxidizer to control CO and VOC emissions at a destruction efficiency of at least 89 percent by weight, and limited usage of diesel fuel in the turbine and natural gas in the duct burner.
- 2.d** The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.
- 2.e** Visible particulate emissions from any stack shall not exceed 10 percent opacity, as a six-minute average except during periods of malfunction as provided in OAC rule 3745-17-07(A)(3)(c).
- 2.f** The hourly emission limitation(s) for PM, PM10, SO2 and VOC outlined in term A.I.1 are based upon the emissions unit's Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.g** "Normal Operation" shall be defined as the period when the combustion turbine achieves dry low NOx mode, burning natural gas at steady state operation, between 50 percent load (equivalent to an output of 7.25 megawatts) and full load.
- 2.h** "Backup Operation" shall be defined as the period when the combustion turbine achieves dry low NOx mode, burning diesel fuel at steady state operation, between 65 percent load (equivalent to an output of 9.425 megawatts) and full load. Duct burners shall not operate during periods of backup operation.
- 2.i** "Full Load" shall be defined as any load greater than or equal to the nominally rated maximum output of 14.5 megawatts.
- 2.j** "Startup" shall be defined as the period between initial fuel light-off in the combustion turbine until the combustion turbine reaches normal or backup operations.

Issued: To be entered upon final issuance

2.k "Shutdown" shall be defined as the period beginning when the combustion turbine leaves normal or backup operations until combustion has ceased.

2.l When burning natural gas, during startup/shutdown cycle, the following emission limits shall not be exceeded for this emission unit:

NO_x = 57.0 lbs/ startup/shutdown cycle

CO = 21.0 lbs/ startup/shutdown cycle.

2.m When burning diesel fuel, during startup/shutdown cycle, the following emission limits shall not be exceeded for this emission unit:

NO_x = 164.7 lbs/ startup/shutdown cycle

CO = 13.6 lbs/ startup/shutdown cycle.

2.n A startup/shutdown cycle shall not exceed a maximum total duration of 3 hours.

II. Operational Restrictions

1. The permittee shall only burn natural gas in the duct burner portion of this emissions unit, and except as allowed in term A.II.3 of this permit, the permittee shall only burn natural gas in the combustion turbine portion of this emission unit. The maximum sulfur content of natural gas shall not exceed 2 grains per 100 standard cubic feet.
2. The sulfur content of the diesel fuel used in this combustion turbine shall not exceed 0.05 percent by weight.
3. The maximum annual operating hours for the combustion turbine while burning diesel fuel shall not exceed 288 hours, based upon a rolling, 12-month summation of the operating hours.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the operating hours levels specified in the following table:

Month(s)	Maximum Allowable Cumulative Operating Hours
1	144
1-2	144
1-3	144

Emissions Unit ID: P004

1-4	144
1-5	144
1-6	170
1-7	195
1-8	220
1-9	245
1-10	270
1-11	288
1-12	288

After the first 12 calendar months of operation, following the issuance of this permit, compliance with the annual operating hours limitation shall be based upon a rolling, 12- month summation of the operating hours.

4. The maximum annual natural gas usage for the duct burner of this emission unit shall not exceed 515 million standard cubic feet, based upon a rolling, 12-month summation of the natural gas usage figures.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the natural gas usage levels specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative Natural Gas Usage, MMscf</u>
1	71
1-2	142
1-3	213
1-4	284
1-5	355
1-6	426
1-7	497
1-8	515
1-9	515
1-10	515
1-11	515
1-12	515

After the first 12 calendar months of operation, following the issuance of this permit, compliance with the annual natural gas usage limitation shall be based upon a rolling, 12- month summation of the natural gas usage levels.

5. The average combustion temperature within the oxidation catalyst, for any 3-hour block of time when the emissions unit is in operation, shall not be more than 50 degrees Fahrenheit below the average temperature during the most recent emission test that demonstrated the emissions unit was in compliance.

Issued: To be entered upon final issuance

6. Duct burners shall not operate during backup mode operation.
7. The number of startup/shutdown cycles per year shall not exceed 180 cycles.
8. The maximum annual heat input rate to the combustion turbine of this emission unit shall not exceed 1,177,200 mmBtu, based upon a rolling, 12-month summation of the fuel usage figures. The permittee has records to demonstrate compliance with this limitation upon issuance of this permit.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain daily records of the following information:
 - a. the emissions unit's actual electrical output for each operating hour; and
 - b. for each day during which the permittee burns a fuel other than natural gas and/or diesel fuel, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
2. The permittee shall maintain monthly records of the following information for this emissions unit:
 - a. The natural gas usage rate in the combustion turbine for each month (in standard cubic feet).
 - b. The natural gas usage rate in the duct burner for each month (in standard cubic feet).
 - c. The diesel fuel usage rate in the combustion turbine for each month (in gallons).
 - d. The hours of operation of the combustion turbine.
 - e. The hours of operation of the duct burners and the fuel used during those hours of operation.
 - f. The hours of operation of the combustion turbine while burning diesel fuel.
 - g. The number of startup/shutdown cycles for each month.
 - h. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of the hours of operation of the combustion turbine while burning diesel fuel.

Issued: To be entered upon final issuance

- i. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of the natural gas usage rate in the duct burner.
- j. The monthly emission rate for NO_x, CO, SO₂, PM/PM₁₀ and VOC, in tons.
- k. Beginning after the first 12 calendar months of operation following issuance of this permit, the rolling, 12-month summation of NO_x, CO, SO₂, PM/PM₁₀ and VOC, in tons.
- l. The rolling, 12-month summation of the actual heat input rate of the combustion turbine.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative hours of operation of the combustion turbine while burning diesel fuel for each calendar month, and the cumulative natural gas usage rate in the duct burner for each calendar month.

3. The permittee shall maintain monthly records of the following information for this emissions unit in order to monitor compliance with the startup and shutdown emission limitations and operational restrictions:
 - a. the date and duration, in minutes, of each startup and shutdown cycle;
 - b. the emissions, in pounds, for NO_x and CO when burning natural gas for each startup and shutdown cycle; and
 - c. the emissions, in pounds, for NO_x and CO when burning diesel fuel for each startup and shutdown cycle.

The permittee shall use the continuous NO_x and CO emissions monitoring data to determine the NO_x and CO emissions for these emissions units. During any period when the NO_x and/or the CO emissions monitoring systems are not operational, the permittee shall use the appropriate missing data procedures specified in 40 CFR Part 75 to determine NO_x and CO (although 40 CFR Part 75 pertains mainly to determining NO_x and SO₂ emissions and not to determining CO emissions, the permittee may use the same procedures allowed in 40 CFR Part 75 to determine NO_x emissions to determine CO emissions) emissions or an approved data substitution protocol. The data substitution values shall not be used to demonstrate compliance with the hourly NO_x and CO emission limitations applicable during normal or backup operation of this emissions unit.

4. For each shipment of diesel fuel received for burning in this emissions unit, the permittee shall maintain records of the total quantity of diesel fuel received, the permittee's or diesel fuel supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission

Emissions Unit ID: P004

rate (in lbs/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch and the quality of the diesel fuel for those loads may be represented by a single batch analysis from the supplier.

The permittee shall collect or require the diesel fuel supplier to collect a representative grab sample for each shipment of diesel fuel that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240, D4294, D6010), or equivalent methods as approved by the Director.

5. Continuous NO_x Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous NO_x monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 6 or 40 CFR Part 75 (The permittee may use 40 CFR Part 75 continuous emissions monitoring systems (CEMS) methodology using fuel flow monitors in conjunction with CEMS data to determination NO_x mass emissions if it is done in accordance with the provisions listed in 40 CFR Part 75) for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and Performance Specification 6 or 40 CFR Part 75 if low mass emission criteria described in 40 CFR Part 75 have been met. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determination mass emissions, the Relative Accuracy requirements of 40 CFR Part 60, Performance Specification 6 are still required to be met, although other requirements from this performance specification may not be required. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous NO_x monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and Performance Specification 6, and 40 CFR Part 75 when applicable.

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO_x monitoring system designed to ensure continuous valid and representative readings of NO_x emissions in units of the applicable standard.

Emissions Unit ID: P004

The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B, Section 1.3 for fuel flow monitors. The quality assurance/quality control plan and a logbook dedicated to the continuous NO_x monitoring system must be kept on site and available for inspection during regular office hours.

6. The permittee shall operate and maintain existing equipment to continuously monitor and record NO_x from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements of the appropriate sections specified in 40 CFR Part 60.13. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, fuel flow meters shall meet the requirements of 40 CFR Part 75, Appendix D, Sections 2.1.2 and 2.1.5.

Data necessary for mass emission calculations per 40 CFR Part 75, Appendix E shall be recorded as outlined in 40 CFR Part 75.58(d).

The permittee shall maintain records of all data obtained by the continuous NO_x monitoring system including, but not limited to, parts per million NO_x on an instantaneous (one-minute) basis, emissions of NO_x in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

During any period when the continuous NO_x emission monitoring systems are not operational, the permittee shall use the appropriate missing data procedures specified in 40 CFR Part 75 to determine the NO_x emissions.

7. Continuous CO Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous CO monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 6, or 40 CFR Part 75 (The permittee may use 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine CO mass emissions if it is done in a manner consistent with NO_x mass emissions determinations as allowed in 40 CFR Part 75) for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of the continuous CO monitoring system pursuant to ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 4A and Performance Specification 6. If 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, the Relative Accuracy requirements of 40 CFR Part 60, Performance Specification 6 are still required to be met, although other requirements from this performance specification may not be required. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In

Issued: To be entered upon final issuance

accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous CO monitoring system shall be granted upon determination by the Ohio EPA Central Office that the system meets all requirements of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4A and 6.

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous CO monitoring system designed to ensure continuous valid and representative readings of CO. The plan shall follow the requirements of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous CO monitoring system must be kept on site and available for inspection during regular office hours.

8. The permittee shall operate and maintain equipment to continuously monitor and record CO from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13. When 40 CFR Part 75 CEMS methodology using fuel flow monitors in conjunction with CEMS data to determine mass emissions, fuel flow meters shall meet the requirements of 40 CFR Part 75, Appendix D, Sections 2.1.2 and 2.1.5.

Data necessary for mass emission calculations per 40 CFR Part 75, Appendix D shall be recorded.

The permittee shall maintain records of all data obtained by the continuous CO monitoring system including, but not limited to, parts per million CO on an instantaneous (one minute) basis, emissions of CO in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, annual, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

9. Continuous O₂ or CO₂ Monitoring - Certified Systems
Statement of Certification

Prior to the installation of the continuous O₂ monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 3 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section

Emissions Unit ID: P004

3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 3. Personnel from the appropriate Ohio EPA District Office or local air agency shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days after the test is completed. Copies of the test results shall be sent to the appropriate Ohio EPA District Office or local air agency and the Ohio EPA, Central Office. Certification of the continuous O₂ monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 3.

Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous O₂ monitoring system designed to ensure continuous valid and representative readings of O₂. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous O₂ monitoring system must be kept on site and available for inspection during regular office hours.

10. The permittee shall operate and maintain equipment to continuously monitor and record O₂ from this emissions unit in percent O₂. Such continuous monitoring and recording equipment shall comply with the requirements in the appropriate sections specified in 40 CFR Part 60.13

The permittee shall maintain records of all data obtained by the continuous O₂ monitoring system including, but not limited to, percent O₂ on an instantaneous (one-minute) basis, emissions of O₂ results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

11. The permittee shall maintain hourly records of the following information for this emissions unit:
- in lb(s)/hr emissions rate for NO_x and CO as obtained from terms III.6. and 8, and NO_x ppmvd@15% O₂ as obtained from term A.III. 6. based upon an hourly averaging period as allowed in the appropriate sections of 40 CFR Part 60.
12. The permittee shall monitor the sulfur content and gross calorific value of the fuel being fired in the duct burner. Fuel sampling and analysis shall be conducted according to the procedures and at the frequency specified by 40 CFR Part 75, Appendix D.
13. The permittee shall monitor the sulfur content and nitrogen content of the fuel being fired in the turbine. The frequency of the monitoring shall be determined as follows:
- a. If the turbine is supplied its fuel from a bulk storage tank, the values shall be determined on each occasion that fuel is transferred to the storage tank from any other source.
 - b. If the turbine is supplied its fuel without intermediate bulk storage the values shall be determined and recorded daily. Owners, operators, or fuel vendors may develop custom fuel schedules for the determination of the values based on the design and operation of the affected facility and the characteristics of the fuel supply. These

Emissions Unit ID: P004

custom schedules shall be substantiated with data and must be approved by the Ohio EPA, Central Office before they can be used.

14. The permittee shall maintain documentation on the sulfur and nitrogen contents of the fuels as required in 40 CFR 60.334(b). The permittee may submit a custom fuel monitoring schedule to deviate from the sampling schedule in 40 CFR 60.334(b).
15. The permittee shall perform weekly checks, when this emissions unit is in operation, during daylight hours, and when weather conditions allow, for any visible particulate emissions from the stack/stacks serving this/these emissions unit(s). The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and,
 - e. any corrective actions taken to eliminate the visible emissions.
16. The permittee shall maintain daily records of the natural gas usage rate in the duct burner.
17. The permittee shall operate and maintain a continuous temperature monitor and recorder which measures and records the combustion temperature within the oxidation catalyst when the emissions unit is in operation. Units shall be in degrees Fahrenheit. The monitoring and recording devices shall be capable of accurately measuring the desired parameter. The temperature monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee.

The permittee shall collect and record the following information for each day:

- a. All 3-hour blocks of time during which the average combustion temperature within the oxidation catalyst, when the emissions unit was in operation, was more than 50 degrees Fahrenheit below the average temperature during the most recent emission test that demonstrated the emissions unit was in compliance.
- b. A log of the downtime for the capture (collection) system, control device, and monitoring equipment, when the associated emissions unit was in operation.

Issued: To be entered upon final issuance**IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas or diesel fuel was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurred.
2. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12-month operating hours limitation while burning diesel fuel in the combustion turbine and for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative operating hours levels. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).
3. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12-month actual heat input limitation to the combustion turbine; the rolling, 12-month natural gas usage limitation for the duct burner and for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative natural gas usage levels. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).
4. The permittee shall notify the Hamilton County Department of Environmental Services in writing of any record that shows a deviation of the allowable sulfur dioxide limitation specified in term A.II.2. of this permit. The notification shall include a copy of such record and shall be sent to the Hamilton County Department of Environmental Services within 45 days after the deviation occurs.
5. Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031 and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of NO_x values in excess of the applicable limits specified in 40 CFR Part 76 and any limitations specified in the terms and conditions of this permit or variance. These reports shall also contain the total NO_x emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous NO_x monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total

Emissions Unit ID: P004

operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031, the permittee shall submit a summary of the excess emission reports pursuant to 40 CFR Part 60.7. The summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

6. Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031 and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of CO values in excess of any applicable limitation(s) specified in OAC Chapter 3745-21, 40 CFR Part 60, or any limitation(s) specified in the terms and conditions of this permit, in units of the standard. These reports shall also contain the total CO emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting any continuous CO monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

Pursuant to OAC rules 3745-15-04, and ORC sections 3704.03(I) and 3704.031, the permittee shall submit a summary of the excess emission reports pursuant to 40 CFR Part 60.7. The

Emissions Unit ID: P004

summary shall be submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following the end of each calendar quarter in a manner prescribed by the Director.

7. Pursuant to 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting all instances of continuous O₂ monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.
8. The permittee shall submit deviation (excursion) reports that identify any record which shows that the sulfur content of the natural gas exceeded 2 grains per standard cubic foot. These reports are due by the date described in Part I - General Terms and Conditions of this permit under section (A)(2).
9. In lieu of the excess emissions reports required under 40 CFR Part 60.334, the permittee shall submit excess emissions reports for emissions unit P004 in accordance with this permit.
10. The permittee shall submit semiannual written reports which (a) identify all weeks during which any visible particulate emissions were observed from the stack serving this emissions units and (b) if needed describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.
11. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year. The CAA, Title V Fee Emission Report (FER) required to be submitted annually by April 15 for the facility will also satisfy the emission reporting requirement of this condition.
12. This emissions unit is subject to the applicable provisions of Subpart Dc. and GG of the New Source Performance Standards (NSPS) as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60. The application and enforcement of these standards are delegated to the Ohio EPA. The requirements of 40 CFR Part 60 are also federally enforceable.

Pursuant to 40 CFR Part 60.7, the permittee is hereby advised of the requirement to report the following at the appropriate times:

- a. construction date (no later than 30 days after such date);
- b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);

- c. actual start-up date (within 15 days after such date); and,
- d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P. O. Box 163669
Columbus, Ohio 43216-3669

Issued: To be entered upon final issuance

and

Hamilton County Department of Environmental Services
250 William Howard Taft Rd.
Cincinnati, Ohio 45219

13. The permittee shall submit deviation (excursion) reports which identify all 3-hour blocks of time during which the average combustion temperature within the oxidation catalyst does not comply with the temperature limitation specified in term A.II.5.
14. The permittee shall submit deviation (excursion) reports which identify all exceedances of the NO_x and CO emissions limitations for each startup/shutdown cycle as specified in term and condition A.I.2.1 and A.I.2.m.
15. The permittee shall submit deviation (excursion) reports which identify all exceedances of the number of startup/shutdown cycles limit in term A.II.7 or the startup/shutdown duration limit in term A.I.2.n.
16. Unless specified, the deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of such emissions unit.
 - b. The emission testing shall be conducted to demonstrate compliance with the NO_x outlet concentration, and the mass emissions limitations for NO_x,* CO, OC, PM, and visible emission limitation, and destruction efficiency for CO and OC.
 - c. The following test method(s) shall be employed to demonstrate compliance with the above emissions limitations: for NO_x, Method 20 of 40 CFR Part 60, Appendix A; for PM, Method 5 of 40 CFR Part 60, Appendix A; for visible emission limitations, Method 9,; for OC Method 25 of 40 CFR Part 60, Appendix A; and for CO Method 10 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.

Issued: To be entered upon final issuance

- d. The testing shall be conducted while the emissions unit is operating at or near its maximum capacity with and without duct burner firing, unless otherwise specified or approved by Ohio EPA or local air agency.
- e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Hamilton County Department of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Hamilton County Department of Environmental Services refusal to accept the results of the emission test(s).
- f. Personnel from the Hamilton County Department of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- g. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Hamilton County Department of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Hamilton County Department of Environmental Services.

* Using the test methods and procedures required under 40 CFR Part 60.335.

2. Compliance with the allowable emission limitations in section A.I.1 of this permit shall be determined according to the following methods:

- a. NOx Emission Limitations

See section A.I.1.

Applicable Compliance Method

Initial compliance with the allowable outlet concentration, and the lbs/hr emission limitations shall be demonstrated by the performance testing as described in condition V.1 and continual compliance with those limitations shall be demonstrated by the use of the CEM in condition A.III.6 based upon an hourly averaging period . Compliance with the annual emission limitation shall be determined by the record keeping required in condition

A.III.2.

b. PM Emission Limitation

See section A.I.1.

Applicable Compliance Method

Compliance with the lbs/hr emission limitations shall be demonstrated by the performance testing in condition A.V.1. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

Issued: To be entered upon final issuancec. SO₂ Emission Limitation

See section A.I.1.

Applicable Compliance Method

Compliance with the hourly emission limitation shall be determined by the record keeping required in condition A.III.2,4,13,and 14. If required, the permittee shall demonstrate compliance by emission testing in accordance with approved US EPA test methods. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

d. OC Emission Limitations

See section A.I.1.

Applicable Compliance Method

Compliance with the lbs/hr limitations shall be demonstrated by the performance testing in condition A.V.1. Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by the actual annual hours of operation and dividing by 2000 lbs/ton.

e. CO Emission Limitation

See section A.I.1.

Applicable Compliance Method

Initial compliance with the lbs/hr emission limitations shall be demonstrated by the performance testing as described in condition A.V.1 and continual compliance with those limitations shall be demonstrated by the use of the CEM in condition A.III.8 based upon an hourly averaging period . Compliance with the annual emission limitation shall be determined by the record keeping required in condition A.III.2.

f. Emission Limitation

Visible particulate emissions from any stack shall not exceed 10 percent opacity as a six-minute average.

Applicable Compliance Method

63

Unive]

PTI A

Emissions Unit ID: P004

Issued: To be entered upon final issuance

Compliance with the visible emissions limitation established by this permit shall be determined by Method 9, 40 CFR Part 60 Appendix A.

Issued: To be entered upon final issuance

3. Emission Limitation:

0.05 percent sulfur by weight for the diesel fuel.

Applicable Compliance Method:

When firing diesel fuel, except as provided below, compliance with the allowable SO₂ emission limitation shall be demonstrated by documenting that the sulfur content of each shipment of diesel fuel received during a calendar month meets the limitation.

If required, the permittee shall demonstrate compliance with this emission limitation (when firing diesel fuel) in accordance with 40 CFR, Part 60, Appendix A, Method 6C.

4. Compliance with the hours of operation limitation when burning diesel fuel in the combustion turbine shall be demonstrated by the record keeping in term A.III.2.
5. Compliance with the natural gas usage limitation for the duct burner shall be demonstrated by the record keeping in term A.III.2.
6. Compliance with the emissions limitations in terms and conditions A.I.2.l. and A.I.2.m. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.3.
7. Compliance with the limitation in term and condition A.I.2.n. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.3.
8. Compliance with the operational restriction in term and condition A.II.7. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.2.g.
9. Compliance with the annual heat input operational restriction in term and condition A.II.8. shall be demonstrated by the monitoring and record keeping required in term and condition A.III.2.l.

VI. Miscellaneous Requirements

1. The terms and conditions in this Permit to Install supersede the terms and conditions in Permit to Install 14-05108 as issued on August 15, 2002.

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P004 - 14.5 MW combined cycle natural gas / transportation grade diesel fuel-fired combustion turbine with 98.5 MMBTU/hr natural gas-fired duct burner and CO oxidation catalyst		See term B.VI

2. Additional Terms and Conditions

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

1. Modeling to demonstrate compliance with the Ohio EPA's "Air Toxic Policy" was not necessary because the emissions unit's maximum annual emissions for each toxic compound will be less than 1.0 ton. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified

Unive]

PTI A

Emissions Unit ID: P004

Issued: To be entered upon final issuance

permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any pollutant that has a listed TLV to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.

Univer

PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
P005 - 2 MW diesel fired stationary engine	<p>OAC rule 3745-31-05(A)(3)</p> <p>OAC rules 3745-31-10 through 3745-31-20.</p> <p>OAC 3745-17-07(A)(1)</p> <p>OAC 3745-17-11(B)(5)(b)</p>

Univer

PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance

OAC rule 3745-18-06(B)

Applicable Emissions Limitations/Control Measures	microns (PM10) emissions shall not exceed 0.04 gallon/hp-hr and 0.06 ton per year*.
Particulate Matter (PM) emissions shall not exceed 0.012 lb/MMBTU actual heat input	Sulfur content of diesel fuel less than 0.05 per cent.
Sulfur dioxide (SO ₂) emissions shall not exceed 0.043 lb/MMBTU actual heat input	Good combustion practices.
Nitrogen oxides (NO _x) emissions shall not exceed 40.92 lbs/hr	Visible particulate emissions from any stack shall not exceed 20 percent opacity, as a six-minute average, except as specified by rule.
Organic compounds (OC) emissions shall not exceed 1.04 lbs/hr	The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).
Carbon monoxide (CO) emissions shall not exceed 1.73 lbs/hr	Exempt
PM10 emissions shall not exceed 0.23 lb/hr	* Based on a rolling, 12-month summation.
TOTAL TONS PER YEAR NO _x - 10.23 PM/PM10 - 0.06 SO ₂ - 0.21 OC - 0.26 CO - 0.43	
The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A)(1) and 3745-31-10 through 3745-31-20.	
NO _x emissions shall not exceed 7.1 gallons/hp-hr and 10.23 tons per year*.	
Particulate Matter less than 10	

Emissions Unit ID: P005

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and the hours of operation limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit's Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.

II. Operational Restrictions

1. The maximum annual operating hours for this emissions unit shall not exceed 500 hours, based upon a rolling, 12-month summation of the operating hours.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the operating hours levels specified in the following table:

Issued: To be entered upon final issuance

<u>Month(s)</u>	<u>Maximum Allowable Cumulative Operating Hours</u>
1	250
1-2	250
1-3	250
1-4	250
1-5	250
1-6	250
1-7	295
1-8	340
1-9	385
1-10	430
1-11	475
1-12	500

After the first 12 calendar months of operation, following the issuance of this permit, compliance with the annual operating hours limitation shall be based upon a rolling, 12- month summation of the operating hours.

2. The sulfur content of the diesel fuel used in this combustion turbine shall not exceed 0.05 percent by weight.

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of diesel fuel received for burning in this emissions unit, the permittee shall maintain records of the total quantity of diesel fuel received, the permittee's or diesel fuel supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch and the quality of the diesel fuel for those loads may be represented by a single batch analysis from the supplier.

The permittee shall collect or require the diesel fuel supplier to collect a representative grab sample for each shipment of diesel fuel that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240, D4294, D6010), or equivalent methods as approved by the Director.

2. The permittee shall maintain monthly records of the following information for this emissions

Issued: To be entered upon final issuance

unit:

- a. the operating hours for each month; and
- b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the operating hours.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative operating hours for each calendar month.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month operating hours limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative hours of operation limitation. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).
2. The permittee shall notify the Hamilton County Department of Environmental Services in writing of any record that shows a deviation of the allowable sulfur dioxide limitation specified in term A.II.2. of this permit. The notification shall include a copy of such record and shall be sent to the Hamilton County Department of Environmental Services within 45 days after the deviation occurs.
These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under section (A)(2).

V. Testing Requirements

1. Compliance with the visible particulate emission limitation shall be demonstrated by the Methods outlined in 40 CFR Part 60, Appendix A, Method 9.
2. Compliance with the sulfur content limitation in term A.II.2 shall be determined by the diesel fuel analysis and recordkeeping in term A.III.1.
3. Compliance with the hours of operation limitation in term A.II.1 shall be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.I.1 shall be demonstrated by the emission factors, and the operational parameters as submitted in PTI application 14-05108 submitted February 26, 2001.

VI. Miscellaneous Requirements

1. The terms and conditions in this Permit to Install supersede the terms and conditions in Permit to Install 14-05108 as issued on August 15, 2002.

Unive|

PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance**B. State Only Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P005 - 2 MW diesel fired stationary engine		

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None