



State of Ohio Environmental Protection Agency

RE: DRAFT PERMIT TO INSTALL CERTIFIED MAIL
HAMILTON COUNTY

Street Address:

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:
Lazarus Gov.
Center

Application No: 14-05139

DATE: 6/5/2001

Childrens Hospital Medical Center
Thomas Kinman
3333 Burnet Avenue
Cincinnati, OH 452293039

You are hereby notified that the Ohio Environmental Protection Agency has made a draft action recommending that the Director issue a Permit to Install for the air contaminant source(s) [emissions unit(s)] shown on the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the proposed installation. A public notice concerning the draft permit will appear in the Ohio EPA Weekly Review and the newspaper in the county where the facility will be located. Public comments will be accepted by the field office within 30 days of the date of publication in the newspaper. Any comments you have on the draft permit should be directed to the appropriate field office within the comment period. A copy of your comments should also be mailed to Robert Hodanbosi, Division of Air Pollution Control, Ohio EPA, P.O. Box 1049, Columbus, OH, 43266-0149.

A Permit to Install may be issued in proposed or final form based on the draft action, any written public comments received within 30 days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting. Upon issuance of a final Permit to Install a fee of \$1200 will be due. Please do not submit any payment now.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469. If you have any questions about this draft permit, please contact the field office where you submitted your application, or Mike Ahern, Field Operations & Permit Section at (614) 644-3631.

Very truly yours,

Thomas G. Rigo
Field Operations and Permit Section
Division of Air Pollution Control

CC: USEPA HCDES KY IN Ohio-Kentucky-Indiana Reg Council of Gov



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

Permit To Install

Issue Date: To be entered upon final issuance

DRAFT PERMIT TO INSTALL 14-05139

Application Number: 14-05139
APS Premise Number: 1431071395
Permit Fee: **To be entered upon final issuance**
Name of Facility: Childrens Hospital Medical Center
Person to Contact: Thomas Kinman
Address: 3333 Burnet Avenue
Cincinnati, OH 452293039

Location of proposed air contaminant source(s) [emissions unit(s)]:

**3333 Burnet Avenue
Cincinnati, Ohio**

Description of proposed emissions unit(s):

Three 2.2 megawatt peaking diesel generators, Two 1.75 megawatt peaking diesel generators and Two 20,000 gallon underground storage tanks.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

A. State and Federally Enforceable Permit To Install General Terms and Conditions**1. Monitoring and Related Recordkeeping and Reporting Requirements**

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.10 below if no deviations occurred during the quarter.

Childrens Hospital Medical Center

Facility ID: 1431071395

PTI Application: 14-05139

Issued: To be entered upon final issuance

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

Issued: To be entered upon final issuance

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees within 30 days after the issuance of this Permit To Install.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit

Childrens Hospital Medical Center

Facility ID: 1431071395

PTI Application: 14-05139

Issued: To be entered upon final issuance

shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit To Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within thirty (30) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

Childrens Hospital Medical Center

Facility ID: 1431071395

PTI Application: 14-05139

Issued: To be entered upon final issuance

B. State Only Enforceable Permit To Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

5. Termination of Permit To Install

This permit to install shall terminate within eighteen months of the effective date of the permit to install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

6. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

7. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

8. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

Childrens Hospital Medical Center

Facility ID: 1431071395

PTI Application: 14-05139

Issued: To be entered upon final issuance

9. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

10. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit To Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

**SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
PM/PM10	2.4
SO2	15.5
VOC	9.6
NOx	144.7
CO	24.7

Childrens Hospital Medical Center

PTI Application: 14-05139

Issued: To be entered upon final issuance

Facility ID: 1431071395

12

Childrens Hospital Medical Center

PTI Application: 14-05139

Issued: To be entered upon final issuance

Facility ID: 1431071395

Child

PTI A

Emissions Unit ID: P001

Issued: To be entered upon final issuance

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Child

PTI A

Emissions Unit ID: P001

Issued: To be entered upon final issuance**Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)****A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property,
and/or Equipment

Applicable Rules/Requirements

OAC rule 3745-18-06(D)

P001 - 2.2 megawatt
peaking diesel generator

OAC rule 3745-31-05(A)(3)

OAC rule 3745-31-05(D)
Synthetic Minor to avoid PSD

OAC rule 3745-17-07(A)(1)

OAC rule 3745-17-11(B)(5)(b)

Child

PTI A

Emissions Unit ID: P001

Issued: To be entered upon final issuance

Applicable Emissions
Limitations/Control
Measures

pursuant to OAC rule
3745-31-05(A)(3).

0.062 lb PM10/MMBtu
actual heat input
0.404 lb SO2/MMBTU
0.98 lb VOC/hr
61.62 lbs NOx/hr
2.2 lbs CO/hr

See term A.I.2.c thru A.I.2.f

The requirements of this rule
also include compliance with
the requirements of OAC
rules 3745-31-05(D),
3745-17-07(A)(1) and
3745-17-11(B)(5)(b).

88.9 TPY NOx, as a rolling,
12-month summation,
combined from emissions
units
P001 - P003.

See term A.II.2.

Visible particulate emissions
from any stack shall not
exceed 20 percent opacity,
as a six-minute average,
except as specified by rule.

0.062 lb PM/MMBtu actual
heat input

The emission limitation
specified by this rule is less
stringent than the emission
limitation established

16

Child

PTI A

Issued: To be entered upon final issuance

Emissions Unit ID: P001

Issued: To be entered upon final issuance

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit’s Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.c** The combined particulate matter (PM-PM10) emissions from emissions unit P001 thru P003 shall not exceed 1.9 TPY, based upon a rolling, 12-month summation.
- 2.d** The combined sulfur dioxide (SO2) emissions from emissions unit P001 thru P003 shall not exceed 12.3 TPY, based upon a rolling, 12-month summation.
- 2.e** The combined volatile organic compound (VOC) emissions from emissions unit P001 thru P003 shall not exceed 3.3 TPY, based upon a rolling, 12-month summation.
- 2.f** The combined carbon monoxide (CO) emissions from emissions unit P001 thru P003 shall not exceed 8.1 TPY, based upon a rolling, 12-month summation.

II. Operational Restrictions

- 1. The quality of the No. 2 fuel oil burned in this emissions unit shall have a combination of sulfur content and heat content sufficient to meet the sulfur dioxide emission limitation of 0.404 lb/MMBtu of actual heat input.

Compliance with the above-mentioned SO2 emission limitation shall be determined by using the analytical results provided by the permittee or oil supplier and the calculated SO2 emission rate for each shipment of oil.

- 2. The maximum annual No. 2 fuel oil usage for emission units P001, P002 and P003 combined shall not exceed 443,000 gallons per year based upon a rolling, 12- month summation of the No. 2 fuel oil usage.

To ensure enforceability during the first 12 calendar months of operation following issuance of this permit, the permittee shall not exceed the No. 2 fuel oil usage limits specified in the following table:

	Maximum Allowable
<u>Month(s)</u>	<u>Cumulative No.2 Fuel Oil Usage (Gallons)</u>

1	36,917
1-2	73,833
1-3	110,750
1-4	147,667
1-5	184,583
1-6	221,500
1-7	258,417
1-8	295,333
1-9	332,250
1-10	369,167
1-11	406,083
1-12	443,000

After the first 12 calendar months of operation following issuance of this permit, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the No. 2 fuel oil usage figures

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content, heat content and the calculated SO₂ emission rate [the SO₂ emission rate shall be calculated as specified in OAC 3745-18-04(F)].

The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the appropriate Ohio EPA District Office or local air agency.

2. The permittee shall maintain monthly records of the following information for emissions units P001, P002 and P003, combined:
 - a. the total No. 2 fuel oil usage for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the No. 2 fuel oil usage figures.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative No. 2 fuel oil usage for each calendar month.

3. The permittee shall perform weekly checks, when any/all of emission units P001, P002 and P003 is/are in operation and when weather conditions allow, for any visible particulate emissions from

Issued: To be entered upon final issuance

the stack/stacks serving this/these emissions unit(s). The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:

- a. the color of the emissions;
- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month No. 2 fuel oil usage limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative No.2 fuel oil usage limitation.
2. The permittee shall submit, on a quarterly basis, copies of the permittee's or oil supplier's analyses for each shipment of oil which is received for burning in this emissions unit. The permittee's or oil supplier's analysis shall document the sulfur content (percent) and heat content (Btu/gallon) for each shipment of oil. The following information shall also be included with the copies of the permittee's or oil supplier's analysis:
 - a. the total quantity of oil received in each shipment (gallons);
 - b. the weighted* average sulfur dioxide emission rate (pounds/mmBtu) for the oil received during the calendar month; and
 - c. the weighted* average heat content (Btu/gallon) of the oil received during the calendar month.

*In proportion to the quantity of oil received in each shipment during the calendar month. The quarterly reports shall be submitted by January 31, April 30, July 31 and October 31 of each year and shall cover the previous calendar quarters.

3. The permittee shall submit semiannual written reports which (a) identify all weeks during which

Emissions Unit ID: P001

any visible particulate emissions were observed from the stack serving emissions units P001, P002 and P003 and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.

4. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
5. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. Compliance with the visible particulate emission limitation shall be demonstrated by the Methods outlined in 40 CFR Part 60, Appendix A, Method 9.
2. Compliance with the sulfur content limitation in term A.II.1 shall be determined by the fuel oil analysis and recordkeeping in term A.III.1.
3. Compliance with the No. 2 fuel oil usage limitation in term A.II.2 shall be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.I.1 and A.I.2 shall be demonstrated by the emission factors and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child

PTI A

Emissions Unit ID: P001

Issued: To be entered upon final issuance**B. State Only Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P001 - 2.2 megawatt peaking diesel generator	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Child
PTI A

Emissions Unit ID: P002

Issued: To be entered upon final issuance

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	OAC rule 3745-18-06(D)
P002 - 2.2 megawatt peaking diesel generator	OAC rule 3745-31-05(A)(3)	
	OAC rule 3745-31-05(D) Synthetic Minor to avoid PSD	
	OAC rule 3745-17-07(A)(1)	
	OAC rule 3745-17-11(B)(5)(b)	

Child**PTI A**

Emissions Unit ID: P002

Issued: To be entered upon final issuance

Applicable Emissions
Limitations/Control
Measures

3745-31-05(A)(3).

0.062 lb PM10/MMBtu
 actual heat input
 0.404 lb SO2/MMBTU
 0.98 lb VOC/hr
 61.62 lbs NOx/hr
 2.2 lbs CO/hr

See term A.I.2.c thru A.I.2.f

The requirements of this rule
 also include compliance with
 the requirements of OAC
 rules 3745-31-05(D),
 3745-17-07(A)(1) and
 3745-17-11(B)(5)(b).

88.9 TPY NOx, as a rolling,
 12-month summation,
 combined from emissions
 unit P001 - P003.

See term A.II.2.

Visible particulate emissions
 from any stack shall not
 exceed 20 percent opacity,
 as a six-minute average,
 except as specified by rule.

0.062 lb PM/MMBtu actual
 heat input

The emission limitation
 specified by this rule is less
 stringent than the emission
 limitation established
 pursuant to OAC rule

Emissions Unit ID: P002

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit’s Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.c** The combined particulate matter (PM-PM10) emissions from emissions unit P001 thru P003 shall not exceed 1.9 TPY, based upon a rolling, 12-month summation.
- 2.d** The combined sulfur dioxide (SO2) emissions from emissions unit P001 thru P003 shall not exceed 12.3 TPY, based upon a rolling, 12-month summation.
- 2.e** The combined volatile organic compound (VOC) emissions from emissions unit P001 thru P003 shall not exceed 3.3 TPY, based upon a rolling, 12-month summation.
- 2.f** The combined carbon monoxide (CO) emissions from emissions unit P001 thru P003 shall not exceed 8.1 TPY, based upon a rolling, 12-month summation.

II. Operational Restrictions

- 1. The quality of the No. 2 fuel oil burned in this emissions unit shall have a combination of sulfur content and heat content sufficient to meet the sulfur dioxide emission limitation of 0.404 lb/MMBtu of actual heat input.

Compliance with the above-mentioned SO2 emission limitation shall be determined by using the analytical results provided by the permittee or oil supplier and the calculated SO2 emission rate for each shipment of oil.

- 2. The maximum annual No. 2 fuel oil usage for emission units P001, P002 and P003, combined shall not exceed 443,000 gallons per year based upon a rolling, 12- month summation of the No. 2 fuel oil usage.

To ensure enforceability during the first 12 calendar months of operation following issuance of this permit, the permittee shall not exceed the No. 2 fuel oil usage limits specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative No.2 Fuel Oil Usage (Gallons)</u>
1	36,917
1-2	73,833
1-3	110,750
1-4	147,667

Child
PTI A

Emissions Unit ID: P002

Issued: To be entered upon final issuance

1-5	184,583
1-6	221,500
1-7	258,417
1-8	295,333
1-9	332,250
1-10	369,167
1-11	406,083
1-12	443,000

After the first 12 calendar months of operation following issuance of this permit, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the No. 2 fuel oil usage figures

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content, heat content and the calculated SO₂ emission rate [the SO₂ emission rate shall be calculated as specified in OAC 3745-18-04(F)].

The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the appropriate Ohio EPA District Office or local air agency.

2. The permittee shall maintain monthly records of the following information for emissions units P001, P002 and P003, combined:
 - a. the total No. 2 fuel oil usage for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the No. 2 fuel oil usage figures.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative No. 2 fuel oil usage for each calendar month.

3. The permittee shall perform weekly checks, when any/all of emission units P001, P002 and P003 is/are in operation and when weather conditions allow, for any visible particulate emissions from

Emissions Unit ID: P002

the stack/stacks serving this/these emissions unit(s). The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:

- a. the color of the emissions;
- b. whether the emissions are representative of normal operations;
- c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
- d. the total duration of any visible emission incident; and,
- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month No. 2 fuel oil usage limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative No.2 fuel oil usage limitation.
2. The permittee shall submit, on a quarterly basis, copies of the permittee's or oil supplier's analyses for each shipment of oil which is received for burning in this emissions unit. The permittee's or oil supplier's analysis shall document the sulfur content (percent) and heat content (Btu/gallon) for each shipment of oil. The following information shall also be included with the copies of the permittee's or oil supplier's analysis:
 - a. the total quantity of oil received in each shipment (gallons);
 - b. the weighted* average sulfur dioxide emission rate (pounds/mmBtu) for the oil received during the calendar month; and
 - c. the weighted* average heat content (Btu/gallon) of the oil received during the calendar month.

*In proportion to the quantity of oil received in each shipment during the calendar month. The quarterly reports shall be submitted by January 31, April 30, July 31 and October 31 of each year and shall cover the previous calendar quarters.

3. The permittee shall submit semiannual written reports which (a) identify all weeks during which any visible particulate emissions were observed from the stack serving emissions units P001, P002 and P003 and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.

Issued: To be entered upon final issuance

4. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
5. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. Compliance with the visible particulate emission limitation shall be demonstrated by the Methods outlined in 40 CFR Part 60, Appendix A, Method 9.
2. Compliance with the sulfur content limitation in term A.II.1 shall be determined by the fuel oil analysis and recordkeeping in term A.III.1.
3. Compliance with the No. 2 fuel oil usage limitation in term A.II.2 shall be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.I.1. and A.I.2. shall be demonstrated by the emission factors and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child
PTI A

Emissions Unit ID: P002

Issued: To be entered upon final issuance

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P002 - 2.2 megawatt peaking diesel generator	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P003 - 2.2 megawatt peaking diesel generator	OAC rule 3745-31-05(A)(3)	0.062 lb PM10/MMBTu actual heat input 0.404 lb SO ₂ /MMBTU 0.98 lb VOC/hr 61.62 lbs NO _x /hr 2.2 lbs CO/hr See term A.I.2.c thru A.I.2.f The requirements of this rule also include compliance with the requirements of OAC rules 3745-31-05(D), 3745-17-07(A)(1) and 3745-17-11(B)(5)(b).
	OAC rule 3745-31-05(D) Synthetic Minor to avoid PSD	88.9 TPY NO _x , as a rolling, 12-month summation, combined from emissions unit P001 - P003. See term A.II.2.
	OAC rule 3745-17-07(A)(1)	Visible particulate emissions from any stack shall not exceed 20 percent opacity, as a six-minute average, except as specified by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PM/MMBTu actual heat input
	OAC rule 3745-18-06	The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

Issued: To be entered upon final issuance**2. Additional Terms and Conditions**

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit's Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.c** The combined particulate matter (PM-PM10) emissions from emissions unit P001 thru P003 shall not exceed 1.9 TPY, based upon a rolling, 12-month summation.
- 2.d** The combined sulfur dioxide (SO₂) emissions from emissions unit P001 thru P003 shall not exceed 12.3 TPY, based upon a rolling, 12-month summation.
- 2.e** The combined volatile organic compound (VOC) emissions from emissions unit P001 thru P003 shall not exceed 3.3 TPY, based upon a rolling, 12-month summation.
- 2.f** The combined carbon monoxide (CO) emissions from emissions unit P001 thru P003 shall not exceed 8.1 TPY, based upon a rolling, 12-month summation.

II. Operational Restrictions

1. The quality of the No. 2 fuel oil burned in this emissions unit shall have a combination of sulfur content and heat content sufficient to meet the sulfur dioxide emission limitation of 0.404 lb/MMBtu of actual heat input.

Compliance with the above-mentioned SO₂ emission limitation shall be determined by using the analytical results provided by the permittee or oil supplier and the calculated SO₂ emission rate for each shipment of oil.

2. The maximum annual No. 2 fuel oil usage for emission units P001, P002 and P003, combined shall not exceed 443,000 gallons per year based upon a rolling, 12-month summation of the No. 2 fuel oil usage.

To ensure enforceability during the first 12 calendar months of operation following issuance of this permit, the permittee shall not exceed the No. 2 fuel oil usage limits specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative No.2 Fuel Oil Usage (Gallons)</u>
-----------------	---

Issued: To be entered upon final issuance

1	36,917
1-2	73,833
1-3	110,750
1-4	147,667
1-5	184,583
1-6	221,500
1-7	258,417
1-8	295,333
1-9	332,250
1-10	369,167
1-11	406,083
1-12	443,000

After the first 12 calendar months of operation following issuance of this permit, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the No. 2 fuel oil usage figures

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content, heat content and the calculated SO₂ emission rate [the SO₂ emission rate shall be calculated as specified in OAC 3745-18-04(F)].

The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the appropriate Ohio EPA District Office or local air agency.

2. The permittee shall maintain monthly records of the following information for emissions units P001, P002 and P003, combined:
 - a. the total No. 2 fuel oil usage for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the No. 2 fuel oil usage figures.

Emissions Unit ID: P003

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative No. 2 fuel oil usage for each calendar month.

3. The permittee shall perform weekly checks, when any/all of emission units P001, P002 and P003 is/are in operation and when weather conditions allow, for any visible particulate emissions from the stack/stacks serving this/these emissions unit(s). The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month No. 2 fuel oil usage limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative No.2 fuel oil usage limitation.
2. The permittee shall submit, on a quarterly basis, copies of the permittee's or oil supplier's analyses for each shipment of oil which is received for burning in this emissions unit. The permittee's or oil supplier's analysis shall document the sulfur content (percent) and heat content (Btu/gallon) for each shipment of oil. The following information shall also be included with the copies of the permittee's or oil supplier's analysis:
 - a. the total quantity of oil received in each shipment (gallons);
 - b. the weighted* average sulfur dioxide emission rate (pounds/mmBtu) for the oil received during the calendar month; and
 - c. the weighted* average heat content (Btu/gallon) of the oil received during the calendar month.

*In proportion to the quantity of oil received in each shipment during the calendar month. The quarterly reports shall be submitted by January 31, April 30, July 31 and October 31 of each year and shall cover the previous calendar quarters.

3. The permittee shall submit semiannual written reports which (a) identify all weeks during which

Issued: To be entered upon final issuance

any visible particulate emissions were observed from the stack serving emissions units P001, P002 and P003 and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.

4. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
5. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. Compliance with the visible particulate emission limitation shall be demonstrated by the Methods outlined in 40 CFR Part 60, Appendix A, Method 9.
2. Compliance with the sulfur content limitation in term A.II.1. shall be determined by the fuel oil analysis and recordkeeping in term A.III.1
3. Compliance with the No. 2 fuel oil usage limitation in term A.II.2 shall be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.I.1 and A.I.2 shall be demonstrated by the emission factors and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

The permittee will submit a Title V application within one year of issuance of this permit.

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P003 - 2.2 megawatt peaking diesel generator	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Child

PTI A

Emissions Unit ID: P004

Issued: To be entered upon final issuance

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment	Applicable Rules/Requirements	Applicable Emissions <u>Limitations/Control</u> <u>Measures</u>
P004 - 1.75 megawatt peaking diesel generator	OAC rule 3745-31-05(A)(3)	0.062 lb PM10/MMBtu actual heat input, 0.24 TPY PM/PM10* 0.404 lb SO2/MMBTU, 1.6 TPY SO2* 1.27 lbs VOC/hr, 3.1 TPY VOC* 62.56 lbs NOx/hr 12.31 lbs CO/hr, 8.3 TPY CO* The requirements of this rule also include compliance with the requirements of OAC rules 3745-31-05(D), 3745-17-07(A)(1) and 3745-17-11(B)(5)(b).
	OAC rule 3745-31-05(D) Synthetic Minor to avoid PSD	27.9 TPY NOx, as a rolling, 12-month summation
	OAC rule 3745-17-07(A)(1)	Visible particulate emissions from any stack shall not exceed 20 percent opacity, as a six-minute average, except as specified by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PM/MMBtu actual heat input
	OAC rule 3745-18-06	The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

36

Child

PTI A

Issued: To be entered upon final issuance

Emissions Unit ID: P004

* Based upon a rolling
12-month summation.

Issued: To be entered upon final issuance**2. Additional Terms and Conditions**

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit's Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.

II. Operational Restrictions

1. The quality of the No. 2 fuel oil burned in this emissions unit shall have a combination of sulfur content and heat content sufficient to meet the sulfur dioxide emission limitation of 0.404 lb/MMBtu of actual heat input.

Compliance with the above-mentioned SO₂ emission limitation shall be determined by using the analytical results provided by the permittee or oil supplier and the calculated SO₂ emission rate for each shipment of oil.

2. The maximum annual No. 2 fuel oil usage for emissions unit P004 shall not exceed 57,500 gallons per year based upon a rolling, 12 month summation of the No. 2 fuel oil usage.

To ensure enforceability during the first 12 calendar months of operation following issuance of this permit, the permittee shall not exceed the No. 2 fuel oil usage limits specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative No.2 Fuel Oil Usage (Gallons)</u>
1	4,792
1-2	9,588
1-3	14,357
1-4	19,167
1-5	23,958
1-6	28,750
1-7	33,542
1-8	38,333
1-9	43,125
1-10	47,917
1-11	52,708
1-12	57,500

After the first 12 calendar months of operation following issuance of this permit, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the No. 2 fuel oil usage figures

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content, heat content and the calculated SO₂ emission rate [the SO₂ emission rate shall be calculated as specified in OAC 3745-18-04(F)].

The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the appropriate Ohio EPA District Office or local air agency.

2. The permittee shall maintain monthly records of the following information for emissions unit P004:
 - a. the total No. 2 fuel oil usage for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the No. 2 fuel oil usage figures.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative No. 2 fuel oil usage for each calendar month.

3. The permittee shall perform weekly checks, when emissions unit P004 is in operation and when weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and

Issued: To be entered upon final issuance

- e. any corrective actions taken to eliminate the visible emissions.

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month No. 2 fuel oil usage limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative No.2 fuel oil usage limitation.
2. The permittee shall submit, on a quarterly basis, copies of the permittee's or oil supplier's analyses for each shipment of oil which is received for burning in this emissions unit. The permittee's or oil supplier's analysis shall document the sulfur content (percent) and heat content (Btu/gallon) for each shipment of oil. The following information shall also be included with the copies of the permittee's or oil supplier's analysis:
 - a. the total quantity of oil received in each shipment (gallons);
 - b. the weighted* average sulfur dioxide emission rate (pounds/MMBtu) for the oil received during the calendar month; and
 - c. the weighted* average heat content (Btu/gallon) of the oil received during the calendar month.

*In proportion to the quantity of oil received in each shipment during the calendar month. The quarterly reports shall be submitted by January 31, April 30, July 31 and October 31 of each year and shall cover the previous calendar quarters.

3. The permittee shall submit semiannual written reports which (a) identify all weeks during which any visible particulate emissions were observed from the stack serving emission units P004, and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.
4. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
5. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

Childrens Hospital Medical Center**PTI Application: 14-05139****Issued****Facility ID: 1431071395**

Emissions Unit ID: P004

V. Testing Requirements

1. Compliance with the visible particulate emissions limitation shall be demonstrated by the Methods outlined in 40 CFR Part 60, Appendix A, Method 9.
2. Compliance with the sulfur content limitation in term A.II.1. shall be determined by the fuel oil analysis and recordkeeping in term A.III.1.
3. Compliance with the No. 2 fuel oil usage limitation in term A.II.2 will be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.I.1 and A.I.2 shall be demonstrated by the emission factors, control efficiencies (if applicable) and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child
PTI A

Emissions Unit ID: P004

Issued: To be entered upon final issuance

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P004 - 1.75 megawatt peaking diesel generator	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Child
PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P005 - 1.75 megawatt peaking diesel generator	OAC rule 3745-31-05(A)(3)	0.062 lb PM10/MMBtu actual heat input, 0.24 TPY PM/PM10* 0.404 lb SO2/MMBTU, 1.6 TPY SO2* 1.27 lbs VOC/hr, 3.1 TPY VOC* 62.56 lbs NOx/hr 12.31 lbs CO/hr, 8.3 TPY CO* The requirements of this rule also include compliance with the requirements of OAC rules 3745-31-05(D), 3745-17-07(A)(1) and 3745-17-11(B)(5)(b).
	OAC rule 3745-31-05(D) Synthetic Minor to avoid PSD	27.9 TPY NOx, as a rolling, 12-month summation
	OAC rule 3745-17-07(A)(1)	Visible particulate emissions from any stack shall not exceed 20 percent opacity, as a six-minute average, except as specified by rule.
	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PM/MMBtu actual heat input
	OAC rule 3745-18-06	The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

43

Childrens Hospital Medical Center

PTI Application: 14-05130

Issued

Facility ID: 1431071395

Emissions Unit ID: P005

* Based upon a rolling
12-month summation.

Issued: To be entered upon final issuance

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.
- 2.b** The hourly emission limitations outlined are based upon the emissions unit’s Potential to Emit (PTE). Therefore, no hourly records are required to demonstrate compliance with these limits.

II. Operational Restrictions

- 1. The quality of the No. 2 fuel oil burned in this emissions unit shall have a combination of sulfur content and heat content sufficient to meet the sulfur dioxide emission limitation of 0.404 lb/MMBtu of actual heat input.

Compliance with the above-mentioned SO2 emission limitation shall be determined by using the analytical results provided by the permittee or oil supplier and the calculated SO2 emission rate for each shipment of oil.

- 2. The maximum annual No. 2 fuel oil usage for emissions unit P005 shall not exceed 57,500 gallons per year based upon a rolling, 12 month summation of the No. 2 fuel oil usage.

To ensure enforceability during the first 12 calendar months of operation following issuance of this permit, the permittee shall not exceed the No. 2 fuel oil usage limits specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Cumulative No.2 Fuel Oil Usage (Gallons)</u>
1	4,792
1-2	9,588
1-3	14,357
1-4	19,167
1-5	23,958
1-6	28,750
1-7	33,542
1-8	38,333
1-9	43,125
1-10	47,917
1-11	52,708
1-12	57,500

Child

PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance

After the first 12 calendar months of operation following issuance of this permit, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the No. 2 fuel oil usage figures

Issued: To be entered upon final issuance

III. Monitoring and/or Recordkeeping Requirements

1. For each shipment of oil received for burning in this emissions unit, the permittee shall maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content, heat content and the calculated SO₂ emission rate [the SO₂ emission rate shall be calculated as specified in OAC 3745-18-04(F)].

The permittee shall collect or require the oil supplier to collect a representative grab sample for each shipment of oil that is received for burning in this emissions unit. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with the following ASTM methods: ASTM method D4294, ASTM method D240, or ASTM method 6010 for sulfur content; and ASTM method D240 for heat content. Alternative, equivalent methods may be used upon written approval by the appropriate Ohio EPA District Office or local air agency.

2. The permittee shall maintain monthly records of the following information for emissions unit P005:
 - a. the total No. 2 fuel oil usage for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the No. 2 fuel oil usage figures.

Also, during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative No. 2 fuel oil usage for each calendar month.

3. The permittee shall perform weekly checks, when emissions unit P005 is in operation and when weather conditions allow, for any visible particulate emissions from the stack serving this emission unit. The presence or absence of any visible emissions shall be noted in an operation log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and

- e. any corrective actions taken to eliminate the visible emissions.

Issued: To be entered upon final issuance**IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12- month No. 2 fuel oil limitation and, for the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative No.2 fuel oil usage limitation.
2. The permittee shall submit, on a quarterly basis, copies of the permittee's or oil supplier's analyses for each shipment of oil which is received for burning in this emissions unit. The permittee's or oil supplier's analysis shall document the sulfur content (percent) and heat content (Btu/gallon) for each shipment of oil. The following information shall also be included with the copies of the permittee's or oil supplier's analysis:
 - a. the total quantity of oil received in each shipment (gallons);
 - b. the weighted* average sulfur dioxide emission rate (pounds/MMBtu) for the oil received during the calendar month; and
 - c. the weighted* average heat content (Btu/gallon) of the oil received during the calendar month.

*In proportion to the quantity of oil received in each shipment during the calendar month. The quarterly reports shall be submitted by January 31, April 30, July 31 and October 31 of each year and shall cover the previous calendar quarters.

3. The permittee shall submit semiannual written reports which (a) identify all weeks during which any visible particulate emissions were observed from the stack serving emission units P005, and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Hamilton County Department of Environmental Services by January 31 and July 31 of each year and shall cover the previous 6 calendar month period.
4. The permittee shall submit annual reports which specify the total NO_x, SO₂, OC, PM/PM₁₀ and CO emissions from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
5. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. Compliance with the visible particulate emissions limitation shall be demonstrated by the Methods

Issued: To be entered upon final issuance

outlined in 40 CFR Part 60, Appendix A, Method 9.

2. Compliance with the sulfur content limitation in term A.II.1. shall be determined by the fuel oil analysis and recordkeeping in term A.III.1.
3. Compliance with the No. 2 fuel oil usage limitation in term A.II.2 will be demonstrated by the recordkeeping in term A.III.2.
4. Compliance with the emissions limitations in term A.1 shall be demonstrated by the emission factors, control efficiencies (if applicable) and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child

PTI A

Emissions Unit ID: P005

Issued: To be entered upon final issuance**B. State Only Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P005 - 1.75 megawatt peaking diesel generator	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
T001 - 20,000 gallon underground storage tank	OAC rule 3745-31-05(A)(3)	0.05 TPY VOC See term A.I.2.b. The requirements of this rule also include compliance with the requirements of 40 CFR Part 60 Subpart Kb.
	OAC rule 3745-21-09(L)	Exempt
	40 CFR Part 60 Subpart Kb	See term A.III.1.

2. Additional Terms and Conditions

- 2.a Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by compliance with the specified emission rate, the use of submerged fill and compliance with 40 CFR Part 60 Subpart Kb.
- 2.b The annual emission limitation outlined is based upon the emission unit's Potential to Emit (PTE). Therefore, no records or reports are required to demonstrate compliance with this limit.
- 2.c The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.

II. Operational Restrictions

None

Issued: To be entered upon final issuance

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR part 60.116b (a) and (b), the permittee shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the storage vessel.

IV. Reporting Requirements

1. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. Construction date (no later than 30 days after such date),
 - b. Anticipated startup date (not more than 60 days or less than 30 days prior to such date),
 - c. Actual startup date (within 15 days after such date), and
 - d. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P.O. Box 163669
Columbus, OH 43216-3669

and

Hamilton County Department of Environmental Services
250 Wm. H. Taft Road
Cincinnati, OH 45219

V. Testing Requirements

1. Compliance with the emissions limitations in term A.I.1 shall be demonstrated by the emission factors, control efficiencies (if applicable) and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

53

Child

PTI A

Emissions Unit ID: T001

Issued: To be entered upon final issuance

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child

PTI A

Emissions Unit ID: T001

Issued: To be entered upon final issuance**B. State Only Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
T001 - 20,000 gallon underground storage tank	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
T002 - 20,000 gallon underground storage tank	OAC rule 3745-31-05(A)(3)	0.05 TPY VOC See term A.I.2.b. The requirements of this rule also include compliance with the requirements of 40 CFR Part 60 Subpart KB
	OAC rule 3745-21-09(L)	Exempt
	40 CFR Part 60 Subpart Kb	See term A.III.1.

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by compliance with the specified emission rate, the use of submerged fill and compliance with 40 CFR Part 60 Subpart Kb.
- 2.b** The annual emission limitation outlined is based upon the emission unit's Potential to Emit (PTE). Therefore, no records or reports are required to demonstrate compliance with this limit.
- 2.c** The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.

II. Operational Restrictions

None

Issued: To be entered upon final issuance

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR part 60.116b (a) and (b), the permittee shall keep readily accessible records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel for the life of the storage vessel.

IV. Reporting Requirements

1. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. Construction date (no later than 30 days after such date),
 - b. Anticipated startup date (not more than 60 days or less than 30 days prior to such date),
 - c. Actual startup date (within 15 days after such date), and
 - d. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P.O. Box 163669
Columbus, OH 43216-3669

and

Hamilton County Department of Environmental Services
250 Wm. H. Taft Road
Cincinnati, OH 45219

V. Testing Requirements

1. Compliance with the emissions limitations in term A.I.1 shall be demonstrated by the emission factors, control efficiencies (if applicable) and the operational parameters as submitted in PTI application 14-05139 submitted April 17, 2001.

VI. Miscellaneous Requirements

57

Child

PTI A

Emissions Unit ID: T002

Issued: To be entered upon final issuance

1. The permittee will submit a Title V application within one year of issuance of this permit.

Child
PTI A

Emissions Unit ID: T002

Issued: To be entered upon final issuance

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
T002 - 20,000 gallon underground storage tank	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

NEW SOURCE REVIEW FORM B

PTI Number: 14-05139 Facility ID: 1431071395

FACILITY NAME Childrens Hospital Medical Center

FACILITY DESCRIPTION Three 2.2 megawatt peaking diesel generators, Two 1.75 megawatt peaking diesel generators and Two 20,000 gallon underground storage tanks. CITY/TWP Cincinnati

SIC CODE 8069 SCC CODE 2-02-004-01 EMISSIONS UNIT ID P001

EMISSIONS UNIT DESCRIPTION 2.2 megawatt peaking diesel generator

DATE INSTALLED upon issuance

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
PM ₁₀	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
Sulfur Dioxide	attainment	0.404 lb/MMBTU	12.3 (P001-P003)	0.404 lb/MMBTU	12.3 (P001-P003)
Organic Compounds	attainment	0.98 lb/hr	3.3 (P001-P003)	0.98 lb/hr	3.3 (P001-P003)
Nitrogen Oxides	attainment	61.62 lb/hr	88.9 (P001-P003)	61.62 lb/hr	88.9 (P001-P003)
Carbon Monoxide	attainment	2.2 lb/hr	8.1 (P001-P003)	2.2 lb/hr	8.1 (P001-P003)
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? NESHAP? PSD? OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$NA

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to contaminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: NA

NEW SOURCE REVIEW FORM B

PTI Number: 14-05139 Facility ID: 1431071395

FACILITY NAME Childrens Hospital Medical Center

FACILITY DESCRIPTION Three 2.2 megawatt peaking diesel CITY/TWP Cincinnati

Emissions Unit ID: T002

SIC CODE 8069 SCC CODE 2-02-004-01 EMISSIONS UNIT ID P002

EMISSIONS UNIT DESCRIPTION 2.2 megawatt peaking diesel generator

DATE INSTALLED upon issuance

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
PM ₁₀	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
Sulfur Dioxide	attainment	0.404 lb/MMBTU	12.3 (P001-P003)	0.404 lb/MMBTU	12.3 (P001-P003)
Organic Compounds	attainment	0.98 lb/hr	3.3 (P001-P003)	0.98 lb/hr	3.3 (P001-P003)
Nitrogen Oxides	attainment	61.62 lb/hr	88.9 (P001-P003)	61.62 lb/hr	88.9 (P001-P003)
Carbon Monoxide	attainment	2.2 lb/hr	8.1 (P001-P003)	2.2 lb/hr	8.1 (P001-P003)
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? _____ NESHAP? _____ PSD? _____ OFFSET POLICY? _____

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$NA

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to containinants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: NA

NEW SC

PTI Num

FACILITY

Emissions Unit ID: T002

FACILITY DESCRIPTION Three 2.2 megawatt peaking diesel generators, Two 1.75 megawatt peaking diesel generators and Two 20,000 gallon underground storage tanks.

CITY/TWP Cincinnati

SIC CODE 8069 SCC CODE 2-02-004-01 EMISSIONS UNIT ID P003

EMISSIONS UNIT DESCRIPTION 2.2 megawatt peaking diesel generator

DATE INSTALLED upon issuance

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
PM ₁₀	attainment	0.062 lb/MMBTU	1.9 (P001-P003)	0.062 lb/MMBTU	1.9 (P001-P003)
Sulfur Dioxide	attainment	0.404 lb/MMBTU	12.3 (P001-P003)	0.404 lb/MMBTU	12.3 (P001-P003)
Organic Compounds	attainment	0.98 lb/hr	3.3 (P001-P003)	0.98 lb/hr	3.3 (P001-P003)
Nitrogen Oxides	attainment	61.62 lb/hr	88.9 (P001-P003)	61.62 lb/hr	88.9 (P001-P003)
Carbon Monoxide	attainment	2.2 lb/hr	3.3 (P001-P003)	2.2 lb/hr	3.3 (P001-P003)
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? NESHAP? PSD? OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$NA

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to containinants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? YES X NO

IDENTIFY THE AIR CONTAMINANTS: NA

NEW SOURCE REVIEW FORM B

PTI Number: 14-05139

Facility ID: 1431071395

FACILITY NAME Childrens Hospital Medical Center

FACILITY DESCRIPTION Three 2.2 megawatt peaking diesel

CITY/TWP Cincinnati

Emissions Unit ID: T002

SIC CODE 8069

SCC CODE 2-02-004-01

EMISSIONS UNIT ID P004

EMISSIONS UNIT DESCRIPTION 1.75 megawatt peaking diesel generator

DATE INSTALLED upon issuance

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.062 lb/MMBTU	0.24	0.062 lb/MMBTU	0.24
PM ₁₀	attainment	0.062 lb/MMBTU	0.24	0.062 lb/MMBTU	0.24
Sulfur Dioxide	attainment	0.404 lb/MMBTU	1.6	0.404 lb/MMBTU	1.6
Organic Compounds	attainment	1.27 lb/hr	3.1 TPY	1.27 lb/hr	3.1
Nitrogen Oxides	attainment	62.56 lb/hr	27.9	62.56 lb/hr	27.9
Carbon Monoxide	attainment	12.31 lb/hr	8.3	12.31 lb/hr	8.3
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS?

NESHAP?

PSD?

OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$NA

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to containinants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: NA

NEW SOURCE REVIEW FORM B

PTI Number: 14-05139

Facility ID: 1431071395

FACILITY NAME Childrens Hospital Medical CenterFACILITY DESCRIPTION Three 2.2 megawatt peaking dieselCITY/TWP Cincinnati

Emissions Unit ID: T002

SIC CODE 8069SCC CODE 2-02-004-01EMISSIONS UNIT ID P005EMISSIONS UNIT DESCRIPTION 1.75 megawatt peaking diesel generatorDATE INSTALLED upon issuance

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.062 lb/MMBTU	0.24	0.062 lb/MMBTU	0.24
PM ₁₀	attainment	0.062 lb/MMBTU	0.24	0.062 lb/MMBTU	0.24
Sulfur Dioxide	attainment	0.404 lb/MMBTU	1.6	0.404 lb/MMBTU	1.6
Organic Compounds	attainment	1.27 lb/hr	3.1	1.27 lb/hr	3.1
Nitrogen Oxides	attainment	62.56 lb/hr	27.9	62.56 lb/hr	27.9
Carbon Monoxide	attainment	12.31 lb/hr	8.3	12.31 lb/hr	8.3
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS?

NESHAP?

PSD?

OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by emission limitations and No. 2 fuel oil usage limitations.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT?

\$NA**TOXIC AIR CONTAMINANTS**

Ohio EPA's air toxics policy applies to contaminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*?

YESX NO

IDENTIFY THE AIR CONTAMINANTS:

NA

NEW SOURCE REVIEW FORM B

PTI Number: 14-05139 Facility ID: 1431071395

FACILITY NAME Childrens Hospital Medical Center

FACILITY DESCRIPTION Three 2.2 megawatt peaking diesel CITY/TWP Cincinnati

Emissions Unit ID: T002

SIC CODE 8069 SCC CODE 4-03-010-21 EMISSIONS UNIT ID T001

EMISSIONS UNIT DESCRIPTION 20,000 gallon underground storage tank

DATE INSTALLED 1990

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants		Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter					
PM ₁₀					
Sulfur Dioxide					
Organic Compounds	attainment		0.01		0.05
Nitrogen Oxides					
Carbon Monoxide					
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? Kb NESHAP? PSD? OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by compliance with the specified emission rate, the use of submerged fill and compliance with 40 CFR Part 60 Subpart Kb.

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$NA

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to contaminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? YES X NO

IDENTIFY THE AIR CONTAMINANTS: NA

