



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
HAMILTON COUNTY**

CERTIFIED MAIL

Street Address:

50 West Town Street, Suite 700

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 14-05895

Fac ID: 1431071395

DATE: 3/22/2007

Childrens Hospital Medical Center
Thomas Kinman
3333 Burnet Avenue
Cincinnati, OH 45229-3039

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

Sincerely,

Michael W. Ahern

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

HCDES



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

FINAL PERMIT TO INSTALL 14-05895

Application Number: 14-05895
Facility ID: 1431071395
Permit Fee: **\$400**
Name of Facility: Childrens Hospital Medical Center
Person to Contact: Thomas Kinman
Address: 3333 Burnet Avenue
Cincinnati, OH 45229-3039

Location of proposed air contaminant source(s) [emissions unit(s)]:
**3333 Burnet Avenue
Cincinnati, Ohio**

Description of proposed emissions unit(s):
34 MMBtu/hr Natural gas/No.2 fuel oil fired boiler.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Chris Korleski
Director

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Permit-To-Install General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to

the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.9 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - iv. If this permit is for an emissions unit located at a Title V facility, then each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d. The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

- iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit-To-Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this permit is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

13. Permit-To-Install

A permit-to-install must be obtained pursuant to OAC Chapter 3745-31 prior to "installation" of "any air contaminant source" as defined in OAC rule 3745-31-01, or "modification", as defined in OAC rule 3745-31-01, of any emissions unit included in this permit.

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

B. State Only Enforceable Permit-To-Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Authorization To Install or Modify

If applicable, authorization to install or modify any new or existing emissions unit included in this permit shall terminate within eighteen months of the effective date of

the permit if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

5. Construction of New Sources(s)

This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

8. Construction Compliance Certification

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the permit-to-install application and the terms and conditions of the permit-to-install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

9. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

C. Permit-To-Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
PE/PM10	2.97
NOx	8.16
SO2	2.56
CO	8.57
VOC	1.09

Childrens Hospital Medical Center
PTI Application: 14-05895
Issued: 3/22/2007

Facility ID: 1431071395

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

As part of this permitting project for purposes of New Source Review permitting, the permittee is installing two 2.2 megawatt (MW) emergency generators powered by internal combustion diesel engines that are limited by the 500 hour operating restriction in OAC 3745-31-03(A)(4)(b) and taken together with emissions unit B022 - 34 mmBtu/hr natural gas /No. 2 fuel oil fired boiler contained within this permit their NOx emissions will be limited to 38.97 tons per year, based upon a 12-month summation of their monthly NOx emissions.

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (B022) - 34 mmBtu/hr Natural Gas / No. 2 Fuel Oil Fired Boiler

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
OAC rule 3745-31-05(C) Synthetic Minor to avoid Non-attainment New Source Review and Prevention of Significant Deterioration	Nitrogen Oxides (NOx) emissions shall not exceed 8.16 tons per year based upon a rolling, 12-month summation. See terms and conditions A.II.1 through A.II.3.
OAC rule 3745-31-05(A)(3)	When burning natural gas: Nitrogen Oxides (NOx) emissions shall not exceed 0.08 lb/mmBtu of actual heat input. When burning No. 2 fuel oil: Nitrogen Oxides (NOx) emissions shall not exceed 0.16 lb/mmBtu of actual heat input. See terms and conditions A.II.1 through A.II.3.
OAC rule 3745-17-10(B)(1)	Particulate Emissions (PE) shall not exceed 0.020 lb/mmBtu of actual heat input.
OAC rule 3745-18-06	The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-02(A)(2).
OAC rule 3745-17-07(A)(1)	The emissions limitation specified by this rule is less stringent than the emission limitation established pursuant to 40 CFR Part 60 Subpart Dc.

Emissions Unit ID: B022

40 CFR Part 60 Subpart Dc	Visible particulate emissions from any stack shall not exceed twenty percent (20%) opacity, as a six-minute average, except for one 6-minute period per hour not more than 27 percent opacity. The SO2 emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-02(A)(2).
OAC rule 3745-21-08(B)	See term and condition A.I.2.d.
ORC 3704.03(T)(4)	See term and condition A.I.2.e.
OAC rule 3745-31-02(A)(2)	See term and condition A.I.2.f.

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by the use of natural gas and/or No. 2 fuel oil, the use of low NOx burners, the emission limitations listed in term A.I.1 above and the fuel usage limitations.
- 2.b** The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency (U.S. EPA), 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency (Ohio EPA).
- 2.c** The lb/mmBtu actual heat input emission limitation, for NOx, is based on the emissions unit's potential to emit. Therefore, no monitoring, record keeping and reporting requirements are necessary to ensure ongoing compliance with this emission limitation.
- 2.d** The design of the emissions unit and the technology associated with the proposed operating practices satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B).

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

- 2.e** The best available technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to Particulate Emissions (PE), Particulate Matter less than 10 microns in diameter (PM10) and Volatile Organic Compounds (VOC) from this air contaminant source since the uncontrolled potential to emit for PE, PM10 and VOC is less than ten tons per year.

Emissions Unit ID: B022

- 2.f** Permit to Install 14-05895 for this air contaminant source takes into account the following voluntary restrictions as proposed by the permittee for the purpose of avoiding Best Available technology (BAT) under OAC rule 3745-31-05(A)(3):
- i. for Sulfur Dioxide (SO₂) emissions: the permittee shall use of ultra low sulfur No. 2 fuel oil to ensure the controlled potential to emit is less than 10.0 tons per year. The No. 2 fuel oil sulfur content shall not exceed 0.05 percent sulfur by weight; and
 - ii. for Carbon Monoxide (CO) emissions: the permittee shall limit the natural gas use to the amounts provided in term and condition II.3 below.

II. Operational Restrictions

1. The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
2. The maximum annual No. 2 fuel oil usage rate for this emissions unit shall not exceed 720,000 gallons per rolling, 12-month period.

To ensure enforceability during the first 12 calendar months of operation, the permittee shall not exceed the No. 2 fuel oil usage levels specified in the following table:

Month	Maximum Allowable Cumulative Usage (gallons oil)
1	177,000
1-2	354,000
1-3	531,000
1-4	720,000
1-5	720,000
1-6	720,000
1-7	720,000
1-8	720,000
1-9	720,000
1-10	720,000
1-11	720,000
1-12	720,000

The usage limitations above are for the sole use of No. 2 fuel oil in emissions unit B022. Under this usage scenario, no additional use of natural gas shall be permitted throughout the 12 month period. The usage of a combination of No. 2 fuel oil and natural gas shall be in such quantities to maintain compliance with the NO_x emission limitation in Section A.I.1.

After the first 12 calendar months of operation following the issuance of this permit,

Issued: 3/22/2007

compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the oil usage rates. The usage of a combination of No. 2 fuel oil and natural gas shall be in such quantities to maintain compliance with the rolling, 12-month NOx emission limitation in Section A.I.1.

3. The maximum annual natural gas usage rate for this emissions unit shall not exceed 204.0 million cubic feet per rolling, 12-month period.

To ensure enforceability during the first 12 calendar months of operation, the permittee shall not exceed the natural gas usage levels specified in the following table:

Month	Maximum Allowable Cumulative Usage (million cubic feet gas)
1	25.3
1-2	50.6
1-3	75.9
1-4	101.2
1-5	126.5
1-6	151.8
1-7	177.1
1-8	202.4
1-9	204.0
1-10	204.0
1-11	204.0
1-12	204.0

The usage limitations above are for the sole use of natural gas in emissions unit B022. Under this usage scenario, no additional use of No. 2 fuel oil shall be permitted throughout the 12 month period. The usage of a combination of No. 2 fuel oil and natural gas shall be in such quantities to maintain compliance with the NOx emission limitation in Section A.I.1.

After the first 12 calendar months of operation following the issuance of this permit, compliance with the annual natural gas usage limitation shall be based upon a rolling, 12-month summation of the gas usage rates. The usage of a combination of No. 2 fuel oil and natural gas shall be in such quantities to maintain compliance with the rolling, 12-month NOx emission limitation in Section A.I.1.

Issued: 3/22/2007

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

- a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch, and the quality of the oil for those loads may be represented by a single batch analysis from the supplier.

- b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)].

- c. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240 and D4294), or equivalent methods as approved by the Director.

Emissions Unit ID: B022

2. The permittee shall maintain monthly records of the following information:
 - a. the total volume of natural gas (million ft³) burned in this emissions unit;
 - b. the total number of gallons of No. 2 fuel oil used in this emissions unit for each month;
 - c. beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the million ft³ of natural gas used;
 - d. beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the gallons of No. 2 fuel oil used; and
 - e. the type and total amount of fuel, other than natural gas or No. 2 fuel oil, burned in this emissions unit.

Also, during the first 12 calendar months of operation, the permittee shall record the cumulative fuel usage rates for each calendar month.

3. The permittee shall maintain monthly records of the following information for this emissions unit in order to monitor compliance with the rolling, 12-month summation emission limitation:
 - a. the total emissions, in tons, for NO_x, when burning any combination of fuels; and
 - b. the rolling, 12-monthly summation emissions total, in tons, for NO_x, when burning any combination of fuels (the total amount of emissions calculated for the current month plus the total amount of emissions for the previous eleven calendar months).

IV. Reporting Requirements

1. Pursuant to the NSPS, the permittee is required to report the following information at the appropriate times (if the information has not already been reported):
 - a. construction date (no later than 30 days after such date);
 - b. actual start-up date (within 15 days after such date); and,
 - c. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Hamilton County Department of Environmental Services
250 William Howard Taft Road
Cincinnati, Ohio 45219

Issued: 3/22/2007

2. The permittee shall notify the Hamilton County Department of Environmental Services in writing of any record which shows a deviation of the allowable sulfur content limitation based upon the calculated sulfur dioxide emission rates from Section A.III.1 above. The notification shall include a copy of such record and shall be sent to the Hamilton County Department of Environmental Services within 45 days after the deviation occurs.
3. The permittee shall notify the Hamilton County Department of Environmental Services in writing of any fuel burned in this emissions unit other than natural gas or No. 2 fuel oil. The notification shall include a copy of such record and shall be sent to the Hamilton County Department of Environmental Services within 45 days after the deviation occurs.
4. The permittee shall submit annual reports that specify the NOx emissions for this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year. The CAA, Title V Fee Emission Report (FER) required to be submitted annually by April 15 for the facility will also satisfy the emission reporting requirement of this condition.
5. The permittee shall submit annual reports which identify the total amount of natural gas (in million cubic feet) and No. 2 fuel oil (in gallons) combusted in emissions unit B022. These reports shall be submitted by January 31 of each year. The CAA, Title V Fee Emission Report (FER) required to be submitted annually by April 15 for the facility will also satisfy the emission reporting requirement of this condition.
6. The permittee shall submit deviation (excursion) reports to the Hamilton County Department of Environmental Services which identify all exceedances of the following:
 - a. an identification of all exceedances of the rolling, 12-month No. 2 fuel oil usage limitation, and for the first 12 calendar months of operation following issuance of this permit, all exceedances of the maximum allowable cumulative fuel oil usage limitation;
 - b. an identification of all exceedances of the rolling, 12-month natural gas usage limitation, and for the first 12 calendar months of operation following issuance of this permit, all exceedances of the maximum allowable cumulative natural gas usage limitation; and
 - c. an identification of all exceedances of the rolling, 12-month emission limitation

Emissions Unit ID: B022

for NOx.

7. Unless otherwise specified, the deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

V. Testing Requirements

1. Compliance with the emission limitations in Sections A.I.1 and A.I.2 of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation:

Visible particulate emissions from any stack shall not exceed twenty percent (20%) opacity, as a six-minute average, except for one 6-minute period per hour not more than 27 percent opacity.

Applicable Compliance Method:

If required, compliance shall be determined in accordance with Test Method 9, as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources").

The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

- i. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial startup of the emissions unit.
- ii. The emission testing shall be conducted to demonstrate compliance with the visible particulate emissions limitation
- iii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):

[Test Method 9, as set forth in "Appendix on Test Methods" in 40 CFR Part 60 ("Standards of Performance for New Stationary Sources").

Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.

- iv. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.
- v. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall

Issued: 3/22/2007

describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emission test(s).

- vi. Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- vii. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

- b. Emission Limitation:
Particulate Emissions (PE) shall not exceed 0.020 lb/mmBtu of actual heat input.

Applicable Compliance Method:

For the use of natural gas, compliance may be determined by multiplying the hourly gas burning capacity of the emissions unit (mm cu. ft/hr) by the AP-42, Fifth Edition, Section 1.4, Table 1.4-2 (revised 7/98) emission factor of 7.6 lbs of total PM/mm cu. ft, and then dividing by the maximum hourly heat input of the emissions unit (mmBtu/hr).

For the use of No. 2 fuel oil, compliance may be determined by multiplying the hourly oil burning capacity of the emissions unit (in 1000 gallons/hr) by the AP-42, Fifth Edition, Section 1.3, Table 1.3-1 (revised 9/98) emission factor of 2 lbs of PM/1000 gallons, and then dividing by the maximum hourly heat input of the emissions unit (mmBtu/hr).

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR

Emissions Unit ID: B022

Part 60, Appendix A, Methods 1- 5.

- c. Emission Limitation:
less than 10.0 tons per year SO₂.

Applicable Compliance Method:

The actual annual emission rate shall be calculated by multiplying the actual annual fuel usages by the emission factors from AP-42, Fifth Edition, Section 1.4, Table 1.4-2 (revised 7/98) emission factor for natural gas burning and AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98) for No. 2 fuel oil burning.

- d. c. Emission Limitation:
less than 10.0 tons per year CO.

Applicable Compliance Method:

The actual annual emission rate shall be calculated by multiplying the actual annual fuel usages by the emission factors from AP-42, Fifth Edition, Section 1.4, Table 1.4-1 (revised 7/98) emission factor for natural gas burning and AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98) for No. 2 fuel oil burning.

- e. Emission Limitations:
0.08 lb NO_x/mmBtu of actual heat input (natural gas firing);
0.16 lb NO_x/mmBtu of actual heat input (No. 2 fuel oil firing); and
8.16 TPY NO_x (combined emissions).

Applicable Compliance Method:

For the use of natural gas, the short term emission limitation is based upon the emissions unit's potential to emit and the manufacturer's guaranteed emissions data as provided in PTI application 14-05895 submitted on November 28, 2006.

For the use of No. 2 fuel oil, the short term emission limitation is based upon the emission unit's potential to emit and the manufacturer's guaranteed emission data as provided in PTI application 14-05895 submitted on November 28, 2006.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 7.

The actual annual emission rate shall be calculated by using the actual fuel usages and emission factors and methodologies specified above. The annual emissions shall be summed over the rolling 12 month period to determine compliance with the annual emissions limitation.

3. Compliance with the fuel usage limitations in term and condition A.II.1 shall be

Issued: 3/22/2007

- demonstrated by the record keeping in term and condition A.III.2.
4. Compliance with the sulfur limitation in term and condition A.I.2.f shall be demonstrated by the record keeping in term and condition A.III.1.
 5. Compliance with the fuel usage limitations in term and condition A.II.2 shall be demonstrated by the record keeping in term and condition A.III.2.
 6. Compliance with the fuel usage limitations in term and condition A.II.3 shall be demonstrated by the record keeping in term and condition A.III.2.
 7. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. the emission testing shall be conducted within six months after startup of this emissions unit;
 - b. the emissions testing shall be conducted to demonstrate compliance with the allowable NOx emissions limitation while combusting natural gas;
 - c. the following test methods(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):1-5, and 7. Alternative U.S. EPA approved test methods may be used with prior approval from the Hamilton County Department of Environmental Services; and,
 - d. the test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Hamilton County Department of Environmental Services.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Hamilton County Department of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Hamilton County Department of Environmental Services refusal to accept the results of the emission test(s).

Personnel from the Hamilton County Department of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and

Childrens Hospital Medical Center**DTI Application: 11 05905****Facility ID:****1431071395**

Emissions Unit ID: B022

information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Hamilton County Department of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report where warranted, with prior approval from the Hamilton County Department of Environmental Services.

VI. Miscellaneous Requirements

None

Issued: 3/22/2007

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (B022) - 34 mmBtu/hr Natural Gas / No. 2 Fuel Oil Fired Boiler

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None