



State of Ohio Environmental Protection Agency

P.O. Box 1049, 361 E. Broad Street  
Columbus, Ohio 43266-1049  
(614) 466-8565

Richard F. Celeste  
Governor

Re: Permit to Install  
SUMMIT County  
Application No. 16-548

CERTIFIED MAIL

MAY 13, 1987

HOLLAND OIL CO, #41  
686 E NORTH ST  
AKRON, OHIO 44305

Attention: THOMAS S. CONTI

Dear Sir:

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review  
236 East Town Street, Room 300  
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager  
Field Operations Section  
Division of Air Pollution Control

TGR/gs

cc: AKRON AIR POLLUTION CONTROL



## Permit to Install Terms and Conditions

Application No. 16-548  
APS Premise No. 1677010885  
Permit Fee: \$50.

Name of Facility: HOLLAND OIL CO, #41

Person to Contact: THOMAS S. CONTI

Address: 686 E NORTH ST  
AKRON, OHIO 44305

Location of proposed source(s): 650 E MARKET ST  
AKRON, OHIO

Description of proposed source(s): GASOLINE DISPENSING FACILITY W/3  
UNDERGROUND STORAGE TANKS-4000,  
6000 & 10000 GALLONS.


Date of Issuance: MAY 13, 1987

Effective Date: MAY 13, 1987

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

  
Warren W. Tyler

Substantial construction for installation must take place within eighteen months of the effective date of this permit. This deadline may be extended by up to twelve months, if application is made to the Director no less than sixty days before the expiration of this permit and the party shows good cause for any such extension.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

The specified permit fee must be remitted within 15 days of the effective date of this permit to install.

The proposed source shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

#### EMISSION SUMMARY

The air contaminant sources listed below comprise the Permit to Install for Holland Oil Co., #41 located in Summit County. The sources listed below shall not exceed the emission limits/control requirements contained in the following table:

<u>Ohio EPA Source No.</u>	<u>Source Identification</u>	<u>BAT Determination</u>	<u>Applicable Ohio EPA rule</u>	<u>Allowable Emissions (lb/hr, lb/MMBTU, gr/DSCF, etc.)</u>
G001	Gasoline dispensing facility	Vapor balance system & submerged fill	3745-21-09(R)	9.14 TPY

SUMMARY  
TOTAL NEW SOURCE EMISSIONS

<u>Pollutant</u>	<u>Tons/Year</u>
VOC	9.14

This condition in no way limits the applicability of any other state or federal regulation.

APPLICABILITY

This Permit to Install is applicable only to the air contaminant sources listed and does not include the installation or modification of wastewater disposal systems or solid waste disposal facilities. Separate application must be made to the Director for the installation or modification of any such wastewater disposal systems or solid waste disposal facilities.

PERMIT TO OPERATE APPLICATION

A Permit to Operate Application and a \$15 application fee must be submitted to the appropriate field office for each source in this Permit to Install. In accordance with OAC rule 3745-35-02, the application shall be made at least ninety days prior to start-up of the source.

PUBLIC DISCLOSURE

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source are subject to public disclosure in accordance with OAC Rule 3745-49-03.

MALFUNCTION/ABATEMENT

This source and its associated air pollution control system(s) shall be maintained regularly in accordance with good engineering practices and the recommendations of the respective manufacturers in order to minimize air contaminant emissions.

In accordance with OAC Rule 3745-15-06, any malfunction of the source(s) or associated air pollution control system(s) shall be reported immediately to the Akron Air Pollution Control, 177 S. Broadway, Akron, Ohio 44308. Except as provided by OAC Rule 3745-15-06(A)(3), scheduled maintenance of air pollution control equipment, that requires the shutdown or bypassing of said equipment, must be accompanied by the shutdown of the associated air pollution sources.

GASOLINE DISPENSING FACILITIES (WITH STAGE I)

As specified in Ohio Administrative Code (OAC) Rule 3745-31-05, all new sources must, at a minimum, employ Best Available Technology (BAT). BAT for this source consists of the use of Stage I vapor balance system. The vapor balance system shall be designed and operated to route at least 90% by weight of the organic compounds in the displaced vapors from the storage tanks to the delivery vessel and shall be equipped with a means to prevent the discharge into the atmosphere of displaced vapors from an unconnected vapor line. This shall be used at all times when filling the tanks.

The transfer of gasoline from a delivery vessel to a stationary storage tank shall be conducted by use of submerged fill into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank.

This facility shall be serviced by a bulk gasoline plant or terminal that is in compliance with OAC Rule 3745-21-09(P) or (Q), respectively.

There shall be no leaks in the vapor and liquid lines during the transfer of gasoline.

All dust caps shall be "in place" and clamped during normal storage conditions.

The gasoline dispensing facility shall repair within fifteen (15) days any leaks from the vapor balance system which is employed to meet the requirements of Paragraph (A)(3) of OAC Rule 3745-31-05 or Paragraph (R)(1) of OAC Rule 3745-21-09 when such leaks are equal to or greater than 100% of the lower explosive limit of propane, as determined under paragraph (K) of OAC Rule 3745-21-10.