



5/12/2015

Michael Zeilstra
Tennessee Gas Pipeline - Station 216.5
1001 Louisiana Street, #1446A
Houston, TX 77002

RE: FINALAIR POLLUTION PERMIT-TO-INSTALL AND OPERATE
Facility ID: 0250002033
Permit Number: P0118454
Permit Type: Initial Installation
County: Mahoning

Dear Permit Holder:

Enclosed please find a final Ohio Environmental Protection Agency (EPA) Air Pollution Permit-to-Install and Operate (PTIO) which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully. In this letter you will find the information on the following topics:

- How to appeal this permit
• How to save money, reduce pollution and reduce energy consumption
• How to give us feedback on your permitting experience
• How to get an electronic copy of your permit

How to appeal this permit

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
77 South High Street, 17th Floor
Columbus, OH 43215

Certified Mail

Table with 2 columns: Status (No/Yes) and Item (TOXIC REVIEW, SYNTHETIC MINOR TO AVOID MAJOR NSR, CEMS, MACT/GACT, NSPS, NESHAPS, NETTING, MODELING SUBMITTED, SYNTHETIC MINOR TO AVOID TITLE V, FEDERALLY ENFORCABLE PTIO (FEPTIO), SYNTHETIC MINOR TO AVOID MAJOR GHG)

How to save money, reduce pollution and reduce energy consumption

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: www.ohioairquality.org/clean_air

How to give us feedback on your permitting experience

Please complete a survey at www.epa.ohio.gov/survey.aspx and give us feedback on your permitting experience. We value your opinion.

How to get an electronic copy of your permit

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Search for Permits" link under the Permitting topic on the Programs tab.

If you have any questions, please contact Ohio EPA DAPC, Northeast District Office at (330)963-1200 or the Office of Compliance Assistance and Pollution Prevention at (614) 644-3469.

Sincerely,



Erica R. Engel-Ishida, Manager
Permit Issuance and Data Management Section, DAPC

Cc: Ohio EPA-NEDO



FINAL

**Division of Air Pollution Control
Permit-to-Install and Operate
for
Tennessee Gas Pipeline - Station 216.5**

Facility ID:	0250002033
Permit Number:	P0118454
Permit Type:	Initial Installation
Issued:	5/12/2015
Effective:	5/12/2015
Expiration:	5/12/2025



Division of Air Pollution Control
Permit-to-Install and Operate
for
Tennessee Gas Pipeline - Station 216.5

Table of Contents

Authorization	1
A. Standard Terms and Conditions	3
1. What does this permit-to-install and operate ("PTIO") allow me to do?.....	4
2. Who is responsible for complying with this permit?	4
3. What records must I keep under this permit?	4
4. What are my permit fees and when do I pay them?.....	4
5. When does my PTIO expire, and when do I need to submit my renewal application?	4
6. What happens to this permit if my project is delayed or I do not install or modify my source?	5
7. What reports must I submit under this permit?	5
8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?	5
9. What are my obligations when I perform scheduled maintenance on air pollution control equipment? ...	5
10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?	6
11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?	6
12. What happens if one or more emissions units operated under this permit is/are shut down permanently?	6
13. Can I transfer this permit to a new owner or operator?.....	7
14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?	7
15. What happens if a portion of this permit is determined to be invalid?	7
B. Facility-Wide Terms and Conditions.....	8
C. Emissions Unit Terms and Conditions	10
1. P001, TURB-1.....	11



Authorization

Facility ID: 0250002033
Application Number(s): A0052667
Permit Number: P0118454
Permit Description: Initial installation PTIO for a 21,044 HP (167.4 MMBtu/hr) natural gas-fired compressor Solar Turbine.
Permit Type: Initial Installation
Permit Fee: \$150.00
Issue Date: 5/12/2015
Effective Date: 5/12/2015
Expiration Date: 5/12/2025
Permit Evaluation Report (PER) Annual Date: Jan 1 - Dec 31, Due Feb 15

This document constitutes issuance to:

Tennessee Gas Pipeline - Station 216.5
3379 E Garfield Rd
Springfield Twp., OH 44443

of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page.

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087
(330)963-1200

The above named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency


Craig W. Butler
Director



Final Permit-to-Install and Operate
Tennessee Gas Pipeline - Station 216.5
Permit Number: P0118454
Facility ID: 0250002033
Effective Date: 5/12/2015

Authorization (continued)

Permit Number: P0118454

Permit Description: Initial installation PTIO for a 21,044 HP (167.4 MMBtu/hr) natural gas-fired compressor Solar Turbine.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	P001
Company Equipment ID:	TURB-1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable



Final Permit-to-Install and Operate
Tennessee Gas Pipeline - Station 216.5
Permit Number: P0118454
Facility ID: 0250002033
Effective Date: 5/12/2015

A. Standard Terms and Conditions



1. What does this permit-to-install and operate ("PTIO") allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11, or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is



very important that you submit a complete renewal permit application (postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended by up to 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective, and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.



10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the [DO/LAA] in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction, but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.



13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, you must follow the procedures in OAC Chapter 3745-31, including notifying Ohio EPA or the local air agency of the change in ownership or operator. Any transferee of this permit must assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.



Final Permit-to-Install and Operate
Tennessee Gas Pipeline - Station 216.5
Permit Number: P0118454
Facility ID: 0250002033
Effective Date: 5/12/2015

B. Facility-Wide Terms and Conditions



1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (1) B.3.
 - b) For the purpose of a permit-to-operate document, the facility-wide terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (1) None.
2. The following emissions unit contained in this permit is subject to 40 CFR Part 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines: P001. The complete New Source Performance Standards (NSPS) requirements, including the NSPS General Provisions may be accessed via the internet from the Electronic Code of Federal Regulations (e-CFR) website <http://ecfr.gpoaccess.gov> or by contacting the Ohio EPA Northeast District Office.
3. Modeling to demonstrate compliance with, the "Toxic Air Contaminant Statute", ORC 3704.03(F)(4)(b), was not necessary because the emissions units' (turbine, emergency generator and natural gas heater) maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires a permittee to apply for and obtain a new or modified PTIO prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new PTIO.



Final Permit-to-Install and Operate
Tennessee Gas Pipeline - Station 216.5
Permit Number: P0118454
Facility ID: 0250002033
Effective Date: 5/12/2015

C. Emissions Unit Terms and Conditions



1. P001, TURB-1

Operations, Property and/or Equipment Description:

21,044 HP (167.4 MMBtu/hr) natural gas-fired Solar Turbines Titan-130-20502S Compressor Turbine equipped with SoLoNOx technology

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) June 30, 2008	Particulate emissions (PE) shall not exceed 0.40 ton/month averaged over a 12-month rolling period. Sulfur dioxide (SO ₂) emissions shall not exceed 0.20 ton/month averaged over a 12-month rolling period. Install a turbine that is designed to meet 25 ppmvd of volatile organic compounds (VOC) at 15% oxygen. The requirements of this rule also include compliance with the requirements of 40 CFR Part 60, Subpart KKKK. See b)(2)a.



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
b.	OAC rule 3745-31-05(A)(3)(a)(ii) June 30, 2008	<p>The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the PE, SO₂ and VOC emissions from this air contaminant source since the potential to emit is less than 10 tons/year.</p> <p>See b)(2)b.</p>
c.	ORC 3704.03(T) and OAC rule 3745-31-05(A)(3)	<p>Install a turbine that is designed to meet 15 ppmvd of nitrogen oxide (NO_x) at 15% oxygen.</p> <p>Install a turbine that is designed to meet 25 ppmvd of carbon monoxide (CO) at 15% oxygen.</p> <p>The requirements of this rule also include compliance with the requirements of 40 CFR Part 60, Subpart KKKK.</p>
d.	OAC rule 3745-17-07(A)	Visible PE from any stack serving this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
e.	OAC rule 3745-17-11(B)(4)	PE from the turbine's exhaust shall not exceed 0.040 pound per million Btu of actual heat input.
f.	OAC rule 3745-18-06(F)	Pursuant to OAC rule 3745-18-06(A), this stationary gas turbine is exempt from the sulfur dioxide (SO ₂) emission limitation specified by this rule during any calendar day in which natural gas is the only fuel burned.
g.	OAC rule 3745-110-03(E)	This emission limitation is less stringent than the limitation listed under 40 CFR 60, Subpart KKKK.
h.	<p>40 CFR Part 60, Subpart KKKK (40 CFR Part 60.4300 – 60.4420)</p> <p>[In accordance with 40 CFR 60.4305(a), this emissions unit has a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel.]</p>	<p>NO_x emissions shall not exceed 25 ppm at 15% O₂ or 150 ng/J of useful output (1.2 lb/MWh) while firing natural gas.</p> <p>SO₂ emissions shall not exceed 110 nanograms per Joule (0.90 pounds per mega-Watt hour) or 26 ng SO₂/J (0.060 lb SO₂/mmBtu).</p>



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
i.	40 CFR Part 60, Subpart GG (40 CFR Part 60.330 – 60.335) [In accordance with 40 CFR 60.330 (a), this emissions unit has a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel.]	Stationary combustion turbines regulated under 40 CFR Part 60, Subpart KKKK are exempt from the requirements of 40 CFR Part 60, Subpart GG.
j.	40 CFR Part 60, Subpart A (40 CFR Part 60.1 – 60.19) [General Provisions]	See b)(2)c.

(2) Additional Terms and Conditions

- a. This Best Available Technology (BAT) emission limit applies until U.S. EPA approves Ohio Administrative Code (OAC) paragraph 3745-31-05(A)(3)(a)(ii) (the less than 10 tons per year BAT exemption) into the Ohio State Implementation Plan (SIP).
- b. These requirements apply once U.S. EPA approves OAC paragraph 3745-31-05(A)(3)(a)(ii) (the less than 10 tons per year BAT exemption) as part of the Ohio SIP.
- c. The permittee shall demonstrate compliance with the applicable provisions of 40 CFR Part 60, Subpart KKKK in accordance with 40 CFR Part 60, Subpart A.

c) Operational Restrictions

- (1) The permittee shall burn only natural gas in this emissions unit.
- (2) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart KKKK, including the following sections:

60.4333(a)	Utilize good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction
------------	--



d) Monitoring and/or Recordkeeping Requirements

- (1) For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
- (2) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart KKKK, including the following sections:

60.4360	Exemption from determining the total sulfur content of the fuel being fired in the turbine as provided in §60.4365
60.4365(a)	Maintain current, valid purchase contract, tariff sheet or transportation contract that specifies the maximum total sulfur content for natural gas in continental areas is 20 grains of sulfur or less per 100 standard cubic feet

e) Reporting Requirements

- (1) The reports required by this permit may be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal; or they may be mailed as a hard copy to the appropriate district office or local air agency.
- (2) The permittee shall submit an annual PER to the Ohio EPA District Office or Local Air Agency by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve months for each air contaminant source identified in this permit.
- (3) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
- (4) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart KKKK, including the following sections:

60.7	Submit notification of date of construction within 30 days, initial notification of startup within 15 days, and notification of any physical or operational change that would increase the emission rate of any air pollutant to which a standard applies within 60 days
------	--



f) Testing Requirements

(1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. Emissions Limitation:

PE shall not exceed 0.40 ton per month averaged over a twelve-month, rolling period.

Applicable Compliance Method:

Compliance shall be determined by using the following equation:

Normal Operating conditions (worst case MMBtu/hr):

$$0.0066 \text{ lbs/MMBtu} \times 167.4 \text{ MMBtu/hr} = 1.10 \text{ lbs/hr} \times 8,660 \text{ hrs/yr} / 2,000 \text{ lbs/ton} = 4.78 \text{ TPY}$$

Sub-zero operating conditions (worst case MMBtu/hr):

$$0.0066 \text{ lbs/MMBtu} \times 167.4 \text{ MMBtu/hr} = 1.10 \text{ lbs/hr} \times 100 \text{ hrs/yr} / 2,000 \text{ lbs/ton} = 0.06 \text{ TPY}$$

$$4.78 + 0.06 = 4.84 \text{ TPY} / 12 \text{ months} = 0.40 \text{ tons per month}$$

Emission factor from AP-42, Section 3.1, Table 3.1-2a, revised 4/2000

If required, compliance shall be demonstrated based upon emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5.

b. Emissions Limitation:

SO₂ emissions shall not exceed 0.20 ton per month averaged over a twelve-month, rolling period.

Applicable Compliance Method:

Compliance shall be determined by using the following equation:

Normal Operating conditions (worst case MMBtu/hr):

$$0.0034 \text{ lbs/MMBtu} \times 167.4 \text{ MMBtu/hr} = 0.57 \text{ lbs/hr} \times 8,660 \text{ hrs/yr} / 2,000 \text{ lbs/ton} = 2.46 \text{ TPY}$$

Sub-zero operating conditions (worst case MMBtu/hr):

$$0.0034 \text{ lbs/MMBtu} \times 167.4 \text{ MMBtu/hr} = 0.57 \text{ lbs/hr} \times 100 \text{ hrs/yr} / 2,000 \text{ lbs/ton} = 0.03 \text{ TPY}$$



$2.46 + 0.03 = 2.49$ TPY / 12 months = 0.20 tons per month

Emission factor from AP-42, Section 3.1, Table 3.1-2a, revised 4/2000

If required, compliance shall be demonstrated based upon emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

c. Emission Limitation:

Install a turbine that is designed to meet 25 ppmvd VOC at 15% oxygen.

Applicable Compliance Method:

Compliance is demonstrated by the turbine manufacturer's emissions specifications.

If required, compliance shall be demonstrated based upon emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 18, 25 or 25A.

d. Emission Limitation:

Install a turbine that is designed to meet 15 ppmvd of NO_x at 15% oxygen.

Applicable Compliance Method:

Compliance shall be demonstrated based upon the emissions testing requirements specified in f)(2).

e. Emission Limitation:

Install a turbine that is designed to meet 25 ppmvd CO at 15% oxygen.

Applicable Compliance Method:

Compliance is demonstrated by the turbine manufacturer's emissions specifications.

If required, compliance shall be demonstrated based upon emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 10.

f. Opacity Limitation:

Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity, as a six-minute average, except as specified by rule.



Applicable Compliance Method:

If required, compliance with the stack visible particulate emission limitation shall be demonstrated through visible emission observations performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 9.

g. Emission Limitation:

PE from the turbine's exhaust shall not exceed 0.040 pound per MMBTU.

Applicable Compliance Method:

The particulate emission limitation is from OAC rule 3745-17-11(B)(4) for stationary combustion turbines.

Compliance is demonstrated by the emissions factor of 0.0066 lb/MMBtu as listed in permittee's application.

If required, compliance shall be demonstrated based upon emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5.

h. Emission Limitation:

The combustion turbine shall not utilize any fuel which contains total potential sulfur emissions in excess of 0.060 lb SO₂/MMBtu heat input.

Applicable Compliance Method:

Compliance shall be demonstrated by recordkeeping required in d)(2).

(2) Pursuant to 40 CFR 60.8, 60.4340(a), 60.4375(b) and 60.4400, OAC rules 3745-31-05(A)(3) and 3745-110-05, and ORC 3704.03(T), the permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

- a. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of such facility and on annual bases (no more than 14 calendar months following the previous performance test).
- b. The emissions testing shall be conducted to demonstrate compliance with the NO_x emissions limitation identified in 40 CFR 60.4320.
- c. Pursuant to Table 1 of 40 CFR Part 60, Subpart KKKK and OAC rule 3745-31-05(A)(3) the following test methods shall be employed to demonstrate compliance with the allowable NO_x emissions rate and design standard for NO_x:

Methods 7, 7a, 7c, 7d, or 7e of 40 CFR Part 60, Appendix A for NO_x



- d. The test(s) shall be conducted under those representative conditions that challenge to the fullest extent possible a facility's ability to meet the applicable emissions limits and/or control requirements, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency or as required by 40 CFR 60.4400(b). Although this generally consists of operating the emissions unit at its maximum material input/production rates and results in the highest emission rate of the tested pollutant, there may be circumstances where a lower emissions loading is deemed the most challenging control scenario. Failure to test under these conditions is justification for not accepting the test results as a demonstration of compliance.
 - e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emission test(s).
 - f. Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
 - g. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.
- g) Miscellaneous Requirements
- (1) None.