

Ohio EPA

Re: Permit to Install
Summit County
Application No. 16-384

July 31, 1985

City of Akron
Central Services Facility
1428 Triplett Blvd.
Akron, Ohio 44306

Attention: Don Brown

CERTIFIED MAIL

Dear Sir:

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
250 East Town Street, Room 101
Columbus, Ohio 43215

Very truly yours,

Patricia P. Walling

Patricia P. Walling, Manager
Authorization & Compliance Section
Division of Air Pollution Control

PPW/gs

cc: US EPA
Akron Air Pollution Control

Permit to Install Terms and Conditions

Application No. 16-384

APS Premise No. 1677010919

Permit Fee: \$50.00

Name of Facility: City of Akron
Central Services Facility
Person to Contact: Don Brown

Address: 1428 Triplett Blvd.
Akron, Ohio 44306

Location of proposed source(s): 850 E. Market St.
Akron, Ohio

Description of proposed source(s): Motor Vehicle Maintenance, Gasoline
Dispensing Facility - Dual Vapor
Balance


Date of Issuance: July 31, 1985

Effective Date: July 31, 1985

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Director

City of Akron - Central Services Facility
Application No. 16-384
Page Two
July 31, 1985

Substantial construction for installation must take place within eighteen months of the effective date of this permit. This deadline may be extended by up to twelve months, if application is made to the Director no less than sixty days before the expiration of this permit and the party shows good cause for any such extension.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

The proposed source shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

The specified permit fee must be remitted within 15 days of the effective date of this permit to install.

This permit shall apply only to the source(s) shown on the application approved by the Ohio Environmental Protection Agency.

This Permit to Install is applicable only to the air contaminant sources listed below and does not include the installation of wastewater disposal systems or solid waste disposal facilities. Separate application must be made to the Director for the installation of any such sources.

The air contaminant sources listed below comprise the Permit to Install for this City of Akron, Central Services Facility located in Summit County.

Emissions from the sources shall not exceed the emission limits specified below:

City of Akron - Central Services Facility
 Application No. 16-384
 Page Three
 July 31, 1985

<u>OEPA Source No.</u>	<u>Source and Identification</u>	<u>BAT Determination</u>	<u>Applicable OAC Rule</u>	<u>Annual Emissions (T/YR)</u>
16-384	Gasoline Dispensing Facility	Dual Vapor Balance	3745-21-09 (R)	1.65*

*Assume 300,000 gallon per year throughput.

SUMMARY
 TOTAL FACILITY EMISSIONS

<u>Pollutant</u>	<u>Tons/Year</u>
Particulate Matter	0.00
Volatile Organic Compounds	1.65
Sulfur Dioxide	0.00

As specified in OAC 3745-31-05, all new sources must, at a minimum, employ Best Available Technology. The following terms and conditions fulfill these requirements and any applicable federal regulations.

Dual vapor balance system shall be used at this facility.