Ohio Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

10/1/2015

Certified Mail

No	TOXIC REVIEW
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
No	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MODELING SUBMITTED
No	SYNTHETIC MINOR TO AVOID TITLE V
No	FEDERALLY ENFORCABLE PTIO (FEPTIO)
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Mr. PATRICK SICONOLFI
Riverside Methodist Hospital
ATTN: FACILITIES ENGINEERING
3535 OLENTANGY RIVER RD
COLUMBUS, OH 43214

RE: FINALAIR POLLUTION PERMIT-TO-INSTALL AND OPERATE
Facility ID: 0125040598
Permit Number: P0118829
Permit Type: Initial Installation
County: Franklin

Dear Permit Holder:

Enclosed please find a final Ohio Environmental Protection Agency (EPA) Air Pollution Permit-to-Install and Operate (PTIO) which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully. In this letter you will find the information on the following topics:

- **How to appeal this permit**
- **How to save money, reduce pollution and reduce energy consumption**
- **How to give us feedback on your permitting experience**
- **How to get an electronic copy of your permit**

How to appeal this permit

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of $70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
77 South High Street, 17th Floor
Columbus, OH 43215

How to save money, reduce pollution and reduce energy consumption

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. Additionally, all or a portion of the capital expenditures related to installing air pollution control equipment under this permit may be eligible for financing and State tax exemptions through the Ohio Air Quality Development Authority (OAQDA) under Ohio Revised Code Section 3706. For more information, see the OAQDA website: www.ohioairquality.org/clean_air

How to give us feedback on your permitting experience

Please complete a survey at www.epa.ohio.gov/survey.aspx and give us feedback on your permitting experience. We value your opinion.

How to get an electronic copy of your permit

This permit can be accessed electronically via the eBusiness Center: Air Services in Microsoft Word format or in Adobe PDF on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Search for Permits" link under the Permitting topic on the Programs tab.

If you have any questions, please contact Ohio EPA DAPC, Central District Office at (614)728-3778or the Office of Compliance Assistance and Pollution Prevention at (614) 644-3469.

Sincerely,

Michael E. Hopkins, P.E.
Assistant Chief, Permitting Section, DAPC

Cc: Ohio EPA-CDO

Ohio Environmental Protection Agency

FINAL

Division of Air Pollution Control Permit-to-Install and Operate

for

Riverside Methodist Hospital

Facility ID:	0125040598
Permit Number:	P0118829
Permit Type:	Initial Installation
Issued:	10/1/2015
Effective:	10/1/2015
Expiration:	4/24/2018

Ohio Environmental Protection Agency

Division of Air Pollution Control
Permit-to-Install and Operate
for
Riverside Methodist Hospital

Table of Contents

Authorization 1

A. Standard Terms and Conditions 3

1. What does this permit-to-install and operate ("PTIO") allow me to do? 4
2. Who is responsible for complying with this permit? 4
3. What records must I keep under this permit? 4
4. What are my permit fees and when do I pay them? 4
5. When does my PTIO expire, and when do I need to submit my renewal application? 4
6. What happens to this permit if my project is delayed or I do not install or modify my source? 5
7. What reports must I submit under this permit? 5
8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit? 5
9. What are my obligations when I perform scheduled maintenance on air pollution control equipment? 5
10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report? 6
11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located? 6
12. What happens if one or more emissions units operated under this permit is/are shut down permanently? 6
13. Can I transfer this permit to a new owner or operator? 7
14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"? 7
15. What happens if a portion of this permit is determined to be invalid? 7

B. Facility-Wide Terms and Conditions 8

C. Emissions Unit Terms and Conditions 10

1. B019, Boiler No. 7 11

Authorization

Facility ID:	0125040598
Application Number(s):	A0050423
Permit Number:	P0118829
Permit Description:	Initial installation permit for a 36 MMBtu/hr natural gas-fired boiler with No.2 fuel oil backup.
Permit Type:	Initial Installation
Permit Fee:	$800.00
Issue Date:	10/1/2015
Effective Date:	10/1/2015
Expiration Date:	4/24/2018

Permit Evaluation Report (PER) Annual Date: Jan 1 - Dec 31, Due Feb 15

This document constitutes issuance to:

Riverside Methodist Hospital
3535 OLENTANGY RIVER RD
Columbus, OH 43214

of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page.

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Central District Office
50 West Town Street, 6th Floor
P.O. Box 1049
Columbus, OH 43216-1049
(614)728-3778

The above named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s))listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Craig W. Butler
Director

Authorization (continued)

Permit Number: P0118829
Permit Description: Initial installation permit for a 36 MMBtu/hr natural gas-fired boiler with No.2 fuel oil backup.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	**B019**
Company Equipment ID:	Boiler No. 7
Superseded Permit Number:	
General Permit Category and Type:	Boilers - 35-39.9 mmBTU/hr Natural Gas and Oil-Fired, Post 1989 (GP1.12)

A. Standard Terms and Conditions

1. What does this permit-to-install and operate ("PTIO") allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

PTIO fee.This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11, or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

Annual emissions fee.Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is

very important that you submit a complete renewal permit application (postmarked prior to expiration of this permit) even if you do not receive the renewal notice.

If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended by up to 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions of this permit will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective, and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.

10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the [DO/LAA] in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction, but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as beingpermanently shut down without first applying for and obtaining a permit pursuantto OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, you must follow the procedures in OAC Chapter 3745-31, including notifying Ohio EPA or the local air agency of the change in ownership or operator. Any transferee of this permit must assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.

B. Facility-Wide Terms and Conditions

1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

   a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

      (1) None.

   b) For the purpose of a permit-to-operate document, the facility-wide terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

      (1) None.

C. Emissions Unit Terms and Conditions

1. B019, Boiler No. 7

Operations, Property and/or Equipment Description:

Gas fired boiler with #2 fuel oil backup - 36 MMBTU/HR

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)	Particulate emissions (PE) shall not exceed 0.014 lb/mmBtu and 1.64 tons per year (TPY). Organic compound (OC) emissions shall not exceed 0.011 lb/mmBtu and 1.88 TPY. Nitrogen oxide (NOx) emissions shall not exceed 0.14 lb/mmBtuand 19.33 TPY. Carbon monoxide (CO) emissions shall not exceed 0.082 lb/mmBtu and 14.39 TPY. Sulfur dioxide (SO_2) emissions shall not exceed 0.50lb/mmBtu and 24.87 TPY. Visible particulate emissions from any stack shall not exceed 10% opacity, as a 6-minute average, except for one

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		6-minute period per hour of not more than 27% opacity. The requirements of this rule also include compliance with the requirements of OAC rules 3745-31-05(C), 3745-21-07(B), 3745-21-08(B), 3745-23-06(B), and 40 CFR, Part 60, Subpart Dc.
b.	OAC rule 3745-17-07(A)(1) OAC rule 3745-17-10(B)(1) OAC rule 3745-18-06(D) 40 CFR Part 60 Subpart Dc	The emission limitation specified by these rules are less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).
c.	OAC rule 3745-21-08(B)	See b)(2)e.
d.	OAC rule 3745-21-07(B) OAC rule 3745-23-06(B)	e b)(2)d.
e.	OAC rule 3745-31-05(D) (to avoid state modeling)	This emissions unit shall not use more than 700,000 gallons of No. 2 fuel oil per rolling, 12-month period.

(2) Additional Terms and Conditions

a. Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by the use of natural gas or No. 2 fuel oil, fuel sulfur content limitation, and the emission limitations listed in b)(1) above.

b. The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency (U.S. EPA), 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency (Ohio EPA).

c. The lb/mmBtu actual heat input and tons per year emission limitations, except for SO_2, are based on the emissions unit's potentials to emit. Therefore, no monitoring, record keeping, and reporting requirements are necessary to ensure ongoing compliance with these emission limitations.

d. The permittee has satisfied the "latest available control techniques and operating practices" required pursuant to OAC rules 3745-21-07(B) and 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3).

e. The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply

with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3).

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revisions occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

(1) The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.

(2) The quality of No. 2 fuel oil received for burning in this emissions unit shall have a combination of sulfur content and heat content sufficient to comply with the allowable sulfur dioxide emission limitation of 0.50 lb/mmBtu of actual heat input and the sulfur content limitation for No. 2 fuel oil of less than or equal to 0.5 weight per cent sulfur.

(3) The maximum annual No. 2 fuel oil usage rate for this emissions unit shall not exceed 700,000 gallons per rolling, 12-month period.

To ensure enforceability during the first 12 calendar months of operation, the permittee shall not exceed the No. 2 fuel oil usage levels specified in the following table:

Month	Maximum Allowable Cumulative Usage (gallons)
1	58,333
1-2	116,667
1-3	175,000
1-4	233,333
1-5	291,667
1-6	350,000
1-7	408,333
1-8	466,667

1-9	525,000
1-10	583,333
1-11	641,667
1-12	700,000

After the first 12 calendar months of operation, compliance with the annual No. 2 fuel oil usage limitation shall be based upon a rolling, 12-month summation of the usage rates.

d) Monitoring and/or Recordkeeping Requirements

(1) The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch, and the quality of the oil for those loads may be represented by a single batch analysis from the supplier.

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)].

c. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240 and D4294), or equivalent methods as approved by the Director.

(2) The owner or operator of each affected facility shall record and maintain records of the amounts of each fuel combusted during each day.

(3) The permittee shall maintain monthly records of the following information:

a. The total volume of natural gas ($mmft^3$) burned in this emissions unit.

b. The total number of gallons of No. 2 fuel oil used in this boiler for each month.

c. Beginning after the first 12 calendar months of operation, the rolling, and 12-month summation of the gallons of No. 2 fuel oil used.

Also, during the first 12 calendar months of operation, the permittee shall record the cumulative production rate for each calendar month.

e) Reporting Requirements

(1) Pursuant to the NSPS, the permittee is required to report the following information at the appropriate times (if the information has not already been reported):

a. Construction date (no later than 30 days after such date);

b. Anticipated start-up date (not more than 60 days or less than 30 days prior to such date);

c. Actual start-up date (within 15 days after such date); and,

d. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to Central District Office and to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P.O. Box 163669
Columbus, Ohio43216-3669

(2) The permittee shall notify the Director (Ohio EPA, Central District Office) in writing of any fuel burned in this emissions unit other than natural gas or No. 2 fuel oil.

(3) The permittee shall notify the Director (Ohio EPA, Central District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation and/or sulfur content limitation based upon the record keeping requirements from d)(1) above.

(4) The notifications identified in e)(2) and e)(3) shall include a copy of such record and shall be sent to the Director (Ohio EPA, Central District Office) within 45 days after the deviation occurs.

(5) The permittee shall submit annual reports that specify the total SO_2 emissions from this emissions unit during the previous twelve-month period. The reports shall be submitted with the annual Permit Evaluation Reports by the due date identified in the Authorization section of this permit.

(6) The permittee shall submit deviation (excursion) reports that identify all exceedances of the rolling, 12-month No. 2 fuel oil usage limitation and, for the first 12 calendar months of operation, all exceedances of the maximum allowable cumulative No. 2 fuel oil usage limitations. These reports shall be submitted with the annual Permit Evaluation Reports by the due date identified in the Authorization section of this permit.

(7) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.

f) Testing Requirements

(1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitation(s):

10% opacity, as a six-minute average, except for one 6-minute period per hour of not more than 27% opacity.

Applicable Compliance Method(s):

Compliance shall be determined through visible emission observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9.

b. Emission Limitation(s):

0.14 lb/mmBtu, 19.33 TPY NOx emissions

Applicable Compliance Method(s):

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 20 lbs NOx/10^3 gal emission factor into lb NOx/mmBtu by dividing by 140 mmBtu/10^3 gal. Compliance with the annual emission limitation may be demonstrated by multiplying the lb NOx/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 7.

c. Emission Limitation(s):

0.082 lb/mmBtu, 14.39 TPYCO emissions

Applicable Compliance Method(s):

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-1 (7/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 84 lbs CO/10^6scf emission factor into lb CO/mmBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lb CO/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 10.

d. Emission Limitation(s):

0.011 lb/mmBtu, 1.88 TPY OC emissions

Applicable Compliance Method(s):

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 11 lbs TOC/10^6scf emission factor into lb TOC/mmBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lb TOC/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 25.

e. Emission Limitation(s):

0.50 lb/mmBtu, 24.87 TPY SO_2 emissions

Applicable Compliance Method(s):

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation shall be based upon the record keeping in d)(1) and d)(3). Compliance with the annual emission limitation shall be determined by multiplying the annual average lb SO_2/mmBtu value by the annual average heat content and the total gallons on No. 2 fuel oil burned, and then dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 6.

f. Emission Limitation(s):

0.014 lb/mmBtu, 1.64 TPY PE

Applicable Compliance Method(s):

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 2 lbs PE/10^3 gal emission factor into lbs PE/mmBtu by dividing by 140 mmBtu/10^3 gal. Compliance with the annual emission limitation may be demonstrated by multiplying the lb PE/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 5.

g. Sulfur Content Limitation(s):

$\leq$ 0.5 weight percent sulfur

Applicable Compliance Method(s):

Compliance shall be demonstrated by the record keeping requirement described in paragraph d)(1).

(2) The permittee shall conduct, or have conducted, an initial performance test for this emissions unit (if the emissions test has not already been conducted) in accordance with the following requirements:

a. The emission testing shall be conducted within 60 days after achieving the maximum production rate but no later than 180 days after issuance of this permit;

b. The emission testing shall be conducted to demonstrate compliance with the visible particulate emission limitation, while burning fuel oil.

c. The following test method shall be employed to demonstrate compliance with the allowable emission rate: for visible particulate emissions, U.S. EPA's Reference Method 9 of 40 CFR, Part 60, Appendix A. Alternative U.S. EPA approved test methods may be used with prior approval from Ohio EPA, Central District Office.

d. The test shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by Ohio EPA, Central District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an Intent to Test notification to Ohio EPA, Central District Office. The Intent to Test notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test, and the person(s) who will be conducting the test. Failure to submit such notification for review and approval prior to the test may result in Ohio EPA, Central District Office's refusal to accept the results of the visible emissions test.

Personnel from Ohio EPA, Central District Office shall be permitted to witness the test, examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the visible emissions test (including opacity readings and the emissions unit operating parameters) shall be signed by the person(s) responsible for the test and submitted to Ohio EPA, Central District Office within 30 days following the completion of the test. The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from Ohio EPA, Central District Office.

g) Miscellaneous Requirements

(1) None.