



State of Ohio Environmental Protection Agency

P.O. Box 1049, 1800 WaterMark Dr.  
Columbus, Ohio 43266-0149  
(614) 644-3020  
FAX (614) 644-2329

George V. Voinovich  
Governor

Re: Permit to Install  
Medina County  
Application No: 16-952

CERTIFIED MAIL

April 17, 1991

EMRO MARKETING CO - SPEEDWAY #3691  
H. A. FORSHAW  
2525 N LIMESTONE ST  
SPRINGFIELD, OH 45503

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review  
236 East Town Street, Room 300  
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager  
Field Operations & Permit Section  
Division of Air Pollution Control

cc: AKRON AIR POLLUTION CONTROL

1991 APR 22 AM 11:50  
RECEIVED  
AKRON AIR MONT.



## Permit to Install Terms and Conditions

Application No. 16-952  
APS Premise No. 1652010024  
Permit Fee: \$50.00

Name of Facility: EMRO MARKETING CO - SPEEDWAY #3691

Person to Contact: H. A. FORSHAW

Address: 2525 N LIMESTONE ST  
SPRINGFIELD, OH 45503

Location of proposed source(s): 1555 PEARL RD  
BRUNSWICK, OHIO

Description of proposed source(s):  
RECONSTRUCTION OF EXISTING FOUR 10,000 GALLON AND ONE 4,000  
GALLON STORAGE TANK FOR GASOLINE AND KEROSENE.

Date of Issuance: April 17, 1991

Effective Date: April 17, 1991

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

  
\_\_\_\_\_  
Director

EMRO MARKETING CO - SPEEDWAY #3691  
Application No. 16-952  
Page 2 of 5  
April 17, 1991

TERMINATION OF PERMIT TO INSTALL

Substantial construction for installation must take place within 18 months of the effective date of this permit. This deadline may be extended by up to 12 months, if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

NOTICE OF INSPECTION

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, or to examine records or reports pertaining to the construction, modification or installation of the source(s) of environmental pollutants identified within this permit.

CONSTRUCTION OF NEW SOURCE(S)

The proposed source(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

If the construction of the proposed source(s) has already begun or has been completed prior to the date the Director of the Ohio Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of Ohio Administrative Code (OAC) Rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

EMRO MARKETING CO - SPEEDWAY #3691  
Application No. 16-952  
Page 3 of 5  
April 17, 1991

PERMIT TO INSTALL FEE

In accordance with Ohio Revised Code 3745.11, the specified Permit to Install fee must be remitted within 15 days of the effective date of this permit to install.

PUBLIC DISCLOSURE

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC Rule 3745-49-03.

APPLICABILITY

This Permit to Install is applicable only to the contaminant sources identified. Separate application must be made to the Director for the installation or modification of any other contaminant sources.

BEST AVAILABLE TECHNOLOGY

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

PERMIT TO OPERATE APPLICATION

A Permit to Operate application and a \$15 application fee must be submitted to the appropriate field office for each air contaminant source in this Permit to Install. In accordance with OAC Rule 3745-35-02, the application shall be made at least 90 days prior to start-up of the source.

AIR EMISSION SUMMARY

The air contaminant sources listed below comprise the Permit to Install for EMRO MARKETING CO - SPEEDWAY #3691 located in Medina County. The sources listed below shall not exceed the emission limits/control requirements contained in the table. This condition in no way limits the applicability of any other state or federal regulations. Additionally, this condition does not limit the applicability of additional special terms and conditions of this permit.

EMRO MARKETING CO - SPEEDWAY #3691  
Application No. 16-952  
Page 4 of 5  
April 17, 1991

OHIO EPA SOURCE NO.

SOURCE DESCRIPTION

G001

Reconstruction of an Existing Gasoline and Kerosene Dispensing Facility, Involving Four 10,000 Gallon Gasoline Storage Tanks and One 4,000 Gallon Kerosene Storage Tank

EMISSION SUMMARY

The total, allowable volatile organic compound emissions from the source(s) will be 16.25 tons per year.

MALFUNCTION/ABATEMENT

In accordance with OAC Rule 3745-15-06, any malfunction of the source(s) or associated air pollution control system(s) shall be reported immediately to the Akron Air Pollution Control, 177 South Broadway, Akron, Ohio 44308.

Except as provided by OAC Rule 3745-15-06(A)(3), scheduled maintenance of air pollution control equipment that requires the shutdown or bypassing of air pollution control system(s) must be accompanied by the shutdown of the associated air pollution sources.

GASOLINE DISPENSING FACILITIES

BAT for any gasoline dispensing operation identified within this permit consists of the use of Stage I vapor balance system. The vapor balance system shall be designed and operated to route at least 90% by weight of the organic compounds in the displaced vapors from the storage tanks to the delivery vessel and shall be equipped with a means to prevent the discharge into the atmosphere of displaced vapors from an unconnected vapor line. This shall be used at all times when filling the tanks.

EMRO MARKETING CO - SPEEDWAY #3691  
Application No. 16-952  
Page 5 of 5  
April 17, 1991

The transfer of gasoline from a delivery vessel to a stationary storage tank shall be conducted by use of submerged fill into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank.

This facility shall be serviced by a bulk gasoline plant or terminal that is in compliance with OAC Rule 3745-21-09(P) or (Q), respectively.

There shall be no leaks in the vapor and liquid lines during the transfer of gasoline.

All fill caps shall be "in place" and clamped during normal storage conditions.

The gasoline dispensing facility shall repair within 15 days any leaks from the vapor balance system which is employed to meet the requirements of Paragraph (A)(3) of OAC Rule 3745-31-05 or Paragraph (R)(1) of OAC Rule 3745-21-09 when such leaks are equal to or greater than 100% of the lower explosive limit of propane, as determined under Paragraph (K) of OAC Rule 3745-21-10.

#### DIESEL AND/OR KEROSENE DISPENSING FACILITIES

BAT for any diesel and/or kerosene dispensing operation identified within this permit consists of the transfer of diesel and/or kerosene from a delivery vessel to a stationary storage tank through the use of submerged filling into the storage tank. The submerged fill pipe(s) are to be installed so they are within six (6) inches of the bottom of the storage tank.

#### MISCELLANEOUS STORAGE TANKS

Unless otherwise indicated, BAT for any miscellaneous storage tanks identified within this permit consists of the use of submerged fill into the storage tanks. The submerged fill pipe(s) are to be installed within six (6) inches of the bottom of the storage tank.