



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
STARK COUNTY**

CERTIFIED MAIL

Street Address:

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov.
Center

Application No: 15-01406

DATE: 4/26/00

Marathon Ashland Petroleum LLC-Canton
Brent McNeese
2408 Gambrinus Avenue SW
Canton, OH 44706

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Review Appeals Commission pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed within thirty (30) days after the notice of the Directors action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo
Field Operations and Permit Section
Division of Air Pollution Control

CC: USEPA

Canton LAA



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

FINAL PERMIT TO INSTALL 15-01406

Application Number: 15-01406
APS Premise Number: 1576000301
Permit Fee: **\$700**
Name of Facility: Marathon Ashland Petroleum LLC-Canton
Person to Contact: Brent McNeese
Address: 2408 Gambrinus Avenue SW
Canton, OH 44706

Location of proposed air contaminant source(s) [emissions unit(s)]:
2408 Gambrinus Avenue SW
Canton, Ohio

Description of proposed emissions unit(s):
This PTI permits two storage tanks, T174 and T175.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Director

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous

calendar quarters. See B.11 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition

declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees within 30 days after the issuance of this Permit To Install.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit To Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within thirty (30) days after commencing operation of the source(s) covered by this permit.

B. State Only Enforceable Permit To Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

5. Termination of Permit To Install

This permit to install shall terminate within eighteen months of the effective date of the permit to install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

6. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

7. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

8. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

9. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

10. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

11. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit To Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

**SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
VOC	2.0

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

**Part III -
SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
This emission unit, designated T174, is a 40,572 gallon storage tank used for the storage of kerosene at ambient temperatures. The tank is equipped with a fixed roof and a submerged fill line. This tank is designated by the company as Tank No. 268.	OAC rule 3745-31-05(A)(3)	1 ton VOC/yr. (See Section A.I.2.a and A.I.2.c)
	OAC rule 3745-21-09(L)(3)	See section A.I.2.b below.
	40 CFR Part 60, (Subpart Kb)	See section A.I.2.c below.

2. Additional Terms and Conditions

- 2.a The permittee shall employ a permanent submerged fill pipe.
- 2.b In accordance with OAC rule 3745-21-09(L)(3), the permittee shall maintain records for this storage tank as specified in section A.III.1.
- 2.c This storage vessel is exempt from controls but must keep records as required by 40 CFR Part 60.116b(a)&(b) and outlined in section A.III.

II. Operational Restrictions

1. The permittee shall store only volatile organic liquids in this storage tank that have a true vapor pressure of less than 3.5 kPa(0.50 psia) at maximum operating temperature.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain the following records for this storage vessel:
 - a. the type of petroleum liquid stored in the storage vessel;
 - b. the maximum true vapor pressure(in pounds per square inch absolute), as stored, of each petroleum liquid during their respective storage period.
2. The permittee shall maintain records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. These records shall be readily accessible and kept for the life of the emissions unit.
3. The permittee shall maintain records of the actual annual throughput(in gallons/year) of petroleum liquid for this emissions unit.
4. The permittee shall calculate and maintain records of the annual VOC emissions from this emissions unit.
5. The permittee shall fulfill all recordkeeping requirements in the General Provisions Subpart A to 40 CFR Part 60 according to the applicability of Subpart A.

IV. Reporting Requirements

1. The permittee shall submit an excursion(deviation) report of any exceedance of the annual emission rate of 1 ton VOC/year to the Canton Local Air Agency within 30 days of the exceedance. The exceedance report, at a minimum, shall identify the actual emission rate for the calendar year of concern. A report is required only if an exceedance occurs.
2. The permittee shall submit a deviation(excursion) report for the storage of volatile organic liquids with a vapor pressure greater than 3.5 kPa. The report shall describe the type of material stored and the vapor pressure at maximum storage temperature.
3. The permittee shall fulfill all notification and reporting requirements in General Provisions Subpart A to 40 CFR Part 60 according to the applicability of Subpart A.

V. Testing Requirements

1. Compliance with the applicable emission control measures in section A.I.1 of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation: 1 ton VOC/yr

Applicable Compliance Method: Record keeping requirements in sections A.III.3 and A.III.4; and reporting requirements in section A.IV.1. The actual annual throughput volume recorded for any calendar year shall be the basis for calculating the annual emissions of VOC by using the emissions estimation methodologies provided in the most current version of AP-42, Section 7.1, "Organic Liquid Storage Tanks" or USEPA's TANKS computer program.

- b. Emission Limitation: The permittee shall store only petroleum liquids in this storage tank with a true vapor pressure of less than 3.5 kPa(0.50 psia) at maximum storage temperature.

Applicable Compliance Method: Monitoring, record keeping and reporting requirements as shown in sections A.III.1, A.III.2 and A.IV.2.

VI. Miscellaneous Requirements

1. The permittee shall request, in writing, from the Canton Local Air Agency and receive written approval to store any liquids other than kerosene in this storage vessel.

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
This emission unit, designated T174, is a 40,572 gallon storage tank used for the storage of kerosene at ambient temperatures. The tank is equipped with a fixed roof and submerged fill line. This tank is designated by the company as Tank No. 268. .	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

16

Marath

PTI A₁

Issued: 4/26/00

Emissions Unit ID: T174

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
This emission unit, designated T175, is a 533, 400 gallon storage tank for the storage of slop oil. The tank is equipped with an internal floating roof, a submerged fill line, and steam heating to be used during cold weather operations. The tank is designated by the company as Tank No. 254.	OAC rule 3745-31-05(A)(3)	1.0 ton VOC/yr. The permittee shall use a permanent submerged fill line and comply with 40 CFR Part 60, (Subpart Kb)
	OAC rule 3745-21-07(D)	See Section A.I.2.a.
	OAC rule 3745-21-09(L)	See Section A.II.2. b.
	40 CFR Part 60, (Subpart Kb)	See Section A.I.2.b.
	40 CFR Part 61, (Subpart FF)	Controls are as stringent as 40 CFR Part 60 (Subpart Kb)

2. Additional Terms and Conditions

- 2.a The permittee shall employ a permanent submerged fill pipe.
- 2.b The permittee shall install and maintain an internal floating roof (IFR) to control VOC emissions from this storage vessel.

II. Operational Restrictions

1. The permittee shall ensure that the internal floating roof rests or floats on the liquid surface inside the storage vessel. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.
2. The internal floating roof shall be equipped with a mechanical shoe seal as defined in 40 CFR Part 60.112b(a)(1)(ii)(C).
3. Each opening in a non-contact IFR except for automatic bleeder vents and the rim space vents is to provide a projection below the liquid surface.
4. Each opening in the IFR except for stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
5. Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
6. Rim space vents shall be equipped with a gasket and are to be set open only when the IFR is not floating or at the manufacturer's recommended setting.
7. Each penetration of the IFR for the purpose of sampling shall be a sample well. The sample well shall have a slit fabric cover that covers at least 90% of the opening.
8. Each penetration of the IFR that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover.
9. Each penetration of the IFR that allows for passage of a ladder shall have a gasketed sliding cover.
10. The permittee shall store only volatile organic liquid (VOL) with a vapor pressure less than 76.6 kPa(11.1 psia) at maximum storage temperature.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall visually inspect the IFR and primary seal prior to filling the storage vessel

Issued

Emissions Unit ID: T175

with volatile organic liquid. If there are holes, tears, or other openings in the primary seal or the seal fabric or defects in the IFR, or both, the permittee shall repair the items before filling the storage vessel.

2. The permittee shall visually inspect the IFR and primary seal through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the IFR is not resting on the surface of the liquid inside the storage vessel or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the permittee shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days, a 30 day extension may be requested from the Administrator of the U.S. EPA in the inspection report (with a copy submitted to the Canton Local Air Agency). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
3. The permittee shall visually inspect the internal floating roof, the primary seal, gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in section A.III.2.
4. The permittee shall keep a record of each inspection performed. Each record shall identify the storage vessel on which the inspection was performed and shall contain the date the vessel was inspected and the observed condition of each component of the control equipment (seals, internal floating roof, and fittings).
5. The permittee shall maintain records showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. These records shall be maintained for the life of the storage vessel and be readily accessible for inspection.
6. The permittee shall maintain a record of the VOL stored, the period of storage, and the maximum true vapor pressure of that volatile organic liquid during the respective storage period.
7. The permittee may use all available data for the storage temperature to determine the maximum true vapor pressure as specified in 40 CFR Part 60.116b (e).
8. The permittee shall maintain records of the actual annual throughput (in gallons/year) of petroleum liquid for this emissions unit.

Issued

Emissions Unit ID: T175

9. The permittee shall calculate and maintain records of the annual VOC emissions from this emissions unit. The actual annual throughput volume recorded for any calendar year shall be the basis for calculating the annual emissions of VOC by using the emissions estimation methodologies provided
In the most current version of AP-42, Section 7.1, "Organic Liquid Storage Tanks" or USEPA's TANKS computer program.
10. The permittee shall fulfill all recordkeeping requirements in General Provision Subpart A to 40 CFR Parts 60 and 61 according to the applicability of Subpart A.

IV. Reporting Requirements

1. The permittee shall notify the Administrator of the U.S. EPA in writing (with a copy submitted to the Canton Local Air Agency) at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by sections A.III.1. and A.III.3. to afford the Administrator of the U.S. EPA (and the Canton Local Air Agency) the opportunity to have an observer present. If the inspection required by section A.III.3. is not planned and the permittee could not have known about the inspection 30 days in advance of refilling the tank, the permittee shall notify the Administrator of the U.S. EPA and the Canton Local Air Agency at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. A copy of the written documentation shall also be submitted to the Canton Local Air Agency. Alternatively, this notification including the written documentation may be made in writing and sent by express mail so that it is received by the Administrator of the U.S. EPA (with a copy submitted to the Canton Local Air Agency) least 7 days prior to the refilling.
2. The permittee shall submit to the Administrator of the U.S. EPA (with a copy submitted to the Canton Local Air Agency) a report that describes the control equipment and certifies that the control equipment meets the specifications of 40 CFR Part 60.112b(a)(1). This report shall be an attachment to the notification required by 40 CFR Part 60.7(a)(3).
3. If any of the conditions described in section A.III.2. are detected during the annual visual inspection required by section A.III.2., a report shall be submitted to the Administrator of the U.S. EPA (with a copy submitted to the Canton Local Air Agency) within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made.
4. The permittee shall submit a deviation (excursion) report for the storage of volatile organic liquids with a vapor pressure greater than 76.6 kPa. The report shall describe the type of material stored and the maximum true vapor pressure for the material stored at least 30 days prior to storage of the new material.

Issued: 4/26/00

5. The permittee shall fulfill all notification and reporting requirements in General Provisions Subpart A to 40 CFR Parts 60 and 61.
6. The permittee shall submit a deviation(excursion) report if the actual annual VOC emissions exceed 1 ton per year.

V. Testing Requirements

1. Compliance with the applicable emission control measures in section A.I.1 of these terms and conditions shall be determined in accordance with the following method(s):
 - a. Emission Limitation: 1 ton VOC/yr
Applicable Compliance Method: Record keeping requirements in sections A.III.8 and A.III.9; and reporting requirements in section A.IV.7.

VI. Miscellaneous Requirements

1. The permittee shall calculate the total annual benzene quantity from all facility waste in accordance with 40 CFR Part 61(Subpart FF), the National Standard for Benzene Waste Operations(Parts 61.342 and 61.355). If the total calculated annual benzene quantity from all facility waste exceeds 10 megagrams benzene/year, the permittee shall comply with the applicable monitoring, record keeping, reporting requirements for this emissions unit from 40 CFR Part 60,(Subpart FF).

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
This emission unit, designated T175, is a 533, 400 gallon storage tank for the storage of slop oil. The tank is equipped with an internal floating roof, a submerged fill line, and steam heating to be used during cold weather operation. The tank is designated by the company as Tank No. 254.	None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

23

Marath

PTI A₁

Issued: 4/26/00

Emissions Unit ID: T175

VI. Miscellaneous Requirements

None

NEW SOURCE REVIEW FORM B

PTI Number: 15-01406 Facility ID: 1576000301

FACILITY NAME Marathon Ashland Petroleum LLC-Canton

FACILITY DESCRIPTION Tank No. 268(Kerosene storage tank;40,572 gallon capacity fixed roof tank) and Tank No. 254(Slop Oil Tank;533,400 gallon capacity tank with an internal floating roof and submerged fill). CITY/TWP Canton

SIC CODE 2911 SCC CODE _____ EMISSIONS UNIT ID T174

EMISSIONS UNIT DESCRIPTION Tank No. 268 - 40,572 gallon Kerosene storage Tank with a fixed roof tank

DATE INSTALLED _____

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter					
PM ₁₀					
Sulfur Dioxide					
Organic Compounds	Attainment				1.0
Nitrogen Oxides					
Carbon Monoxide					
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? 40 CFR Part 60.116b(a) &(b) (Subpart Kb) NESHAP? PSD? OFFSET POLICY?

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Submerged Fill Line and compliance with 40 CFR Part 60.116b(a) &(b) (Subpart Kb)

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$ _____

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to contaminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: _____

25 NEW SOURCE REVIEW FORM B

PTI Number: 15-01406 Facility ID: 1576000301
 FACILITY NAME Marathon Ashland Petroleum LLC-Canton
 FACILITY DESCRIPTION Tank No. 268(Kerosene storage CITY/TWP Canton

Emissions Unit ID: T175

internal floating roof and submerged fill).

SIC CODE 2911 SCC CODE EMISSIONS UNIT ID T175
 EMISSIONS UNIT DESCRIPTION Tank No. 254-533,400 gallon Slop Oil Storage Tank with an internal floating roof and submerged fill line.
 DATE INSTALLED

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter					
PM ₁₀					
Sulfur Dioxide					
Organic Compounds	Attainment			1.0	1
Nitrogen Oxides					
Carbon Monoxide					
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? 40 CFR, Part 60 NESHAP? 40 CFR Part 61, PSD? OFFSET POLICY?
 (Subpart Kb) (Subpart FF)

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?

Enter Determination Submerged fill line and compliance with 40 CFR, Part 60 (Subpart Kb)

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? No
 OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? \$

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to contaminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: _____

NEW SOURCE REVIEW FORM B

PTI Number: 15-01406

Facility ID: 1576000301

FACILITY NAME Marathon Ashland Petroleum LLC-Canton

FACILITY DESCRIPTION Tank No. 268(Kerosene storage

CITY/TWP Canton

Emissions Unit ID: T175

internal floating roof and submerged fill).

Please describe any hard copy information is being submitted with this recommendation(Please send hard copy information to Pam McGraner, DAPC Central Office - Air Quality Modeling and Planning):

PTI Application including calculations and drawings

Please provide any additional permit specific notes as you deem necessary:

NONE

Permit To Install Synthetic Minor Write-Up

NONE

TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

Pollutant
VOC

Tons Per Year
2.0