



State Of Ohio Environmental Protection Agency

P.O. Box 1049, 361 East Broad St., Columbus, Ohio 43216-1049  
(614) 466-8565



Richard F. Celeste, Governor

Re: Permit to Install  
Summit County

August 27, 1986

CERTIFIED MAIL

HOLLAND OIL CO. #44  
686 E. NORTH ST.  
AKRON, OHIO 44305

16-450

ATTN: CHARLES H. HOLLAND

Dear Sir:

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review  
250 East Town Street, Room 101  
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo, Manager  
Field Operations Section  
Division of Air Pollution Control

TGR/gs

cc: US EPA  
Akron Air Pollution Control

## Permit to Install Terms and Conditions

Application No. 16-450  
APS Premise No. 1677000181  
Permit Fee: \$50.

Name of Facility: HOLLAND OIL CO #44

Person to Contact: CHARLES H. HOLLAND

Address: 686 E NORTH ST  
AKRON, OHIO 44305

Location of proposed source(s): 5915 DARROW RD  
HUDSON, OHIO

Description of proposed source(s): MODIFICATION OF EXISTING GASOLINE  
DISPENSING FACILITY BY  
INSTALLATION OF NEW TANKAGE.


Date of Issuance: AUGUST 27, 1986

Effective Date: AUGUST 27, 1986

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

  
\_\_\_\_\_  
Warren W. Tyler

HOLLAND OIL CO #44  
APPLICATION NO 16-450  
PAGE 2  
AUGUST 27, 1986

Substantial construction for installation must take place within eighteen months of the effective date of this permit. This deadline may be extended by up to twelve months, if application is made to the Director no less than sixty days before the expiration of this permit and the party shows good cause for any such extension.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

If the construction of the proposed source has already begun or has been completed prior to the date the Director of the Ohio Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC Rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

The specified permit fee must be remitted within 15 days of the effective date of this permit to install.

This permit shall apply only to the source(s) shown on the application approved by the Ohio Environmental Protection Agency.

This permit to install is applicable only to the air contaminant sources listed below and does not include the installation of wastewater disposal systems or solid waste disposal facilities. Separate application must be made to the Director for the installation of any such sources.

The air contaminant sources listed below comprise the Permit to Install for Holland Oil Co. #44 - GDF, located in Summit County.

Emissions from the sources shall not exceed the limits specified below:

<u>OEPA Source No.</u>	<u>Source and Identification</u>	<u>BAT Determination</u>	<u>Applicable OAC Rule</u>	<u>Annual Emissions (T/YR)</u>
G001	Gasoline Dispensing Facility	Single Point Vapor Balance System, Submerged Fill Tanks.	3745-21-09(R)	3.90

SUMMARY  
TOTAL NEW SOURCE EMISSIONS

<u>Pollutant</u>	<u>Tons/Year</u>
Volatile Organic Compounds	3.90

As specified in OAC 3745-31-05, all new sources must at a minimum, employ Best Available Technology. The following terms and conditions fulfill these requirements and any applicable federal regulations.

- a. The permit holder shall install, operate and maintain a single point vapor balance system for use when filling the storage tanks with gasoline.
- b. All gasoline storage tanks shall be equipped with submerged fill pipes.
- c. There shall be no leaks in the delivery vessel pressure/vacuum relief valves and hatch covers.
- d. There shall be no leaks in the vapor and liquid lines during the transfer of gasoline.