



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL MODIFICATION
SUMMIT COUNTY**

CERTIFIED MAIL

Street Address:

122 S. Front Street

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 16-00766

DATE: 5/11/2004

OMEGA JV1 Cuyahoga Falls
Randy Meyer
2600 Airport Drive
Columbus, OH 432192226

Enclosed Please find a modification to the Ohio EPA Permit To Install referenced above which will modify the terms and conditions.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Review Appeals Commission pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed within thirty (30) days after the notice of the Directors action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, Ohio 43215

Sincerely,

Michael W. Ahern

Michael W. Ahern, Supervisor
Field Operations and Permit Section
Division of Air Pollution Control

CC: USEPA

ARAQMD



**Permit To Install
Terms and Conditions**

**Issue Date: 5/11/2004
Effective Date: 5/11/2004**

FINAL ADMINISTRATIVE MODIFICATION OF PERMIT TO INSTALL 16-00766


Application Number: 16-00766
APS Premise Number: 1677050142
Permit Fee: **\$0**
Name of Facility: OMEGA JV1 Cuyahoga Falls
Person to Contact: Randy Meyer
Address: 2600 Airport Drive
Columbus, OH 432192226

Location of proposed air contaminant source(s) [emissions unit(s)]:
**2550 Bailey Road
Cuyahoga Falls, Ohio**

Description of proposed emissions unit(s):
Administrative modification to change the NOx emissions limitation for each of the 6 identical diesel generator units at the facility.

The above named entity is hereby granted a modification to the permit to install described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this modification does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

This permit is granted subject to the conditions attached hereto.


Ohio Environmental Protection Agency

Director

Part I - GENERAL TERMS AND CONDITIONS

A. Permit to Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized

representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Termination of Permit to Install

This Permit to Install shall terminate within eighteen months of the effective date of the Permit to Install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

9. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio

OMEGA JV1 Cuyahoga Falls
PTI Application: 16-00766
Modification Issued: 5/11/2004

Facility ID: 1677050142

Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

10. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

11. Applicability

This Permit To Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate Permit To Install for the installation or modification of any other emissions unit(s) are required for any emissions unit for which a Permit To Install is required.

12. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

13. Source Operation and Operating Permit Requirements After Completion of Construction

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or

OMEGA JV1 Cuyahoga Falls

PTI Application: 16-00766

Modification Issued: 5/11/2004

Facility ID: 1677050142

modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up

Emissions Unit ID: B001

to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

14. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

15. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit to Install fees within 30 days after the issuance of this Permit to Install.

B. Permit to Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

**SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
NOx	24.78

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B001 (Diesel Generator Unit No. 1) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

2.a none

B. Operational Restrictions

- 1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

- 1. The facility shall maintain monthly records of operating hours for each of the six units, along with a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

- 1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

E. Testing Requirements

none

F. Miscellaneous Requirements

none

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B002 (Diesel Generator Unit No. 2) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

- 2.a none

B. Operational Restrictions

- 1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

- 1. The facility shall maintain monthly records of operating hours for each of the six units, along with a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

- 1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

OMEI

PTI A

Modification Issued: 5/11/2004

Emissions Unit ID: B003

E. Testing Requirements

none

F. Miscellaneous Requirements

none

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B003 (Diesel Generator Unit No. 3) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

2.a none

B. Operational Restrictions

1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

1. The facility shall maintain monthly records of operating hours for each of the six units, along with a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

E. Testing Requirements

none

F. Miscellaneous Requirements

none

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B004 (Diesel Generator Unit No. 4) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

2.a none

B. Operational Restrictions

1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

1. The facility shall maintain monthly records of operating hours for each of the six units, along with

a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

E. Testing Requirements

none

F. Miscellaneous Requirements

none

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B005 (Diesel Generator Unit No. 5) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

2.a none

B. Operational Restrictions

1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

- 1. The facility shall maintain monthly records of operating hours for each of the six units, along with a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

- 1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

E. Testing Requirements

none

F. Miscellaneous Requirements

none

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B006 (Diesel Generator Unit No. 6) 17.78 mmBtu/hr maximum rated heat input diesel-powered electrical generator	OAC rule 3745-31-05	Nitrogen oxides emissions shall not exceed 24.78 tons/year from the facility. The facility consists of six (6) identical diesel-powered electrical generators, Unit Nos. 1 through 6.

2. Additional Terms and Conditions

- 2.a none

B. Operational Restrictions

1. The facility shall not operate more than 1200 unit hours during any consecutive 12-month period.

C. Monitoring and/or Recordkeeping Requirements

1. The facility shall maintain monthly records of operating hours for each of the six units, along with a record of the total unit operating hours of the previous 12 months.

D. Reporting Requirements

1. The facility shall report the monthly operating hours and the cumulative hours to the Akron Regional Air Quality Management District each quarter for the preceeding three months.

E. Testing Requirements

none

F. Miscellaneous Requirements

none