

nl
OhioEPA

RECEIVED

State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
50 West Town Street, Suite 700
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

FEB 13 2007

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

Ohio Environmental
Protection Agency
Southeast District

02/02/07

Meigs Co.

Facemyer Lumber Co. Inc. (06-53-00-0062)
Denny Facemyer
31940 Bailey Run Rd.
Middleport, OH 45760

CERTIFIED MAIL

RE: Final Chapter 3745-35 Permit To Operate

B001 (WB1) Wood Burning Boiler

Dear Denny Facemyer:

The enclosed Permit(s) to Operate allow you to operate the described emissions unit(s) in the manner indicated in the Permit(s). Because each permit contains several terms and conditions, I urge you to read them carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (800) 329-7518. For more information related to air pollution control in Ohio, visit www.epa.state.oh/dapc.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

If you have any questions, please contact Southeast District Office.

Sincerely,

Michael W. Ahern

Michael W. Ahern
Permit Issuance and Data Management Section
Division of Air Pollution Control

cc: Southeast District Office



State of Ohio Environmental Protection Agency

Final Permit To Operate An Emissions Unit

Effective Date: 02/02/07

Expiration Date: 02/02/12

This document constitutes issuance to:

Facility ID: 06-53-00-0062
Facemyer Lumber Co. Inc.
31940 Bailey Run Rd.
Middleport, OH 45760

of a permit to operate for:

B001 (WB1)
Wood Burning Boiler

You will be contacted six months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency identified below. This permit and the authorization to operate the air contaminant source (emissions unit) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC Chapter 3745-35 and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your permit:

Southeast District Office
2195 Front Street
Logan, OH 43138
(740) 385-8501

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

A handwritten signature in cursive script that reads "Chris Korleski".

Chris Korleski
Director

Part I: General Terms and Conditions

1. Compliance Requirements

The above-described emissions unit is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.

2. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

3. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

4. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit. Such records may be maintained in computerized form.

5. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine

compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

6. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions unit or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this emissions unit(s) that is (are) served by such control system(s).

7. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permittee. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Permit Renewal

Approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the following Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located:

Southeast District Office
2195 Front Street
Logan, OH 43138
(740) 385-8501

It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Part II: Special Terms and Conditions

A. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B001 - 9.94 million Btu/hr Wood Fired Boiler with Multiclone	OAC rule 3745-31-05(A)(3) (PTI 06-07893)	Particulate emissions (PE) shall not exceed 0.32 pound per million Btu of actual heat input; 13.9 tons per year.
		Sulfur Dioxide (SO ₂) emissions shall not exceed 0.25 pounds per hour; 1.1 ton per year.
		Volatile Organic Compound (VOC) emissions shall not exceed 0.17 pound per hour; 0.7 ton per year.
		Nitrogen Oxide (NO _x) emissions shall not exceed 4.87 pounds per hour; 21.3 tons per year.
		Carbon monoxide (CO) emissions shall not exceed 5.96 pounds per hour; 26.1 tons per year.
	OAC 3745-17-07(A)(1)	The requirements of this rule also include compliance with OAC rule 3745-17-07(A)(1).
	OAC rule 3745-17-10(C)(1)	Visible particulate emissions shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
		The emission limitation specified by this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

2. Additional Terms and Conditions

None

B. Operational Restrictions

- The maximum heat input to this emissions unit shall not exceed 9.94 million Btu per hour, the maximum rated capacity of this boiler.
- The fuel used to fire this boiler shall be restricted to saw dust only.

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform daily checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. The color of the emissions;
 - b. Whether the emissions are representative of normal operations;
 - c. If the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. The total duration of any visible emission incident; and
 - e. Any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the daily check until the incident has ended. The observer may indicate that the visible emission incident was continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

2. For each day during which the permittee burns a fuel other than saw dust, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

D. Reporting Requirements

1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit and (b) describe any corrective actions taken to minimize or eliminate the visible particulate emissions. These reports shall be submitted to the Ohio EPA, Southeast District Office by January 31 and July 31 of each year and shall cover the previous 6-month period.
2. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than saw dust was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

E. Testing Requirements

1. Compliance with the emission limitations in sections A.1 of these terms and conditions shall be determined in accordance with the following methods:

1.a Emission Limitation:

Visible particulate emissions shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method:

If required, visible particulate emissions shall be determined according to test Method 9 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources" as such appendix existed on July 1, 2002.

E. Testing Requirements (continued)

1.b Emission Limitation:

Particulate emissions shall not exceed 0.32 pound per million Btu; 13.9 tons per year.

Applicable Compliance Method:

Compliance with the 0.32 pound per million Btu particulate emissions limitation may be demonstrated by the use of AP-42, Chapter 1.6, Table 1.6-1 (9/03) particulate emission factors (0.30 lb/million Btu for dry wood and 0.22 lb/million Btu for wet wood), multiplied by the maximum hourly fuel burning capacity of the emissions unit (9.94 million Btu/hr), provided by the permittee.

The TPY emission limitation was developed by multiplying the allowable particulate emission limitation (0.32 lb/million btu) by the maximum hourly gas burning capacity of the emissions unit (9.94 million btu/hr), and by the maximum annual hours of operation (8,760 hours), and then dividing by 2000 lbs/ton. Therefore, provided compliance is shown with the hourly limitation, compliance shall also be shown with the annual emission limitation.

If required, particulate emissions shall be determined according to test Methods 1 - 5, as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

1.c Emission Limitation:

SO2 emissions shall not exceed 0.25 pound per hour; 1.1 tons per year.

Applicable Compliance Method:

Compliance with the 0.25 lb/hour SO2 emission limitation may be demonstrated by the use of AP-42, Chapter 1.6, Table 1.6-2 (9/03) SO2 emission factor (0.025 lb/million Btu), multiplied by the maximum hourly fuel burning capacity of the emissions unit (9.94 million Btu/hr), provided by the permittee.

The TPY emission limitation was developed by multiplying the allowable SO2 limitation (0.25 lb/hour) by the maximum annual hours of operation (8,760 hours), and then dividing by 2000 lbs/ton. Therefore, provided compliance is shown with the hourly emission limitation, compliance shall also be shown with the annual emission limitation.

If required, sulfur dioxide emissions shall be determined according to test Methods 1 - 4, and 6 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

1.d Emission Limitation:

VOC emissions shall not exceed 0.17 pound per hour; 0.7 ton per year.

Applicable Compliance Method:

Compliance with the 0.17 lb/hour VOC emission limitation may be demonstrated by the use of AP-42, Chapter 1.6, Table 1.6-3 (9/03) VOC emission factor (0.017 lb/million Btu), multiplied by the maximum hourly fuel burning capacity of the emissions unit (9.94 million Btu/hr), provided by the permittee.

The TPY emission limitation was developed by multiplying the allowable VOC limitation (0.17 lb/hour) by the maximum annual hours of operation (8,760 hours), and then dividing by 2000 lbs/ton. Therefore, provided compliance is shown with the hourly emission limitation, compliance shall also be shown with the annual emission limitation.

If required, volatile organic compound emissions shall be determined according to test Methods 1 - 4, and 18, 25, or 25A as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

E. Testing Requirements (continued)

1.e Emission Limitation:

NOx shall not exceed 4.87 pounds per hour; 21.3 tons per year.

Applicable Compliance Method:

Compliance with the 4.87 lbs/hour NOx emission limitation may be demonstrated by the use of AP-42, Chapter 1.6, Table 1.6-2 (9/03) NOx emission factor (0.49 lb/million Btu), multiplied by the maximum hourly fuel burning capacity of the emissions unit (9.94 million Btu/hr), provided by the permittee.

The TPY emission limitation was developed by multiplying the allowable NOx limitation (4.87 lbs/ hour) by the maximum annual hours of operation (8,760 hours), and then dividing by 2000 lbs/ton. Therefore, provided compliance is shown with the hourly emission limitation, compliance shall also be shown with the annual emission limitation.

If required, nitrogen oxides emissions shall be determined according to test Methods 1 - 4, and 7 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

1.f Emission Limitation:

CO emissions shall not exceed 5.96 pounds per hour; 26.1 tons per year.

Applicable Compliance Method:

Compliance with the 5.96 lbs/hour CO emission limitation may be demonstrated by the use of AP-42, Chapter 1.6, Table 1.6-2 (9/03) CO emission factor (0.60 lb/million Btu), multiplied by the maximum hourly fuel burning capacity of the emissions unit (9.94 million Btu/hr), provided by the permittee.

The TPY emission limitation was developed by multiplying the allowable CO limitation (5.96 lbs/hour) by the maximum annual hours of operation (8,760 hours), and then dividing by 2000 lbs/ton. Therefore, provided compliance is shown with the hourly emission limitation, compliance shall also be shown with the annual emission limitation.

If required, carbon monoxide emissions shall be determined according to test Methods 1 - 4, and 10 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

F. Miscellaneous Requirements

None