

Facility ID: 1667050023 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

[Go to Part II for Emissions Unit T005](#)

[Go to Part II for Emissions Unit T006](#)

\*\*\*THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION\*\*\*

Facility ID: 1667050023 Emissions Unit ID: T005 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

**Part II - Special Terms and Conditions**

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
  - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
  - (a) None.

**A. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
External floating roof tank	OAC rule 3745-21-09(Z)	See A.2.a below.

**2. Additional Terms and Conditions**

- (a) The welded external floating roof storage tank, equipped with a mechanical shoe primary seal and a rim-mounted secondary seal, shall meet the following requirements:
  - i. There shall be no visible holes, tears, or other openings in the seal or seal fabric.
  - ii. For the primary seal, the total seal gap area shall not exceed 10.0 square inches per foot of tank diameter.
  - iii. For the secondary seal, the total seal gap area shall not exceed 1.0 square inch per foot of tank diameter.

**B. Operational Restrictions**

1. The external floating roof tank shall be maintained using the following control measures:
  - a. Any opening in the external floating roof, except automatic bleeder vents, rim space vents, leg sleeves, stub drains, and slotted gauging/sampling wells shall be equipped with:
    - i. a cover, seal, or lid which remains in the closed position at all times without any visible gaps, except when the opening is in actual use; and
    - ii. a projection into the tank below the liquid surface.
  - b. Any automatic bleeder vent shall remain in the closed position, except when the external floating roof is floated off or landed on the roof leg supports.
  - c. Any rim vent shall be set to open at the manufacturers recommended setting, except when the external floating roof is being floated off the roof leg supports.
  - d. Any emergency roof drain shall be equipped with a slotted membrane fabric cover or other device which covers at least 90 percent of the area of the opening.
  - e. Any stub drain shall be equipped with a projection into the tank below the liquid surface.
  - f. Any slotted gauging/sampling well shall be equipped with an object which floats on the liquid surface within the well and which covers at least 90 percent of the area of the well opening.
2. The permittee shall operate the facility such that none of the facility parameters used to calculate results under paragraph (a)(1) or (b)(1) of 40 CFR 63.420 is exceeded in any rolling, 30-day period.

**C. Monitoring and/or Record Keeping Requirements**

1. The seals of the external floating roof tank shall be inspected as follows:
  - a. The seal and seal fabric shall be inspected annually for visible holes, tears, or other openings.

- b. The secondary seal gap shall be measured annually, in accordance with the method specified in paragraph (l) of OAC rule 3745-21-10.
    - c. The primary seal gap shall be measured at least once every 5 years, in accordance with the method specified in paragraph (l) of OAC rule 3745-21-10.
  - 2. The permittee shall maintain records of the following information for at least two years:
    - a. the dates and results of each seal and seal fabric inspection and each seal gap measurement; and
    - b. the annual throughput of each petroleum liquid stored in the tank.

A copy of these records shall be made available to the director or an authorized representative of the director upon written or verbal request.
  - 3. The permittee shall maintain records of the following information for at least five years:
    - a. the types of petroleum liquids stored in the tank; and
    - b. the maximum true vapor pressure (in pounds per square inch absolute), as stored, of each liquid.

A copy of these records shall be made available to the director or an authorized representative of the director upon written or verbal request.
  - 4. The permittee shall maintain a record of the calculations in 40 CFR 63.420 (a)(1) or (b)(1), including methods, procedures, and assumptions supporting the calculations for determining criteria in 40 CFR 63.420(d).

**D. Reporting Requirements**

- 1. The permittee shall notify the director (the appropriate Ohio EPA District Office or local air agency) within 30 days of any seal and seal fabric inspection or any seal gap measurement, which documents a violation of the applicable control equipment requirements. The notification shall also describe the corrective actions which have been or will be taken to achieve compliance.
- 2. At any time following the notification required under 40 CFR 63.428 (j)(1), and prior to any of the parameters being exceeded, the permittee shall notify the Administrator of modifications to the facility parameters. Each such notification shall document any expected HAP emission change resulting from the change in parameter.

**E. Testing Requirements**

- 1. None

**F. Miscellaneous Requirements**

- 1. All requirements of 40 CFR 63.428 (j) shall be available for public inspection.

\*\*\*THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION\*\*\*

Facility ID: 1667050023 Emissions Unit ID: T006 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

**Part II - Special Terms and Conditions**

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

- 1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
  - (a) None.
- 2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
  - (a) None.

**A. Applicable Emissions Limitations and/or Control Requirements**

- 1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
External floating roof tank	OAC rule 3745-21-09(Z)	See A.2.a below.

**2. Additional Terms and Conditions**

- (a) The welded external floating roof storage tank, equipped with a mechanical shoe primary seal and a rim-mounted secondary seal, shall meet the following requirements:
  - i. There shall be no visible holes, tears, or other openings in the seal or seal fabric.

ii. For the primary seal, the total seal gap area shall not exceed 10.0 square inches per foot of tank diameter.

iii. For the secondary seal, the total seal gap area shall not exceed 1.0 square inch per foot of tank diameter.

**B. Operational Restrictions**

1. The external floating roof tank shall be maintained using the following control measures:
  - a. Any opening in the external floating roof, except automatic bleeder vents, rim space vents, leg sleeves, stub drains, and slotted gauging/sampling wells shall be equipped with:
    - i. a cover, seal, or lid which remains in the closed position at all times without any visible gaps, except when the opening is in actual use; and
    - ii. a projection into the tank below the liquid surface.
  - b. Any automatic bleeder vent shall remain in the closed position, except when the external floating roof is floated off or landed on the roof leg supports.
  - c. Any rim vent shall be set to open at the manufacturers recommended setting, except when the external floating roof is being floated off the roof leg supports.
  - d. Any emergency roof drain shall be equipped with a slotted membrane fabric cover or other device which covers at least 90 percent of the area of the opening.
  - e. Any stub drain shall be equipped with a projection into the tank below the liquid surface.
  - f. Any slotted gauging/sampling well shall be equipped with an object which floats on the liquid surface within the well and which covers at least 90 percent of the area of the well opening.
2. The permittee shall operate the facility such that none of the facility parameters used to calculate results under paragraph (a)(1) or (b)(1) of 40 CFR 63.420 is exceeded in any rolling, 30-day period.

**C. Monitoring and/or Record Keeping Requirements**

1. The seals of the external floating roof tank shall be inspected as follows:
  - a. The seal and seal fabric shall be inspected annually for visible holes, tears, or other openings.
  - b. The secondary seal gap shall be measured annually, in accordance with the method specified in paragraph (l) of OAC rule 3745-21-10.
  - c. The primary seal gap shall be measured at least once every 5 years, in accordance with the method specified in paragraph (l) of OAC rule 3745-21-10.
2. The permittee shall maintain records of the following information for at least two years:
  - a. the dates and results of each seal and seal fabric inspection and each seal gap measurement; and
  - b. the annual throughput of each petroleum liquid stored in the tank.

A copy of these records shall be made available to the director or an authorized representative of the director upon written or verbal request.
3. The permittee shall maintain records of the following information for at least five years:
  - a. the types of petroleum liquids stored in the tank; and
  - b. the maximum true vapor pressure (in pounds per square inch absolute), as stored, of each liquid.

A copy of these records shall be made available to the director or an authorized representative of the director upon written or verbal request.
4. The permittee shall maintain a record of the calculations in 40 CFR 63.420 (a)(1) or (b)(1), including methods, procedures, and assumptions supporting the calculations for determining criteria in 40 CFR 63.420(d).

**D. Reporting Requirements**

1. The permittee shall notify the director (the appropriate Ohio EPA District Office or local air agency) within 30 days of any seal and seal fabric inspection or any seal gap measurement, which documents a violation of the applicable control equipment requirements. The notification shall also describe the corrective actions which have been or will be taken to achieve compliance.
2. At any time following the notification required under 40 CFR 63.428 (j)(1), and prior to any of the parameters being exceeded, the permittee shall notify the Administrator of modifications to the facility parameters. Each such notification shall document any expected HAP emission change resulting from the change in parameter.

**E. Testing Requirements**

1. None

**F. Miscellaneous Requirements**

1. All requirements of 40 CFR 63.428 (j) shall be available for public inspection.