

Facility ID: 1677150003 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

[Go to Part II for Emissions Unit T001](#)

[Go to Part II for Emissions Unit T003](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 1677150003 Emissions Unit ID: T001 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
17,000 BBL external floating roof tank with a geodesic dome.	OAC rule 3745-21-09(L)	See B.1 below.

2. Additional Terms and Conditions

- (a) None

B. Operational Restrictions

1. The permittee shall install the following control equipment and shall maintain tank vents, seals, and or covers as follows:
 - a. The fixed roof storage tank shall be equipped with an internal floating roof.
 - b. The automatic bleeder vents shall be closed at all times except when the roof is floated off or landed on the roof leg supports.
 - c. The rim vents, if present, shall be set to open or at the manufacturer's recommended setting when the roof is being floated off the roof leg supports.
 - d. All openings, except stub drains, shall be equipped with a cover, seal, or lid which is to be in a closed position at all times except when in actual use for tank gauging or sampling.

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain records of the following information for the fixed roof tank:
 - a. the types of petroleum liquids stored in the tank; and
 - b. the maximum true vapor pressure (in pounds per square inch absolute), as stored, of each petroleum liquid that has a maximum true vapor pressure greater than 1.0 pound per square inch absolute.

These records shall be maintained for at least 5 years and shall be made available to the director or his representative upon verbal or written request.

D. Reporting Requirements

1. The permittee shall notify the director (the appropriate Ohio EPA District Office or local air agency) within 30 days of the occurrence, of any period of time in which the automatic bleeder vents, rim vents, and all openings other than stub drains were not maintained as required in this permit.

E. Testing Requirements

1. None

F. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 1677150003 Emissions Unit ID: T003 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
17,000 BBL external floating roof tank with a geodesic dome.	OAC rule 3745-21-09(L)	See B.1 below.

2. **Additional Terms and Conditions**
 - (a) None

B. Operational Restrictions

1. The permittee shall equip the tank with the following control equipment and shall maintain tank vents, seals, and or covers as follows:
 - a. The fixed roof storage tank shall be equipped with an internal floating roof.
 - b. The automatic bleeder vents shall be closed at all times except when the roof is floated off or landed on the roof leg supports.
 - c. The rim vents, if present, shall be set to open or at the manufacturer's recommended setting when the roof is being floated off the roof leg supports.
 - d. All openings, except stub drains, shall be equipped with a cover, seal, or lid which is to be in a closed position at all times except when in actual use for tank gauging or sampling.

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall maintain records of the following information for the fixed roof tank:
 - a. the types of petroleum liquids stored in the tank; and
 - b. the maximum true vapor pressure (in pounds per square inch absolute), as stored, of each petroleum liquid that has a maximum true vapor pressure greater than 1.0 pound per square inch absolute.

These records shall be maintained for at least 5 years and shall be made available to the director or his representative upon verbal or written request.

D. Reporting Requirements

1. The permittee shall notify the director (the appropriate Ohio EPA District Office or local air agency) within 30 days of the occurrence, of any period of time in which the automatic bleeder vents, rim vents, and all openings other than stub drains were not maintained as required in this permit.

E. Testing Requirements

1. None

F. Miscellaneous Requirements

1. None