



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

8/19/2008

RANDY MEYER
OMEGA JV1
c/o AMP Ohio
2600 AIRPORT RD
Columbus, OH 43219

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL AND OPERATE
Facility ID: 1677050142
Permit Number: P0103253
Permit Type: Renewal
County: Summit

Certified Mail

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR
No	CEMS
No	MACT
No	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install and Operate ("PTIO") which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully.

Ohio EPA maintains a document entitled "Frequently Asked Questions about the PTIO". The document can be downloaded from the DAPC Web page, www.epa.state.oh.us/dapc, from the "Permits" link. This document contains additional information related to your permit, such as what activities are covered under the PTIO, who has enforcement authority over the permit and Ohio EPA's authorization to inspect your facility and records. Please contact the Office of Compliance Assistance and Pollution Prevention at (614) 644-3469 if you need assistance.

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission ("ERAC") under Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and describe the action complained of and the grounds for the appeal. The appeal must be filed with the ERAC within thirty (30) days after notice of the Director's action. A filing fee of \$70.00 must be submitted to the ERAC with the appeal, although the ERAC, has discretion to reduce the amount of the filing fee if you can demonstrate (by affidavit) that payment of the full amount of the fee would cause extreme hardship. If you file an appeal of this action, you must notify Ohio EPA of the filing of the appeal (by providing a copy to the Director) within three (3) days of filing your appeal with the ERAC. Ohio EPA requests that a copy of the appeal also be provided to the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the ERAC at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

If you have any questions regarding this permit, please contact the Akron Regional Air Quality Management District. This permit has been posted to the Division of Air Pollution Control (DAPC) Web page www.epa.state.oh.us/dapc.

Sincerely,


Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: ARAQMD

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



**State of Ohio Environmental Protection Agency
Division of Air Pollution Control**

FINAL

**Air Pollution Permit-to-Install and Operate
for
OMEGA JV1**

Facility ID: 1677050142
Permit Number: P0103253
Permit Type: Renewal
Issued: 8/19/2008
Effective: 8/19/2008
Expiration: 8/19/2013



Air Pollution Permit-to-Install and Operate
for
OMEGA JV1

Table of Contents

Authorization 1

A. Standard Terms and Conditions 3

 1. What does this permit-to-install and operate ("PTIO") allow me to do?..... 4

 2. Who is responsible for complying with this permit? 4

 3. What records must I keep under this permit? 4

 4. What are my permit fees and when do I pay them?..... 4

 5. When does my PTIO expire, and when do I need to submit my renewal application? 4

 6. What happens to this permit if my project is delayed or I do not install or modify my source? 5

 7. What reports must I submit under this permit? 5

 8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit? 5

 9. What are my obligations when I perform scheduled maintenance on air pollution control equipment? ... 5

 10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report? 6

 11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located? 6

 12. What happens if one or more emissions units operated under this permit is/are shut down permanently? 6

 13. Can I transfer this permit to a new owner or operator?..... 6

 14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"? 7

 15. What happens if a portion of this permit is determined to be invalid? 7

B. Facility-Wide Terms and Conditions..... 8

C. Emissions Unit Terms and Conditions 10

 1. B001, Engine No. 1 11

 2. B002, Engine No. 2 16

 3. B003, Engine No. 3 21

 4. B004, Engine No. 4 26

 5. B005, Engine No. 5 31

 6. B006, Engine No. 6 36



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate
Permit Number: P0103253
Facility ID: 1677050142
Effective Date: 8/19/2008

Authorization

Facility ID: 1677050142
Application Number(s): A0035129
Permit Number: P0103253
Permit Description: Final Issue FEPTIO for the operation of Six diesel fired internal combustion engines powering 1500 KW generators
Permit Type: Renewal
Permit Fee: \$0.00
Issue Date: 8/19/2008
Effective Date: 8/19/2008
Expiration Date: 8/19/2013
Permit Evaluation Report (PER) Annual Date: Feb 15, for Jan 1 - Dec 31
This document constitutes issuance to:

OMEGA JV1
2550 Bailey Rd
Cuyahoga Falls, OH 44221

of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page.

Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Akron Regional Air Quality Management District
146 South High Street, Room 904
Akron, OH 44308
(330)375-2480

The above named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director



Authorization (continued)

Permit Number: P0103253
 Permit Description: Final Issue FEPTIO for the operation of Six diesel fired internal combustion engines powering 1500 KW generators

Permits for the following emissions unit(s) or groups of emissions units are in this document as indicated below:

Emissions Unit ID:	B001
Company Equipment ID:	Engine No. 1
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B002
Company Equipment ID:	Engine No. 2
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B003
Company Equipment ID:	Engine No. 3
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B004
Company Equipment ID:	Engine No. 4
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B005
Company Equipment ID:	Engine No. 5
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B006
Company Equipment ID:	Engine No. 6
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

A. Standard Terms and Conditions



1. What does this permit-to-install and operate ("PTIO") allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

- PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11, or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

- Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is very important that you submit a complete renewal permit application (postmarked prior to expiration of this permit) even if you do not receive the renewal notice.



If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended by up to 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective, and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.



10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the Akron Regional Air Quality Management District in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction, but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, you must follow the procedures in OAC Chapter 3745-31, including notifying Ohio EPA or the local air agency of the



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

change in ownership or operator. Any transferee of this permit must assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

B. Facility-Wide Terms and Conditions



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (1) None.
 - b) For the purpose of a permit-to-operate document, the facility-wide terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (1) None.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

C. Emissions Unit Terms and Conditions



1. B001, Engine No. 1

Operations, Property and/or Equipment Description:

Unit 1 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

- (1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):
- a. Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.
 - b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .
 - b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.
 - c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.
 - d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.



If required, the permittee shall demonstrate compliance with the hourly allowable NOx emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the AToxic Air Contaminant Statute^g, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit=s maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.



2. B002, Engine No. 2

Operations, Property and/or Equipment Description:

Unit 2 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

- (1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):
- a. Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.
 - b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .
 - b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.
 - c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.
 - d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.



If required, the permittee shall demonstrate compliance with the hourly allowable NOx emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the AToxic Air Contaminant Statute^e, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit=s maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.



3. B003, Engine No. 3

Operations, Property and/or Equipment Description:

Unit 3 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

(1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):

a. Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.

b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .

b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.

c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.

d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

If required, the permittee shall demonstrate compliance with the hourly allowable NOx emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the AToxic Air Contaminant Statute^g, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit=s maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.



4. B004, Engine No. 4

Operations, Property and/or Equipment Description:

Unit 4 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

- (1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):

Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.

- b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .

- b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.

- c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.

- d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.

If required, the permittee shall demonstrate compliance with the hourly allowable NO_x emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the AToxic Air Contaminant Statute^e, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit's maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.



5. B005, Engine No. 5

Operations, Property and/or Equipment Description:

Unit 5 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

- (1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.

- b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .

- b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.

- c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.

- d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

If required, the permittee shall demonstrate compliance with the hourly allowable NOx emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the AToxic Air Contaminant Statute^g, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit's maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.



6. B006, Engine No. 6

Operations, Property and/or Equipment Description:

Unit 6 17.78 mmBtu/hr diesel generator

- a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - (1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - a. None.
 - (2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - a. None.
- b) Applicable Emissions Limitations and/or Control Requirements
 - (1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3) (PTI 16-00766)	Nitrogen oxides (NOx) emissions from this emissions unit shall not exceed 41.2 pounds NOx per hour. The requirements of OAC rule 3745-31-05(A)(3) also include compliance with the requirements of OAC rule 3745-31-05(D). Section b)(2).
b.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) from this emissions unit shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
c.	OAC rule 3745-17-11(B)(5)(b)	0.062 pound particulate emissions/million Btu actual heat input
d.	OAC rule 3745-18-06(G)	0.5 pound SO2 per million Btu actual heat input
e.	OAC rule 3745-21-08(B)	See b.2.b below.
f.	OAC rule 3745-31-05(D)	Facility-wide (emissions units B001 – B006, combined) NOx emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		monthly NOx emission rates.

(2) Additional Terms and Conditions

- a. The 41.2 pounds NOx/hour, 0.062 pound PE/million Btu, and 0.5 pound SO2/million emission limitations are equal to or greater than the potentials to emit for this emissions unit, as determined from the application. Therefore, no monitoring, record keeping, or reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- b. The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. On June 24, 2003, the rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP); however, until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

c) Operational Restrictions

The maximum annual number of hours of operation for the 6 generator units (emissions units B001 through B006), combined, shall not exceed 1200 hours, based upon a rolling, 12-month summation of the monthly aggregate operating number of hours of operation.

For each month, the monthly aggregate operating hours of B001 through B006 is calculated as:

$$M = H1 + H2 + H3 + H4 + H5 + H6,$$

Where:

M = the monthly aggregate operating hours for the generator units of B001 through B006 that ran each month; and

H1 = the hours B001 ran each month, and likewise, for each generator unit of B002 through B006.

The permittee shall have the right to operate any combination of generator units of B001 through B006, as long as the yearly aggregate operating hours of the 6 generator units do not exceed 1200 hours during any rolling, 12-month period.



d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall record the following information each month for emissions units B001 through B006, combined:
 - a. The number of hours of operation for each emissions unit.
 - b. The aggregate number of hours of operation.
 - c. The rolling, 12-month summation of the monthly aggregate number of hours of operation.
 - d. The NOx emissions (in tons) from each emissions unit.
 - e. The aggregate NOx emissions (in tons).
 - f. The rolling, 12-month summation of the monthly aggregate NOx emissions (in tons).

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify the following:
 - a. all exceedances of the rolling, 12-month restriction on the number of hours of operation (for emissions units B001 through B006, combined);
 - b. all exceedances of the rolling, 12-month NOx emission limitation (for emissions units B001 through B006, combined);
 - c. the probable cause of each deviation (excursion);
 - d. any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and
 - e. the magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted (postmarked) each year by the thirty-first of January (covering October to December), the thirtieth of April (covering January to March), the thirty-first of July (covering April to June), and the thirty-first of October (covering July to September), unless an alternative schedule has been established and approved by the director (the appropriate district office or local air agency).

- (2) Annual Permit Evaluation Report (PER) forms will be mailed to the permittee at the end of the reporting period specified in the Authorization section of this permit. The permittee shall submit the PER in the form and manner provided by the director by the due date identified in the Authorization section of this permit. The permit evaluation report shall cover a reporting period of no more than twelve-months for each air contaminant source identified in this permit.



f) Testing Requirements

- (1) Compliance with the emission limitation(s) in Section A.1. of these special terms and conditions shall be determined in accordance with the following method(s):

Emission Limitation: 0.062 pound PE/million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on the AP-42 emission factor of 0.062 lb PE/mmBtu of heat input (USEPA, AP-42, rev. 10/96, Table 3.4-2).

If required, the permittee shall demonstrate compliance by testing in accordance with OAC rule 3745-17-03(B)(10) and Methods 1- 5, 40 CFR Part 60, Appendix A.

- b. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with OAC rule 3745-17-03(B)(1) .

- b. Emission Limitation: 0.5 pound SO₂ per million Btu actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based on USEPA 's AP-42 emission factor of 0.2 lb SO₂/mmBtu of heat input (AP-42, rev. 10/96, Table 3.4-1) (based upon a diesel fuel sulfur content of 0.2%, by weight, as determined from the application)

If required, compliance with the emission limitation above shall be demonstrated based on the results of emission testing conducted in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 6.

- c. Emission Limitation: Facility-wide NO_x emissions shall not exceed 24.78 tons/year, based upon a rolling, 12-month summation of the monthly emissions

Applicable Compliance Method: The annual NO_x emission limitation was established by multiplying the annual number of hours of operation restriction of 1200 hours by the hourly allowable NO_x emission limitation of 41.2 lbs. Therefore, as long as compliance with the number of hours of operation and the hourly allowable emission limitation is maintained, compliance with the annual allowable NO_x emission limitation shall be ensured.

- d. Emission Limitation: 41.2 pounds NO_x per hour

Applicable Compliance Method: The NO_x emission limitation above is equal to the emissions unit's potential to emit per the manufacturer's emissions data, as determined from the application.

If required, the permittee shall demonstrate compliance with the hourly allowable NO_x emissions in accordance with 40 CFR Part 60, Appendix A, Methods 1 – 4 and 7E.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0103253

Facility ID: 1677050142

Effective Date: 8/19/2008

g) Miscellaneous Requirements

- (1) Modeling to demonstrate compliance with, the toxic Air Contaminant Statute, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit's maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.