State of Ohio Environmental Protection Agency

STREET ADDRESS:
Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:
P.O. Box 1049
Columbus, OH 43216-1049

4/23/2009

Pamela Blakley *Via E-Mail Notification*
United States Environmental Protection Agency
Mail Code: AR-18J
77 West Jackson Blvd.
Chicago, IL 60604-3507

RE: PROPOSED AIR POLLUTION TITLE V PERMIT
Facility Name: SHELBY MUNICIPAL LIGHT PLANT
Facility ID: 0370020002
Permit Type: Renewal
Permit Number: P0087588

Dear Ms. Blakley:

A proposed OAC Chapter 3745-77 Title V permit for the referenced facility has been issued for review by U.S. EPA. This permit has been posted to the Division of Air Pollution Control (DAPC) Web page http://www.epa.state.oh.us/dapc in Microsoft Word and Adobe Acrobat format. If U.S. EPA does not object to this proposed permit, the permit will be processed for issuance as a final action not less than 45 days from the date of this letter. Please contact me at (614) 644-3631 by the end of the 45 day review period if you wish to object to the proposed permit.

Sincerely,

Michael W. Ahern

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: Ohio EPA DAPC, Northwest District Office

State of Ohio Environmental Protection Agency
Division of Air Pollution Control

PROPOSED

Air Pollution Title V Permit
for
SHELBY MUNICIPAL LIGHT PLANT

Facility ID: 0370020002
Permit Number: P0087588
Permit Type: Renewal
Issued: 4/23/2009
Effective: To be entered upon final issuance
Expiration: To be entered upon final issuance

State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Air Pollution Title V Permit
for
SHELBY MUNICIPAL LIGHT PLANT

Table of Contents

Authorization 1
A. Standard Terms and Conditions 2
1. Federally Enforceable Standard Terms and Conditions 3
2. Monitoring and Related Record Keeping and Reporting Requirements 3
3. Scheduled Maintenance 6
4. Risk Management Plans 6
5. Title IV Provisions 6
6. Severability Clause 7
7. General Requirements 7
8. Fees 8
9. Marketable Permit Programs 8
10. Reasonably Anticipated Operating Scenarios 8
11. Reopening for Cause 8
12. Federal and State Enforceability 9
13. Compliance Requirements 9
14. Permit Shield 10
15. Operational Flexibility 10
16. Emergencies 11
17. Off-Permit Changes 11
18. Compliance Method Requirements 12
19. Insignificant Activities or Emissions Levels 12
20. Permit to Install Requirement 12
21. Air Pollution Nuisance 12
22. Permanent Shutdown of an Emissions Unit 12
23. Title VI Provisions 13
24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only 13
25. Records Retention Requirements Under State Law Only 13
26. Inspections and Information Requests 13
27. Scheduled Maintenance/Malfunction Reporting 14
28. Permit Transfers 14

29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 14

B. Facility-Wide Terms and Conditions..... 15

C. Emissions Unit Terms and Conditions 17

1. P002, Dual Fuel Generator 18

2. Emissions Unit Group - Group 1: B006, B007, B008, ... 20

Authorization

Facility ID: 0370020002
Facility Description:
Application Number(s): A0018593, A0018594
Permit Number: P0087588
Permit Description: Renewal Title V Permit for an Electric Services Operation
Permit Type: Renewal
Issue Date: 4/23/2009
Effective Date: To be entered upon final issuance
Expiration Date: To be entered upon final issuance
Superseded Permit Number: P0087587

This document constitutes issuance of an OAC Chapter 3745-77 Title V permit to:

SHELBY MUNICIPAL LIGHT PLANT
34 Mansfield Ave.
P. O. Box 311
Shelby, OH 44875-0311

Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402
(419)352-8461

The above named entity is hereby granted a Title V permit pursuant to Chapter 3745-77 of the Ohio Administrative Code. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. You will be sent a notice approximately 18 months prior to the expiration date regarding the renewal of this permit. If you do not receive a notice, please contact the Ohio EPA DAPC, Northwest District Office. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, if a timely renewal application is submitted. A renewal application will be considered timely if it is submitted no earlier than 18 months (540 days) and no later than 6 months (180 days) prior to the expiration date.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director

A. Standard Terms and Conditions

1. Federally Enforceable Standard Terms and Conditions

a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:

(1) Standard Term and Condition A. 24., Reporting Requirements Related to Monitoring and Record Keeping Requirements of State-Only Enforceable Permit Terms and Conditions

(2) Standard Term and Condition A. 25., Records Retention Requirements for State-Only Enforceable Permit Terms and Conditions

(3) Standard Term and Condition A. 27., Scheduled Maintenance/Malfunction Reporting

(4) Standard Term and Condition A. 29., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
(Authority for term: ORC 3704.036(A))

2. Monitoring and Related Record Keeping and Reporting Requirements

a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit), the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

(1) The date, place (as defined in the permit), and time of sampling or measurements.

(2) The date(s) analyses were performed.

(3) The company or entity that performed the analyses.

(4) The analytical techniques or methods used.

(5) The results of such analyses.

(6) The operating conditions existing at the time of sampling or measurement.
(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))

b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))

c) The permittee shall submit required reports in the following manner:

(1) All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:

Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year in accordance with Standard Term and Condition A.2.c)(2) below; and each report shall cover the previous calendar quarter. An exceedance of the visible emission limitations specified in OAC rule 3745-17-07(A)(1) that is caused by a malfunction is not a violation and does not need to be reported as a deviation if the owner or operator of the affected air contaminant source or air pollution control equipment complies with the requirements of OAC rule 3745-17-07(A)(3)(c).

In accordance with OAC rule 3745-15-06, a malfunction reportable under OAC rule 3745-15-06(B) constitutes a violation of an emission limitation (or control requirement) and, therefore, is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any scheduled maintenance, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

(2) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit or, in some cases, in section B. Facility-Wide Terms and Conditions of this Title V permit), all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as provided below, the written reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.

These written deviation reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. Full compliance with OAC rule 3745-77-07(A)(3)(c) requires reporting of all other deviations of the federally enforceable requirements specified in the permit as required by such rule.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement satisfies the reporting requirements specified in this Standard Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy (for the deviations so reported) the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this Standard Term and Condition.

See A.29 below if no deviations occurred during the quarter.
(Authority for term: OAC rule 3745-77-07(A)(3)(c))

(3) All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not reported in accordance with Standard Term and Condition A.2)c)(2) above shall be submitted in the following manner:

Unless otherwise specified by rule, written reports that identify deviations of the following federally enforceable requirements contained in this permit; Standard Terms and Conditions: A.3, A.4, A.5, A.7.e), A.8, A.13, A.15, A.19, A.20, A.21, and A.23 of this Title V permit, as well as any deviations from the requirements in section C. Emissions Unit Terms and Conditions of this Title V permit, and any monitoring, record keeping, and reporting requirements, which are not reported in accordance with Standard Term and Condition A.2.c)(2) above shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months. Unless otherwise specified by rule, all other deviations from federally enforceable requirements identified in this permit shall be submitted annually as part of the annual compliance certification, including deviations of federally enforceable requirements not specifically addressed by permit or rule for the insignificant activities or emissions levels (IEU) identified in section B. Facility-Wide Terms and Conditions of this Title V permit. Annual reporting of deviations is deemed adequate to meet the deviation reporting requirements for IEUs unless otherwise specified by permit or rule.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual and annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with Standard Term and Condition A.2.c)(2) above.

If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.
(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii) and OAC rule 3745-77-07(A)(13)(b))

(4) Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."
(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))

(5) Reports of any required monitoring and/or record keeping information shall be submitted to Ohio EPA DAPC, Northwest District Office.
(Authority for term: OAC rule 3745-77-07(A)(3)(c))

3. Scheduled Maintenance

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in Standard Term and Condition A.2.c)(1) above.
(Authority for term: OAC rule 3745-77-07(A)(3)(c))

4. Risk Management Plans

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

a) a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or

b) as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

(Authority for term: OAC rule 3745-77-07(A)(4))

5. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.
(Authority for term: OAC rule 3745-77-07(A)(5))

6. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
(Authority for term: OAC rule 3745-77-07(A)(6))

7. General Requirements

a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.

b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.

c) This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with Standard Term and Condition A.11 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.

d) This permit does not convey any property rights of any sort, or any exclusive privilege.

e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

f) Except as otherwise indicated below, this Title V permit, or permit modification, is effective for five years from the original effective date specified in the permit. In the event that this facility becomes eligible for non-title V permits, this permit shall cease to be enforceable when:

(1) the permittee submits an approved facility-wide potential to emit analysis supporting a claim that the facility no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on the permanent shutdown and removal of one or more emissions units identified in this permit; or

(2) the permittee no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on obtaining restrictions on the facility-wide potential(s) to emit that are federally enforceable or legally and practically enforceable ; or

(3) a combination of (1) and (2) above.

The permittee shall continue to comply with all applicable OAC Chapter 3745-31 requirements for all regulated air contaminent sources once this permit ceases to be enforceable. The permittee

shall comply with any residual requirements, such as quarterly deviation reports, semi-annual deviation reports, and annual compliance certifications covering the period during which this Title V permit was enforceable. All records relating to this permit must be maintained in accordance with law.
(Authority for term: OAC rule 3745-77-01(W), OAC rule 3745-77-07(A)(3)(b)(ii), OAC rule 3745-77(A)(7))

8. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.
(Authority for term: OAC rule 3745-77-07(A)(8))

9. Marketable Permit Programs

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.
(Authority for term: OAC rule 3745-77-07(A)(9))

10. Reasonably Anticipated Operating Scenarios

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these standard terms and conditions shall apply to all operating scenarios authorized in this permit.
(Authority for term: OAC rule 3745-77-07(A)(10))

11. Reopening for Cause

This Title V permit will be reopened prior to its expiration date under the following conditions:

a) Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.

b) This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.

c) The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.

d) The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))

12. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

(Authority for term: OAC rule 3745-77-07(B))

13. Compliance Requirements

a) Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.

b) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:

(1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.

(2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.

(3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

(4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.

c) The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:

(1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.

(2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

d) Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the

Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:

(1) Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted (i.e., postmarked) on or before April 30th of each year during the permit term.

(2) Compliance certifications shall include the following:

(a) An identification of each term or condition of this permit that is the basis of the certification.

(b) The permittee's current compliance status.

(c) Whether compliance was continuous or intermittent.

(d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.

(e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.

(3) Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.
(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))

14. Permit Shield

a) Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.

b) This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

(Authority for term: OAC rule 3745-77-07(F))

15. Operational Flexibility

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as

soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).
(Authority for term: OAC rules 3745-77-07(H)(1) and (2))

16. Emergencies

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.
(Authority for term: OAC rule 3745-77-07(G))

17. Off-Permit Changes

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

a) The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.

b) The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emissions levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.

c) The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).

d) The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.

e) The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit-to-install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.
(Authority for term: OAC rule 3745-77-07(I))

18. Compliance Method Requirements

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.
(This term is provided for informational purposes only.)

19. Insignificant Activities or Emissions Levels

Each IEU that has one or more applicable requirements shall comply with those applicable requirements.
(Authority for term: OAC rule 3745-77-07(A)(1))

20. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.
(Authority for term: OAC rule 3745-77-07(A)(1))

21. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.
(Authority for term: OAC rule 3745-77-07(A)(1))

22. Permanent Shutdown of an Emissions Unit

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification from the responsible official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the responsible official that the emissions unit was permanently shut down.

After the date on which an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an "emissions unit" as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the certification and submission to Ohio EPA, to meet any Title V permit requirements applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

No emissions unit certified by the responsible official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.
(Authority for term: OAC rule 3745-77-01)

23. Title VI Provisions

If applicable, the permittee shall comply with the standards for recycling and reducing emissions of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:

a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices specified in 40 CFR 82.156.

b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment specified in 40 CFR 82.158.

c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.

(Authority for term: OAC rule 3745-77-01(H)(11))

24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only

The permittee shall submit required reports in the following manner:

a) Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.

b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

25. Records Retention Requirements Under State Law Only

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

26. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports

pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.
(Authority for term: OAC rule 3745-77-07(C))

27. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

28. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.
(Authority for term: OAC rule 3745-77-01(C))

29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

a) where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in Standard Term and Condition A.2.c)(2); or

b) where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potentials to emit; or

c) where the company's responsible official has certified that an emissions unit has been permanently shut down.

B. Facility-Wide Terms and Conditions

1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:

   a) 2.

2. The following insignificant emissions units are exempt from permit requirements because they are not subject to any applicable requirements or because they meet the "de minimis" criteria established in OAC rule 3745-15-05:

   a) F001 – Roadway Fugitive Dust Emissions

   b) F002 – Coal Storage and Handling

   c) P003 – Maintenance Welding

   d) P901 – Ash Silo Loadout

   e) T001 – Diesel Fuel Storage Tank

C. Emissions Unit Terms and Conditions

1. P002, Dual Fuel Generator

Operations, Property and/or Equipment Description:

Dual Fuel Generator

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
b.	OAC rule 3745-17-11(B)(5)(b)	0.062 lb PE/mmBtu of actual heat input
c.	OAC rule 3745-18-06(G)	See b)(2)a.
d.	40 CFR, Part 63, Subpart ZZZZ (40 CFR 63.6580-6675) [In accordance with 40 CFR 63.6590 (a)(1)(i), this emissions unit is an existing stationary reciprocating internal combustion engine with a site rating of more than 500 brake HP.]	See b)(2)b.

(2) Additional Terms and Conditions

a. Since the rated heat input capacity for this emissions unit is less than 10 mmBtu/hr, this emissions unit is exempt from the sulfur dioxide emission limitation in OAC rule 3745-18-06(G), pursuant to OAC rule 3745-18-06(B).

b. This emission unit does not have to meet the requirement of this subpart and of subpart A in accordance with 40 CFR 63.6590(b)(3) because it is an existing spark ignition 4 stroke lean burn (4SLB) stationary reciprocating internal combustion engine (RICE) with a site rating of more than 500 brake horsepower at a major source. In addition, no initial notification is required.

c) Operational Restrictions

(1) The permittee shall burn only natural gas and/or no. 2 fuel oil in this emissions unit.

[OAC rule 3745-77-07(A)(1)]

d) Monitoring and/or Recordkeeping Requirements

(1) For each day during which the permittee burns a fuel other than natural gas and/or no. 2 fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[OAC rule 3745-77-07(C)(1)]

e) Reporting Requirements

(1) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than no. 2 fuel oil and/or natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[OAC rule 3745-77-07(C)(1)]

f) Testing Requirements

(1) Compliance with the emission limitations in Section b)(1) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[OAC rule 3745-77-07(C)(1)]

b. Emission Limitation: 0.062 lb PE/mmBtu of actual heat input

Applicable Compliance Method: The permittee may determine be based upon the emission factor of 0.062 lb PE/mmBtu (AP-42, Fifth Edition, Section 3.4, Table 3.4-2).

If required, the permittee shall demonstrate compliance with the PE limitation above in accordance with Methods in OAC rule 3745-17-03(B)(10).

[OAC rule 3745-77-07(C)(1)]

g) Miscellaneous Requirements

(1) None.

2. Emissions Unit Group - Group 1: B006, B007, B008,

EU ID	Operations, Property and/or Equipment Description
B006	223.3 MMBtu Coal Fired Boiler #1
B007	228.0 MMBtu Coal Fired Boiler #2
B008	133.0 MMBtu Coal Fired Boiler #4

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-17-07(A)	Visible particulate emissions (PE) shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
b.	OAC rule 3745-17-10(C)(1)	0.12 pound of PE per mmBtu of actual heat input
c.	OAC rule 3745-18-76(G)	8.1 pounds of sulfur dioxide (SO_2) per mmBtu of actual heat input
d.	40 CFR Part 63.52(a)(2)	See b)(2)a.
e.	40 CFR, Part 64 – Compliance Assurance Monitoring (CAM)	See d)(1), d)(2), e)(1), e)(2) and g)(1)

(2) Additional Terms and Conditions

a. This emissions unit is subject to a case-by-case MACT determination pursuant to section 112(j) of the Clean Air Act (CAA) due to the June 8, 2007 D.C. Circuit Court of Appeals decision to vacate the Boiler MACT (40 CFR Part 63, Subpart DDDDD).

If notified by the Ohio EPA or U.S. EPA, the permittee shall submit an application for a revision to this Title V permit that meets the requirements of 40 CFR 63.52(a)(2) pertaining to case-by-case MACT determinations. The 30-day clock for submittal of a 112(j) application does not begin until such notification is made by Ohio EPA or U.S. EPA.

c) Operational Restrictions

(1) The permittee shall operate the ESP during any operation of this emissions unit, except during periods of start-up and shutdown that are exempted pursuant to OAC rules 3745-

17-07(A)(3)(a)(i) and 3745-17-07(A)(3)(b)(i), or during malfunctions that are exempted pursuant to OAC rule 3745-17-07(A)(3)(c).

[OAC rule 3745-77-07(A)(1)]

(2) The coal received for burning in this emissions unit shall have a sulfur content that, when calculated in terms of pounds of sulfur dioxide per million Btu of heat content, complies with the allowable sulfur dioxide emission limitation of 8.1 pounds SO_2 per mmBtu of actual heat input contained in this permit.

[OAC rule 3745-77-07(A)(1)]

d) Monitoring and/or Recordkeeping Requirements

(1) The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR, Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR, Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

The opacity monitoring requirements specified in 40 CFR sections 63.7525(b) and 63.7535 will replace the monitoring requirements of 40 CFR Part 64, and therefore, this provision will no longer apply after the compliance date in 40 CFR Part 63, Subpart DDDDD.

[OAC rule 3745-77-07(C)(1) and 40 CFR, Part 64]

(2) The CAM plan for this emissions unit has been developed for particulate emissions. The CAM performance indicator for particulate emissions, until the compliance date in 40 CFR Part 63, Subpart DDDDD, shall be the opacity of the visible particulate emissions from the electrostatic precipitator exhaust stack.

Stack opacity shall be measured and recorded by the certified continuous opacity monitoring (COM) system. The visible particulate emissions indicator range is each six-minute block average with an opacity value greater than 15%. When the opacity value is greater than 15%, corrective action (including, but not limited to, an evaluation of the emissions unit and electrostatic precipitator) will be required.

When the opacity exceeds 15% for more than six consecutive minutes, additional corrective action focused on the ESP will be required. When opacity exceeds 15% for

more than six consecutive minutes, corrective action focused on the emissions unit will be required.

Upon detecting an excursion of the visible particulate emission value above 15% opacity, the permittee shall restore operation of the emissions unit (including the control device) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion. Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as thorough response by the computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range.

If a determination is made by the Administrator or Ohio EPA that the permittee has not used acceptable procedures in response to an excursion or exceedance based on the results of a determination made under 40 CFR Part 64.7(d)(2), the permittee may be required to develop a Quality Improvement Plan (QIP) consistent with the requirements of 40 CFR Part 64.8.

The opacity monitoring requirements specified in 40 CFR sections 63.7525(b) and 63.7535 will replace the monitoring requirements of 40 CFR Part 64, and therefore, this provision will no longer apply after the compliance date in 40 CFR Part 63, Subpart DDDDD.

[OAC rule 3745-77-07(C)(1) and 40 CFR, Part 64]

(3) To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

[OAC rules 3745-77-07(C)(1), 3745-17-07(A)(3)(a)(i) and 3745-17-07(A)(3)(b)(i)]

(4) The permittee shall collect representative grab samples of the coal burned in this emissions unit on a frequency of once per shift. Each sample shall be collected from the feeder belt. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal. At the end of each calendar month, all of the grab samples which were collected during that calendar month shall be combined into one composite sample.

Each monthly composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods to

be used to determine the ash content, sulfur content, and heat content shall be the most recent version of: ASTM method D3174, Standard Test Method for Ash in the Analysis Sample of Coal and Coke from Coal; ASTM method D3177, Standard Test Methods for Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Standard Test Methods for Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D5865 Standard Test Method for Gross Calorific Value of Coal and Coke, respectively. Alternative, equivalent methods may be used upon written approval from the appropriate Ohio EPA District Office or local air agency.

[OAC rule 3745-77-07(C)(1)]

(5) The permittee shall maintain records of the total quantity of coal received, the results of the analyses for ash content, sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu) for each calendar month.

[OAC rule 3745-77-07(C)(1)]

e) Reporting Requirements

(1) The permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the Director (the appropriate Ohio EPA District Office or local air agency) documenting any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit, control equipment, and/or monitoring system malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

[OAC rule 3745-77-07(C)(1) and 40 CFR, Part 64]

(2) If the results of the predictive model indicate that the particulate emission limitation may have been exceeded, the permittee shall submit the results of the predictive modeling and document any corrective action taken to restore operation of the emissions unit to its

normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The reports shall be submitted in accordance with the Standard Term and Conditions of this permit.

[OAC rule 3745-77-07(C)(1) and 40 CFR, Part 64]

(3) Quarterly reports shall be submitted concerning the quality and quantity of the coal burned in this emissions unit. These reports shall include the following information for the emissions unit for each calendar month during the calendar quarter:

a. the total quantity of coal burned (tons);

b. the average ash content (percent) of the coal burned;

c. the average sulfur content (percent) of the coal burned;

d. the average heat content (Btu/pound) of the coal burned; and

e. the average SO_2 emission rate (pounds SO_2/mmBtu actual heat input) from the coal burned.

The reports containing this information shall be submitted on a quarterly basis within 30 days following the end of each calendar quarter to Ohio EPA, Northwest District Office.

[OAC rule 3745-77-07(C)(1)]

f) Testing Requirements

(1) The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

a. The emission testing shall be conducted approximately 2.5 years after permit issuance. The testing time frame(s) specified may be amended or waived for cause upon prior request of, or written approval of, the Ohio EPA, Northwest District Office.

b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rate for PE (0.12 pound of PE per mmBtu of actual heat input).

c. The following test methods shall be employed to demonstrate compliance with the allowable mass emission rate: for PE, Methods 1 through 5 of 40 CFR, Part 60, Appendix A.

d. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Director (the appropriate Ohio EPA District Office or local air agency).

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to

submit such notification for review and approval prior to the test(s) may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emission test(s).

Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

[OAC rule 3745-77-07(C)(1)]

(2) Compliance with the emission limitations in Section b)(1) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitation: Visible PE shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.

Applicable Compliance Method: If required, the permittee shall demonstrate compliance with the visible PE limitation above in accordance with the methods specified in OAC rule 3745-17-03(B)(1).

[OAC rule 3745-77-07(C)(1)]

b. Emission Limitation: 0.12 pound of PE per mmBtu of actual heat input

Applicable Compliance Method: The permittee shall demonstrate compliance with the emission limitation above based upon the results of emission testing conducted in accordance with Methods 1 through 5 of 40 CFR, Part 60 Appendix A [See f)(1)].

[OAC rule 3745-77-07(C)(1)]

c. Emission Limitation: 8.1 pounds SO_2 per mmBtu of actual heat input

Applicable Compliance Method: Compliance with this emission limitation shall be demonstrated through the record keeping requirements established in sections d)(4) and d)(5) of this permit.

If required, the permittee shall demonstrate compliance with the emission limitation above in accordance with the provisions of OAC rule 3745-18-04(D)(3).

[OAC rule 3745-77-07(C)(1)]

g) Miscellaneous Requirements

(1) The permittee shall maintain a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that sections 7.1.4, 7.4.1, 7.4.2, and Table 1-1 of Performance Specification 1 are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.

(2) [OAC rule 3745-15-04(C), OAC rule 3745-77-07(A)(3)(b) and 40 CFR, Part 64]