



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.state.oh.us

MAILING ADDRESS:

P.O. Box 1049
Columbus, OH 43216-1049

5/15/2009

Mr. GREG MOORE
MARATHON PETROLEUM CO LLC- LEBANON
539 South Main Street
TT&M HES&S - Office 6692
Findlay, OH 45840

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL AND OPERATE
Facility ID: 1483000170
Permit Number: P0104799
Permit Type: OAC Chapter 3745-31 Modification
County: Warren

Certified Mail

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR
No	CEMS
No	MACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install and Operate ("PTIO") which will allow you to install, modify, and/or operate the described emissions unit(s) in the manner indicated in the permit. Because this permit contains conditions and restrictions, please read it very carefully.

Ohio EPA maintains a document entitled "Frequently Asked Questions about the PTIO". The document can be downloaded from the DAPC Web page, www.epa.state.oh.us/dapc, from the "Permits" link. This document contains additional information related to your permit, such as what activities are covered under the PTIO, who has enforcement authority over the permit and Ohio EPA's authorization to inspect your facility and records. Please contact the Office of Compliance Assistance and Pollution Prevention at (614) 644-3469 if you need assistance.

The issuance of this PTIO is a final action of the Director and may be appealed to the Environmental Review Appeals Commission ("ERAC") under Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and describe the action complained of and the grounds for the appeal. The appeal must be filed with the ERAC within thirty (30) days after notice of the Director's action. A filing fee of \$70.00 must be submitted to the ERAC with the appeal, although the ERAC, has discretion to reduce the amount of the filing fee if you can demonstrate (by affidavit) that payment of the full amount of the fee would cause extreme hardship. If you file an appeal of this action, you must notify Ohio EPA of the filing of the appeal (by providing a copy to the Director) within three (3) days of filing your appeal with the ERAC. Ohio EPA requests that a copy of the appeal also be provided to the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the ERAC at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

If you have any questions regarding this permit, please contact the Hamilton County Dept. of Environmental Services. This permit has been posted to the Division of Air Pollution Control (DAPC) Web page www.epa.state.oh.us/dapc.

Sincerely,


Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: HCDOES

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director



**State of Ohio Environmental Protection Agency
Division of Air Pollution Control**

FINAL

**Air Pollution Permit-to-Install and Operate
for
MARATHON PETROLEUM CO LLC- LEBANON**

Facility ID: 1483000170
Permit Number: P0104799
Permit Type: OAC Chapter 3745-31 Modification
Issued: 5/15/2009
Effective: 5/15/2009
Expiration: 5/15/2019



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Air Pollution Permit-to-Install and Operate
for
MARATHON PETROLEUM CO LLC- LEBANON

Table of Contents

Authorization 1

A. Standard Terms and Conditions 3

 1. What does this permit-to-install and operate ("PTIO") allow me to do?..... 4

 2. Who is responsible for complying with this permit? 4

 3. What records must I keep under this permit? 4

 4. What are my permit fees and when do I pay them?..... 4

 5. When does my PTIO expire, and when do I need to submit my renewal application? 4

 6. What happens to this permit if my project is delayed or I do not install or modify my source? 5

 7. What reports must I submit under this permit? 5

 8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit? 5

 9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?... 5

 10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report? 6

 11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located? 6

 12. What happens if one or more emissions units operated under this permit is/are shut down permanently? 6

 13. Can I transfer this permit to a new owner or operator?..... 6

 14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"? 7

 15. What happens if a portion of this permit is determined to be invalid? 7

B. Facility-Wide Terms and Conditions..... 8

C. Emissions Unit Terms and Conditions 10

 1. T001, Tank 80-1.....11

 2. T002, Tank 67-4.....17



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate
Permit Number: P0104799
Facility ID: 1483000170
Effective Date: 5/15/2009

Authorization

Facility ID: 1483000170
Application Number(s): A0037390
Permit Number: P0104799
Permit Description: This PTIO application has been submitted requesting Chapter 31 modification of the permit to install PTI # 14-05848 to establish increased allowable emissions limits for emissions units T001 and T004.
Permit Type: OAC Chapter 3745-31 Modification
Permit Fee: \$1,500.00
Issue Date: 5/15/2009
Effective Date: 5/15/2009
Expiration Date: 5/15/2019
Permit Evaluation Report (PER) Annual Date: Jan 1 - Dec 31, Due Feb 15

This document constitutes issuance to:

MARATHON PETROLEUM CO LLC- LEBANON
999 WEST STATE ROUTE 122
LEBANON, OH 45036

of a Permit-to-Install and Operate for the emissions unit(s) identified on the following page.

Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Hamilton County Dept. of Environmental Services
250 William Howard Taft Pkwy.
Cincinnati, OH 45219-2660
(513)946-7777

The above named entity is hereby granted this Permit-to-Install and Operate for the air contaminant source(s) (emissions unit(s)) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the described emissions unit(s) will operate in compliance with applicable State and federal laws and regulations.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director



State of Ohio Environmental Protection Agency
 Division of Air Pollution Control

Final Permit-to-Install and Operate
Permit Number: P0104799
Facility ID: 1483000170
Effective Date: 5/15/2009

Authorization (continued)

Permit Number: P0104799
 Permit Description: This PTIO application has been submitted requesting Chapter 31 modification of the permit to install PTI # 14-05848 to establish increased allowable emissions limits for emissions units T001 and T004.

Permits for the following emissions unit(s) or groups of emissions units are in this document as indicated below:

Emissions Unit ID:	T001
Company Equipment ID:	Tank 80-1
Superseded Permit Number:	14-05848
General Permit Category and Type:	Not Applicable
 Emissions Unit ID:	 T004
Company Equipment ID:	Tank 67-4
Superseded Permit Number:	14-05848
General Permit Category and Type:	Not Applicable



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

A. Standard Terms and Conditions



1. What does this permit-to-install and operate ("PTIO") allow me to do?

This permit allows you to install and operate the emissions unit(s) identified in this PTIO. You must install and operate the unit(s) in accordance with the application you submitted and all the terms and conditions contained in this PTIO, including emission limits and those terms that ensure compliance with the emission limits (for example, operating, recordkeeping and monitoring requirements).

2. Who is responsible for complying with this permit?

The person identified on the "Authorization" page, above, is responsible for complying with this permit until the permit is revoked, terminated, or transferred. "Person" means a person, firm, corporation, association, or partnership. The words "you," "your," or "permittee" refer to the "person" identified on the "Authorization" page above.

The permit applies only to the emissions unit(s) identified in the permit. If you install or modify any other equipment that requires an air permit, you must apply for an additional PTIO(s) for these sources.

3. What records must I keep under this permit?

You must keep all records required by this permit, including monitoring data, test results, strip-chart recordings, calibration data, maintenance records, and any other record required by this permit for five years from the date the record was created. You can keep these records electronically, provided they can be made available to Ohio EPA during an inspection at the facility. Failure to make requested records available to Ohio EPA upon request is a violation of this permit requirement.

4. What are my permit fees and when do I pay them?

There are two fees associated with permitted air contaminant sources in Ohio:

- PTIO fee. This one-time fee is based on a fee schedule in accordance with Ohio Revised Code (ORC) section 3745.11, or based on a time and materials charge for permit application review and permit processing if required by the Director.

You will be sent an invoice for this fee after you receive this PTIO and payment is due within 30 days of the invoice date. You are required to pay the fee for this PTIO even if you do not install or modify your operations as authorized by this permit.

- Annual emissions fee. Ohio EPA will assess a separate fee based on the total annual emissions from your facility. You self-report your emissions in accordance with Ohio Administrative Code (OAC) Chapter 3745-78. This fee assessed is based on a fee schedule in ORC section 3745.11 and funds Ohio EPA's permit compliance oversight activities. For facilities that are permitted as synthetic minor sources, the fee schedule is adjusted annually for inflation. Ohio EPA will notify you when it is time to report your emissions and to pay your annual emission fees.

5. When does my PTIO expire, and when do I need to submit my renewal application?

This permit expires on the date identified at the beginning of this permit document (see "Authorization" page above) and you must submit a renewal application to renew the permit. Ohio EPA will send a renewal notice to you approximately six months prior to the expiration date of this permit. However, it is very important that you submit a complete renewal permit application (postmarked prior to expiration of this permit) even if you do not receive the renewal notice.



If a complete renewal application is submitted before the expiration date, Ohio EPA considers this a timely application for purposes of ORC section 119.06, and you are authorized to continue operating the emissions unit(s) covered by this permit beyond the expiration date of this permit until final action is taken by Ohio EPA on the renewal application.

6. What happens to this permit if my project is delayed or I do not install or modify my source?

This PTIO expires 18 months after the issue date identified on the "Authorization" page above unless otherwise specified if you have not (1) started constructing the new or modified emission sources identified in this permit, or (2) entered into a binding contract to undertake such construction. This deadline can be extended by up to 12 months, provided you apply to Ohio EPA for this extension within a reasonable time before the 18-month period has ended and you can show good cause for any such extension.

7. What reports must I submit under this permit?

An annual permit evaluation report (PER) is required in addition to any malfunction reporting required by OAC rule 3745-15-06 or other specific rule-based reporting requirement identified in this permit. Your PER due date is identified in the Authorization section of this permit.

8. If I am required to obtain a Title V operating permit in the future, what happens to the operating provisions and PER obligations under this permit?

If you are required to obtain a Title V permit under OAC Chapter 3745-77 in the future, the permit-to-operate portion of this permit will be superseded by the issued Title V permit. From the effective date of the Title V permit forward, this PTIO will effectively become a PTI (permit-to-install) in accordance with OAC rule 3745-31-02(B). The following terms and conditions will no longer be applicable after issuance of the Title V permit: Section B, Term 1.b) and Section C, for each emissions unit, Term a)(2).

The PER requirements in this permit remain effective until the date the Title V permit is issued and is effective, and cease to apply after the effective date of the Title V permit. The final PER obligation will cover operations up to the effective date of the Title V permit and must be submitted on or before the submission deadline identified in this permit on the last day prior to the effective date of the Title V permit.

9. What are my obligations when I perform scheduled maintenance on air pollution control equipment?

You must perform scheduled maintenance of air pollution control equipment in accordance with OAC rule 3745-15-06(A). If scheduled maintenance requires shutting down or bypassing any air pollution control equipment, you must also shut down the emissions unit(s) served by the air pollution control equipment during maintenance, unless the conditions of OAC rule 3745-15-06(A)(3) are met. Any emissions that exceed permitted amount(s) under this permit (unless specifically exempted by rule) must be reported as deviations in the annual permit evaluation report (PER), including nonexempt excess emissions that occur during approved scheduled maintenance.



10. Do I have to report malfunctions of emissions units or air pollution control equipment? If so, how must I report?

If you have a reportable malfunction of any emissions unit(s) or any associated air pollution control system, you must report this to the Hamilton County Dept. of Environmental Services in accordance with OAC rule 3745-15-06(B). Malfunctions that must be reported are those that result in emissions that exceed permitted emission levels. It is your responsibility to evaluate control equipment breakdowns and operational upsets to determine if a reportable malfunction has occurred.

If you have a malfunction, but determine that it is not a reportable malfunction under OAC rule 3745-15-06(B), it is recommended that you maintain records associated with control equipment breakdown or process upsets. Although it is not a requirement of this permit, Ohio EPA recommends that you maintain records for non-reportable malfunctions.

11. Can Ohio EPA or my local air agency inspect the facility where the emission unit(s) is/are located?

Yes. Under Ohio law, the Director or his authorized representative may inspect the facility, conduct tests, examine records or reports to determine compliance with air pollution laws and regulations and the terms and conditions of this permit. You must provide, within a reasonable time, any information Ohio EPA requests either verbally or in writing.

12. What happens if one or more emissions units operated under this permit is/are shut down permanently?

Ohio EPA can terminate the permit terms associated with any permanently shut down emissions unit. "Shut down" means the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31.

You should notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification that identifies the date on which the emissions unit was permanently shut down. The certification must be submitted by an authorized official from the facility. You cannot continue to operate an emission unit once the certification has been submitted to Ohio EPA by the authorized official.

You must comply with all recordkeeping and reporting for any permanently shut down emissions unit in accordance with the provisions of the permit, regulations or laws that were enforceable during the period of operation, such as the requirement to submit a PER, air fee emission report, or malfunction report. You must also keep all records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, for at least five years from the date the record was generated.

Again, you cannot resume operation of any emissions unit certified by the authorized official as being permanently shut down without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

13. Can I transfer this permit to a new owner or operator?

You can transfer this permit to a new owner or operator. If you transfer the permit, you must follow the procedures in OAC Chapter 3745-31, including notifying Ohio EPA or the local air agency of the



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

change in ownership or operator. Any transferee of this permit must assume the responsibilities of the transferor permit holder.

14. Does compliance with this permit constitute compliance with OAC rule 3745-15-07, "air pollution nuisance"?

This permit and OAC rule 3745-15-07 prohibit operation of the air contaminant source(s) regulated under this permit in a manner that causes a nuisance. Ohio EPA can require additional controls or modification of the requirements of this permit through enforcement orders or judicial enforcement action if, upon investigation, Ohio EPA determines existing operations are causing a nuisance.

15. What happens if a portion of this permit is determined to be invalid?

If a portion of this permit is determined to be invalid, the remainder of the terms and conditions remain valid and enforceable. The exception is where the enforceability of terms and conditions are dependent on the term or condition that was declared invalid.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

B. Facility-Wide Terms and Conditions



1. This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).
 - a) For the purpose of a permit-to-install document, the facility-wide terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (1) None.
 - b) For the purpose of a permit-to-operate document, the facility-wide terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (1) none.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

C. Emissions Unit Terms and Conditions



1. T001, Tank 80-1

Operations, Property and/or Equipment Description:

Internal floating roof storage tank 80-1

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)(a)(ii)	See b)(2)a.
b.	40 CFR Part 60 Subpart Kb	See b)(2)b. and c)(1).
c.	OAC rule 3745-21-09(L) (when petroleum liquids are stored)	The requirements established pursuant to this rule are equivalent to the requirements of 40 CFR Part 60, Subpart Kb.

(2) Additional Terms and Conditions

a. The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the volatile organic compound (VOC) emissions from this air contaminant source because the calculated annual emission rate for VOC is less than ten tons per year taking into account the federally enforceable requirements under 40 CFR Part 60 Subpart Kb.

b. The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.



c) Operational Restrictions

- (1) The permittee shall equip the storage vessel with a fixed roof in combination with an internal floating roof meeting the following specifications:
 - a. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.
 - b. Each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof:
 - i. A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.
 - ii. Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous
 - iii. A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
 - c. Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.
 - d. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
 - e. Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
 - f. Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.



- c. If any of the conditions described in 40 CFR 60.113b(a)(2) are detected during the annual visual inspection required by 40 CFR 60.113b(a)(2), a report shall be furnished to the Administrator within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made.
 - d. After each inspection required by 40 CFR 60.113b(a)(3) that finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in 40 CFR 60.113b(a)(3)(ii), a report shall be furnished to the Administrator within 30 days of the inspection. The report shall identify the storage vessel and the reason it did not meet the specifications of 40 CFR 61.112b(a)(1) or 40 CFR 60.113b(a)(3) and list each repair made.
- (3) Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
- a. Construction date (no later than 30 days after such date);
 - b. Actual start-up date (within 15 days after such date), including a description of each affected emissions unit, equipment manufacturer, and serial number of the equipment if available; and
 - c. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Hamilton County Environmental Services
250 William Howard Taft Road
Cincinnati, Ohio 45219

f) Testing Requirements

(1) Emissions Limitations:

The uncontrolled potential to emit VOC is less than 10 tons per year.

Applicable Compliance Method:

Compliance with the emissions limitation shall be demonstrated by calculating the total emissions losses using the Tanks 4.0.9d emissions estimating software or other appropriate software based on equations developed by the American Petroleum Institute documented in AP-42, Section 7.1, Organic Liquid Storage Tanks.

- (2) After installing the control equipment required to meet 40 CFR 60.112b(a)(1) (permanently affixed roof and internal floating roof), each owner or operator shall:
 - a. Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL (volatile organic liquid). If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.



- b. For vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in 40 CFR 60.115b(a)(3). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
- c. For vessels equipped with a double-seal system as specified in 40 CFR 60.112b(a)(1)(ii)(B):
 - i. Visually inspect the vessel as specified in paragraph (a)(4) of 40 CFR 60.113b at least every 5 years; or
 - ii. Visually inspect the vessel as specified in paragraph (a)(2) of 40 CFR 60.113b.
- d. Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in paragraphs (a)(2) and (a)(3)(ii) of 40 CFR 60.113b and at intervals no greater than 5 years in the case of vessels specified in paragraph (a)(3)(i) of 40 CFR 60.113b.
- e. Notify the Administrator in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by paragraphs (a)(1) and (a)(4) of 40 CFR 60.113b to afford the Administrator the opportunity to have an observer present. If the inspection required by paragraph (a)(4) of 40 CFR 60.113b is not planned and the owner or operator could not have known about the inspection 30 days in advance or refilling the tank, the owner or operator shall notify the Administrator at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

sent by express mail so that it is received by the Administrator at least 7 days prior to the refilling.

g) Miscellaneous Requirements

- (1) The terms and conditions in this permit shall supersede the terms and conditions in the permit PTI 14-05848 issued on August 3, 2006.



2. T004, Tank 67-4

Operations, Property and/or Equipment Description:

Internal floating roof storage tank 67-4

a) This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

(1) For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

a. None.

(2) For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

a. None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)(a)(ii)	See b)(2)a.
b.	40 CFR Part 60 Subpart Kb	See b)(2)b. and c)(1).
c.	OAC rule 3745-21-09(L) (when petroleum liquids are stored)	The requirements established pursuant to this rule are equivalent to the requirements of 40 CFR Part 60, Subpart Kb.

(2) Additional Terms and Conditions

a. The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the volatile organic compound (VOC) emissions from this air contaminant source because the calculated annual emission rate for VOC is less than ten tons per year taking into account the federally enforceable requirements under 40 CFR Part 60 Subpart Kb.

b. The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.



c) Operational Restrictions

- (1) The permittee shall equip the storage vessel with a fixed roof in combination with an internal floating roof meeting the following specifications:
 - a. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal floating roof shall be floating on the liquid surface at all times, except during initial fill and during those intervals when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible.
 - b. Each internal floating roof shall be equipped with one of the following closure devices between the wall of the storage vessel and the edge of the internal floating roof:
 - i. A foam- or liquid-filled seal mounted in contact with the liquid (liquid-mounted seal). A liquid-mounted seal means a foam- or liquid-filled seal mounted in contact with the liquid between the wall of the storage vessel and the floating roof continuously around the circumference of the tank.
 - ii. Two seals mounted one above the other so that each forms a continuous closure that completely covers the space between the wall of the storage vessel and the edge of the internal floating roof. The lower seal may be vapor-mounted, but both must be continuous
 - iii. A mechanical shoe seal. A mechanical shoe seal is a metal sheet held vertically against the wall of the storage vessel by springs or weighted levers and is connected by braces to the floating roof. A flexible coated fabric (envelope) spans the annular space between the metal sheet and the floating roof.
 - c. Each opening in a noncontact internal floating roof except for automatic bleeder vents (vacuum breaker vents) and the rim space vents is to provide a projection below the liquid surface.
 - d. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use.
 - e. Automatic bleeder vents shall be equipped with a gasket and are to be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports.
 - f. Rim space vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting.



- c. If any of the conditions described in 40 CFR 60.113b(a)(2) are detected during the annual visual inspection required by 40 CFR 60.113b(a)(2), a report shall be furnished to the Administrator within 30 days of the inspection. Each report shall identify the storage vessel, the nature of the defects, and the date the storage vessel was emptied or the nature of and date the repair was made.
 - d. After each inspection required by 40 CFR 60.113b(a)(3) that finds holes or tears in the seal or seal fabric, or defects in the internal floating roof, or other control equipment defects listed in 40 CFR 60.113b(a)(3)(ii), a report shall be furnished to the Administrator within 30 days of the inspection. The report shall identify the storage vessel and the reason it did not meet the specifications of 40 CFR 61.112b(a)(1) or 40 CFR 60.113b(a)(3) and list each repair made.
- (3) Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
- a. Construction date (no later than 30 days after such date);
 - b. Actual start-up date (within 15 days after such date), including a description of each affected emissions unit, equipment manufacturer, and serial number of the equipment if available; and
 - c. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Hamilton County Environmental Services
250 William Howard Taft Road
Cincinnati, Ohio 45219

f) Testing Requirements

(1) Emissions Limitations:

The uncontrolled potential to emit VOC is less than 10 tons per year.

Applicable Compliance Method:

Compliance with the emissions limitation shall be demonstrated by calculating the total emissions losses using the Tanks 4.0.9d emissions estimating software or other appropriate software based on equations developed by the American Petroleum Institute documented in AP-42, Section 7.1, Organic Liquid Storage Tanks.

- (2) After installing the control equipment required to meet 40 CFR 60.112b(a)(1) (permanently affixed roof and internal floating roof), each owner or operator shall:
- a. Visually inspect the internal floating roof, the primary seal, and the secondary seal (if one is in service), prior to filling the storage vessel with VOL (volatile organic liquid). If there are holes, tears, or other openings in the primary seal, the secondary seal, or the seal fabric or defects in the internal floating roof, or both, the owner or operator shall repair the items before filling the storage vessel.



- b. For vessels equipped with a liquid-mounted or mechanical shoe primary seal, visually inspect the internal floating roof and the primary seal or the secondary seal (if one is in service) through manholes and roof hatches on the fixed roof at least once every 12 months after initial fill. If the internal floating roof is not resting on the surface of the VOL inside the storage vessel, or there is liquid accumulated on the roof, or the seal is detached, or there are holes or tears in the seal fabric, the owner or operator shall repair the items or empty and remove the storage vessel from service within 45 days. If a failure that is detected during inspections required in this paragraph cannot be repaired within 45 days and if the vessel cannot be emptied within 45 days, a 30-day extension may be requested from the Administrator in the inspection report required in 40 CFR 60.115b(a)(3). Such a request for an extension must document that alternate storage capacity is unavailable and specify a schedule of actions the company will take that will assure that the control equipment will be repaired or the vessel will be emptied as soon as possible.
- c. For vessels equipped with a double-seal system as specified in 40 CFR 60.112b(a)(1)(ii)(B):
 - i. Visually inspect the vessel as specified in paragraph (a)(4) of 40 CFR 60.113b at least every 5 years; or
 - ii. Visually inspect the vessel as specified in paragraph (a)(2) of 40 CFR 60.113b.
- d. Visually inspect the internal floating roof, the primary seal, the secondary seal (if one is in service), gaskets, slotted membranes and sleeve seals (if any) each time the storage vessel is emptied and degassed. If the internal floating roof has defects, the primary seal has holes, tears, or other openings in the seal or the seal fabric, or the secondary seal has holes, tears, or other openings in the seal or the seal fabric, or the gaskets no longer close off the liquid surfaces from the atmosphere, or the slotted membrane has more than 10 percent open area, the owner or operator shall repair the items as necessary so that none of the conditions specified in this paragraph exist before refilling the storage vessel with VOL. In no event shall inspections conducted in accordance with this provision occur at intervals greater than 10 years in the case of vessels conducting the annual visual inspection as specified in paragraphs (a)(2) and (a)(3)(ii) of 40 CFR 60.113b and at intervals no greater than 5 years in the case of vessels specified in paragraph (a)(3)(i) of 40 CFR 60.113b.
- e. Notify the Administrator in writing at least 30 days prior to the filling or refilling of each storage vessel for which an inspection is required by paragraphs (a)(1) and (a)(4) of 40 CFR 60.113b to afford the Administrator the opportunity to have an observer present. If the inspection required by paragraph (a)(4) of 40 CFR 60.113b is not planned and the owner or operator could not have known about the inspection 30 days in advance or refilling the tank, the owner or operator shall notify the Administrator at least 7 days prior to the refilling of the storage vessel. Notification shall be made by telephone immediately followed by written documentation demonstrating why the inspection was unplanned. Alternatively, this notification including the written documentation may be made in writing and



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Final Permit-to-Install and Operate

Permit Number: P0104799

Facility ID: 1483000170

Effective Date: 5/15/2009

sent by express mail so that it is received by the Administrator at least 7 days prior to the refilling.

g) Miscellaneous Requirements

- (1) The terms and conditions in this permit shall supersede the terms and conditions in the permit PTI 14-05848 issued on August 3, 2006.