



State of Ohio Environmental Protection Agency

STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215

TELE: (614) 644-3020 FAX: (614) 644-3184
www.epa.ohio.gov

P.O. Box 1049
Columbus, OH 43216-1049

11/19/2009

Eric Brown
E.I. Du Pont Fort Hill Plant
11215 Brower Rd
North Bend,, OH 45052

Certified Mail
Facility ID: 1431350817
Permit Number: P0099754
County: Hamilton

RE: DRAFT AIR POLLUTION TITLE V PERMIT
Permit Type: Renewal

Dear Permit Holder:

A draft of the OAC Chapter 3745-77 Title V permit for the referenced facility has been issued. The purpose of this draft is to solicit public comments. A public notice will appear in the Ohio EPA Weekly Review and the local newspaper, The Cincinnati Enquirer. A copy of the public notice, the Statement of Basis, and the draft permit are enclosed. This permit has been posted to the Division of Air Pollution Control (DAPC) Web page <http://www.epa.ohio.gov/dapc> in Microsoft Word and Adobe Acrobat format. Comments will be accepted as a marked-up copy of the permit or in narrative format. Any comments must be sent to the following:

Andrew Hall
Permit Review/Development Section
Ohio EPA, DAPC
50 W. Town St., 7th Floor
Columbus, Ohio 43215

and Hamilton County Dept. of Environmental Services
250 William Howard Taft Pkwy.
Cincinnati, OH 45219-2660

Comments and/or a request for a public hearing will be accepted within 30 days of the date the notice is published in the newspaper. You will be notified in writing if a public hearing is scheduled. A decision on processing the Title V permit will be made after consideration of comments received and oral testimony if a public hearing is conducted. You will then be provided with a Preliminary Proposed Title V permit and another opportunity to comment prior to the 45-day Proposed Title V permit submittal to U.S. EPA Region 5. The permit will be issued final after U.S. EPA review is completed and no objections to the final issuance have been received. If you have any questions, please contact Hamilton County Dept. of Environmental Services at (513)946-7777.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA Region 5 - *Via E-Mail Notification*
HCDOES; Indiana; Kentucky

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

PUBLIC NOTICE
ISSUANCE OF DRAFT AIR POLLUTION Title V Permit
E.I. Du Pont Fort Hill Plant

Issue Date: 11/19/2009
Permit Number: P0099754
Permit Type: Renewal
Permit Description: Title V Renewal Permit
Facility ID: 1431350817
Facility Location: E.I. Du Pont Fort Hill Plant
11215 Brower Rd,
North Bend, OH 45052
Facility Description: All Other Basic Inorganic Chemical Manufacturing

Chris Korleski, Director of the Ohio Environmental Protection Agency, 50 West Town Street, Columbus Ohio, has issued a draft action of an air pollution control Title V operating permit for the facility at the location identified above on the date indicated. Comments concerning this draft action, or a request for a public meeting, must be sent in writing no later than thirty (30) days from the date this notice is published. All comments, questions, requests for permit applications or other pertinent documentation, and correspondence concerning this action must be directed to Mike Kramer at Hamilton County Dept. of Environmental Services, 250 William Howard Taft Pkwy. or (513)946-7777. The permit, which includes a detailed description of the operations, and associated statement of basis for the permit requirements, can be downloaded from the Web page: www.epa.ohio.gov/dapc



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit
Permit Number: P0099754
Facility ID: 1431350817

Statement of Basis For Air Pollution Title V Permit

Facility ID:	1431350817
Facility Name:	E.I Dupont Fort Hill Plant
Facility Description:	Sulfuric Acid Production Plant
Facility Address:	11215 Brower Rd
Permit #:	P0099754

This facility is subject to Title V because it is major for:

Lead
 Sulfur Dioxide
 Carbon Monoxide
 Volatile Organic Compounds
 Nitrogen Oxides
 Particulate Matter ≤ 10 microns
 Single Hazardous Air Pollutant
 Combined Hazardous Air Pollutants
 Maximum Available Control Technology Standard(s)

A. Standard Terms and Conditions

Has each insignificant emissions unit been reviewed to confirm it meets the definition in OAC rule 3745-77-01 (U)?	Yes
Were there any "common control" issues associated with this facility? If yes, provide a summary of those issues and explain how the DAPC decided to resolve them	No
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a minor permit modification per OAC rule 3745-77-08(C)(1)	NA
Please identify the affected unit(s) and associated PTI, if applicable, along with a brief description of any changes to the permit document that qualify as a significant permit modification per OAC rule 3745-77-08(C)(3)	NA



State of Ohio Environmental Protection Agency
 Division of Air Pollution Control

Draft Title V Permit
Permit Number: P0099754
Facility ID: 1431350817

P001	20% Opacity	17-07(A)		N	N	Y	N	N	Y	N	Y	N	Y	Y	M and R – weekly checks. Rp – semiannual submittal reporting.
	35.4 lbs/hr as sulfuric acid mist	17-11(A)		N	N	Y	N	N	Y	N	Y	N	Y	Y	Based on Table 1 of OAC rule 3745-17-11 and a maximum production rate of 25 tons per year.
	25 lbs SO2 per ton of 100% acid produced	18-37(KK)		N	N	Y	N	N	Y	N	Y	N	Y	Y	CEM in place to determine SO2 emissions. M – CEMS system. R – CEMS records. Rp – CEMS reporting.



**State of Ohio Environmental Protection Agency
Division of Air Pollution Control**

DRAFT

**Air Pollution Title V Permit
for
E.I. Du Pont Fort Hill Plant**

Facility ID: 1431350817
Permit Number: P0099754
Permit Type: Renewal
Issued: 11/19/2009
Effective: To be entered upon final issuance
Expiration: To be entered upon final issuance



State of Ohio Environmental Protection Agency
 Division of Air Pollution Control

Air Pollution Title V Permit
 for
 E.I. Du Pont Fort Hill Plant

Table of Contents

Authorization 1

A. Standard Terms and Conditions 2

 1. Federally Enforceable Standard Terms and Conditions 3

 2. Monitoring and Related Record Keeping and Reporting Requirements..... 3

 3. Scheduled Maintenance..... 6

 4. Risk Management Plans 6

 5. Title IV Provisions 6

 6. Severability Clause 7

 7. General Requirements 7

 8. Fees..... 8

 9. Marketable Permit Programs..... 8

 10. Reasonably Anticipated Operating Scenarios 8

 11. Reopening for Cause 8

 12. Federal and State Enforceability 9

 13. Compliance Requirements 9

 14. Permit Shield 10

 15. Operational Flexibility..... 10

 16. Emergencies 11

 17. Off-Permit Changes 11

 18. Compliance Method Requirements 11

 19. Insignificant Activities or Emissions Levels..... 12

 20. Permit to Install Requirement 12

 21. Air Pollution Nuisance 12

 22. Permanent Shutdown of an Emissions Unit 12

 23. Title VI Provisions 12

 24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only 13

 25. Records Retention Requirements Under State Law Only..... 13

 26. Inspections and Information Requests 13

 27. Scheduled Maintenance/Malfunction Reporting 14

 28. Permit Transfers 14



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

- 29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 14
- B. Facility-Wide Terms and Conditions..... 15
- C. Emissions Unit Terms and Conditions 17
 - 1. P001, Sulfuric Acid Stack..... 18



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit

Permit Number: P0099754

Facility ID: 1431350817

Effective Date: To be entered upon final issuance

Authorization

Facility ID: 1431350817
Facility Description: sulfuric acid production
Application Number(s): A0031462
Permit Number: P0099754
Permit Description: Title V Renewal Permit
Permit Type: Renewal
Issue Date: 11/19/2009
Effective Date: To be entered upon final issuance
Expiration Date: To be entered upon final issuance
Superseded Permit Number:

This document constitutes issuance of an OAC Chapter 3745-77 Title V permit to:

E.I. Du Pont Fort Hill Plant
11215 Brower Rd
North Bend, OH 45052

Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Hamilton County Dept. of Environmental Services
250 William Howard Taft Pkwy.
Cincinnati, OH 45219-2660
(513)946-7777

The above named entity is hereby granted a Title V permit pursuant to Chapter 3745-77 of the Ohio Administrative Code. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. You will be sent a notice approximately 18 months prior to the expiration date regarding the renewal of this permit. If you do not receive a notice, please contact the Hamilton County Dept. of Environmental Services. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-08(E) and in accordance with the terms of this permit beyond the expiration date, if a timely renewal application is submitted. A renewal application will be considered timely if it is submitted no earlier than 18 months (540 days) and no later than 6 months (180 days) prior to the expiration date.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit

Permit Number: P0099754

Facility ID: 1431350817

Effective Date: To be entered upon final issuance

A. Standard Terms and Conditions



1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A. 24., Reporting Requirements Related to Monitoring and Record Keeping Requirements of State-Only Enforceable Permit Terms and Conditions
 - (2) Standard Term and Condition A. 25., Records Retention Requirements for State-Only Enforceable Permit Terms and Conditions
 - (3) Standard Term and Condition A. 27., Scheduled Maintenance/Malfunction Reporting
 - (4) Standard Term and Condition A. 29., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
(Authority for term: ORC 3704.036(A))

2. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit), the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
(Authority for term: OAC rule 3745-77-07(A)(3)(b)(i))
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
(Authority for term: OAC rule 3745-77-07(A)(3)(b)(ii))
- c) The permittee shall submit required reports in the following manner:
 - (1) All reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations caused by malfunctions shall be submitted in the following manner:



Any malfunction, as defined in OAC rule 3745-15-06(B)(1), shall be promptly reported to the Ohio EPA in accordance with OAC rule 3745-15-06. In addition, to fulfill the OAC rule 3745-77-07(A)(3)(c) deviation reporting requirements for malfunctions, written reports that identify each malfunction that occurred during each calendar quarter (including each malfunction reported only verbally in accordance with OAC rule 3745-15-06) shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year in accordance with Standard Term and Condition A.2.c)(2) below; and each report shall cover the previous calendar quarter. An exceedance of the visible emission limitations specified in OAC rule 3745-17-07(A)(1) that is caused by a malfunction is not a violation and does not need to be reported as a deviation if the owner or operator of the affected air contaminant source or air pollution control equipment complies with the requirements of OAC rule 3745-17-07(A)(3)(c).

In accordance with OAC rule 3745-15-06, a malfunction reportable under OAC rule 3745-15-06(B) constitutes a violation of an emission limitation (or control requirement) and, therefore, is a deviation of the federally enforceable permit requirements. Even though verbal notifications and written reports are required for malfunctions pursuant to OAC rule 3745-15-06, the written reports required pursuant to this term must be submitted quarterly to satisfy the prompt reporting provision of OAC rule 3745-77-07(A)(3)(c).

In identifying each deviation caused by a malfunction, the permittee shall specify the emission limitation(s) (or control requirement(s)) for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. For a specific malfunction, if this information has been provided in a written report that was submitted in accordance with OAC rule 3745-15-06, the permittee may simply reference that written report to identify the deviation. Nevertheless, all malfunctions, including those reported only verbally in accordance with OAC rule 3745-15-06, must be reported in writing on a quarterly basis.

Any scheduled maintenance, as referenced in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described above for malfunctions.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- (2) Except as may otherwise be provided in the terms and conditions for a specific emissions unit (i.e., in section C. Emissions Unit Terms and Conditions of this Title V permit or, in some cases, in section B. Facility-Wide Terms and Conditions of this Title V permit), all reporting required in accordance with OAC rule 3745-77-07(A)(3)(c) for deviations of the emission limitations, operational restrictions, and control device operating parameter limitations shall be submitted in the following manner:

Written reports of (a) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. Except as provided below, the written reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

In identifying each deviation, the permittee shall specify the emission limitation(s), operational restriction(s), and/or control device operating parameter limitation(s) for which the deviation occurred, describe each deviation, and provide the estimated magnitude and duration of each deviation.



These written deviation reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations. Full compliance with OAC rule 3745-77-07(A)(3)(c) requires reporting of all other deviations of the federally enforceable requirements specified in the permit as required by such rule.

If an emissions unit has a deviation reporting requirement for a specific emission limitation, operational restriction, or control device operating parameter limitation that is not on a quarterly basis (e.g., within 30 days following the end of the calendar month, or within 30 or 45 days after the exceedance occurs), that deviation reporting requirement satisfies the reporting requirements specified in this Standard Term and Condition for that specific emission limitation, operational restriction, or control device parameter limitation. Following the provisions of that non-quarterly deviation reporting requirement will also satisfy (for the deviations so reported) the requirements of OAC rule 3745-77-07(A)(3)(c) pertaining to the submission of monitoring reports every six months and to the prompt reporting of all deviations, and additional quarterly deviation reports for that specific emission limitation, operational restriction, or control device parameter limitation are not required pursuant to this Standard Term and Condition.

See A.29 below if no deviations occurred during the quarter.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

- (3) All reporting required in accordance with the OAC rule 3745-77-07(A)(3)(c) for other deviations of the federally enforceable permit requirements which are not reported in accordance with Standard Term and Condition A.2)c)(2) above shall be submitted in the following manner:

Unless otherwise specified by rule, written reports that identify deviations of the following federally enforceable requirements contained in this permit; Standard Terms and Conditions: A.3, A.4, A.5, A.7.e), A.8, A.13, A.15, A.19, A.20, A.21, and A.23 of this Title V permit, as well as any deviations from the requirements in section C. Emissions Unit Terms and Conditions of this Title V permit, and any monitoring, record keeping, and reporting requirements, which are not reported in accordance with Standard Term and Condition A.2.c)(2) above shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency by January 31 and July 31 of each year; and each report shall cover the previous six calendar months. Unless otherwise specified by rule, all other deviations from federally enforceable requirements identified in this permit shall be submitted annually as part of the annual compliance certification, including deviations of federally enforceable requirements not specifically addressed by permit or rule for the insignificant activities or emissions levels (IEU) identified in section B. Facility-Wide Terms and Conditions of this Title V permit. Annual reporting of deviations is deemed adequate to meet the deviation reporting requirements for IEUs unless otherwise specified by permit or rule.

In identifying each deviation, the permittee shall specify the federally enforceable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation.

These semi-annual and annual written reports shall satisfy the reporting requirements of OAC rule 3745-77-07(A)(3)(c) for any deviations from the federally enforceable requirements contained in this permit that are not reported in accordance with Standard Term and Condition A.2.c)(2) above.



If no such deviations occurred during a six-month period, the permittee shall submit a semi-annual report which states that no such deviations occurred during that period.

(Authority for term: OAC rules 3745-77-07(A)(3)(c)(i) and (ii) and OAC rule 3745-77-07(A)(13)(b))

- (4) Each written report shall be signed by a responsible official certifying that, "based on information and belief formed after reasonable inquiry, the statements and information in the report (including any written malfunction reports required by OAC rule 3745-15-06 that are referenced in the deviation reports) are true, accurate, and complete."

(Authority for term: OAC rule 3745-77-07(A)(3)(c)(iv))

- (5) Reports of any required monitoring and/or record keeping information shall be submitted to Hamilton County Dept. of Environmental Services.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

3. Scheduled Maintenance

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. Except as provided in OAC rule 3745-15-06(A)(3), any scheduled maintenance necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s). Any scheduled maintenance, as defined in OAC rule 3745-15-06(A)(1), that results in a deviation from a federally enforceable emission limitation (or control requirement) shall be reported in the same manner as described for malfunctions in Standard Term and Condition A.2.c)(1) above.

(Authority for term: OAC rule 3745-77-07(A)(3)(c))

4. Risk Management Plans

If applicable, the permittee shall develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. § 7401 et seq. ("Act"); and, pursuant to 40 C.F.R. 68.215(a), the permittee shall submit either of the following:

- a) a compliance plan for meeting the requirements of 40 C.F.R. Part 68 by the date specified in 40 C.F.R. 68.10(a) and OAC 3745-104-05(A); or
- b) as part of the compliance certification submitted under 40 C.F.R. 70.6(c)(5), a certification statement that the source is in compliance with all requirements of 40 C.F.R. Part 68 and OAC Chapter 3745-104, including the registration and submission of the risk management plan.

(Authority for term: OAC rule 3745-77-07(A)(4))

5. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

(Authority for term: OAC rule 3745-77-07(A)(5))



6. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
(Authority for term: OAC rule 3745-77-07(A)(6))

7. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, reopened, revoked, or revoked and reissued, for cause, in accordance with Standard Term and Condition A.11 below. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.
- f) Except as otherwise indicated below, this Title V permit, or permit modification, is effective for five years from the original effective date specified in the permit. In the event that this facility becomes eligible for non-title V permits, this permit shall cease to be enforceable when:
 - (1) the permittee submits an approved facility-wide potential to emit analysis supporting a claim that the facility no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on the permanent shutdown and removal of one or more emissions units identified in this permit; or
 - (2) the permittee no longer meets the definition of a "major source" as defined in OAC rule 3745-77-01(W) based on obtaining restrictions on the facility-wide potential(s) to emit that are federally enforceable or legally and practically enforceable ; or



(3) a combination of (1) and (2) above.

The permittee shall continue to comply with all applicable OAC Chapter 3745-31 requirements for all regulated air contaminant sources once this permit ceases to be enforceable. The permittee shall comply with any residual requirements, such as quarterly deviation reports, semi-annual deviation reports, and annual compliance certifications covering the period during which this Title V permit was enforceable. All records relating to this permit must be maintained in accordance with law.

(Authority for term: OAC rule 3745-77-01(W), OAC rule 3745-77-07(A)(3)(b)(ii), OAC rule 3745-77(A)(7))

8. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

(Authority for term: OAC rule 3745-77-07(A)(8))

9. Marketable Permit Programs

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

(Authority for term: OAC rule 3745-77-07(A)(9))

10. Reasonably Anticipated Operating Scenarios

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these standard terms and conditions shall apply to all operating scenarios authorized in this permit.

(Authority for term: OAC rule 3745-77-07(A)(10))

11. Reopening for Cause

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a) Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen (18) months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b) This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c) The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate



statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.

- d) The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.
(Authority for term: OAC rules 3745-77-07(A)(12) and 3745-77-08(D))

12. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

(Authority for term: OAC rule 3745-77-07(B))

13. Compliance Requirements

- a) Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c) The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.



d) Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) and the Administrator of the U.S. EPA in the following manner and with the following content:

(1) Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted (i.e., postmarked) on or before April 30th of each year during the permit term.

(2) Compliance certifications shall include the following:

(a) An identification of each term or condition of this permit that is the basis of the certification.

(b) The permittee's current compliance status.

(c) Whether compliance was continuous or intermittent.

(d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.

(e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.

(3) Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

(Authority for term: OAC rules 3745-77-07(C)(1),(2),(4) and (5) and ORC section 3704.03(L))

14. Permit Shield

a) Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.

b) This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

(Authority for term: OAC rule 3745-77-07(F))

15. Operational Flexibility

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the



Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

(Authority for term: OAC rules 3745-77-07(H)(1) and (2))

16. Emergencies

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

(Authority for term: OAC rule 3745-77-07(G))

17. Off-Permit Changes

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a) The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition.
- b) The permittee provides contemporaneous written notice of the change to the Director and the Administrator of the U.S. EPA, except that no such notice shall be required for changes that qualify as insignificant emissions levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or pollutants emitted, and any federally applicable requirement that would apply as a result of the change.
- c) The change shall not qualify for the permit shield under OAC rule 3745-77-07(F).
- d) The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes.
- e) The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit-to-install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

(Authority for term: OAC rule 3745-77-07(I))

18. Compliance Method Requirements

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the



permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.
(This term is provided for informational purposes only.)

19. Insignificant Activities or Emissions Levels

Each IEU that has one or more applicable requirements shall comply with those applicable requirements.
(Authority for term: OAC rule 3745-77-07(A)(1))

20. Permit to Install Requirement

Prior to the "installation" or "modification" of any "air contaminant source," as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.
(Authority for term: OAC rule 3745-77-07(A)(1))

21. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.
(Authority for term: OAC rule 3745-77-07(A)(1))

22. Permanent Shutdown of an Emissions Unit

The permittee may notify Ohio EPA of any emissions unit that is permanently shut down by submitting a certification from the responsible official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the responsible official that the emissions unit was permanently shut down.

After the date on which an emissions unit is permanently shut down (i.e., that has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31 and therefore ceases to meet the definition of an "emissions unit" as defined in OAC rule 3745-77-01(O)), rendering existing permit terms and conditions irrelevant, the permittee shall not be required, after the date of the certification and submission to Ohio EPA, to meet any Title V permit requirements applicable to that emissions unit, except for any residual requirements, such as the quarterly deviation reports, semi-annual deviation reports and annual compliance certification covering the period during which the emissions unit last operated. All records relating to the shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law.

No emissions unit certified by the responsible official as being permanently shut down may resume operation without first applying for and obtaining a permit to install pursuant to OAC Chapter 3745-31.
(Authority for term: OAC rule 3745-77-01)

23. Title VI Provisions

If applicable, the permittee shall comply with the standards for recycling and reducing emissions of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, except as provided for motor vehicle air conditioners in Subpart B of 40 CFR Part 82:



- a) Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices specified in 40 CFR 82.156.
- b) Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment specified in 40 CFR 82.158.
- c) Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to 40 CFR 82.161.
(Authority for term: OAC rule 3745-77-01(H)(11))

24. Reporting Requirements Related to Monitoring and Record Keeping Requirements Under State Law Only

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (i) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. In identifying each deviation, the permittee shall specify the applicable requirement for which the deviation occurred, describe each deviation, and provide the magnitude and duration of each deviation. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

25. Records Retention Requirements Under State Law Only

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

26. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio



EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

(Authority for term: OAC rule 3745-77-07(C))

27. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

28. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

(Authority for term: OAC rule 3745-77-01(C))

29. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no emission limitation (or control requirement), operational restriction and/or control device parameter limitation deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) by January 31, April 30, July 31, and October 31 of each year; and each report shall cover the previous calendar quarter.

The permittee is not required to submit a quarterly report which states that no deviations occurred during that quarter for the following situations:

- a) where an emissions unit has deviation reporting requirements for a specific emission limitation, operational restriction, or control device parameter limitation that override the deviation reporting requirements specified in Standard Term and Condition A.2.c)(2); or
- b) where an uncontrolled emissions unit has no monitoring, record keeping, or reporting requirements and the emissions unit's applicable emission limitations are established at the potentials to emit; or
- c) where the company's responsible official has certified that an emissions unit has been permanently shut down.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit

Permit Number: P0099754

Facility ID: 1431350817

Effective Date: To be entered upon final issuance

B. Facility-Wide Terms and Conditions



1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under Ohio EPA law only:

a) None.

2. 40 CFR, Part 68 is an applicable requirement for this facility. The permittee shall submit a Risk Management Plan, pursuant to 40 CFR, Part 68, to the appropriate designated agency and comply with all appropriate subparts by no later than June 20, 1999

3. The following insignificant emissions units are located at this facility:

- B003 - 6.3 MMBTU/Hr #2 Oil Fired Boiler
- B004 - 512 KVA Back-up Power Generator (Back-up Generator)
- P002 - Sulfuric Acid Loading Equipment (Barge Dock)
- P003 - Sulfuric Acid Loading Facility (65% Oleum Truck Spot)
- P004 - Sulfuric Acid Loading Facility (#1 SO3 Truck Spot)
- P005 - Sulfuric Acid Loading Facility (#2 SO3 Truck Spot)
- P006 - Sulfuric Acid Loading Facility (#3 SO3 Truck Spot)
- P007 - Sulfuric Acid Loading Facility (Tank Truck Rack)
- P008 - Sulfuric Acid Loading Facility (#7 Tank Car Spot)
- P009 - Sulfuric Acid Loading Facility (#8 Tank Car Spot)
- P010 - Sulfuric Acid Loading Facility (#12 Tank Car Spot)
- P011- Molten sulfur unloading pit (Molten Sulfur Pit 1)
- P012- Molten sulfur process fee pit (Molten Sulfur Pit 2)
- P013- Unloading of molten sulfur rail and truck station (Unloading of molten sulfur rail and truck station)
- P014- Product Loading Area (Loading Spot 7E)
- T001 - Sulfuric Acid Storage Tank (Tank #1)
- T002 - Sulfuric Acid Storage Tank (Tank #2)
- T003 – Fuming Storage Tank (Tank #3)
- T004 - Fuming Acid Storage Tank (Tank #4)
- T005 - Fuming Storage Tank (Tank #5)
- T007 - Sulfuric Acid Storage Tank (Low Iron Tank)
- T012 – Molten Sulfur Storage Tank (Molten Sulfur Storage Tank)
- T013 – 2000 gallon fuel oil storage tank(Fuel Oil Storage Tank)

Each insignificant emissions unit at this facility must comply with all applicable Ohio EPA and federal regulations, as well as any emission limitations and/or control requirements contained within a permit to install for the emissions unit. Insignificant emissions units listed above that are not subject to specific permit to install requirements are subject to one or more applicable requirements contained in the SIP-approved versions of OAC Chapters 3745-17, 3745-18, and 3745-21.



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit

Permit Number: P0099754

Facility ID: 1431350817

Effective Date: To be entered upon final issuance

C. Emissions Unit Terms and Conditions



1. P001, Sulfuric Acid Stack

Operations, Property and/or Equipment Description:

Production of sulfuric acid - various grades

- a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under Ohio EPA law only.

None.

- b) Applicable Emissions Limitations and/or Control Requirements

The specific operations(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC 3745-17-07(A)	Visible particulate emissions from this emissions unit shall not exceed twenty percent opacity, as a six-minute average, except as a specified by rule.
b.	OAC 3745-17-11(A)	Particulate emissions shall not exceed 35.4 lbs/hr as sulfuric acid mist based on Table 1 of OAC rule 3745-17-11 and a maximum production rate of 25 tons/hr.
c.	OAC 3745-18-37(KK)	Sulfur dioxide (SO ₂) emissions shall not exceed 25.0 lbs/ton of 100% sulfuric acid produced.

See b)(2)a.

Additional Terms and Conditions

Stack height shall be no lower than 300 feet above ground level.

- c) Operational Restrictions
- d) Monitoring and/or Recordkeeping Requirements

The permittee shall maintain a written quality assurance/quality control plan for the continuous SO₂ monitoring system, designed to ensure continuous valid and representative readings of SO₂ emissions in units of the applicable standard(s). The plan shall follow the requirements of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous SO₂ monitoring system must be kept on site and available for inspection during regular office hours.



The plan shall include the requirement to conduct quarterly cylinder gas audits or relative accuracy audits as required in 40 CFR Part 60; and to conduct relative accuracy test audits in units of the standard(s), in accordance with and at the frequencies required per 40 CFR Part 60.

(Authority for term: OAC rule 3745-45-77(C)(1), 40 CFR 60.13. and 40 CFR Part 60, Appendix F)

The continuous emission monitoring system consists of all the equipment used to acquire data to provide a record of emissions and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

(Authority for term: OAC rule 3745-45-77(C)(1), 40 CFR 60.2, and/or 40 CFR 63.2 and Appendix F to 40 CFR Part 60)

The permittee shall maintain on-site, the document of certification received from the U.S. EPA or the Ohio EPA's Central Office documenting that the continuous SO₂ monitoring system has been certified to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specification 2. The letter/document of certification shall be made available to the Director (the appropriate Ohio EPA District Office or local air agency) upon request.

(Authority for term: OAC rule 3745-45-77(C)(1), 40 CFR 60.13, and 40 CFR Part 60, Appendix B)

The permittee shall operate and maintain equipment to continuously monitor and record SO₂ emissions from this emissions unit in units of the applicable standard(s). The continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.

The permittee shall maintain records of data obtained by the continuous SO₂ monitoring system including, but not limited to:

emissions of SO₂ in parts per million on an instantaneous (one-minute) basis;

emissions of SO₂ in lbs of SO₂ per ton of 100% sulfuric acid produced based on a 3-hour average;

results of quarterly cylinder gas audits;

results of daily zero/span calibration checks and the magnitude of manual calibration adjustments;

results of required relative accuracy test audit(s), including results in units of the applicable standard(s);

hours of operation of the emissions unit, continuous SO₂ monitoring system, and control equipment;

the date, time, and hours of operation of the emissions unit without the control equipment and/or the continuous SO₂ monitoring system;



the date, time, and hours of operation of the emissions unit during any malfunction of the control equipment and/or the continuous SO₂ monitoring system; as well as,

the reason (if known) and the corrective actions taken (if any) for each such event in (g) and (h).

(Authority for term: OAC rule 3745-45-77(C)(1), 40 CFR 60.13 and 40 CFR Part 60, Appendices B & F)

The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:

the color of the emissions;

whether the emissions are representative of normal operations;

if the emissions are not representative of normal operations, the cause of the abnormal emissions;

the total duration of any visible emission incident; and

any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the daily check until the incident has ended. The observer may indicate that the visible emission incident was continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

(Authority for term: OAC rule 3745-45-77(C)(1))

e) Reporting Requirements

The permittee shall comply with the following quarterly reporting requirements for the emissions unit and its continuous SO₂ monitoring system:

Pursuant to the monitoring, record keeping, and reporting requirements for continuous monitoring systems contained in 40 CFR Parts 60.7 and 60.13(h) and the requirements established in this permit, the permittee shall submit reports within 30 days following the end of each calendar quarter to the appropriate Ohio EPA District Office or local air agency, documenting all instances of SO₂ emissions in excess of any applicable limit specified in this permit, 40 CFR Part 60, OAC Chapter 3745-18, and any other applicable rules or regulations. The report shall document the date, commencement and completion times, duration, and



magnitude of each exceedance, as well as the reason (if known) and the corrective actions taken (if any) for each exceedance. Excess emissions shall be reported in units of the applicable standard(s).

These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall include the following:

the facility name and address;

the manufacturer and model number of the continuous SO₂ and other associated monitors;

a description of any change in the equipment that comprises the continuous emission monitoring system (CEMS), including any change to the hardware, changes to the software that may affect CEMS readings, and/or changes in the location of the CEMS sample probe;

the excess emissions report (EER)*, i.e., a summary of any exceedances during the calendar quarter, as specified above;

the total SO₂ emissions for the calendar quarter (tons);

the total operating time (hours) of the emissions unit;

the total operating time of the continuous SO₂ monitoring system while the emissions unit was in operation;

results and dates of quarterly cylinder gas audits;

unless previously submitted, results and dates of the relative accuracy test audit(s), including results in units of the applicable standard(s), (during appropriate quarter(s));

unless previously submitted, the results of any relative accuracy test audit showing the continuous SO₂ monitor out-of-control and the compliant results following any corrective actions;

the date, time, and duration of any/each malfunction** of the continuous SO₂ monitoring system, emissions unit, and/or control equipment;

the date, time, and duration of any downtime** of the continuous SO₂ monitoring system and/or control equipment while the emissions unit was in operation; and

the reason (if known) and the corrective actions taken (if any) for each event in (b)(xi) and (xii).

Each report shall address the operations conducted and data obtained during the previous calendar quarter.

* where no excess emissions have occurred or the continuous monitoring system(s) has/have not been inoperative, repaired, or adjusted during the calendar quarter, such information shall be documented in the EER quarterly report



** each downtime and malfunction event shall be reported regardless if there is an exceedance of any applicable limit

(Authority for term: OAC rule 3745-45-77(C)(1), and 40 CFR 60.7)

The permittee shall submit semiannual written reports that identify:

all days during which any visible particulate emissions were observed from the stack serving this emissions unit; and

any corrective actions taken to minimize or eliminate the visible particulate emissions.

These reports shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

(Authority for term: OAC rule 3745-45-77(C)(1))

f) Testing Requirements

Compliance with the emission limitation(s) in b) of these terms and conditions shall be determined in accordance with the following method(s):

Emission Limitation:

Visible particulate emissions from this emissions unit shall not exceed twenty percent opacity, as a six-minute average, except as specified by rule.

Applicable Compliance Method:

If required, compliance shall be determined by visible emission evaluations performed in accordance with OAC rule 3745-17-03(B)(1).

(Authority for term: OAC rules 3745-17-03(B)(1), and 3745-77-07(C)(1))

Emission Limitation:

Sulfur dioxide (SO₂) emissions shall not exceed 25.0 lbs/ton of 100% sulfuric acid produced.

Applicable Compliance Method:

Ongoing compliance with the SO₂ emission limitations contained in this permit, 40 CFR Part 60 and any other applicable standard(s) shall be demonstrated through the data collected as required in the monitoring and record keeping section of this permit; and through demonstration of compliance with the quality assurance/quality control plan, which shall meet the testing and recertification requirements of 40 CFR Part 60.

(Authority for term: OAC rule 3745-45-77(C)(1), and 40 CFR Part 60, Appendices B & F)

Emission Limitation:



State of Ohio Environmental Protection Agency
Division of Air Pollution Control

Draft Title V Permit

Permit Number: P0099754

Facility ID: 1431350817

Effective Date: To be entered upon final issuance

Particulate emissions (sulfuric acid mist) shall not exceed 35.4 lbs/hr.

Applicable Compliance Method:

Compliance with the PE limitation was demonstrated by a stack test performed on March 25, 2003. During the March 25, 2003, stack test a PE rate of 0.115 lb of PE/hr was determined.

If additional testing required, the permittee shall demonstrate compliance with the lb/hr of PE emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(9).

g) Miscellaneous Requirements

None.