

Facility ID: 0238000128 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0238000128 Emissions Unit ID: P001 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
cyclone dust collection system controlling wood cabinet manufacturing equipment	OAC rule 3745-31-05(A)(3) PTI 02-3310 (Effective April 28, 1993)	0.039 grain of particulate emissions (PE) per dry standard cubic feet of exhaust air 1.8 pounds of PE per hour
	OAC rule 3745-17-11(B)	The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-07(A). The particulate emission limitation established pursuant to this rule is less stringent than the emissions limitations established pursuant to OAC rule 3745-31-05(A)(3).
	OAC rule 3745-17-07(A)	Visible emissions from the stack shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-07(B) OAC rule 3745-17-08(B)	See A.2.a below. See A.2.b below.

2. Additional Terms and Conditions

- (a) This emissions unit is exempt from the visible emissions limitations in OAC rule 3745-17-07(B), pursuant to OAC rule 3745-17-07(B)(11)(e). This facility is not located within an "Appendix A" areas, as defined in OAC rule 3745-17-08; therefore, pursuant to OAC rule 3745-17-08(A), this emissions unit is exempt from the requirements of OAC rule 3745-17-08(B).

B. Operational Restrictions

1. The permittee shall operate the cyclone dust collector at all times the unit is in operation.
2. The cyclone control system shall be operated with a sufficient volumetric flow rate to minimize or eliminate visible particulate emissions at the point(s) of capture to the extent possible with good engineering design.

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform daily checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the daily check until the incident has ended. The observer may indicate that the visible emission incident was

continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

D. Reporting Requirements

1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit and (b) describe any corrective actions taken to minimize or eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month period.

E. Testing Requirements

1. Compliance with the emission limitation(s) in section A.1 of these terms and conditions shall be determined in accordance with the following method(s):

Emission Limitation-
0.039 gr/dscf and 1.8 lbs/hr of PE

Applicable Compliance Method-

Compliance with this emission limitation may be determined by the following equation:

$$\text{lbs/hr PE} = (0.03 \text{ gr/dscf}) * (7,000 \text{ cfm}) * (60 \text{ min/hr}) * (\text{lb}/7000 \text{ gr})$$

Where:

0.03 gr/dscf is the emission factor from AP-42, table 10.4-1 Particulate Emission Factor for Large Diameter Cyclones in Woodworking Waste Collection Systems, version 2/80; and

7,000 cfm is the cyclone flow rate.

If required compliance shall be determined according to OAC rule 3745-17-03(B)(10) (USEPA Method 5, 40 CFR 60, Appendix A).

Emission Limitation-
20% opacity as a 6-minute average, except as provided by rule

Applicable Compliance Method-

Compliance shall be determined by the methods in OAC rule 3745-17-03(B)(1), (USEPA Method 9, 40 CFR 60, Appendix A).

F. Miscellaneous Requirements

1. None