Facility ID: 0238000165 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0238000165 Emissions Unit ID: P004 Issuance type: Final State Permit To Operate

Go to the top of this document

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.

   (a) None.

2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.

   (a) None.

A. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

Operations, Property, and/or Equipment	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
270 HP Detron stationary diesel engine	OAC rule 3745-31-05(A)(3) (PTI 02-22720 Effective 8/21/2007)	0.59 lb/hr and 1.11 TPY of particulate emissions (PE)/PM less than 10 microns in diameter (PM-10). 0.55 lb/hr and 1.03 TPY of sulfur dioxide (SO2). Also includes B.1 below. 8.37 lbs/hr of nitrogen dioxides (NOx). 0.67 lb/hr and 1.26 TPY of organic compounds (OC). 1.80 lb/hr and 3.38 TPY of carbon monoxide (CO). Visible particulate emissions from the stack serving this emissions unit shall not exceed 10% opacity, as a six-minute average. The requirements of this rule also include compliance with the requirements of OAC rule 3745-17-11(B)(5)(a).
	OAC rule 3745-17-11(B)(5)(a)	0.310 lb/mmBtu of particulate emissions.
	OAC rule 3745-17-07(A)(1)	The opacity limitation specified in this rule is less stringent than the limit established pursuant to OAC rule 3745-31-05(A)(3).
	OAC rule 3745-18-06(G)	This emissions unit is exempt from the requirements of OAC rule 3745-18-06 pursuant to OAC rule 3745-18-06(B).
	OAC rule 3745-31-05(C) (State Synthetic Minor to avoid modeling)	9.30 TPY of nitrogen dioxides (NOx). See B.2 below.

2. **Additional Terms and Conditions**

   (a) In accordance with OAC rule 3745-31-05(A)(3), best available technology for this emissions unit includes the emission limitations and fuel sulfur content restriction.

B. **Operational Restrictions**

1. The permittee shall use only diesel fuel/number 2 fuel oil with a maximum sulfur content of 0.5 percent, by weight, for combustion in this emissions unit.

2. The maximum operating hours for this emissions unit shall not exceed 72.1 hours per week and 3750 hours per year.

C. **Monitoring and/or Record Keeping Requirements**

1. For each day during which the permittee burns a fuel other than diesel fuel, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

2. The permittee shall maintain documentation of the sulfur content of all fuels received.

3. The permittee shall maintain weekly records of the operating hours for this emissions unit.

D. **Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day during which a fuel other than diesel fuel with a maximum sulfur content of 0.5 percent by weight was burned in this emissions unit and any corrective action(s) that were taken. Each report shall be submitted to the Ohio EPA Northeast District Office within 30 days of the deviation.

2. The permittee shall submit annual reports by January 31 of each year that include the total annual operating hours for the previous calendar year, as a summation of the weekly records kept according to C.3 above.

   The reports contained in this permit shall be submitted in accordance with the reporting requirements specified in Part 1 - General Terms and Conditions, Section A of this permit.

E. **Testing Requirements**

1. Compliance with the emission limitations specified in section A.1 of these terms and conditions shall be determined in accordance with the following methods:
   Emission Limitation:
   0.59 lb/hr of PM/PM-10

   Applicable Compliance Method:
   If required, compliance shall be demonstrated based upon an emission test performed in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Methods 1 through 5.
   Emission Limitation:
   1.11 TPY of PM/PM-10

   Applicable Compliance Method:
   The tpy emission limitation was developed by multiplying the short-term allowable particulate emission limitation (0.59 lb/hr) by the maximum allowable hours of operation (3,750 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance shall also be shown with the annual emission limitation.
   Emission Limitation:
   0.55 lb/hr of SO2

   Applicable Compliance Method:
   Compliance with the hourly emission limitation above shall be determined by multiplying 0.00205 lb/hp-hr, emission factor for SOx emission from AP-42, Table 3.3-1 (10/96), by 270 hp, the power output rating of this unit.
   Emission Limitation:
   1.03 TPY of SO2

   Applicable Compliance Method:
   The tpy emission limitation was developed by multiplying the short-term allowable SO2 emission limitation (0.0.55 lb/hr) by the maximum allowable hours of operation (3,750 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance shall also be shown with the annual emission limitation.
   Emission Limitation:
   8.37 lbs/hr of NOx

   Applicable Compliance Method:
   Compliance with the hourly emission limitation above shall be determined by multiplying 0.031 lb/hp-hr, emission factor for NOx emission from AP-42, Table 3.3-1 (10/96), by 270 hp, the power output rating of this unit.
   Emission Limitation:
   15.69 TPY of NOx

   Applicable Compliance Method:
   The tpy emission limitation was developed by multiplying the short-term allowable NOx emission limitation (8.37 lbs/hr) by the maximum allowable hours of operation (3,750 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance shall also be shown with the annual emission limitation.
   Emission Limitation:
   0.67 lb/hr of OC

   Applicable Compliance Method:
   Compliance with the hourly emission limitation above shall be determined by multiplying 0.00251 lb/hp-hr, the emission factor from AP-42, Table 3.3-1 (10/96), by 270 hp, the power output rating of this unit.
   Emission Limitation:
   1.26 TPY of OC

   Applicable Compliance Method:
   The tpy emission limitation was developed by multiplying the short-term allowable OC emission limitation (0.31 lb/hr) by the maximum allowable hours of operation (3,750 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance shall also be shown with the annual emission limitation.
   Emission Limitation:
   1.80 lb/hr of CO

   Applicable Compliance Method:
   Compliance with the hourly emission limitation above shall be determined by multiplying 0.00668 lb/hp-hr, the emission factor from AP-42, Table 3.3-1 (10/96), by 270 hp, the power output rating of this unit.
   Emission Limitation:
   3.38 TPY of CO

   Applicable Compliance Method:

The tpy emission limitation was developed by multiplying the short-term allowable OC emission limitation (1.80 lb/hr) by the maximum allowable hours of operation (3,750 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance shall also be shown with the annual emission limitation.
Emission Limitation:
10% opacity, as a 6-minute average

Applicable Compliance Method:
If required, compliance with the visible particulate emission limitation shall be demonstrated based upon the visible emission observations performed in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Method 9.
Emission Limitation:
0.310 lb/mmBtu of particulate emissions

Applicable Compliance Method:
Compliance with the short term emission limitation above may be determined by the following equation:

(0.0022 lb/hp-hr) / (hp-hr/7000 Btu) * (106 Btu/mmBtu)

where:
0.0022 lb/hp-hr, the emission factor from AP-42, Table 3.3-1 (10/96).

If required, compliance shall be demonstrated based upon an emission test performed in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Methods 1 through 5.

F. **Miscellaneous Requirements**

1. None