



State of Ohio Environmental Protection Agency

Street Address:

Lazarus Gov. Center
122 S. Front Street
Columbus, OH 43215

TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049
Columbus, OH 43216-1049

10/24/01

CERTIFIED MAIL

RE: Final Title V Chapter 3745-77 permit

01-25-04-0057

Delphi Interior & Lighting Systems, Columbus Operations
Carmen M. Durand
200 Georgesville Road
Columbus, OH 43228

Dear Carmen M. Durand:

Enclosed is the Title V permit that allows you to operate the facility in the manner indicated in the permit. Because this permit may contain several conditions and restrictions, we urge you to read it carefully.

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Review Appeals Commission within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. It is also requested by the Director that a copy of the appeal be served upon the Environmental Enforcement Section of the Office of the Attorney General. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
236 East Town Street
Room 300
Columbus, Ohio 43215

If you have any questions, please contact Central District Office.

Very truly yours,

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

cc: Central District Office
File, DAPC PMU



State of Ohio Environmental Protection Agency

FINAL TITLE V PERMIT

Issue Date: 10/24/01	Effective Date: 10/24/01	Expiration Date: 10/24/06
-----------------------------	---------------------------------	----------------------------------

This document constitutes issuance of a Title V permit for Facility ID: 01-25-04-0057 to:
 Delphi Interior & Lighting Systems, Columbus Operations
 Delphi Interior Systems
 200 Georgesville Road
 Columbus, OH 43228

Emissions Unit ID (Company ID)/Emissions Unit Activity Description

B001 (Boiler #1) Coal fired boiler which provides space heat and process heat to the GM DILS facility.	K021 (Maintenance Paint Booth) Maintenance Paint Spray Booth	K058 (Lock Line Process) The source is a grease dip system used to apply grease to automotive door locks. The grease is thinned with Rule 66 mineral spirits prior to application. After application the locks are heated in the dry off oven to drive off the mineral spirits.
B002 (Boiler #2) Coal fired boiler which provides space heat and process heat to the GM DILS facility.	K052 (Adhesive Coating Booth #3) Window molding adhesive spray application	
B003 (Boiler #3) Coal fired boiler which provides space heat and process heat to the GM DILS facility.		

You will be contacted approximately eighteen (18) months prior to the expiration date regarding the renewal of this permit. If you are not contacted, please contact the appropriate Ohio EPA District Office or local air agency listed below. This permit and the authorization to operate the air contaminant sources (emissions units) at this facility shall expire at midnight on the expiration date shown above. If a renewal permit is not issued prior to the expiration date, the permittee may continue to operate pursuant to OAC rule 3745-77-04(A) and in accordance with the terms of this permit beyond the expiration date, provided that a complete renewal application is submitted no earlier than eighteen (18) months and no later than one-hundred eighty (180) days prior to the expiration date.

Described below is the Ohio EPA District Office or local air agency that is responsible for processing and administering your Title V permit:

Central District Office
 3232 Alum Creek Drive
 PO Box 1049
 Columbus, OH 43216-1049
 (614) 728-3778

OHIO ENVIRONMENTAL PROTECTION AGENCY

Christopher Jones
Director

PART I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Section

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be promptly made to the appropriate Ohio EPA District Office or local air agency. These quarterly written reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(i) and (ii) pertaining to the submission of monitoring reports every six months and OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of all deviations except malfunctions, which shall be reported in accordance with OAC rule 3745-15-06. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.) See B.8 below if no deviations occurred during the quarter.
 - iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to

the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. These semi-annual written reports shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(i) and (ii) pertaining to the reporting of any deviations related to the monitoring, recordkeeping, and reporting requirements. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.

- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports submitted pursuant to OAC rule 3745-15-06 shall satisfy the requirements of OAC rule 3745-77-07(A)(3)(c)(iii) pertaining to the prompt reporting of deviations caused by malfunctions or upsets.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78.

8. Marketable Permit Programs

No revision of this permit is required under any approved economic incentive, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit.

9. Reasonably Anticipated Operating Scenarios

The permittee is hereby authorized to make changes among operating scenarios authorized in this permit without notice to the Ohio EPA, but, contemporaneous with making a change from one operating scenario to another, the permittee must record in a log at the permitted facility the scenario under which the permittee is operating. The permit shield provided in these general terms and conditions shall apply to all operating scenarios authorized in this permit.

10. Reopening for Cause

This Title V permit will be reopened prior to its expiration date under the following conditions:

- a. Additional applicable requirements under the Act become applicable to one or more emissions units covered by this permit, and this permit has a remaining term of three or more years. Such a reopening shall be completed not later than eighteen months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to paragraph (E)(1) of OAC rule 3745-77-08.
- b. This permit is issued to an affected source under the acid rain program and additional requirements (including excess emissions requirements) become applicable. Upon approval by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit, and shall not require a reopening of this permit.
- c. The Director of the Ohio EPA or the Administrator of the U.S. EPA determines that the federally applicable requirements in this permit are based on a material mistake, or that inaccurate statements were made in establishing the emissions standards or other terms and conditions of this permit related to such federally applicable requirements.
- d. The Administrator of the U.S. EPA or the Director of the Ohio EPA determines that this permit must be revised or revoked to assure compliance with the applicable requirements.

11. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

12. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this Title V permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.

- ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with paragraph (E) of OAC rule 3745-77-03.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.
- d. Compliance certifications concerning the terms and conditions contained in this permit that are federally enforceable emission limitations, standards, or work practices, shall be submitted to the appropriate Ohio EPA District Office or local air agency in the following manner and with the following content:
- i. Compliance certifications shall be submitted annually on a calendar year basis. The annual certification shall be submitted on or before April 30th of each year during the permit term.
 - ii. Compliance certifications shall include the following:
 - (a) An identification of each term or condition of this permit that is the basis of the certification.
 - (b) The permittee's current compliance status.
 - (c) Whether compliance was continuous or intermittent.
 - (d) The method(s) used for determining the compliance status of the source currently and over the required reporting period.
 - (e) Such other facts as the Director of the Ohio EPA may require in the permit to determine the compliance status of the source.
 - iii. Compliance certifications shall contain such additional requirements as may be specified pursuant to sections 114(a)(3) and 504(b) of the Act.

13. Permit Shield

- a. Compliance with the terms and conditions of this permit (including terms and conditions established for alternate operating scenarios, emissions trading, and emissions averaging, but

excluding terms and conditions for which the permit shield is expressly prohibited under OAC rule 3745-77-07) shall be deemed compliance with the applicable requirements identified and addressed in this permit as of the date of permit issuance.

- b. This permit shield provision shall apply to any requirement identified in this permit pursuant to OAC rule 3745-77-07(F)(2), as a requirement that does not apply to the source or to one or more emissions units within the source.

14. Operational Flexibility

The permittee is authorized to make the changes identified in OAC rule 3745-77-07(H)(1)(a) to (H)(1)(c) within the permitted stationary source without obtaining a permit revision, if such change is not a modification under any provision of Title I of the Act [as defined in OAC rule 3745-77-01(JJ)], and does not result in an exceedance of the emissions allowed under this permit (whether expressed therein as a rate of emissions or in terms of total emissions), and the permittee provides the Administrator of the U.S. EPA and the appropriate Ohio EPA District Office or local air agency with written notification within a minimum of seven days in advance of the proposed changes, unless the change is associated with, or in response to, emergency conditions. If less than seven days notice is provided because of a need to respond more quickly to such emergency conditions, the permittee shall provide notice to the Administrator of the U.S. EPA and the appropriate District Office of the Ohio EPA or local air agency as soon as possible after learning of the need to make the change. The notification shall contain the items required under OAC rule 3745-77-07(H)(2)(d).

15. Emergencies

The permittee shall have an affirmative defense of emergency to an action brought for noncompliance with technology-based emission limitations if the conditions of OAC rule 3745-77-07(G)(3) are met. This emergency defense provision is in addition to any emergency or upset provision contained in any applicable requirement.

16. Off Permit Changes

The owner or operator of a Title V source may make any change in its operations or emissions at the source that is not specifically addressed or prohibited in the Title V permit, without obtaining an amendment or modification of the permit, provided that the following conditions are met:

- a. The change does not result in conditions that violate any applicable requirements or that violate any existing federally enforceable permit term or condition;
- b. The permittee provides contemporaneous written notice of the change to the director and the administrator, except that no such notice shall be required for changes that qualify as insignificant emission levels or activities as defined in OAC rule 3745-77-01(U). Such written notice shall describe each such change, the date of such change, any change in emissions or

pollutants emitted, and any federally applicable requirement that would apply as a result of the change;

- c. The change shall not qualify for the permit shield under OAC rule 3745-77-07(F);
- d. The permittee shall keep a record describing all changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes; and
- e. The change is not subject to any applicable requirement under Title IV of the Act or is not a modification under any provision of Title I of the Act.

Paragraph (I) of rule 3745-77-07 of the Administrative Code applies only to modification or amendment of the permittee's Title V permit. The change made may require a permit to install under Chapter 3745-31 of the Administrative Code if the change constitutes a modification as defined in that Chapter. Nothing in paragraph (I) of rule 3745-77-07 of the Administrative Code shall affect any applicable obligation under Chapter 3745-31 of the Administrative Code.

(For further clarification, the permittee can refer to Engineering Guide #63 that is available in their STARSHIP software package.)

17. Compliance Method Requirements

Nothing in this permit shall alter or affect the ability of any person to establish compliance with, or a violation of, any applicable requirement through the use of credible evidence to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the permittee, including but not limited to, any challenge to the Credible Evidence Rule (see 62 Fed. Reg. 8314, Feb. 24, 1997), in the context of any future proceeding.

18. Insignificant Activity

Each insignificant activity that has one or more applicable requirements shall comply with those applicable requirements.

B. State Only Enforceable Section

1. Permit to Install Requirement

Prior to the “installation” or “modification” of any “air contaminant source,” as those terms are defined in OAC rule 3745-31-01, a permit to install must be obtained from the Ohio EPA pursuant to OAC Chapter 3745-31.

2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with

this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

Part II - Specific Facility Terms and Conditions

A. State and Federally Enforcable Section

None

B. State Only Enforceable Section

1. The following insignificant emissions units are located at this facility:

- B005 - 3MMBtu/hr boiler;
- B006 - 3MMBtu/hr boiler;
- B007 - 3MMBtu/hr boiler;
- B008 - 3MMBtu/hr boiler;
- B009 - 3MMBtu/hr boiler;
- B010 - 3MMBtu/hr boiler;
- B011 - 3MMBtu/hr boiler;
- B012 - 3MMBtu/hr boiler;
- B013 - 3MMBtu/hr boiler;
- B014 - 3MMBtu/hr boiler;
- P006 - heat treat furnace;
- P008 - steam cleaning booth;
- P013 - zinc barrel plater;
- P025 - steam cleaning booth;
- P050 - EK cathodic washer;
- P051 - EK Mask Washer #1;
- P052 - EK dryoff oven;
- T001 - tank for storing mineral spirits;
- T002 - unleaded gasoline tank;
- T003 - leaded gasoline tank;
- T004 - south Rykon grease tank;
- T005 - north Rykon grease tank;
- T006 - quench oil tank;
- T007 - water soluble waste oil tank;
- T008 - water soluble waste oil tank;
- T009 - waste fein blank oil tank;
- T010 - waste fein blank oil tank;
- T011 - non-soluble waste oil tank;
- T012 - non-soluble waste oil tank;
- Z001 - laboratory fume hood;
- Z003 - Cincinnati washer;
- Z004 - hand welder;
- Z005 - laser welder;
- Z006 - welding booth rack repair;
- Z007 - resistance welder;
- Z008 - seam welder;
- Z009 - sheet metal welder
- Z010 - upset welder
- Z011 - weld booth
- Z012 - 1002-77 welder
- Z013 - 1002-86 welder;
- Z014 - 1004-84 welder;
- Z015 - 1006-77 welder;
- Z016 - 1024-82 welder;
- Z017 - 35609 welder;
- Z018 - 36146 welder;
- Z019 - Welder G-55 A;
- Z020 - Welder G-55 B;
- Z021 - Welder G-55 C;
- Z022 - welding vent;
- Z023 - COL 37012 injection molder;
- Z024 - COL 37013 injection molder;
- Z025 - COL 37014 injection molder;
- Z026 - COL 37015 injection molder;
- Z027 - COL 37301 Newbury molder;
- Z028 - Inert Atmosphere Generator #1;
- Z029 - Inert Atmosphere Generator #2;
- Z030 - AGF Heat Treat Furnace #1;
- Z031 - AGF Heat Treat Furnace #2;

B. State Only Enforceable Section

Z032 - AGF Heat Treat Furnace #3;
Z033 - AGF Heat Treat Furnace #4;
Z034 - AGF Heat Treat Furnace #5;
F002 - outdoor coal storage;
Z036 - underground diesel fuel tank;
Z037 - anchor bolts parts washers;
Z038 - impact mask washer;
Z039 - EK Mask Washer #2;
Z040 - EK Mask Washer #3;
B015 - standby generator;
Z002 - sm. heat treat process;
P026 - plastisol coating and curing process; and
F003 - coal handling system.

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a permit to install for the emissions unit.

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Boiler #1 (B001)

Activity Description: Coal fired boiler which provides space heat and process heat to the GM DILS facility.

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-17-07(A)	Visible particulate emissions from any stack shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input.
	40 CFR 52.1881(b)(16)(ii)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-17-10, the total heat input for B001 through B003 is derated from 268.38 mmBtu/hr to 210 mmBtu/hr. (The derated total heat input of 210 mmBtu/hr corresponds to a steam load of 180,000 lbs/hr.) Using the derated total heat input, the allowable particulate emissions rate for B001, from Figure I of OAC rule 3745-17-10, is 0.16 lb/mmBtu actual heat input.

II. Operational Restrictions

1. The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in Section A.I above
2. At no time shall the steam flow rate from B001 through B003 exceed 60,000 lbs/hr per boiler and a total 180,000 lbs/hr (as an average over any one-hour period).

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect or require the coal supplier to collect a representative sample of each shipment of coal which is received for burning. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal. At the end of each calendar month, the representative samples of coal from all shipments of coal which were received during that calendar month shall be combined into one composite-sample.

Each monthly composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isothermal Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Central District Office.

2. The permittee shall maintain monthly records of the total quantity of coal received in each shipment (tons), the weighted* average sulfur content and heat content (percent) of the coal received during each calendar month, and the weighted* average sulfur dioxide emissions rate (pounds sulfur dioxide/mmBtu actual heat input) from the coal received each calendar month.

*In proportion to the quantity of coal received in each shipment during the calendar month.

3. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that sections 7.1.4, 7.4.1, 7.4.2, and Table 1-1 of Performance Specification 1 are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
5. The permittee shall operate and maintain equipment to continuously monitor and record the steam flow rate from B001. The monitoring and recording devices shall be capable of accurately measuring the desired parameter. The steam flow rate monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee.

IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Central District Office) in writing of any monthly record that shows a deviation of the allowable sulfur dioxide emission limitation. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Central District Office) within 45 days after the deviation occurs.

IV. Reporting Requirements (continued)

2. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Central District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total downtime of the analyzer while the emissions unit was on line shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If for any reason the steam flow rate from B001 exceeds 60,000 lbs/hr as an average over any one-hour period, the following information shall be reported within 5 days after the exceedance:
 - a. the date of the exceedance;
 - b. the time interval over which the exceedance occurred;
 - c. the value of the exceedance;
 - d. the cause(s) of the exceedance;
 - e. the corrective action which has been or will be taken to prevent similar exceedances in the future; and
 - f. a copy of the steam chart which shows the exceedance.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method -

If required, compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

V. Testing Requirements (continued)

- 1.b** Emission Limitation -
Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input

Applicable Compliance Method -

The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate for particulate matter in accordance with the following requirements:

- i. The emission testing shall be conducted within 1 year of permit issuance and within 6 months prior to permit renewal.
- ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate: Methods 1 through 5, 40 CFR Part 60, Appendix A.
- iii. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA, Central District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Central District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Central District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA, Central District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Central District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Central District Office.

- 1.c** Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -

Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-18-31(G)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section B.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -
Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Boiler #2 (B002)

Activity Description: Coal fired boiler which provides space heat and process heat to the GM DILS facility.

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-17-07(A)	Visible particulate emissions from any stack shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input.
	40 CFR 52.1881(b)(16)(ii)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-17-10, the total heat input for B001 through B003 is derated from 268.38 mmBtu/hr to 210 mmBtu/hr. (The derated total heat input of 210 mmBtu/hr corresponds to a steam load of 180,000 lbs/hr.) Using the derated total heat input, the allowable particulate emissions rate for B002, from Figure I of OAC rule 3745-17-10, is 0.16 lb/mmBtu actual heat input.

II. Operational Restrictions

1. The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in Section A.I above
2. At no time shall the steam flow rate from B001 through B003 exceed 60,000 lbs/hr per boiler and a total 180,000 lbs/hr (as an average over any one-hour period).

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect or require the coal supplier to collect a representative sample of each shipment of coal which is received for burning. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal. At the end of each calendar month, the representative samples of coal from all shipments of coal which were received during that calendar month shall be combined into one composite-sample.

Each monthly composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isothermal Bomb Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Central District Office.

2. The permittee shall maintain monthly records of the total quantity of coal received in each shipment (tons), the weighted* average sulfur content and heat content (percent) of the coal received during each calendar month, and the weighted* average sulfur dioxide emissions rate (pounds sulfur dioxide/mmBtu actual heat input) from the coal received each calendar month.

*In proportion to the quantity of coal received in each shipment during the calendar month.

3. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that sections 7.1.4, 7.4.1, 7.4.2, and Table 1-1 of Performance Specification 1 are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
5. The permittee shall operate and maintain equipment to continuously monitor and record the steam flow rate from B002. The monitoring and recording devices shall be capable of accurately measuring the desired parameter. The steam flow rate monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee.

IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Central District Office) in writing of any monthly record that shows a deviation of the allowable sulfur dioxide emission limitation. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Central District Office) within 45 days after the deviation occurs.

IV. Reporting Requirements (continued)

2. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Central District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total downtime of the analyzer while the emissions unit was on line shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If for any reason the steam flow rate from B002 exceeds 60,000 lbs/hr as an average over any one-hour period, the following information shall be reported within 5 days after the exceedance:
 - a. the date of the exceedance;
 - b. the time interval over which the exceedance occurred;
 - c. the value of the exceedance;
 - d. the cause(s) of the exceedance;
 - e. the corrective action which has been or will be taken to prevent similar exceedances in the future; and
 - f. a copy of the steam chart which shows the exceedance.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method -

If required, compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

V. Testing Requirements (continued)

- 1.b** Emission Limitation -
Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input

Applicable Compliance Method -

The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate for particulate matter in accordance with the following requirements:

- i. The emission testing shall be conducted within 1 year of permit issuance and within 6 months prior to permit renewal.
- ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate: Methods 1 through 5, 40 CFR Part 60, Appendix A.
- iii. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA, Central District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Central District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Central District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA, Central District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Central District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Central District Office.

- 1.c** Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -

Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-18-31(G)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section B.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -
Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Boiler #3 (B003)

Activity Description: Coal fired boiler which provides space heat and process heat to the GM DILS facility.

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-17-07(A)	Visible particulate emissions from any stack shall not exceed 20% opacity, as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-10(C)(1)	Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input.
	40 CFR 52.1881(b)(16)(ii)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

- 2.a Pursuant to OAC rule 3745-17-10, the total heat input for B001 through B003 is derated from 268.38 mmBtu/hr to 210 mmBtu/hr. (The derated total heat input of 210 mmBtu/hr corresponds to a steam load of 180,000 lbs/hr.) Using the derated total heat input, the allowable particulate emissions rate for B003, from Figure I of OAC rule 3745-17-10, is 0.16 lb/mmBtu actual heat input.

II. Operational Restrictions

1. The quality of the coal burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in Section A.I above
2. At no time shall the steam flow rate from B001 through B003 exceed 60,000 lbs/hr per boiler and a total 180,000 lbs/hr (as an average over any one-hour period).

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect or require the coal supplier to collect a representative sample of each shipment of coal which is received for burning. The coal sampling shall be performed in accordance with ASTM method D2234, Collection of a Gross Sample of Coal. At the end of each calendar month, the representative samples of coal from all shipments of coal which were received during that calendar month shall be combined into one composite-sample.

Each monthly composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isothermal Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Ohio EPA, Central District Office.

2. The permittee shall maintain monthly records of the total quantity of coal received in each shipment (tons), the weighted* average sulfur content and heat content (percent) of the coal received during each calendar month, and the weighted* average sulfur dioxide emissions rate (pounds sulfur dioxide/mmBtu actual heat input) from the coal received each calendar month.

*In proportion to the quantity of coal received in each shipment during the calendar month.

3. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous opacity monitoring system designed to ensure continuous valid and representative readings of opacity. The plan shall include, as a minimum, conducting and recording daily automatic zero/span checks, provisions for conducting a quarterly audit of the continuous opacity monitoring system, and a description of preventive maintenance activities. The plan shall describe step by step procedures for ensuring that sections 7.1.4, 7.4.1, 7.4.2, and Table 1-1 of Performance Specification 1 are maintained on a continuous basis. The quality assurance/quality control plan and a logbook dedicated to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
5. The permittee shall operate and maintain equipment to continuously monitor and record the steam flow rate from B003. The monitoring and recording devices shall be capable of accurately measuring the desired parameter. The steam flow rate monitor and recorder shall be installed, calibrated, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee.

IV. Reporting Requirements

1. The permittee shall notify the Director (the Ohio EPA, Central District Office) in writing of any monthly record that shows a deviation of the allowable sulfur dioxide emission limitation. The notification shall include a copy of such record and shall be sent to the Director (the Ohio EPA, Central District Office) within 45 days after the deviation occurs.

IV. Reporting Requirements (continued)

2. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Ohio EPA, Central District Office documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective actions taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total downtime of the analyzer while the emissions unit was on line shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

3. If for any reason the steam flow rate from B003 exceeds 60,000 lbs/hr as an average over any one-hour period, the following information shall be reported within 5 days after the exceedance:
 - a. the date of the exceedance;
 - b. the time interval over which the exceedance occurred;
 - c. the value of the exceedance;
 - d. the cause(s) of the exceedance;
 - e. the corrective action which has been or will be taken to prevent similar exceedances in the future; and
 - f. a copy of the steam chart which shows the exceedance.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
20% opacity, as a 6-minute average, except as provided by rule

Applicable Compliance Method -

If required, compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

V. Testing Requirements (continued)

- 1.b** Emission Limitation -
Particulate emissions shall not exceed 0.16 lb/mmBtu actual heat input

Applicable Compliance Method -

The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate for particulate matter in accordance with the following requirements:

- i. The emission testing shall be conducted within 1 year of permit issuance and within 6 months prior to permit renewal.
- ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate: Methods 1 through 5, 40 CFR Part 60, Appendix A.
- iii. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA, Central District Office.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Central District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Central District Office's refusal to accept the results of the emission test(s).

Personnel from the Ohio EPA, Central District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Central District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Central District Office.

- 1.c** Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -

Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
70 mmBtu/hr coal-fired boiler with multiclone	OAC rule 3745-18-31(G)	Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section B.I of these terms and conditions shall be determined in accordance with the following method(s):

- 1.a Emission Limitation -
Sulfur dioxide emissions shall not exceed 1.5 lbs/mmBtu actual heat input

Applicable Compliance Method -
Compliance shall be determined by using the fuel analysis records required pursuant to Section A.III.2 and the applicable equation in OAC rule 3745-18-04(F).

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Maintenance Paint Booth (K021)
Activity Description: Maintenance Paint Spray Booth

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Maintenance paint spray booth for miscellaneous metal parts	OAC rule 3745-21-09(U)(1)(c)	The VOC content limit of this rule does not apply pursuant to OAC rule 3745-21-09(U)(2)(e)(ii). See A.II.1 below.

2. Additional Terms and Conditions

None

II. Operational Restrictions

1. The coating usage in this emissions unit shall not exceed 10 gallons per day.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect and record the following information each day for the coating line:
 - a. The name and identification number of each coating employed.
 - b. The volume, in gallons, of each coating employed.
 - c. The total volume, in gallons, of all of the coatings employed.

IV. Reporting Requirements

1. The permittee shall notify the Ohio EPA Central District Office in writing of any daily record showing that the coating line employs more than the applicable maximum daily coating usage limit. The notification shall include a copy of such record and shall be sent to the Ohio EPA Central District Office within 45 days after the exceedance occurs.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I of these terms and conditions shall be determined in accordance with the following method(s):

V. Testing Requirements (continued)

- 1.a** Emission Limitation -
Daily coating usage shall not exceed 10 gallons.

Applicable Compliance Method -
Compliance with the above limitation shall be demonstrated through the records required pursuant to Section A.III.

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Adhesive Coating Booth #3 (K052)
Activity Description: Window molding adhesive spray application

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

- The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Window molding adhesive spray application	OAC rule 3745-31-05(D) PTI No. 01-4249	The VOC content of each coating employed shall not exceed 6.14 lbs VOC per gallon, excluding water and exempt solvents. Monthly coating usage shall not exceed 250 gallons. Monthly cleanup material usage shall not exceed 50 gallons. VOC emissions shall not exceed 6.57 pounds per hour. VOC emissions shall not exceed 11.25 tons per year.
	OAC rule 3745-21-09(U)(1)(c)	The VOC content limit of this rule does not apply pursuant to OAC rule 3745-21-09(U)(2)(e)(ii). See A.II.1. below.

2. Additional Terms and Conditions

None

II. Operational Restrictions

- The coating usage in this emissions unit shall not exceed 10.0 gallons per day.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect and record the following information each day for K052:
 - a. The name and identification number of each coating and cleanup material employed.
 - b. The volume, in gallons, of each coating and cleanup material employed.
 - c. The VOC content of each coating, in pounds per gallon and in pounds per gallon excluding water and exempt solvents, and of each cleanup material, in pounds per gallon.
 - d. The total volume, in gallons, of all of the coatings and of all the cleanup materials employed.
 - e. The total VOC emissions from all coatings and cleanup materials employed, in pounds, i.e., the summation of b. times c. for each coating and each cleanup material.
 - f. The hours of operation.
 - g. The calculated average hourly emission rate, in pounds, i.e., e/f.
2. The permittee shall record each month, for the purpose of determining annual VOC emissions from K052, the calculated, VOC emission rate for all coatings and cleanup materials, in tons (i.e., the summation of the daily values from 1.e. above for the calendar month divided by 2,000 pounds per ton).
3. The permittee shall record each month, the total volume, in gallons, of all the coatings and of all the cleanup materials employed in this emissions unit (i.e., the summation of the daily values from 1. d. above for the calendar month).

IV. Reporting Requirements

1. The permittee shall notify the Ohio EPA Central District Office in writing of any daily record showing that the coating line employs more than the applicable maximum daily coating usage limit. The notification shall include a copy of such record and shall be sent to the Ohio EPA Central District Office within 45 days after the exceedance occurs.
2. The permittee shall submit annual reports which specify the total VOC emissions from K052 for the previous calendar year. These reports shall be submitted by January 31 of each year.
3. In accordance with paragraph A.1.c.ii of the General Terms and Conditions, the permittee shall submit quarterly deviation (excursion) reports, which identify any exceedances of the hourly VOC emission limitation, the maximum allowable VOC content limitation for coatings, and the monthly coating and cleanup material usage restrictions.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.1 of these terms and conditions shall be determined in accordance with the following method(s):
 - 1.a Emission Limitation -
VOC emissions shall not exceed 6.57 pounds per hour.

Applicable Compliance Method -
Compliance with the above emission limitation shall be demonstrated through the records required pursuant to Section A.III.
 - 1.b Emission Limitation -
VOC emissions shall not exceed 11.25 tons per year.

Applicable Compliance Method -
Compliance with the above emission limitation shall be demonstrated through the records required pursuant to Section A.III.

V. Testing Requirements (continued)

- 1.c** Emission Limitation -
VOC content of coating shall not exceed 6.14 lbs VOC per gallon, excluding water and exempt solvents.

Applicable Compliance Method -

U.S. EPA Method 24 or 24A shall be used to determine the VOC contents of the coatings. If, pursuant to section 4.3 of Method 24, 40 CFR Part 60, Appendix A, an owner or operator determines that Method 24 cannot be used for a particular coating or cleanup material, the owner or operator shall so notify the Administrator of the U.S. EPA and shall use formulation data for that coating and cleanup material to demonstrate compliance until the U.S. EPA provides alternative analytical procedures or alternative precision statements for Method 24. Note: The Method 24 data may be supplied by the manufacturer of the coatings.

Compliance with this limitation shall be demonstrated through the records required pursuant to Section A.III.

- 2.** Formulation data or U.S. EPA Method 24 shall be used to determine the VOC contents of the cleanup materials.

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - Terms and Conditions for Emissions Units

Emissions Unit ID: Lock Line Process (K058)

Activity Description: The source is a grease dip system used to apply grease to automotive door locks. The grease is thinned with Rule 66 mineral spirits prior to application. After application the locks are heated in the dry off oven to drive off the mineral spirits.

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
This emission unit is a grease dip system used to apply grease to automotive door locks. The grease is thinned with mineral spirits prior to application. After application the locks are heated in the dry off oven to drive off the mineral spirits.	OAC rule 3745-21-09(U)(1)(c)	The VOC content of each coating shall not exceed 3.5 lbs VOC per gallon, excluding water and exempt solvents.

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall collect and record the following information each month for the line:
 - a. The name and identification number of each coating, as applied.
 - b. The VOC content of each coating (excluding water and exempt solvents), as applied.

IV. Reporting Requirements

1. The permittee shall notify the Ohio EPA Central District Office in writing of any monthly record showing the use of noncomplying coatings. The notification shall include a copy of such record and shall be sent to the Ohio EPA Central District Office within 30 days following the end of the calendar month

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.1 of these terms and conditions shall be determined in accordance with the following method(s):

V. Testing Requirements (continued)

- 1.a** Emission Limitation -
VOC content of coating shall not exceed 3.5 lbs VOC per gallon, excluding water and exempt solvents.

Applicable Compliance Method -

U.S. EPA Method 24 or 24A shall be used to determine the VOC contents of the coatings. If, pursuant to section 4.3 of Method 24, 40 CFR Part 60, Appendix A, an owner or operator determines that Method 24 cannot be used for a particular coating or cleanup material, the owner or operator shall so notify the Administrator of the U.S. EPA and shall use formulation data for that coating and cleanup material to demonstrate compliance until the U.S. EPA provides alternative analytical procedures or alternative precision statements for Method 24. Note: The Method 24 data may be supplied by the manufacturer of the coatings.

Compliance with this limitation shall be demonstrated through the records required pursuant to Section A.III.

VI. Miscellaneous Requirements

None

B. State Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/ Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	---	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Record Keeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

THIS IS THE LAST PAGE OF THE PERMIT
