



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL MODIFICATION
ASHTABULA COUNTY**

CERTIFIED MAIL

Street Address:

122 S. Front Street

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:
Lazarus Gov. Center
P.O. Box 1049

Application No: 02-13197

Fac ID: 0204010193

DATE: 12/14/2006

Millennium Inorganic Chemicals Inc Plt2
Rick Hughes
P.O. Box 310 2426 Middle Rd
Ashtabula, OH 44004

Enclosed Please find a modification to the Ohio EPA Permit To Install referenced above which will modify the terms and conditions.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

NEDO



Permit To Install
Terms and Conditions

Issue Date: 12/14/2006
Effective Date: 12/14/2006

FINAL ADMINISTRATIVE MODIFICATION OF PERMIT TO INSTALL 02-13197

Application Number: 02-13197
Facility ID: 0204010193
Permit Fee: **\$2200**
Name of Facility: Millennium Inorganic Chemicals Inc Plt2
Person to Contact: Rick Hughes
Address: P.O. Box 310 2426 Middle Rd
Ashtabula, OH 44004

Location of proposed air contaminant source(s) [emissions unit(s)]:
2426 Middle Rd
Ashtabula, Ohio

Description of proposed emissions unit(s):
Administrative Modification to PTI 02-13197, originally issued on 2/9/00 and modified on 8/6/02, to allow the use of alternative NOx controls.

The above named entity is hereby granted a modification to the permit to install described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this modification does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Permit-To-Install General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.9 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - iv. If this permit is for an emissions unit located at a Title V facility, then each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d. The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

- iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit-To-Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this permit is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

13. Permit-To-Install

A permit-to-install must be obtained pursuant to OAC Chapter 3745-31 prior to "installation" of "any air contaminant source" as defined in OAC rule 3745-31-01, or "modification", as defined in OAC rule 3745-31-01, of any emissions unit included in this permit.

B. State Only Enforceable Permit-To-Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

Millennium Inorganic Chemicals Inc Plt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

4. Authorization To Install or Modify

If applicable, authorization to install or modify any new or existing emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

5. Construction of New Sources(s)

This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

8. Construction Compliance Certification

Millennium Inorganic Chemicals Inc Pt2
PTI Application: 02-13197
Modification Issued: 12/14/2006

Facility ID: 020401019

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the permit-to-install application and the terms and conditions of the permit-to-install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

9. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit-To-Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
NO _x	187.2
CO	163.4
Total OC	35.76
Particulates	58.32
SO ₂	13.84

Millennium Inorganic Chemicals Inc Plt2
 PTI Application: 02-13197
 Modification Issued: 12/14/2006

Facility ID: 020401019

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

1. At no time will the installation of emissions units B013 through B016 (combined cycle combustion turbine/heat recovery steam generators) and B017 (single cycle combustion turbine) listed in this permit and the shut down or restricted operation of two existing emissions units B004 (coal-fired steam boiler) and B003, B009, and B012 (three gas-fired steam boilers) violate the NOx, CO, Particulate, and Total Organic Compound emissions netting calculations.
2. Pursuant to your application of June 16, 1999, the terms and conditions in this permit to install are contingent upon the following sequential events occurring: the installation, start-up, and initial operation of emissions units B013 through B017 and the permanent shut-down and removal of emissions units B003, B004, B009, and B012 located at this facility; in lieu of removal, the rendering of emissions units B003, B004, B009, and B012 physically inoperable by the removal of some critical piece of operating equipment (boiler feed pump, main steam line, gas supply line, coal feeders, etc.) will be sufficient.
3. The permittee shall notify the Ohio EPA in writing of the dates on which installation of emissions units B013 through B017 commenced and were completed. The permittee shall also notify the Ohio EPA in writing of the dates on which emissions units B003, B004, B009, and B012 were permanently shut down and removed from the property (or rendered completely inoperable). These notifications shall be submitted to the Northeast District Office within 15 days after each event occurs.

The following is a table demonstrating the resultant effect of the shutdowns and removal of the above referenced emissions units on the emissions from this facility related to the emissions units installed under this permit:

Pollutants	New Emissions	Old Emissions	Net Change
NOx	+ 187.2 TPY	- 147.33 TPY	+ 39.87 TPY
CO	+ 163.4 TPY	- 68.82 TPY	+ 94.58 TPY
TOC	+ 35.76 TPY	- 1.17 TPY	+ 34.59 TPY
Particulates	+ 58.32 TPY	- 55.24 TPY	+ 3.08 TPY
SO ₂	+ 13.84 TPY	- 639.68 TPY	- 625.84 TPY

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B013 - Combined cycle 65.1 mmBtu/hr (4.92 MW) natural gas-fired combustion turbine with NO _x emissions control technology (a dry, low NO _x emissions combustion system, a low NO _x steam injection system or an equivalent NO _x emissions control technology) & a 55.0 mmBtu/hr natural gas-fired duct heater/ heat recovery boiler. Co. ID: combustion turbine with heat recovery boiler no. 2. THIRD MODIFICATION OF PTI 02-3197, ORIGINALLY ISSUED FEBRUARY 9, 2000, AND MODIFIED AS PTI 02-13197 ON MAY 3, 2001 AND ON AUGUST 6, 2002	OAC rule 3745-31-05(A)(3)
	OAC rule 3745-17-11(B)(4)
	OAC rule 3745-17-10(B)(1)
	OAC rule 3745-18-06(F)
	40 CFR Part 60, Subpart GG
	40 CFR Part 60, Subpart Dc

Miller

PTI A

Modification Issued: 12/14/2006

Emissions Unit ID: B013

OAC rule 3745-17-07(A)(1)	<u>Applicable Emissions Limitations/Control Measures</u>	emissions from the turbine portion shall not exceed 0.015 percent by volume at 15% oxygen, on a dry basis ; see section A.I.2.d.
OAC rule 3745-31-05(C) - federally enforceable restrictions to avoid PSD requirements.	<p>Nitrogen oxides (NO_x) emissions shall not exceed 12.53 lbs/hr and 50.37 TPY; see sections A.I.2.a. and A.I.2.b. Carbon monoxide (CO) emissions shall not exceed 12.70 lbs/hr and 43.58 TPY see section A.I.2.c. Organic compound (OC) emissions shall not exceed 2.12 lbs/hr and 8.94 TPY; see section A.I.2.c. Particulate emissions (PE) shall not exceed 3.70 lbs/hr. and 14.58 TPY; see section A.I.2.f. Sulfur dioxide (SO₂) emissions shall not exceed 0.86 lb/hr and 3.46 TPY. The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A), 3745-21-08(B) and 3745-23-06(B) and the fuel sulfur content requirements of 40 CFR Part 60, Subpart GG.</p>	The PE rate from the turbine shall not exceed 0.040 pound per million Btu of actual heat input; see section A.I.2.e.
OAC rule 3745-21-08(B)		The PE rate from the duct heater shall not exceed 0.020 lb/mmBtu of actual heat input; see section A.I.2.e.
OAC rule 3745-23-06(B)		SO ₂ emissions from the turbine shall not exceed 0.5 pound per million Btu of actual heat input; see section A.I.2.d.
		See section A.I.2.g.
		Visible PE shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
		For emissions units B013 through B017 <u>collectively</u> , see section A.I.2.h.
		See section A.I.2.i.
	NO _x emissions from the turbine shall not exceed 190.0 parts per million, by volume (ppmv), at 15% oxygen, on a dry basis ; see section A.I.2.d. The sulfur content of natural gas burned in the turbine shall not exceed 0.8 percent by weight ; see section A.I.2.d. SO ₂	See section A.I.2.j.

2. Additional Terms and Conditions

- 2.a** The combustion turbine shall be equipped with a dry, low NO_x emissions combustion system, a low NO_x steam injection system or an equivalent, alternate NO_x emissions control technology.
- 2.b** The allowable rate of 12.53 lbs/hour for NO_x emissions is based on emissions factors and is established to reflect the potential to emit for this emissions unit.
- 2.c** The allowable rates of 12.70 lbs/hour for CO emissions and 2.12 lbs/hour OC emissions are based on emissions factors and are established to reflect the potential to emit for this emissions unit.
- 2.d** These emissions limitations are less stringent than the corresponding limitation(s) specified above pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** These PE rate limitations are equal to or less stringent than the corresponding limitation(s) specified below in A.I.2.f.
- 2.f** Per OAC rule 3745-17-10(B), the PE rate from the duct heater portion of this combined cycle unit shall not exceed 0.020 lb/mmBtu. Since the duct burner can not be operated independently of the combustion turbine, the weighted average particulate emissions from this combined cycle emissions unit, when operating at 100 percent load (with total combined cycle heat input of 120.1 mmBtu/hr actual heat input measured at 0° F) shall not exceed 0.0308 lb/mmBtu of actual heat input; this is equivalent to an hourly emissions rate of 3.70 pounds at 0° Fahrenheit.
- 2.g** The duct heater is exempted from the SO₂ emissions limits and from the PE limits referenced in 40 CFR Part 60.42c and in 40 CFR Part 60.43c, respectively, as long as this steam generation unit burns only natural gas as a fuel.
- 2.h** The total annual emissions of NO_x and CO from these new emissions units, B013 through B017, at this facility shall be limited to 187.2 tons and 163.4 tons respectively. These annual NO_x and CO emissions limitations for emissions units B013 through B017 shall be achieved by restricting the maximum quantity of natural gas burned for these emissions units to a cumulative total volume of 3590 million cubic feet on a rolling 12-month summation basis.
- 2.i** The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions

unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

- 2.j** The permittee shall satisfy the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06 by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On February 15, 2005, OAC rule 3745-23-06 was rescinded; therefore, this rule is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-23-06, the requirement to satisfy the "latest available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.
2. The maximum quantity of natural gas which may be burned in emissions units B013 through B017 shall not exceed 3590 million cubic feet per year based on a rolling 12-month summation of fuel usage.
3. The fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight [from 40 CFR Part 60.333(b)].

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR 60.334(h), the permittee shall analyze and maintain records of the fuel-bound sulfur content of the natural gas fuel being fired in the turbine in the following manner:

- a. Monitoring of the sulfur content shall be performed by either the facility, a service contractor retained by the facility, or the fuel supplier.
 - b. In accordance with 40 CFR 60.334(h)(1), analysis for total sulfur content of the natural gas fuel shall be conducted using the methods described in 40 CFR 60.335(b)(10)(ii). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D4404-01, D5228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compound may be used.
 - i. In accordance with 40 CFR 60.334(h)(3), notwithstanding the provisions of 40 CFR 60.334(h)(1), the permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the U.S. EPA administrator for 40 CFR Part 60 subpart GG requires such monitoring. The permittee shall use one of the following sources of information to make the required demonstration:
 - (1) the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
 - (2) representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of 40 CFR.
 - c. In accordance with 40 CFR 60.334(h)(4), for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has been approved, the owner or operator may, without submitting a special petition to the U.S. EPA administrator, continue monitoring on this schedule. During the first six (6) months of operation of this emissions unit, fuel sulfur content monitoring was performed twice per month. The monitoring data showed little variability in the fuel sulfur content, and indicated consistent compliance with 40 CFR 60.333, so that sampling and analysis for fuel sulfur content shall be continue to be conducted once per quarter .
2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

3. The permittee shall install, maintain, and operate a properly calibrated natural gas flow rate meter on both the combustion turbine and the duct heater portions of this emissions unit to allow for accurate determination of the fuel consumption of each portion of this combined cycle unit.
4. The permittee shall maintain monthly records of the following information:
 - a. The volume of natural gas burned in this emissions unit for the calendar month (in millions of cubic feet);
 - b. The volume of natural gas burned in emissions units B013 through B017 collectively during the month (in millions of cubic feet);
 - c. The volume of natural gas burned for the rolling, 12-month summation period for both this emissions unit and emissions units B013 through B017 collectively;
 - d. The number of hours of operation of this emissions unit for each calendar month;
 - e. The collective number of hours of operation of emissions units B013 through B017; and
 - f. A calculation of the NO_x and CO emissions from this emissions unit based on factors listed in Section A.V.1.j. & A.V.1.k. or upon an emissions factor developed from the initial performance/emissions compliance test data.
5. The permittee shall maintain daily records of the following information for this emissions unit:
 - a. Except as provided in 40 CFR 60.334 (b) on any day when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, the permittee shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine. The permittee shall collect and record the following information each day:
 - i. the fuel consumption, in cubic feet on an hourly basis;
 - ii. the water or steam injection volume, in cubic feet, on an hourly basis;

- iii. the hourly ratio of water or steam to fuel;
 - iv. if applicable, other operating parameter(s) identified in an on-site parameter monitoring plan, required by 40 CFR 60.334(g); and
 - v. the operating times for the capture (collection) system, control device, monitoring equipment, and the associated emissions unit.
- b. In accordance with 40 CFR 60.334 (b) for any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous fuel and steam(water) monitoring system described in 40 CFR 60.334(a), the permittee shall install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F of 40 CFR Part 75 and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:
- i. Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
 - (1) on a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
 - (2) on a ppm at 15 percent O₂ basis; or
 - (3) on a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).
 - ii. As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a

minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

- iii. For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
 - (1) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.334(b)(2), is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under 40 CFR 60.332(a), *i.e.*, percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a diluent cap value of 19.0 percent O₂ may be used in the emission calculations.
 - (2) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.
 - (3) If the owner or operator has installed a NO_x CEMS to meet the requirements of 40 CFR Part 75, and is continuing to meet the ongoing requirements of 40 CFR Part 75, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR Part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).

Emissions Unit ID: **B013**

- c. In accordance with 40 CFR 60.334(c) for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the permittee may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of 40 CFR 60.334(b). Also, if the permittee has previously submitted and received U.S. EPA, or Ohio EPA approval of a procedure for monitoring compliance with the applicable NO_x emissions limit under 40 CFR 60.332, that approved procedure may continue to be used.

IV. Reporting Requirements

1. The permittee shall submit annual deviation reports which identify all periods during which the sulfur content of the fuel fired in this emissions unit exceeded 0.8%, by weight. These reports shall be submitted by January 31 of each year.
2. The permittee shall submit deviation (excursion) reports that identify all periods during which the emissions limitations listed above in these terms and conditions were exceeded or the required records were not maintained. Such report shall be sent to the Northeast District Office within 30 days following the end of the calendar month during which the exceedance or deviation occurred.
3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
4. The permittee shall submit quarterly deviation (excursion) reports which identify all exceedances of the rolling, 12-month natural gas usage limitation for emissions units B013-B017.
5. Permittee shall submit an annual report which summarizes the monthly and cumulative annual hours of operation of this emissions unit. This report shall be submitted to the Northeast District Office of the Ohio EPA by January 31 of each year for data recorded during the previous calendar year.
6. The permittee shall also submit annual reports which specify the total NO_x emissions and total CO emissions (in tons per year) from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
7. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, excess emissions reports shall be submitted in accordance with 40 CFR 60.334(j). An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water fuel ration needed to demonstrate compliance with the NO_x emissions

standard in 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

The permittee shall submit quarterly deviation (excursion) reports that identify all periods of time during which the operating parameter(s) does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the emissions unit. The quarterly report shall include the following information:

- a. date(s) and time(s) of parameter deviation;
- b. average steam or water-to-fuel ratio;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

8. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, monitor downtime reports shall be submitted in accordance with 40 CFR 60.334(j). A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ration are unavailable or invalid.

The permittee shall submit semi-annual deviation (excursion) reports that identify all periods of monitor downtime and shall include the following information:

- a. date(s) and time(s) of monitor downtime(s);
- b. average steam or water-to-fuel ratio, if available;
- c. average fuel consumption, in cubic feet;

Emissions Unit ID: **B013**

- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

- 9. The permittee shall submit a notification report 30 days prior to any conversion from a low NO_x steam injection emissions control technology to another NO_x emissions control technology.

V. Testing Requirements

- 1. Compliance with the emission limitation(s) and fuel restriction in Sections A.I. and A.II. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation:

- i. The PE rate from the combustion turbine portion of this emissions unit shall not exceed 0.040 lbs/mmBtu.
- ii. The PE rate from the duct heater portion of this emissions unit shall not exceed 0.020 lb/mmBtu.

Applicable Compliance Method: If required, compliance with these emission limitations shall be determined during the performance testing of this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- b. Fuel Sulfur Content Limitation: The gaseous fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight.

Applicable Compliance Method: The permittee shall determine compliance with the fuel sulfur content limitation in accordance with the procedures specified in ASTM D1072-80, 90 (Reapproved 1994); , D3246-81, 92; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17) per 40 CFR 60.335(b)(10)(ii). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the U.S. EPA administrator.

- c. Emission Limitation: Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

- d. Emission Limitations: NO_x emissions from the combustion turbine portion of this emissions unit shall not exceed 190 ppmv at 15% oxygen, on a dry basis.

Applicable Compliance Method: Compliance shall be determined by using appropriate NSPS test requirements as specified in 40 CFR 60.8 and 40 CFR Part 60, Subpart GG, as they apply to an emissions unit of this type with a heat input of greater than 10 mmBtu/hr and less than 100 mmBtu/hr.

- e. Emissions Limitation: NO_x emissions from all of these new emissions units (B013 through B017) shall not exceed 187.2 TPY.

Applicable Compliance Method: Compliance with this annual NO_x emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- f. Emissions Limitation: CO emissions from all of these new emissions units (B013 through B017) shall not exceed 163.4 TPY.

Applicable Compliance Method: Compliance with this annual CO emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- g. Emission Limitation: The PE rate from this emissions unit shall not exceed 3.70 lbs/hr and 14.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall

be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.0019 lbs/mmBtu as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 7.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above. If required pursuant to OAC rule 3745-15-04, the permittee shall demonstrate compliance with the particulate emissions limits of this permit by means of physical testing of the effluent from this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- h. Emission Limitation: SO₂ emissions from this emissions unit shall not exceed 0.86 lb/hr and 3.46 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.94 S lb/mmBtu (where S= the % sulfur in the fuel; the percentage of sulfur in natural gas shall be assumed to be 0.00008% based on the reported maximum level of sulfur in natural gas of 2.5 grains per 100 cubic foot and a density of natural gas of 0.045 lb/scf) as specified in USEPA reference document AP-42, Fifth Edition,

Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine an hourly emissions value.

- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 0.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the performance tests are conducted, the SO₂ emissions factor for the entire combined cycle system determined by those tests shall be used to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

Emissions Unit ID: **B013**

- i. Emission Limitation: OC emissions from this emissions unit shall not exceed 2.12 lbs/hr and 8.94 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.007 lb/mmBtu (per manufacturer's emissions test data supplied by applicant) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 11 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity) to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- j. Emission Limitation: NOx emissions from this emissions unit shall not exceed 12.53 lbs/hr and 50.37 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.108 lb/mmBtu as specified by manufacturer's test data for this machine using a low NOx control system to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) by an

emissions factor of 0.10 lb/mmBtu as specified in the manufacturer's guaranteed performance data to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the NO_x emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- k. Emission Limitation: CO emissions from this emissions unit shall not exceed 12.70 lbs/hr and 43.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.082 lb/mmBtu for an uncontrolled system as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 84 lbs/million cubic feet of fuel burned at a low NO_x burner as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance

Millennium Inorganic Chemicals Inc Plt2

PTI Application: 02 12107

Modif

Facility ID: 020401019

Emissions Unit ID: B013

value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the CO emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

2. Emissions Testing Requirements:

- a. Not later than 30 days prior to the proposed test date(s) required in section A.V.2.b., the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).
- b. Within 60 days but not later than 180 days after startup of this emissions unit after the conversion of a NO_x emissions control technology to another NO_x emissions control technology (per 40 CFR 60.8), the permittee shall conduct, or have conducted, performance testing for this emissions unit in accordance with the following requirements:
 - i. The emissions testing shall be conducted to demonstrate compliance with the allowable mass emission rates for NO_x, SO₂, and CO.
 - ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
 - (1) for NO_x, Method 20 of 40 CFR Part 60, Appendix A, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or Method 7E and either EPA Method 3 or 3A of 40 CFR Part 60, Appendix A to determine NO_x and diluent concentration [as specified in 40 CFR 60.335(a)];
 - (2) for SO₂, Method 20 or Method 6C of 40 CFR Part 60, Appendix A; and
 - (3) for CO, Method 10 of 40 CFR Part 60, Appendix A.Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
 - iii. The 3-run performance NO_x tests shall be conducted while the combustion turbine portion of this emissions unit is operating within ± 5 percent at 50, 75, 90 and 100% of peak load or at four other load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-100 percent of peak load, or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. The minimum point and the maximum

Miller

PTI A

Modification Issued: 12/14/2006

Emissions Unit ID: **B013**

point turbine operating conditions 3-run sample sets shall be conducted when the duct heater is operating at or near 100% of peak capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice.

- iv. A 3-run test for SO₂ emissions shall be conducted while the duct heater portion of this emissions unit is operating at or more than 90% of rated capacity (or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice) while the combustion turbine is also at the highest achievable load point.
- v. Two 3-run tests for CO emissions shall be conducted while the combustion turbine portion of the emissions unit is operating at or near 50 and 100% of peak load, or at or near 2 points including the minimum point in the normal operating range of the gas turbine and the highest achievable load point of the gas turbine, while the duct heater is operating at or more than 90% of rated capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. (This testing may be used to establish a CO emissions factor for the combined cycle system.)
- vi. In accordance with 40 CFR 60.334(g) the steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of 40 CFR 60.334 shall be monitored during the performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to 40 CFR Part 75 and that use the low mass emissions methodology in 40 CFR 75.19 or the NO_x emission measurement methodology in appendix E of 40 CFR Part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19(e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to 40 CFR Part 75.

Emissions Unit ID: B013

- c. Personnel from the Ohio EPA Northeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- d. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.
- e. For any conversion of a NO_x emissions control technology to another NO_x emissions control technology, including dry, low NO_x emissions combustion system, additional emissions testing as specified in sections A.V.2.a. - A.V.2.d. shall be required.

VI. Miscellaneous Requirements

- 1. This emissions unit was initially installed on January 1, 2001 with a low NO_x combustor burner within the combustion turbine. This third administrative permit modification allows the use of steam injection for NO_x emissions control at the turbine.
- 2. The fuel-bound nitrogen content will be assumed to be zero as long as natural gas fuel is employed in the turbine. Therefore the permittee is exempt from the nitrogen content monitoring of the fuel specified in 40 CFR 60.334(h)(2).

Miller

PTI A

Modification Issued: 12/14/2006

Emissions Unit ID: B013

B. State Only Enforceable Section**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--------------------------------------	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S) [Continued]

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B014 - Combined cycle 65.1 mmBtu/hr (4.92 MW) natural gas-fired combustion turbine with NO _x emissions control technology (a dry, low NO _x emissions combustion system, a low NO _x steam injection system or an equivalent NO _x emissions control technology) & a 55.0 mmBtu/hr natural gas-fired duct heater/ heat recovery boilerCo. ID: combustion turbine with heat recovery boiler no. 3. THIRD MODIFICATION OF PTI 02-3197, ORIGINALLY ISSUED FEBRUARY 9, 2000, AND MODIFIED AS PTI 02-13197 ON MAY 3, 2001 AND ON AUGUST 6, 2002	OAC rule 3745-31-05(A)(3)
	OAC rule 3745-17-11(B)(4)
	OAC rule 3745-17-10(B)(1)
	OAC rule 3745-18-06(F)
	40 CFR Part 60, Subpart Dc
	OAC rule 3745-17-07(A)(1)
	40 CFR Part 60, Subpart GG
	OAC rule 3745-31-05(C) - federally enforceable restrictions to avoid PSD requirements.
	OAC rule 3745-21-08(B)

OAC rule 3745-23-06(B)

Applicable Emissions Limitations/Control Measures

Nitrogen oxides (NO_x) emissions shall not exceed 12.53 lbs/hr and 50.37 TPY; see sections A.1.2.a. and A.1.2.b. Carbon monoxide (CO) emissions shall not exceed 12.70 lbs/hr and 43.58 TPY see section A.1.2.c. Organic compound (OC) emissions shall not exceed 2.12 lbs/hr and 8.94 TPY; see section A.1.2.c. Particulate emissions (PE) shall not exceed 3.70 lbs/hr. and 14.58 TPY; see section A.1.2.f. Sulfur dioxide (SO₂) emissions shall not exceed 0.86 lb/hr and 3.46 TPY. The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A), 3745-21-08(B) and 3745-23-06(B) and the fuel sulfur content requirements of 40 CFR Part 60, Subpart GG.

NO_x emissions from the turbine shall not exceed 190.0 parts per million, by volume (ppmv), at 15% oxygen, on a dry basis ; see section A.1.2.d. The sulfur content of natural gas burned in the turbine shall not exceed 0.8 percent by weight ; see section A.1.2.d. SO₂ emissions from the turbine portion shall not exceed 0.015 percent by volume at 15% oxygen, on a dry basis ; see section A.1.2.d.

Emissions Unit ID: **B014**

The PE rate from the turbine shall not exceed 0.040 pound per million Btu of actual heat input; see section A.1.2.e.

The PE rate from the duct heater shall not exceed 0.020 lb/mmBtu of actual heat input; see section A.1.2.e.

SO₂ emissions from the turbine shall not exceed 0.5 pound per million Btu of actual heat input; see section A.1.2.d.

See section A.1.2.g.

Visible PE shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

For emissions units B013 through B017 collectively, see section A.1.2.h.

See section A.1.2.i.

See section A.1.2.j.

Modification Issued: 12/14/2006

2. Additional Terms and Conditions

- 2.a** The combustion turbine shall be equipped with a dry, low NO_x emissions combustion system, a low NO_x steam injection system or an equivalent, alternate NO_x emissions control technology.
- 2.b** The allowable rate of 12.53 lbs/hour for NO_x emissions is based on emissions factors and is established to reflect the potential to emit for this emissions unit.
- 2.c** The allowable rates of 12.70 lbs/hour for CO emissions and 2.12 lbs/hour OC emissions are based on emissions factors and are established to reflect the potential to emit for this emissions unit.
- 2.d** These emissions limitations are less stringent than the corresponding limitation(s) specified above pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** These PE rate limitations are equal to or less stringent than the corresponding limitation(s) specified below in A.I.2.f.
- 2.f** Per OAC rule 3745-17-10(B), the PE rate from the duct heater portion of this combined cycle unit shall not exceed 0.020 lb/mmBtu. Since the duct burner can not be operated independently of the combustion turbine, the weighted average particulate emissions from this combined cycle emissions unit, when operating at 100 percent load (with total combined cycle heat input of 120.1 mmBtu/hr actual heat input measured at 0° F) shall not exceed 0.0308 lb/mmBtu of actual heat input; this is equivalent to an hourly emissions rate of 3.70 pounds at 0° Fahrenheit.

Emissions Unit ID: **B014**

- 2.g** The duct heater is exempted from the SO₂ emissions limits and from the PE limits referenced in 40 CFR Part 60.42c and in 40 CFR Part 60.43c, respectively, as long as this steam generation unit burns only natural gas as a fuel.
- 2.h** The total annual emissions of NO_x and CO from these new emissions units, B013 through B017, at this facility shall be limited to 187.2 tons and 163.4 tons respectively. These annual NO_x and CO emissions limitations for emissions units B013 through B017 shall be achieved by restricting the maximum quantity of natural gas burned for these emissions units to a cumulative total volume of 3590 million cubic feet on a rolling 12-month summation basis.
- 2.i** The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

- 2.j** The permittee shall satisfy the "latest available control techniques and operating

Emissions Unit ID: **B014**

Modification Issued: 12/14/2006

practices" required pursuant to OAC rule 3745-23-06 by committing to comply with the best available technology (BAT) requirements established pursuant to OAC

Modification Issued: 12/14/2006

rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On February 15, 2005, OAC rule 3745-23-06 was rescinded; therefore, this rule is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-23-06, the requirement to satisfy the "latest available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.
2. The maximum quantity of natural gas which may be burned in emissions units B013 through B017 shall not exceed 3590 million cubic feet per year based on a rolling 12-month summation of fuel usage.
3. The fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight [from 40 CFR Part 60.333(b)].

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR 60.334(h), the permittee shall analyze and maintain records of the fuel-bound sulfur content of the natural gas fuel being fired in the turbine in the following manner:
 - a. Monitoring of the sulfur content shall be performed by either the facility, a service contractor retained by the facility, or the fuel supplier.
 - b. In accordance with 40 CFR 60.334(h)(1), analysis for total sulfur content of the natural gas fuel shall be conducted using the methods described in 40 CFR

Emissions Unit ID: **B014**

60.335(b)(10)(ii). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D4404-01, D5228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compound may be used.

i. In accordance with 40 CFR 60.334(h)(3), notwithstanding the provisions of 40 CFR 60.334(h)(1), the permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the U.S. EPA administrator for 40 CFR Part 60 subpart GG requires such monitoring. The permittee shall use one of the following sources of information to make the required demonstration:

- (1) the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
- (2) representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of 40 CFR.

c. In accordance with 40 CFR 60.334(h)(4), for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has been approved, the owner or operator may, without submitting a special petition to the U.S. EPA administrator, continue monitoring on this schedule. During the first six (6) months of operation of this emissions unit, fuel sulfur content monitoring was performed twice per month. The monitoring data showed little variability in the fuel sulfur content, and indicated consistent compliance with 40 CFR 60.333, so that sampling and analysis for fuel sulfur content shall be continue to be conducted once per quarter.

2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

Modification Issued: 12/14/2006

3. The permittee shall install, maintain, and operate a properly calibrated natural gas flow rate meter on both the combustion turbine and the duct heater portions of this emissions unit to allow for accurate determination of the fuel consumption of each portion of this combined cycle unit.
4. The permittee shall maintain monthly records of the following information:
 - a. The volume of natural gas burned in this emissions unit for the calendar month (in millions of cubic feet);
 - b. The volume of natural gas burned in emissions units B013 through B017 collectively during the month (in millions of cubic feet);
 - c. The volume of natural gas burned for the rolling, 12-month summation period for both this emissions unit and emissions units B013 through B017 collectively;
 - d. The number of hours of operation of this emissions unit for each calendar month;
 - e. The collective number of hours of operation of emissions units B013 through B017; and
 - f. A calculation of the NO_x and CO emissions from this emissions unit based on factors listed in Section A.V.1.j. & A.V.1.k. or upon an emissions factor developed from the initial performance/emissions compliance test data.
- e. The permittee shall maintain daily records of the following information for this emissions unit:
 - a. Except as provided in 40 CFR 60.334 (b) on any day when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, the permittee shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine. The permittee shall collect and record the following information each day:
 - i. the fuel consumption, in cubic feet on an hourly basis;
 - ii. the water or steam injection volume, in cubic feet, on an hourly basis;

Emissions Unit ID: **B014**

- iii. the hourly ratio of water or steam to fuel;
 - iv. if applicable, other operating parameter(s) identified in an on-site parameter monitoring plan, required by 40 CFR 60.334(g); and
 - v. the operating times for the capture (collection) system, control device, monitoring equipment, and the associated emissions unit.
- b. In accordance with 40 CFR 60.334 (b) for any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous fuel and steam(water) monitoring system described in 40 CFR 60.334(a), the permittee shall install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F of 40 CFR Part 75 and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:
- i. Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
 - (1) on a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
 - (2) on a ppm at 15 percent O₂ basis; or
 - (3) on a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).
 - ii. As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

Modification Issued: 12/14/2006

- iii. For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
 - (1) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.334(b)(2), is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under 40 CFR 60.332(a), *i.e.*, percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a diluent cap value of 19.0 percent O₂ may be used in the emission calculations.
 - (2) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.
 - (3) If the owner or operator has installed a NO_x CEMS to meet the requirements of 40 CFR Part 75, and is continuing to meet the ongoing requirements of 40 CFR Part 75, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR Part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).
- c. In accordance with 40 CFR 60.334(c) for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the permittee may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of 40 CFR 60.334(b). Also,

Emissions Unit ID: **B014**

if the permittee has previously submitted and received U.S. EPA, or Ohio EPA approval of a procedure for monitoring compliance with the applicable NO_x emissions limit under 40 CFR 60.332, that approved procedure may continue to be used.

IV. Reporting Requirements

1. The permittee shall submit annual deviation reports which identify all periods during which the sulfur content of the fuel fired in this emissions unit exceeded 0.8%, by weight. These reports shall be submitted by January 31 of each year.
2. The permittee shall submit deviation (excursion) reports that identify all periods during which the emissions limitations listed above in these terms and conditions were exceeded or the required records were not maintained. Such report shall be sent to the Northeast District Office within 30 days following the end of the calendar month during which the exceedance or deviation occurred.
3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
4. The permittee shall submit quarterly deviation (excursion) reports which identify all exceedances of the rolling, 12-month natural gas usage limitation for emissions units B013-B017.
5. Permittee shall submit an annual report which summarizes the monthly and cumulative annual hours of operation of this emissions unit. This report shall be submitted to the Northeast District Office of the Ohio EPA by January 31 of each year for data recorded during the previous calendar year.
6. The permittee shall also submit annual reports which specify the total NO_x emissions and total CO emissions (in tons per year) from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
7. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, excess emissions reports shall be submitted in accordance with 40 CFR 60.334(j). An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water fuel ration needed to demonstrate compliance with the NO_x emissions standard in 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

The permittee shall submit quarterly deviation (excursion) reports that identify all periods of time during which the operating parameter(s) does not achieve the target

Modification Issued: 12/14/2006

value or is outside the acceptable range defined in the parameter monitoring plan for the emissions unit. The quarterly report shall include the following information:

- a. date(s) and time(s) of parameter deviation;
- b. average steam or water-to-fuel ratio;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

8. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, monitor downtime reports shall be submitted in accordance with 40 CFR 60.334(j). A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ration are unavailable or invalid.

The permittee shall submit semi-annual deviation (excursion) reports that identify all periods of monitor downtime and shall include the following information:

- a. date(s) and time(s) of monitor downtime(s);
- b. average steam or water-to-fuel ratio, if available;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the

Emissions Unit ID: **B014**

worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

9. The permittee shall submit a notification report 30 days prior to any conversion from a low NO_x steam injection emissions control technology to another NO_x emissions control technology.

Modification Issued: 12/14/2006

V. Testing Requirements

1. Compliance with the emission limitation(s) and fuel restriction in Sections A.I. and A.II. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation:

- i. The PE rate from the combustion turbine portion of this emissions unit shall not exceed 0.040 lbs/mmBtu.
- ii. The PE rate from the duct heater portion of this emissions unit shall not exceed 0.020 lb/mmBtu.

Applicable Compliance Method: If required, compliance with these emission limitations shall be determined during the performance testing of this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- b. Fuel Sulfur Content Limitation: The gaseous fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight.

Applicable Compliance Method: The permittee shall determine compliance with the fuel sulfur content limitation in accordance with the procedures specified in ASTM D1072-80, 90 (Reapproved 1994); , D3246-81, 92; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17) per 40 CFR 60.335(b)(10)(ii). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the U.S. EPA administrator.

- c. Emission Limitation: Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

Modification Issued: 12/14/2006

- d. Emission Limitations: NO_x emissions from the combustion turbine portion of this emissions unit shall not exceed 190 ppmv at 15% oxygen, on a dry basis.

Applicable Compliance Method: Compliance shall be determined by using appropriate NSPS test requirements as specified in 40 CFR 60.8 and 40 CFR Part 60, Subpart GG, as they apply to an emissions unit of this type with a heat input of greater than 10 mmBtu/hr and less than 100 mmBtu/hr.

- e. Emissions Limitation: NO_x emissions from all of these new emissions units (B013 through B017) shall not exceed 187.2 TPY.

Applicable Compliance Method: Compliance with this annual NO_x emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- f. Emissions Limitation: CO emissions from all of these new emissions units (B013 through B017) shall not exceed 163.4 TPY.

Applicable Compliance Method: Compliance with this annual CO emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- g. Emission Limitation: The PE rate from this emissions unit shall not exceed 3.70 lbs/hr and 14.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.0019 lbs/mmBtu as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine

Emissions Unit ID: **B014**

an hourly emissions value.

- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 7.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above. If required pursuant to OAC rule 3745-15-04, the permittee shall demonstrate compliance with the particulate emissions limits of this permit by means of physical testing of the effluent from this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- h. Emission Limitation: SO₂ emissions from this emissions unit shall not exceed 0.86 lb/hr and 3.46 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.94 S lb/mmBtu (where S= the % sulfur in the fuel; the percentage of sulfur in natural gas shall be assumed to be 0.00008% based on the reported maximum level of sulfur in natural gas of 2.5 grains per 100 cubic foot and a density of natural gas of 0.045 lb/scf) as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 0.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution

Modification Issued: 12/14/2006

Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the performance tests are conducted, the SO₂ emissions factor for the entire combined cycle system determined by those tests shall be used to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- i. Emission Limitation: OC emissions from this emissions unit shall not exceed 2.12 lbs/hr and 8.94 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.007 lb/mmBtu (per manufacturer's emissions test data supplied by applicant) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 11 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity) to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit.

Emissions Unit ID: **B014**

Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- j. Emission Limitation: NO_x emissions from this emissions unit shall not exceed 12.53 lbs/hr and 50.37 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.108 lb/mmBtu as specified by manufacturer's test data for this machine using a low NO_x control system to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) by an emissions factor of 0.10 lb/mmBtu as specified in the manufacturer's guaranteed performance data to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the NO_x emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- k. Emission Limitation: CO emissions from this emissions unit shall not exceed 12.70 lbs/hr and 43.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.082 lb/mmBtu for an uncontrolled system as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (4/00) to determine an hourly emissions value.

Modification Issued: 12/14/2006

- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 84 lbs/million cubic feet of fuel burned at a low NO_x burner as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the CO emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

2. Emissions Testing Requirements:

- a. Not later than 30 days prior to the proposed test date(s) required in section A.V.2.b., the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).
- b. Within 60 days but not later than 180 days after startup of this emissions unit after the conversion of a NO_x emissions control technology to another NO_x emissions control technology (per 40 CFR 60.8), the permittee shall conduct, or have conducted, performance testing for this emissions unit in accordance with the following requirements:
 - i. The emissions testing shall be conducted to demonstrate compliance with

Emissions Unit ID: **B014**

the allowable mass emission rates for NO_x, SO₂, and CO.

- ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
 - (1) for NO_x, Method 20 of 40 CFR Part 60, Appendix A, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or Method 7E and either EPA Method 3 or 3A of 40 CFR Part 60, Appendix A to determine NO_x and diluent concentration [as specified in 40 CFR 60.335(a)];
 - (2) for SO₂, Method 20 or Method 6C of 40 CFR Part 60, Appendix A; and
 - (3) for CO, Method 10 of 40 CFR Part 60, Appendix A.Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
- iii. The 3-run performance NO_x tests shall be conducted while the combustion turbine portion of this emissions unit is operating within ± 5 percent at 50, 75, 90 and 100% of peak load or at four other load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-100 percent of peak load, or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. The minimum point and the maximum point turbine operating conditions 3-run sample sets shall be conducted when the duct heater is operating at or near 100% of peak capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice.
- iv. A 3-run test for SO₂ emissions shall be conducted while the duct heater portion of this emissions unit is operating at or more than 90% of rated capacity (or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice) while the combustion turbine is also at the highest achievable load point.
- v. Two 3-run tests for CO emissions shall be conducted while the combustion turbine portion of the emissions unit is operating at or near 50 and 100% of peak load, or at or near 2 points including the minimum point in the normal operating range of the gas turbine and the highest achievable load point of the gas turbine, while the duct heater is operating at or more than 90% of rated capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. (This testing may be used to establish a CO emissions factor for the combined cycle system.)
- vi. In accordance with 40 CFR 60.334(g) the steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of 40 CFR 60.334 shall be monitored during the

Emissions Unit ID: **B014**

performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to 40 CFR Part 75 and that use the low mass emissions methodology in 40 CFR 75.19 or the NO_x emission measurement methodology in appendix E of 40 CFR Part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19(e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to 40 CFR Part 75.

- c. Personnel from the Ohio EPA Northeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- d. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.
- e. For any conversion of a NO_x emissions control technology to another NO_x emissions control technology, including dry, low NO_x emissions combustion system, additional emissions testing as specified in sections A.V.2.a. - A.V.2.d. shall be required.

Modification Issued: 12/14/2006

VI. Miscellaneous Requirements

1. This emissions unit was initially installed on January 1, 2001 with a low NO_x combustor burner within the combustion turbine. This third administrative permit modification allows the use of steam injection for NO_x emissions control at the turbine.
2. The fuel-bound nitrogen content will be assumed to be zero as long as natural gas fuel is employed in the turbine. Therefore the permittee is exempt from the nitrogen content monitoring of the fuel specified in 40 CFR 60.334(h)(2).

Modification Issued: 12/14/2006

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Modification Issued: 12/14/2006

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B015 - Combined cycle 65.1 mmBtu/hr (4.92 MW) natural gas-fired combustion turbine with NO _x emissions control technology (a dry, low NO _x emissions combustion system, a low NO _x steam injection system or an equivalent NO _x emissions control technology) & a 55.0 mmBtu/hr natural gas-fired duct heater/ heat recovery boilerCo. ID: combustion turbine with heat recovery boiler no. 4. THIRD MODIFICATION OF PTI 02-3197, ORIGINALLY ISSUED FEBRUARY 9, 2000, AND MODIFIED AS PTI 02-13197 ON MAY 3, 2001 AND ON AUGUST 6, 2002	OAC rule 3745-31-05(A)(3)
	OAC rule 3745-17-11(B)(4)
	OAC rule 3745-17-10(B)(1)
	OAC rule 3745-18-06(F)
	40 CFR Part 60, Subpart GG

40 CFR Part 60, Subpart Dc	Applicable Emissions <u>Limitations/Control</u> <u>Measures</u>	Emissions Unit ID: B015 see section A.I.2.d.
OAC rule 3745-17-07(A)(1)	Nitrogen oxides (NO _x) emissions shall not exceed 12.53 lbs/hr and 50.37 TPY;	The PE rate from the turbine shall not exceed 0.040 pound per million Btu of actual heat input; see section A.I.2.e.
OAC rule 3745-31-05(C) - federally enforceable restrictions to avoid PSD requirements.	see sections A.I.2.a. and A.I.2.b. Carbon monoxide (CO) emissions shall not exceed 12.70 lbs/hr and 43.58 TPY see section A.I.2.c. Organic compound (OC) emissions shall not exceed 2.12 lbs/hr and 8.94 TPY; see section A.I.2.c. Particulate emissions (PE) shall not exceed 3.70 lbs/hr. and 14.58 TPY; see section A.I.2.f. Sulfur dioxide (SO ₂) emissions shall not exceed 0.86 lb/hr and 3.46 TPY. The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A), 3745-21-08(B) and 3745-23-06(B) and the fuel sulfur content requirements of 40 CFR Part 60, Subpart GG.	The PE rate from the duct heater shall not exceed 0.020 lb/mmBtu of actual heat input; see section A.I.2.e.
OAC rule 3745-21-08(B)		SO ₂ emissions from the turbine shall not exceed 0.5 pound per million Btu of actual heat input; see section A.I.2.d.
OAC rule 3745-23-06(B)		See section A.I.2.g.
		Visible PE shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
		For emissions units B013 through B017 <u>collectively</u> , see section A.I.2.h.
		See section A.I.2.i.
	NO _x emissions from the turbine shall not exceed 190.0 parts per million, by volume (ppmv), at 15% oxygen, on a dry basis ; see section A.I.2.d. The sulfur content of natural gas burned in the turbine shall not exceed 0.8 percent by weight ; see section A.I.2.d. SO ₂ emissions from the turbine portion shall not exceed 0.015 percent by volume at 15% oxygen, on a dry basis ;	See section A.I.2.j.

Modification Issued: 12/14/2006**2. Additional Terms and Conditions**

- 2.a** The combustion turbine shall be equipped with a dry, low NO_x emissions combustion system, a low NO_x steam injection system or an equivalent, alternate NO_x emissions control technology.
- 2.b** The allowable rate of 12.53 lbs/hour for NO_x emissions is based on emissions factors and is established to reflect the potential to emit for this emissions unit.
- 2.c** The allowable rates of 12.70 lbs/hour for CO emissions and 2.12 lbs/hour OC emissions are based on emissions factors and are established to reflect the potential to emit for this emissions unit.
- 2.d** These emissions limitations are less stringent than the corresponding limitation(s) specified above pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** These PE rate limitations are equal to or less stringent than the corresponding limitation(s) specified below in A.I.2.f.
- 2.f** Per OAC rule 3745-17-10(B), the PE rate from the duct heater portion of this combined cycle unit shall not exceed 0.020 lb/mmBtu. Since the duct burner can not be operated independently of the combustion turbine, the weighted average particulate emissions from this combined cycle emissions unit, when operating at 100 percent load (with total combined cycle heat input of 120.1 mmBtu/hr actual heat input measured at 0° F) shall not exceed 0.0308 lb/mmBtu of actual heat input; this is equivalent to an hourly emissions rate of 3.70 pounds at 0° Fahrenheit.
- 2.g** The duct heater is exempted from the SO₂ emissions limits and from the PE limits referenced in 40 CFR Part 60.42c and in 40 CFR Part 60.43c, respectively, as long as this steam generation unit burns only natural gas as a fuel.
- 2.h** The total annual emissions of NO_x and CO from these new emissions units, B013 through B017, at this facility shall be limited to 187.2 tons and 163.4 tons respectively. These annual NO_x and CO emissions limitations for emissions units B013 through B017 shall be achieved by restricting the maximum quantity of natural gas burned for these emissions units to a cumulative total volume of 3590 million cubic feet on a rolling 12-month summation basis.

Emissions Unit ID: **B015**

- 2.i** The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

- 2.j** The permittee shall satisfy the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06 by committing to comply with the best available technology (BAT) requirements established pursuant to OAC

Modification Issued: 12/14/2006

rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On February 15, 2005, OAC rule 3745-23-06 was rescinded; therefore, this rule is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-23-06, the requirement to satisfy the "latest available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.
2. The maximum quantity of natural gas which may be burned in emissions units B013 through B017 shall not exceed 3590 million cubic feet per year based on a rolling 12-month summation of fuel usage.
3. The fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight [from 40 CFR Part 60.333(b)].

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR 60.334(h), the permittee shall analyze and maintain records of the fuel-bound sulfur content of the natural gas fuel being fired in the turbine in the following manner:
 - a. Monitoring of the sulfur content shall be performed by either the facility, a service contractor retained by the facility, or the fuel supplier.
 - b. In accordance with 40 CFR 60.334(h)(1), analysis for total sulfur content of the natural gas fuel shall be conducted using the methods described in 40 CFR 60.335(b)(10)(ii). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D4404-01, D5228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compound may be used.
 - i. In accordance with 40 CFR 60.334(h)(3), notwithstanding the provisions

Emissions Unit ID: **B015**

of 40 CFR 60.334(h)(1), the permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the U.S. EPA administrator for 40 CFR Part 60 subpart GG requires such monitoring. The permittee shall use one of the following sources of information to make the required demonstration:

- (1) the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
 - (2) representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1..4 or 2.3.2.4 of appendix D to part 75 of 40 CFR.
 - c. In accordance with 40 CFR 60.334(h)(4), for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has been approved, the owner or operator may, without submitting a special petition to the U.S. EPA administrator, continue monitoring on this schedule. During the first six (6) months of operation of this emissions unit, fuel sulfur content monitoring was performed twice per month. The monitoring data showed little variability in the fuel sulfur content, and indicated consistent compliance with 40 CFR 60.333, so that sampling and analysis for fuel sulfur content shall be continue to be conducted once per quarter .
2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
 3. The permittee shall install, maintain, and operate a properly calibrated natural gas flow rate meter on both the combustion turbine and the duct heater portions of this emissions unit to allow for accurate determination of the fuel consumption of each portion of this combined cycle unit.
 4. The permittee shall maintain monthly records of the following information:
 - a. The volume of natural gas burned in this emissions unit for the calendar month (in millions of cubic feet);
 - b. The volume of natural gas burned in emissions units B013 through B017 collectively during the month (in millions of cubic feet);

Modification Issued: 12/14/2006

- c. The volume of natural gas burned for the rolling, 12-month summation period for both this emissions unit and emissions units B013 through B017 collectively;
 - d. The number of hours of operation of this emissions unit for each calendar month;
 - e. The collective number of hours of operation of emissions units B013 through B017; and
 - f. A calculation of the NO_x and CO emissions from this emissions unit based on factors listed in Section A.V.1.j. & A.V.1.k. or upon an emissions factor developed from the initial performance/emissions compliance test data.
5. The permittee shall maintain daily records of the following information for this emissions unit:
- a. Except as provided in 40 CFR 60.334 (b) on any day when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, the permittee shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine. The permittee shall collect and record the following information each day:
 - i. the fuel consumption, in cubic feet on an hourly basis;
 - ii. the water or steam injection volume, in cubic feet, on an hourly basis;
 - iii. the hourly ratio of water or steam to fuel;
 - iv. if applicable, other operating parameter(s) identified in an on-site parameter monitoring plan, required by 40 CFR 60.334(g); and
 - v. the operating times for the capture (collection) system, control device, monitoring equipment, and the associated emissions unit.
 - b. In accordance with 40 CFR 60.334 (b) for any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous fuel and steam(water) monitoring system described in 40 CFR 60.334(a), the permittee

Emissions Unit ID: **B015**

shall install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F of 40 CFR Part 75 and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

- i. Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
 - (1) on a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
 - (2) on a ppm at 15 percent O₂ basis; or
 - (3) on a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).
- ii. As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.
- iii. For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
 - (1) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.334(b)(2), is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under 40 CFR 60.332(a), *i.e.*, percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a

Modification Issued: 12/14/2006

diluent cap value of 19.0 percent O₂ may be used in the emission calculations.

- (2) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.
 - (3) If the owner or operator has installed a NO_x CEMS to meet the requirements of 40 CFR Part 75, and is continuing to meet the ongoing requirements of 40 CFR Part 75, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR Part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).
- c. In accordance with 40 CFR 60.334(c) for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the permittee may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of 40 CFR 60.334(b). Also,

Emissions Unit ID: **B015**

if the permittee has previously submitted and received U.S. EPA, or Ohio EPA approval of a procedure for monitoring compliance with the applicable NO_x emissions limit under 40 CFR 60.332, that approved procedure may continue to be used.

IV. Reporting Requirements

1. The permittee shall submit annual deviation reports which identify all periods during which the sulfur content of the fuel fired in this emissions unit exceeded 0.8%, by weight. These reports shall be submitted by January 31 of each year.
2. The permittee shall submit deviation (excursion) reports that identify all periods during which the emissions limitations listed above in these terms and conditions were exceeded or the required records were not maintained. Such report shall be sent to the Northeast District Office within 30 days following the end of the calendar month during which the exceedance or deviation occurred.
3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
4. The permittee shall submit quarterly deviation (excursion) reports which identify all exceedances of the rolling, 12-month natural gas usage limitation for emissions units B013-B017.
5. Permittee shall submit an annual report which summarizes the monthly and cumulative annual hours of operation of this emissions unit. This report shall be submitted to the Northeast District Office of the Ohio EPA by January 31 of each year for data recorded during the previous calendar year.
6. The permittee shall also submit annual reports which specify the total NO_x emissions and total CO emissions (in tons per year) from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
7. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, excess emissions reports shall be submitted in accordance with 40 CFR 60.334(j). An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water fuel ration needed to demonstrate compliance with the NO_x emissions standard in 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

The permittee shall submit quarterly deviation (excursion) reports that identify all periods of time during which the operating parameter(s) does not achieve the target

Emissions Unit ID: **B015**

value or is outside the acceptable range defined in the parameter monitoring plan for the emissions unit. The quarterly report shall include the following information:

- a. date(s) and time(s) of parameter deviation;
- b. average steam or water-to-fuel ratio;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

8. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, monitor downtime reports shall be submitted in accordance with 40 CFR 60.334(j). A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ration are unavailable or invalid.

The permittee shall submit semi-annual deviation (excursion) reports that identify all periods of monitor downtime and shall include the following information:

- a. date(s) and time(s) of monitor downtime(s);
- b. average steam or water-to-fuel ratio, if available;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

9. The permittee shall submit a notification report 30 days prior to any conversion from a low NO_x steam injection emissions control technology to another NO_x emissions control technology.

70

Millennium Inorganic Chemicals Inc Plt2
DTI Application: 02 12107

Facility ID: 020401019

Emissions Unit ID: B015

Modification Issued: 12/14/2006

V. Testing Requirements

1. Compliance with the emission limitation(s) and fuel restriction in Sections A.I. and A.II. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation:

- i. The PE rate from the combustion turbine portion of this emissions unit shall not exceed 0.040 lbs/mmBtu.
- ii. The PE rate from the duct heater portion of this emissions unit shall not exceed 0.020 lb/mmBtu.

Applicable Compliance Method: If required, compliance with these emission limitations shall be determined during the performance testing of this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- b. Fuel Sulfur Content Limitation: The gaseous fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight.

Applicable Compliance Method: The permittee shall determine compliance with the fuel sulfur content limitation in accordance with the procedures specified in ASTM D1072-80, 90 (Reapproved 1994); , D3246-81, 92; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17) per 40 CFR 60.335(b)(10)(ii). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the U.S. EPA administrator.

- c. Emission Limitation: Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

Modification Issued: 12/14/2006

- d. Emission Limitations: NO_x emissions from the combustion turbine portion of this emissions unit shall not exceed 190 ppmv at 15% oxygen, on a dry basis.

Applicable Compliance Method: Compliance shall be determined by using appropriate NSPS test requirements as specified in 40 CFR 60.8 and 40 CFR Part 60, Subpart GG, as they apply to an emissions unit of this type with a heat input of greater than 10 mmBtu/hr and less than 100 mmBtu/hr.

- e. Emissions Limitation: NO_x emissions from all of these new emissions units (B013 through B017) shall not exceed 187.2 TPY.

Applicable Compliance Method: Compliance with this annual NO_x emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- f. Emissions Limitation: CO emissions from all of these new emissions units (B013 through B017) shall not exceed 163.4 TPY.

Applicable Compliance Method: Compliance with this annual CO emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- g. Emission Limitation: The PE rate from this emissions unit shall not exceed 3.70 lbs/hr and 14.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.0019 lbs/mmBtu as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine

Emissions Unit ID: **B015**

an hourly emissions value.

- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 7.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above. If required pursuant to OAC rule 3745-15-04, the permittee shall demonstrate compliance with the particulate emissions limits of this permit by means of physical testing of the effluent from this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- h. Emission Limitation: SO₂ emissions from this emissions unit shall not exceed 0.86 lb/hr and 3.46 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.94 S lb/mmBtu (where S= the % sulfur in the fuel; the percentage of sulfur in natural gas shall be assumed to be 0.00008% based on the reported maximum level of sulfur in natural gas of 2.5 grains per 100 cubic foot and a density of natural gas of 0.045 lb/scf) as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 0.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution

Modification Issued: 12/14/2006

Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the performance tests are conducted, the SO₂ emissions factor for the entire combined cycle system determined by those tests shall be used to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- i. Emission Limitation: OC emissions from this emissions unit shall not exceed 2.12 lbs/hr and 8.94 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.007 lb/mmBtu (per manufacturer's emissions test data supplied by applicant) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 11 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity) to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit.

Emissions Unit ID: **B015**

Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- j. Emission Limitation: NO_x emissions from this emissions unit shall not exceed 12.53 lbs/hr and 50.37 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.108 lb/mmBtu as specified by manufacturer's test data for this machine using a low NO_x control system to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) by an emissions factor of 0.10 lb/mmBtu as specified in the manufacturer's guaranteed performance data to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the NO_x

Modification Issued: 12/14/2006

emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- k. Emission Limitation: CO emissions from this emissions unit shall not exceed 12.70 lbs/hr and 43.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.082 lb/mmBtu for an uncontrolled system as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 84 lbs/million cubic feet of fuel burned at a low NO_x burner as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the CO emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

2. Emissions Testing Requirements:

- a. Not later than 30 days prior to the proposed test date(s) required in section A.V.2.b., the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).
- b. Within 60 days but not later than 180 days after startup of this emissions unit after the conversion of a NO_x emissions control technology to another NO_x emissions control technology (per 40 CFR 60.8), the permittee shall conduct, or have conducted, performance testing for this emissions unit in accordance with the following requirements:
 - i. The emissions testing shall be conducted to demonstrate compliance with the allowable mass emission rates for NO_x, SO₂, and CO.
 - ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
 - (1) for NO_x, Method 20 of 40 CFR Part 60, Appendix A, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or Method 7E and either EPA Method 3 or 3A of 40 CFR Part 60, Appendix A to determine NO_x and diluent concentration [as specified in 40 CFR 60.335(a)];
 - (2) for SO₂, Method 20 or Method 6C of 40 CFR Part 60, Appendix A; and
 - (3) for CO, Method 10 of 40 CFR Part 60, Appendix A.Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
 - iii. The 3-run performance NO_x tests shall be conducted while the combustion turbine portion of this emissions unit is operating within ± 5 percent at 50, 75, 90 and 100% of peak load or at four other load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-100 percent of peak load, or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. The minimum point and the maximum point turbine operating conditions 3-run sample sets shall be conducted when the duct heater is operating at or near 100% of peak capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice.

Modification Issued: 12/14/2006

- iv. A 3-run test for SO₂ emissions shall be conducted while the duct heater portion of this emissions unit is operating at or more than 90% of rated capacity (or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice) while the combustion turbine is also at the highest achievable load point.
- v. Two 3-run tests for CO emissions shall be conducted while the combustion turbine portion of the emissions unit is operating at or near 50 and 100% of peak load, or at or near 2 points including the minimum point in the normal operating range of the gas turbine and the highest achievable load point of the gas turbine, while the duct heater is operating at or more than 90% of rated capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. (This testing may be used to establish a CO emissions factor for the combined cycle system.)
- vi. In accordance with 40 CFR 60.334(g) the steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of 40 CFR 60.334 shall be monitored during the performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to 40 CFR Part 75 and that use the low mass emissions methodology in 40 CFR 75.19 or the NO_x emission measurement methodology in appendix E of 40 CFR Part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19(e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to 40 CFR Part 75.

Emissions Unit ID: **B015**

- c. Personnel from the Ohio EPA Northeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- d. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.
- e. For any conversion of a NO_x emissions control technology to another NO_x emissions control technology, including dry, low NO_x emissions combustion system, additional emissions testing as specified in sections A.V.2.a. - A.V.2.d. shall be required.

Modification Issued: 12/14/2006

VI. Miscellaneous Requirements

1. This emissions unit was initially installed on January 1, 2001 with a low NO_x combustor burner within the combustion turbine. This third administrative permit modification allows the use of steam injection for NO_x emissions control at the turbine.
2. The fuel-bound nitrogen content will be assumed to be zero as long as natural gas fuel is employed in the turbine. Therefore the permittee is exempt from the nitrogen content monitoring of the fuel specified in 40 CFR 60.334(h)(2).

Modification Issued: 12/14/2006

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B016 - Combined cycle 65.1 mmBtu/hr (4.92 MW) natural gas-fired combustion turbine with NO _x emissions control technology (a dry, low NO _x emissions combustion system, a low NO _x steam injection system or an equivalent NO _x emissions control technology) & a 55.0 mmBtu/hr natural gas-fired duct heater/ heat recovery boiler. ID: combustion turbine with heat recovery boiler no. 5. THIRD MODIFICATION OF PTI 02-3197, ORIGINALLY ISSUED FEBRUARY 9, 2000, AND MODIFIED AS PTI 02-13197 ON MAY 3, 2001 AND ON AUGUST 6, 2002	OAC rule 3745-31-05(A)(3) OAC rule 3745-17-11(B)(4) OAC rule 3745-17-10(B)(1) OAC rule 3745-18-06(F) 40 CFR Part 60, Subpart Dc OAC rule 3745-17-07(A)(1) 40 CFR Part 60, Subpart GG OAC rule 3745-31-05(C) - federally enforceable restrictions to avoid PSD requirements.

OAC rule 3745-21-08(B)	Applicable Emissions <u>Limitations/Control Measures</u>	Emissions Unit ID: B016 The PE rate from the turbine shall not exceed 0.040 pound per million Btu of actual heat input; see section A.I.2.e.
OAC rule 3745-23-06(B)	<p>Nitrogen oxides (NO_x) emissions shall not exceed 12.53 lbs/hr and 50.37 TPY; see sections A.I.2.a. and A.I.2.b. Carbon monoxide (CO) emissions shall not exceed 12.70 lbs/hr and 43.58 TPY see section A.I.2.c. Organic compound (OC) emissions shall not exceed 2.12 lbs/hr and 8.94 TPY; see section A.I.2.c. Particulate emissions (PE) shall not exceed 3.70 lbs/hr. and 14.58 TPY; see section A.I.2.f. Sulfur dioxide (SO₂) emissions shall not exceed 0.86 lb/hr and 3.46 TPY. The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A), 3745-21-08(B) and 3745- 23-06(B) and the fuel sulfur content requirements of 40 CFR Part 60, Subpart GG.</p> <p>NO_x emissions from the turbine shall not exceed 190.0 parts per million, by volume (ppmv), at 15% oxygen, on a dry basis ; see section A.I.2.d. The sulfur content of natural gas burned in the turbine shall not exceed 0.8 percent by weight ; see section A.I.2.d. SO₂ emissions from the turbine portion shall not exceed 0.015 percent by volume at 15% oxygen, on a dry basis ; see section A.I.2.d.</p>	<p>The PE rate from the duct heater shall not exceed 0.020 lb/mmBtu of actual heat input; see section A.I.2.e.</p> <p>SO₂ emissions from the turbine shall not exceed 0.5 pound per million Btu of actual heat input; see section A.I.2.d.</p> <p>See section A.I.2.g.</p> <p>Visible PE shall not exceed 20% opacity as a 6-minute average, except as provided by rule.</p> <p>For emissions units B013 through B017 <u>collectively</u>, see section A.I.2.h.</p> <p>See section A.I.2.i.</p> <p>See section A.I.2.j.</p>

Modification Issued: 12/14/2006**2. Additional Terms and Conditions**

- 2.a** The combustion turbine shall be equipped with a dry, low NO_x emissions combustion system, a low NO_x steam injection system or an equivalent, alternate NO_x emissions control technology.
- 2.b** The allowable rate of 12.53 lbs/hour for NO_x emissions is based on emissions factors and is established to reflect the potential to emit for this emissions unit.
- 2.c** The allowable rates of 12.70 lbs/hour for CO emissions and 2.12 lbs/hour OC emissions are based on emissions factors and are established to reflect the potential to emit for this emissions unit.
- 2.d** These emissions limitations are less stringent than the corresponding limitation(s) specified above pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** These PE rate limitations are equal to or less stringent than the corresponding limitation(s) specified below in A.I.2.f.
- 2.f** Per OAC rule 3745-17-10(B), the PE rate from the duct heater portion of this combined cycle unit shall not exceed 0.020 lb/mmBtu. Since the duct burner can not be operated independently of the combustion turbine, the weighted average particulate emissions from this combined cycle emissions unit, when operating at 100 percent load (with total combined cycle heat input of 120.1 mmBtu/hr actual heat input measured at 0° F) shall not exceed 0.0308 lb/mmBtu of actual heat input; this is equivalent to an hourly emissions rate of 3.70 pounds at 0° Fahrenheit.
- 2.g** The duct heater is exempted from the SO₂ emissions limits and from the PE limits referenced in 40 CFR Part 60.42c and in 40 CFR Part 60.43c, respectively, as long as this steam generation unit burns only natural gas as a fuel.
- 2.h** The total annual emissions of NO_x and CO from these new emissions units, B013 through B017, at this facility shall be limited to 187.2 tons and 163.4 tons respectively. These annual NO_x and CO emissions limitations for emissions units B013 through B017 shall be achieved by restricting the maximum quantity of natural gas burned for these emissions units to a cumulative total volume of 3590 million cubic feet on a rolling 12-month summation basis.

Emissions Unit ID: **B016**

- 2.i** The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

- 2.j** The permittee shall satisfy the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06 by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On February 15, 2005, OAC rule 3745-23-06 was rescinded; therefore, this rule is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-23-06, the requirement to satisfy the "latest available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.
2. The maximum quantity of natural gas which may be burned in emissions units B013 through B017 shall not exceed 3590 million cubic feet per year based on a rolling 12-month summation of fuel usage.
3. The fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight [from 40 CFR Part 60.333(b)].

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR 60.334(h), the permittee shall analyze and maintain records of the fuel-bound sulfur content of the natural gas fuel being fired in the turbine in the following manner:
 - a. Monitoring of the sulfur content shall be performed by either the facility, a

Modification Issued: 12/14/2006

service contractor retained by the facility, or the fuel supplier.

- b. In accordance with 40 CFR 60.334(h)(1), analysis for total sulfur content of the natural gas fuel shall be conducted using the methods described in 40 CFR 60.335(b)(10)(ii). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D4404-01, D5228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compound may be used.
- i. In accordance with 40 CFR 60.334(h)(3), notwithstanding the provisions of 40 CFR 60.334(h)(1), the permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the U.S. EPA administrator for 40 CFR Part 60 subpart GG requires such monitoring. The permittee shall use one of the following sources of information to make the required demonstration:
 - (1) the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
 - (2) representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of 40 CFR.
- c. In accordance with 40 CFR 60.334(h)(4), for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has been approved, the owner or operator may, without submitting a special petition to the U.S. EPA administrator, continue monitoring on this schedule. During the first six (6) months of operation of this emissions unit, fuel sulfur content monitoring was performed twice per month. The monitoring data showed little variability in the fuel sulfur content, and indicated consistent compliance with 40 CFR 60.333, so that sampling and analysis for fuel sulfur content shall be continue to be conducted once per quarter .

Emissions Unit ID: **B016**

2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
3. The permittee shall install, maintain, and operate a properly calibrated natural gas flow rate meter on both the combustion turbine and the duct heater portions of this emissions unit to allow for accurate determination of the fuel consumption of each portion of this combined cycle unit.
4. The permittee shall maintain monthly records of the following information:
 - a. The volume of natural gas burned in this emissions unit for the calendar month (in millions of cubic feet);
 - b. The volume of natural gas burned in emissions units B013 through B017 collectively during the month (in millions of cubic feet);
 - c. The volume of natural gas burned for the rolling, 12-month summation period for both this emissions unit and emissions units B013 through B017 collectively;
 - d. The number of hours of operation of this emissions unit for each calendar month;
 - e. The collective number of hours of operation of emissions units B013 through B017; and
 - f. A calculation of the NO_x and CO emissions from this emissions unit based on factors listed in Section A.V.1.j. & A.V.1.k. or upon an emissions factor developed from the initial performance/emissions compliance test data.
5. The permittee shall maintain daily records of the following information for this emissions unit:
 - a. Except as provided in 40 CFR 60.334 (b) on any day when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, the permittee shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine. The permittee shall collect and record the following information each day:
 - i. the fuel consumption, in cubic feet on an hourly basis;
 - ii. the water or steam injection volume, in cubic feet, on an hourly basis;
 - iii. the hourly ratio of water or steam to fuel;

Modification Issued: 12/14/2006

- iv. if applicable, other operating parameter(s) identified in an on-site parameter monitoring plan, required by 40 CFR 60.334(g); and
 - v. the operating times for the capture (collection) system, control device, monitoring equipment, and the associated emissions unit.
- b. In accordance with 40 CFR 60.334 (b) for any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous fuel and steam(water) monitoring system described in 40 CFR 60.334(a), the permittee shall install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F of 40 CFR Part 75 and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:
- i. Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
 - (1) on a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
 - (2) on a ppm at 15 percent O₂ basis; or
 - (3) on a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).
 - ii. As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which

Emissions Unit ID: **B016**

the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

- iii. For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
 - (1) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.334(b)(2), is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under 40 CFR 60.332(a), *i.e.*, percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a diluent cap value of 19.0 percent O₂ may be used in the emission calculations.
 - (2) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.
 - (3) If the owner or operator has installed a NO_x CEMS to meet the requirements of 40 CFR Part 75, and is continuing to meet the ongoing requirements of 40 CFR Part 75, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR Part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).
- c. In accordance with 40 CFR 60.334(c) for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the permittee may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of 40 CFR 60.334(b). Also, if the permittee has previously submitted and received U.S. EPA, or Ohio EPA approval of a procedure for monitoring compliance with the applicable NO_x emissions limit under 40 CFR 60.332, that approved procedure may continue to be used.

IV. Reporting Requirements

1. The permittee shall submit annual deviation reports which identify all periods during which the sulfur content of the fuel fired in this emissions unit exceeded 0.8%, by weight. These reports shall be submitted by January 31 of each year.
2. The permittee shall submit deviation (excursion) reports that identify all periods during which the emissions limitations listed above in these terms and conditions were exceeded or the required records were not maintained. Such report shall be sent to the Northeast District Office within 30 days following the end of the calendar month during which the exceedance or deviation occurred.
3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
4. The permittee shall submit quarterly deviation (excursion) reports which identify all exceedances of the rolling, 12-month natural gas usage limitation for emissions units B013-B017.
5. Permittee shall submit an annual report which summarizes the monthly and cumulative annual hours of operation of this emissions unit. This report shall be submitted to the Northeast District Office of the Ohio EPA by January 31 of each year for data recorded during the previous calendar year.
6. The permittee shall also submit annual reports which specify the total NO_x emissions and total CO emissions (in tons per year) from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
7. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, excess emissions reports shall be submitted in accordance with 40 CFR 60.334(j). An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water fuel ration needed to demonstrate compliance with the NO_x emissions standard in 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

The permittee shall submit quarterly deviation (excursion) reports that identify all periods of time during which the operating parameter(s) does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the emissions unit. The quarterly report shall include the following information:

- a. date(s) and time(s) of parameter deviation;

Modification Issued: 12/14/2006

- b. average steam or water-to-fuel ratio;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

8. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, monitor downtime reports shall be submitted in accordance with 40 CFR 60.334(j). A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ration are unavailable or invalid.

The permittee shall submit semi-annual deviation (excursion) reports that identify all periods of monitor downtime and shall include the following information:

- a. date(s) and time(s) of monitor downtime(s);
- b. average steam or water-to-fuel ratio, if available;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

9. The permittee shall submit a notification report 30 days prior to any conversion from a low NO_x steam injection emissions control technology to another NO_x emissions control

technology.

Modification Issued: 12/14/2006

V. Testing Requirements

1. Compliance with the emission limitation(s) and fuel restriction in Sections A.I. and A.II. of these terms and conditions shall be determined in accordance with the following method(s):

- a. Emission Limitation:

- i. The PE rate from the combustion turbine portion of this emissions unit shall not exceed 0.040 lbs/mmBtu.
- ii. The PE rate from the duct heater portion of this emissions unit shall not exceed 0.020 lb/mmBtu.

Applicable Compliance Method: If required, compliance with these emission limitations shall be determined during the performance testing of this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- b. Fuel Sulfur Content Limitation: The gaseous fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight.

Applicable Compliance Method: The permittee shall determine compliance with the fuel sulfur content limitation in accordance with the procedures specified in ASTM D1072-80, 90 (Reapproved 1994); , D3246-81, 92; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17) per 40 CFR 60.335(b)(10)(ii). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the U.S. EPA administrator.

- c. Emission Limitation: Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

Modification Issued: 12/14/2006

- d. Emission Limitations: NO_x emissions from the combustion turbine portion of this emissions unit shall not exceed 190 ppmv at 15% oxygen, on a dry basis.

Applicable Compliance Method: Compliance shall be determined by using appropriate NSPS test requirements as specified in 40 CFR 60.8 and 40 CFR Part 60, Subpart GG, as they apply to an emissions unit of this type with a heat input of greater than 10 mmBtu/hr and less than 100 mmBtu/hr.

- e. Emissions Limitation: NO_x emissions from all of these new emissions units (B013 through B017) shall not exceed 187.2 TPY.

Applicable Compliance Method: Compliance with this annual NO_x emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- f. Emissions Limitation: CO emissions from all of these new emissions units (B013 through B017) shall not exceed 163.4 TPY.

Applicable Compliance Method: Compliance with this annual CO emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- g. Emission Limitation: The PE rate from this emissions unit shall not exceed 3.70 lbs/hr and 14.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.0019 lbs/mmBtu as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine

Emissions Unit ID: **B016**

an hourly emissions value.

- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 7.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above. If required pursuant to OAC rule 3745-15-04, the permittee shall demonstrate compliance with the particulate emissions limits of this permit by means of physical testing of the effluent from this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- h. Emission Limitation: SO₂ emissions from this emissions unit shall not exceed 0.86 lb/hr and 3.46 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.94 S lb/mmBtu (where S= the % sulfur in the fuel; the percentage of sulfur in natural gas shall be assumed to be 0.00008% based on the reported maximum level of sulfur in natural gas of 2.5 grains per 100 cubic foot and a density of natural gas of 0.045 lb/scf) as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 0.6 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution

Modification Issued: 12/14/2006

Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the performance tests are conducted, the SO₂ emissions factor for the entire combined cycle system determined by those tests shall be used to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- i. Emission Limitation: OC emissions from this emissions unit shall not exceed 2.12 lbs/hr and 8.94 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.007 lb/mmBtu (per manufacturer's emissions test data supplied by applicant) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 11 lbs/million cubic feet of fuel burned as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity) to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit.

Emissions Unit ID: **B016**

Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- j. Emission Limitation: NO_x emissions from this emissions unit shall not exceed 12.53 lbs/hr and 50.37 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.108 lb/mmBtu as specified by manufacturer's test data for this machine using a low NO_x control system to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) by an emissions factor of 0.10 lb/mmBtu as specified in the manufacturer's guaranteed performance data to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the NO_x

Modification Issued: 12/14/2006

emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

- k. Emission Limitation: CO emissions from this emissions unit shall not exceed 12.70 lbs/hr and 43.58 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined in the following manner:

- i. For the combustion turbine portion of this emissions unit, multiply the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0^o F for hourly emissions or 55.65 mmBtu/hr at 55^o F for annual emissions) by an emissions factor of 0.082 lb/mmBtu for an uncontrolled system as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (4/00) to determine an hourly emissions value.
- ii. For the duct heater portion of this emissions unit, multiply the maximum hourly fuel usage, as determined using the maximum rated heat input capacity of the emissions unit (55.0 mmBtu/hr) and a figure of 1000 Btu/cubic foot for the caloric value of natural gas, by an emissions factor of 84 lbs/million cubic feet of fuel burned at a low NO_x burner as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 1.4, Table 1.4-1 & 2 (7/98) (for industrial boilers of less than 100 mmBtu/hr heat input capacity), to determine an hourly emissions value.

The calculated hourly emissions for the combustion turbine component should then be added to the calculated emissions for the duct heater component of this emissions unit to determine the compliance value for the entire emissions unit. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the CO emissions factor for the entire combined cycle system in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions limit to the annual hours of operation as recorded per A.III above.

2. Emissions Testing Requirements:

- a. Not later than 30 days prior to the proposed test date(s) required in section A.V.2.b., the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters,

Modification Issued: 12/14/2006

the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).

- b. Within 60 days but not later than 180 days after startup of this emissions unit after the conversion of a NO_x emissions control technology to another NO_x emissions control technology (per 40 CFR 60.8), the permittee shall conduct, or have conducted, performance testing for this emissions unit in accordance with the following requirements:
- i. The emissions testing shall be conducted to demonstrate compliance with the allowable mass emission rates for NO_x, SO₂, and CO.
 - ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
 - (1) for NO_x, Method 20 of 40 CFR Part 60, Appendix A, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or Method 7E and either EPA Method 3 or 3A of 40 CFR Part 60, Appendix A to determine NO_x and diluent concentration [as specified in 40 CFR 60.335(a)];
 - (2) for SO₂, Method 20 or Method 6C of 40 CFR Part 60, Appendix A; and
 - (3) for CO, Method 10 of 40 CFR Part 60, Appendix A.Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
 - iii. The 3-run performance NO_x tests shall be conducted while the combustion turbine portion of this emissions unit is operating within ± 5 percent at 50, 75, 90 and 100% of peak load or at four other load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-100 percent of peak load, or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. The minimum point and the maximum point turbine operating conditions 3-run sample sets shall be conducted when the duct heater is operating at or near 100% of peak capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice.
 - iv. A 3-run test for SO₂ emissions shall be conducted while the duct heater

Modification Issued: 12/14/2006

portion of this emissions unit is operating at or more than 90% of rated capacity (or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice) while the combustion turbine is also at the highest achievable load point.

- v. Two 3-run tests for CO emissions shall be conducted while the combustion turbine portion of the emissions unit is operating at or near 50 and 100% of peak load, or at or near 2 points including the minimum point in the normal operating range of the gas turbine and the highest achievable load point of the gas turbine, while the duct heater is operating at or more than 90% of rated capacity or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice. (This testing may be used to establish a CO emissions factor for the combined cycle system.)
 - vi. In accordance with 40 CFR 60.334(g) the steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of 40 CFR 60.334 shall be monitored during the performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to 40 CFR Part 75 and that use the low mass emissions methodology in 40 CFR 75.19 or the NO_x emission measurement methodology in appendix E of 40 CFR Part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19(e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to 40 CFR Part 75.
- c. Personnel from the Ohio EPA Northeast District Office shall be permitted to

Emissions Unit ID: **B016**

witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

- d. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.
- e. For any conversion of a NO_x emissions control technology to another NO_x emissions control technology, including dry, low NO_x emissions combustion system, additional emissions testing as specified in sections A.V.2.a. - A.V.2.d. shall be required.

VI. Miscellaneous Requirements

- 1. This emissions unit was initially installed on January 1, 2001 with a low NO_x combustor burner within the combustion turbine. This third administrative permit modification allows the use of steam injection for NO_x emissions control at the turbine.
- 2. The fuel-bound nitrogen content will be assumed to be zero as long as natural gas fuel is employed in the turbine. Therefore the permittee is exempt from the nitrogen content monitoring of the fuel specified in 40 CFR 60.334(h)(2).

Modification Issued: 12/14/2006

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Modification Issued: 12/14/2006

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B017 - Combined cycle 65.1 mmBtu/hr (4.92 MW) natural gas-fired combustion turbine with NO _x emissions control technology (a dry, low NO _x combustor burner or a steam injection system) with a heat recovery steam generator; Co. ID: combustion turbine no. 1. THIRD MODIFICATION OF PTI 02-3197, ORIGINALLY ISSUED FEBRUARY 9, 2000, AND MODIFIED AS PTI 02-13197 ON MAY 3, 2001 AND ON AUGUST 6, 2002	OAC rule 3745-31-05(A)(3)
	OAC rule 3745-17-11(B)(4)
	OAC rule 3745-18-06(F)
	OAC rule 3745-17-07(A)
	40 CFR Part 60, Subpart GG
	OAC rule 3745-31-05(C) - federally enforceable restrictions to avoid PSD requirements.
	OAC rule 3745-21-08(B)
OAC rule 375-23-06(B)	

Applicable Emissions
Limitations/Control Measures

Nitrogen oxides (NO_x) emissions unit shall not exceed 7.03 lbs/hr and 26.28 TPY; see sections A.I.2.a. and A.I.2.b. Carbon monoxide (CO) emissions shall not exceed 8.57 lbs/hr and 25.49 TPY; see section A.I.2.c. Organic compound (OC) emissions shall not exceed 0.46 lb/hr and 1.71 TPY; see A.I.2.c. Particulate emissions (PE) unit shall not exceed 2.60 lbs/hr. and 9.76 TPY. Sulfur dioxide (SO₂) emissions shall not exceed 0.46 lb/hr and 1.71 TPY.

NO_x emissions from the turbine shall not exceed 190.0 parts per million, by volume (ppmv), at 15% oxygen, on a dry basis; see section A.I.2.d. The sulfur content of natural gas burned in the turbine shall not exceed 0.8 percent by weight; see section A.I.2.d. SO₂ emissions from the turbine shall not exceed 0.015 percent by volume at 15% oxygen, on a dry basis; see section A.I.2.d.

The PE rate from the turbine shall not exceed 0.040 pound per million Btu of actual heat input; see section A.I.2.d.

The SO₂ emissions from the turbine shall not exceed 0.5 pound per million Btu of actual heat input; see section A.I.2.d.

Visible PE shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

For emissions unit B013 through B017 collectively, see section A.I.2.e.

See section A.I.2.f.

See section A.I.2.g.

Modification Issued: 12/14/2006

2. Additional Terms and Conditions

- 2.a** The combustion turbine shall be equipped with a dry, low NO_x emissions combustion system, a low NO_x steam injection system or an equivalent, alternate NO_x emissions control technology.
- 2.b** The allowable rate of 7.03 lbs/hour NO_x emissions is based on emissions factors and is established to reflect the potential to emit for this emissions unit.
- 2.c** The allowable rates of 8.57 lbs/hour for CO emissions and 0.46 lb/hour OC emissions are based on emissions factors and are established to reflect the potential to emit for this emissions unit. Therefore, it is not necessary to develop record keeping and/or reporting requirements to ensure compliance with these limits.
- 2.d** These emissions limitations are either equal to, or less stringent than, the corresponding limitation(s) specified in above in Section A.I.1 pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** The total annual emissions of NO_x and CO from these new emissions units, B013 through B017, at this facility shall be limited to 187.2 tons and 163.4 tons respectively. These annual NO_x and CO emissions limitations for emissions units B013 through B017 shall be achieved by restricting the maximum quantity of natural gas burned for these emissions units to a cumulative total volume of 3590 million cubic feet on a rolling 12-month summation basis.
- 2.f** The permittee shall satisfy the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for

Ohio.

- 2.g** The permittee shall satisfy the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06 by committing to comply with the best available technology (BAT) requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install. The design of the emissions unit and the technology associated with the current operating practices satisfy the BAT requirements.

On February 15, 2005, OAC rule 3745-23-06 was rescinded; therefore, this rule is no longer part of the State regulations. This rule revision was submitted to the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Until the U.S. EPA approves the revision to OAC rule 3745-23-06, the requirement to satisfy the "latest available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.
2. The maximum quantity of natural gas which may be burned in emissions units B013 through B017 shall not exceed 3590 million cubic feet per year based on a rolling 12-month summation of fuel usage.
3. The fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight [from 40 CFR Part 60.333(b)].

III. Monitoring and/or Recordkeeping Requirements

1. In accordance with 40 CFR 60.334(h), the permittee shall analyze and maintain records of the fuel-bound sulfur content of the natural gas fuel in the following manner:
 - a. Monitoring of the sulfur content shall be performed by either the facility, a service contractor retained by the facility, or the fuel supplier.
 - b. In accordance with 40 CFR 60.334(h)(1), analysis for total sulfur content of the natural gas fuel shall be conducted using the methods described in 40 CFR 60.335(b)(10)(ii). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D4404-01, D5228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compound may be used.
 - i. In accordance with 40 CFR 60.334(h)(3), notwithstanding the provisions of 40 CFR 60.334(h)(1), the permittee may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous

Modification Issued: 12/14/2006

fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the U.S. EPA administrator for 40 CFR Part 60 subpart GG requires such monitoring. The permittee shall use one of the following sources of information to make the required demonstration:

- (1) the gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
 - (2) representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20.0 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1..4 or 2.3.2.4 of appendix D to part 75 of 40 CFR.
- c. In accordance with 40 CFR 60.334(h)(4), for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has been approved, the owner or operator may, without submitting a special petition to the U.S. EPA administrator, continue monitoring on this schedule. During the first six (6) months of operation of this emissions unit, fuel sulfur content monitoring was performed twice per month. The monitoring data showed little variability in the fuel sulfur content, and indicated consistent compliance with 40 CFR 60.333, so that sampling and analysis for fuel sulfur content shall be continue to be conducted once per quarter.
2. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
 3. The permittee shall install, maintain, and operate a properly calibrated natural gas flow rate meter on this emissions unit to allow for accurate determination of the fuel consumption of this combustion turbine.
 4. The permittee shall maintain monthly records of the following information:
 - a. The volume of natural gas burned in this emissions unit for the calendar month (in millions of cubic feet);

Emissions Unit ID: **B017**

- b. The volume of natural gas burned in emissions units B013 through B017 collectively during the month (in millions of cubic feet);
 - c. The volume of natural gas burned for the rolling, 12-month summation period for both this emissions unit and emissions units B013 through B017 collectively;
 - d. The number of hours of operation of this emissions unit for each calendar month;
 - e. The collective number of hours of operation of emissions units B013 through B017; and
 - f. A calculation of the NO_x and CO emissions from this emissions unit based on factors listed in Section A.V.1.j. & A.V.1.k. or upon an emissions factor developed from the initial performance/emissions compliance test data.
5. The permittee shall maintain daily records of the following information for this emissions unit:
- a. Except as provided in 40 CFR 60.334 (b) on any day when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, the permittee shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine. The permittee shall collect and record the following information each day:
 - i. the fuel consumption, in cubic feet on an hourly basis;
 - ii. the water or steam injection volume, in cubic feet, on an hourly basis;
 - iii. the hourly ratio of water or steam to fuel;
 - iv. if applicable, other operating parameter(s) identified in an on-site parameter monitoring plan, required by 40 CFR 60.334(g); and
 - v. the operating times for the capture (collection) system, control device, monitoring equipment, and the associated emissions unit.
 - b. In accordance with 40 CFR 60.334 (b) for any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_x emissions may, as an alternative to operating the continuous fuel and steam(water) monitoring system described in 40 CFR 60.334(a), the permittee shall install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_x and O₂ monitors. As an alternative, a CO₂ monitor may be used to adjust the measured NO_x

Modification Issued: 12/14/2006

concentrations to 15 percent O₂ by either converting the CO₂ hourly averages to equivalent O₂ concentrations using Equation F-14a or F-14b in appendix F of 40 CFR Part 75 and making the adjustments to 15 percent O₂, or by using the CO₂ readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

- i. Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_x and diluent monitors may be performed individually or on a combined basis, *i.e.*, the relative accuracy tests of the CEMS may be performed either:
 - (1) on a ppm basis (for NO_x) and a percent O₂ basis for oxygen; or
 - (2) on a ppm at 15 percent O₂ basis; or
 - (3) on a ppm basis (for NO_x) and a percent CO₂ basis (for a CO₂ monitor that uses the procedures in Method 20 to correct the NO_x data to 15 percent O₂).
- ii. As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.
- iii. For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
 - (1) For each unit operating hour in which a valid hourly average, as described in 40 CFR 60.334(b)(2), is obtained for both NO_x and diluent, the data acquisition and handling system must calculate and record the hourly NO_x emissions in the units of the applicable NO_x emission standard under 40 CFR 60.332(a), *i.e.*, percent NO_x by volume, dry basis, corrected to 15 percent O₂ and International

Emissions Unit ID: **B017**

Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O₂ concentration exceeds 19.0 percent O₂, a diluent cap value of 19.0 percent O₂ may be used in the emission calculations.

- (2) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H_o), minimum ambient temperature (T_a), and minimum combustor inlet absolute pressure (P_o) into the ISO correction equation.
 - (3) If the owner or operator has installed a NO_x CEMS to meet the requirements of 40 CFR Part 75, and is continuing to meet the ongoing requirements of 40 CFR Part 75, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR Part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).
- c. In accordance with 40 CFR 60.334(c) for any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO_x emissions, the permittee may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of 40 CFR 60.334(b). Also, if the permittee has previously submitted and received U.S. EPA, or Ohio EPA approval of a procedure for monitoring compliance with the applicable NO_x emissions limit under 40 CFR 60.332, that approved procedure may continue to be used.

IV. Reporting Requirements

1. The permittee shall submit annual deviation reports which identify all periods during which the sulfur content of the fuel fired in this emissions unit exceeded 0.8%, by weight. These reports shall be submitted by January 31 of each year.
2. The permittee shall submit deviation (excursion) reports that identify all periods during which the emissions limitations listed above in these terms and conditions were exceeded or the required records were not maintained. Such report shall be sent to the Northeast District Office within 30 days following the end of the calendar month during which the exceedance or deviation occurred.
3. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be

Modification Issued: 12/14/2006

submitted within 30 days after the deviation occurs.

4. The permittee shall submit quarterly deviation (excursion) reports which identify all exceedances of the rolling, 12-month natural gas usage limitation for emissions units B013-B017.
5. Permittee shall submit an annual report which summarizes the monthly and cumulative annual hours of operation of this emissions unit. This report shall be submitted to the Northeast District Office of the Ohio EPA by January 31 of each year for data recorded during the previous calendar year.
6. The permittee shall also submit annual reports which specify the total NO_x emissions and total CO emissions (in tons per year) from this emissions unit for the previous calendar year. These reports shall be submitted by January 31 of each year.
7. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, excess emissions reports shall be submitted in accordance with 40 CFR 60.334(j). An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water fuel ration needed to demonstrate compliance with the NO_x emissions standard in 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

The permittee shall submit quarterly deviation (excursion) reports that identify all periods of time during which the operating parameter(s) does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the emissions unit. The quarterly report shall include the following information:

- a. date(s) and time(s) of parameter deviation;
- b. average steam or water-to-fuel ratio;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury, and humidity in percent); and
- e. gas turbine load, in kilowatts.

Emissions Unit ID: B017

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

8. For any period when a low NO_x steam injection system or another similar fluid injection NO_x emissions control technology is employed at the combustion turbine, monitor downtime reports shall be submitted in accordance with 40 CFR 60.334(j). A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ration are unavailable or invalid.

The permittee shall submit semi-annual deviation (excursion) reports that identify all periods of monitor downtime and shall include the following information:

- a. date(s) and time(s) of monitor downtime(s);
- b. average steam or water-to-fuel ratio, if available;
- c. average fuel consumption, in cubic feet;
- d. ambient conditions (temperature in Fahrenheit or Celsius, pressure in inches of mercury and humidity in percent); and
- e. gas turbine load, in kilowatts.

The ambient conditions do not need to be reported if the permittee opts to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if the ISO correction equation under the provisions of 40 CFR 60.335(b)(1) are employed.

9. The permittee shall submit a notification report 30 days prior to any conversion from a low NO_x steam injection emissions control technology to another NO_x emissions control technology.

V. Testing Requirements

1. Compliance with the emission limitation(s) and fuel restriction in Sections A.I. and A.II. of these terms and conditions shall be determined in accordance with the following method(s):
 - a. Emission Limitation: The PE rates from this emissions unit shall not exceed 0.040 lbs/mmBtu.

Applicable Compliance Method: If required, compliance with these emission limitations shall be determined during the performance testing of this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A,

Modification Issued: 12/14/2006

Methods 1-5 .

- b. Fuel Sulfur Content Limitation: The gaseous fuel burned in this emissions unit shall not contain sulfur in excess of 0.8%, by weight.

Applicable Compliance Method: The permittee shall determine compliance with the fuel sulfur content limitation in accordance with the procedures specified in ASTM D1072-80, 90 (Reapproved 1994); , D3246-81, 92; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17) per 40 CFR 60.335(b)(10)(ii). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the U.S. EPA administrator.

- c. Emission Limitation: Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

- d. Emission Limitations: NO_x emissions this emissions unit shall not exceed 190 ppmv at 15% oxygen, on a dry basis.

Applicable Compliance Method: Compliance shall be determined by using appropriate NSPS test requirements as specified in 40 CFR 60.8 and 40 CFR Part 60, Subpart GG, as they apply to an emissions unit of this type with a heat input of greater than 10 mmBtu/hr and less than 100 mmBtu/hr.

- e. Emissions Limitation: NO_x emissions from all of these new emissions units (B013 through B017) shall not exceed 187.2 TPY.

Applicable Compliance Method: Compliance with this annual NO_x emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

Emissions Unit ID: **B017**

- f. Emissions Limitation: CO emissions from all of these new emissions units (B013 through B017) shall not exceed 163.4 TPY.

Applicable Compliance Method: Compliance with this annual CO emissions limitation for B013 through B017 shall be determined through calculations utilizing collective natural gas utilization and emission units operating hours data recorded above and emissions factors established for both the combined cycle units (B013 through B016) and the single cycle unit (B017) during the required performance tests.

- g. Emission Limitation: The PE rates from this emissions unit shall not exceed 2.60 lbs/hr and 9.76 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined by multiplying the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.0019 lbs/mmBtu as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00), to determine an hourly emissions value. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions value (annual) to the annual hours of operation as recorded per A.III above. If required pursuant to OAC rule 3745-15-04, the permittee shall demonstrate compliance with the particulate emissions limits of this permit by means of physical testing of the effluent from this emissions unit in accordance with testing procedures listed in 40 CFR Part 60, Appendix A, Methods 1-5 .

- h. Emission Limitation: SO₂ emissions from this emissions unit shall not exceed 0.46 lb/hr and 1.71 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined by multiplying the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.94S lb/mmBtu (where S= the % sulfur in the fuel; the percentage of sulfur in natural gas shall be assumed to be 0.00008% based on the reported maximum level of sulfur in natural gas of 2.5 grains per 100 cubic foot and a density of natural gas of 0.045lb/scf) as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-2a (4/00) , to determine an hourly emissions value. After the performance tests are conducted, the SO₂ emissions factor for this combustion turbine determined by those tests shall be used to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions value (annual) to the annual hours of operation as recorded per A.III above.

Modification Issued: 12/14/2006

- i. Emission Limitation: Total OC emissions from this emissions unit shall not exceed 0.46 lb/hr and 1.71 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined by multiplying the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.007 lb/mmBtu (per manufacturer's emissions test data supplied by applicant) to determine an hourly emissions value. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions value (annual) to the annual hours of operation as recorded per A.III above.

- j. Emission Limitation: NO_x emissions from this emission unit shall not exceed 7.03 lbs/hr and 26.28 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined by multiplying the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.108 lb/mmBtu as specified by manufacturer's test data for this machine using a low NO_x control system to determine an hourly emissions value. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the NO_x emissions factor for this combustion turbine in order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions value (annual) to the annual hours of operation as recorded per A.III above.

- k. Emission Limitation: CO emissions from this emissions unit shall not exceed 8.57 lbs/hr and 25.49 TPY.

Applicable Compliance Method: Compliance with these emission limitations shall be determined by multiplying the maximum rated heat input capacity of the emissions unit (65.1 mmBtu/hr at 0° F for hourly emissions or 55.65 mmBtu/hr at 55° F for annual emissions) by an emissions factor of 0.082 lb/mmBtu for an uncontrolled system as specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (4/00) to determine an hourly emissions value. After the installation of a steam injection or other equivalent NO_x control technology, performance tests shall be conducted to determine the CO_x emissions factor for this combustion turbine in

Emissions Unit ID: **B017**

order to calculate the hourly emissions value for this emissions unit. Compliance with the annual emissions limitation shall be determined by applying the calculated hourly emissions value (annual) to the annual hours of operation as recorded per A.III above.

2. Emissions Testing Requirement :

- a. Not later than 30 days prior to the proposed test date(s) required in section A.V.2.b., the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).
- b. Within 60 days , but not later than 180 days after startup of this emissions unit after the conversion of a NO_x emissions control technology to another NO_x emissions control technology (per 40 CFR 60.8), the permittee shall conduct, or have conducted, performance testing for this emissions unit in accordance with the following requirements:
 - i. The emissions testing shall be conducted to demonstrate compliance with the allowable mass emission rates for NO_x SO₂ , and CO.
 - ii. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s):
 - (1) for NO_x , Method 20 of 40 CFR Part 60, Appendix A, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or Method 7E and either EPA Method 3 or 3A of 40 CFR Part 60, Appendix A to determine NO_x and diluent concentration [as specified in 40 CFR 60.335(a)];
 - (2) for SO₂, Method 20 or Method 6C of 40 CFR Part 60, Appendix A; and
 - (3) for CO, Method 10 of 40 CFR Part 60, Appendix A.
Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
 - iii. The 3-run performance NO_x tests shall be conducted while the combustion turbine is operating within ± 5 percent at 50, 75, 90 and 100% of peak load or at four load points in the normal operating range of the gas turbine, including the minimum point in operating the range and 90-100 percent of peak load or at the highest achievable load point if 90-100 percent of peak load cannot be physically achieved in practice.

Emissions Unit ID: **B017**

- iv. A 3-run test for SO₂ emissions shall be conducted while the combustion turbine is at the highest achievable load point.
 - v. This emissions unit may be tested for CO emissions to establish a CO emissions factor for the combined cycle system. Two 3-run tests for CO emissions shall be conducted while the combustion turbine is operating at or near 50 and 100% of peak load or at or near 2 points including the minimum point in the normal operating range of the gas turbine and the highest achievable load point of the gas turbine.
 - vi. In accordance with 40 CFR 60.334(g) the steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of 40 CFR 60.334 shall be monitored during the performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_x emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to 40 CFR Part 75 and that use the low mass emissions methodology in 40 CFR 75.19 or the NO_x emission measurement methodology in appendix E of 40 CFR Part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19(e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to 40 CFR Part 75.
- c. Personnel from the Ohio EPA Northeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
 - d. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.

Modification Issued: 12/14/2006

- e. For any conversion of a NO_x emissions control technology to another NO_x emissions control technology, including dry, low NO_x emissions combustion system, additional emissions testing as specified in sections A.V.2.a. - A.V.2.d. shall be required.

VI. Miscellaneous Requirements

1. This emissions unit was initially installed on January 1, 2001 with a low NO_x combustor burner within the combustion turbine. This third administrative permit modification allows the use of steam injection for NO_x emissions control at the turbine.
2. The fuel-bound nitrogen content will be assumed to be zero as long as natural gas fuel is employed in the turbine. Therefore the permittee is exempt from the nitrogen content monitoring of the fuel specified in 40 CFR 60.334(h)(2).

Modification Issued: 12/14/2006

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--------------------------------------	--

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None