

Facility ID: 0278000604 Issuance type: Final State Permit To Operate

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part II" and before "A. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

[Go to Part II for Emissions Unit P001](#)

[Go to Part II for Emissions Unit P003](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0278000604 Emissions Unit ID: P001 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Perlite Expansion Furnace #1 Natural Gas Fired with Cyclone and Baghouse	OAC rule 3745-31-05(A)(3) (PTI No. 02-1866)	Particulate emissions (PE) shall not exceed 0.01 gr/dscf from the baghouse stack controlling this emissions unit.
	OAC rule 3745-17-11	The emission limitation required by this applicable rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).
	OAC rule 3745-17-07(A)	Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.

2. **Additional Terms and Conditions**
 - (a) None

B. Operational Restrictions

1. None

C. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to eliminate the visible emissions.

D. Reporting Requirements

1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the Ohio EPA Northeast District Office) by January 31 and July 31 of each year and shall cover the previous 6-month period.

E. Testing Requirements

1. Compliance with the emission limitations in section A.1 of these terms and conditions shall be determined in accordance with the following methods:
Emission Limitation:

Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.

Applicable Compliance Method:

Compliance shall be determined by visible emission evaluations performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 9 and OAC rule 3745-17-03(B)(1).
Emission Limitation:

PE shall not exceed 0.01 gr/dscf from the baghouse stack controlling this emissions unit.

Applicable Compliance Method:

If required, compliance shall be demonstrated based upon an emission test performed in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Methods 1 through 5.

F. **Miscellaneous Requirements**

- 1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0278000604 Emissions Unit ID: P003 Issuance type: Final State Permit To Operate

[Go to the top of this document](#)

Part II - Special Terms and Conditions

This permit document constitutes a permit-to-install issued in accordance with ORC 3704.03(F) and a permit-to-operate issued in accordance with ORC 3704.03(G).

- 1. For the purpose of a permit-to-install document, the emissions unit terms and conditions identified below are federally enforceable with the exception of those listed below which are enforceable under state law only.
 - (a) None.
- 2. For the purpose of a permit-to-operate document, the emissions unit terms and conditions identified below are enforceable under state law only with the exception of those listed below which are federally enforceable.
 - (a) None.

A. **Applicable Emissions Limitations and/or Control Requirements**

- 1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Perlite Expansion Furnace # 3	OAC rule 3745-31-05(A)(3)	Particulate emissions (PE) shall not exceed 0.01 gr/dscf from the baghouse stack controlling this emissions unit. The emission limitation required by this applicable rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3). Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.
Natural Gas Fired with Cyclone and Baghouse	(PTI No. 02-8109)	
	OAC rule 3745-17-11	
	OAC rule 3745-17-07(A)	

- 2. **Additional Terms and Conditions**
 - (a) None

B. **Operational Restrictions**

- 1. None

C. **Monitoring and/or Record Keeping Requirements**

- 1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to eliminate the visible emissions.

D. **Reporting Requirements**

- 1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit and (b) describe any corrective actions taken to eliminate the visible particulate emissions. These reports shall be submitted to the Director (the Ohio

EPA Northeast District Office) by January 31 and July 31 of each year and shall cover the previous 6-month period.

E. Testing Requirements

1. Compliance with the emission limitations in section A.1 of these terms and conditions shall be determined in accordance with the following methods:

Emission Limitation:

Visible particulate emissions from the exhaust stack serving this emissions unit shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.

Applicable Compliance Method:

Compliance shall be determined by visible emission evaluations performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 9 and OAC rule 3745-17-03(B)(1).

Emission Limitation:

PE shall not exceed 0.01 gr/dscf from the baghouse stack controlling this emissions unit.

Applicable Compliance Method:

If required, compliance shall be demonstrated based upon an emission test performed in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Methods 1 through 5.

F. Miscellaneous Requirements

1. None