



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

10/4/2011

Certified Mail

Mr. Michael Henry
Honda of America Mfg., Inc., - Roadways
19900 State Route 739
Marysville, OH 43040-8711

RE: FINALAIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 0180010197
Permit Number: P0108652
Permit Type: Administrative Modification
County: Union

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
No	MACT/GACT
No	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED
No	MAJOR GHG
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install (PTI) which will allow you to install or modify the described emissions unit(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, we urge you to read it carefully. Please complete a survey at www.epa.ohio.gov/dapc/permitsurvey.aspx and give us feedback on your permitting experience. We value your opinion.

The issuance of this PTI is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. If you have any questions regarding this permit, please contact the Ohio EPA DAPC, Central District Office. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Issued Air Pollution Control Permits" link.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA
Ohio EPA-CDO



FINAL

Division of Air Pollution Control
Permit-to-Install
for
Honda of America Mfg., Inc., - Roadways

Facility ID:	0180010197
Permit Number:	P0108652
Permit Type:	Administrative Modification
Issued:	10/4/2011
Effective:	10/4/2011



Division of Air Pollution Control
Permit-to-Install
for
Honda of America Mfg., Inc., - Roadways

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 9
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 10
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 13
1. B418, ISG Emergency Generator 14
2. B419, BRWP Emergency Generator 19



Authorization

Facility ID: 0180010197

Facility Description: Motor Vehicles and Car Bodies

Application Number(s): M0001366

Permit Number: P0108652

Permit Description: This permit is an administrative modification to resolve appeal Case No. ERAC 805730. As agreed upon in the settlement agreement, this permit removes the fuel oil sulfur testing requirement for source B418 and replaces it with the requirement to obtain a fuel oil supplier certification.

Permit Type: Administrative Modification

Permit Fee: \$0.00

Issue Date: 10/4/2011

Effective Date: 10/4/2011

This document constitutes issuance to:

Honda of America Mfg., Inc., - Roadways
24000 Honda Parkway
Marysville, OH 43040-9251

of a Permit-to-Install for the emissions unit(s) identified on the following page.


Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Central District Office
50 West Town Street, 6th Floor
P.O. Box 1049
Columbus, OH 43216-1049
(614)728-3778

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Scott J. Nally
Director



Authorization (continued)

Permit Number: P0108652

Permit Description: This permit is an administrative modification to resolve appeal Case No. ERAC 805730. As agreed upon in the settlement agreement, this permit removes the fuel oil sulfur testing requirement for source B418 and replaces it with the requirement to obtain a fuel oil supplier certification.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	B418
Company Equipment ID:	ISG Emergency Generator
Superseded Permit Number:	01-08882
General Permit Category and Type:	Not Applicable
Emissions Unit ID:	B419
Company Equipment ID:	BRWP Emergency Generator
Superseded Permit Number:	01-08882
General Permit Category and Type:	Not Applicable

A. Standard Terms and Conditions

1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A.2.a), Severability Clause
 - (2) Standard Term and Condition A.3.c) through A. 3.e) General Requirements
 - (3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements
 - (4) Standard Term and Condition A.9., Reporting Requirements
 - (5) Standard Term and Condition A.10., Applicability
 - (6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install
 - (7) Standard Term and Condition A.14., Public Disclosure
 - (8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
 - (9) Standard Term and Condition A.16., Fees
 - (10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

- a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
- b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - (1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Ohio EPA DAPC, Central District Office.

- (2) Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Ohio EPA DAPC, Central District Office. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.
 - (3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the Ohio EPA DAPC, Central District Office every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - (4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Ohio EPA DAPC, Central District Office in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

- a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.
- b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.

- c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- d) The permittee shall submit progress reports to the Ohio EPA DAPC, Central District Office concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Ohio EPA DAPC, Central District Office.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have

been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Ohio EPA DAPC, Central District Office. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

- a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.
- b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.
- c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as "permanently shut down" in Ohio EPA's "Air Services" along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).



- d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

- e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

- a) Completion of initial installation date shall be entered upon completion of construction and prior to start-up.
- b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.



15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the "Owner/Contact Change" functionality in Air Services once the transfer is legally completed. The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

B. Facility-Wide Terms and Conditions



1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:
 - a) None.
2. In accordance with the 40 CFR Part 63, Subpart ZZZZ final MACT rule for "Stationary Reciprocating Internal Combustion Engines," emissions unit B418 is considered a "new limited use stationary reciprocating internal combustion engine" and therefore is not required to meet the requirements of the subpart and of 40 CFR 63, Subpart A except for the initial notification requirements of 63.6645(d). It is considered "limited use" because it is operated less than 100 hours per year.

As specified in Subpart ZZZZ, the permittee shall submit the following notification:

- a) The permittee shall submit an Initial Notification Report that contains the following information, in accordance with 40 CFR Part 63.9(b)(2) not later than December 13, 2004:
 - i. the name and mailing address of the permittee;
 - ii. the physical location of the source if it is different from the mailing address;
 - iii. identification of the relevant MACT standard and the source's compliance date;
 - iv. a brief description of the nature, design, size, and method of operation of the source, and an identification of the types of emission points within the affected source subject to the relevant standard and the types of HAPs emitted; and
 - v. a statement confirming the facility is a major source for HAPs.

C. Emissions Unit Terms and Conditions



1. B418, ISG Emergency Generator

Operations, Property and/or Equipment Description:

1073 HP stationary diesel emergency generator

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)	Emissions from this emissions unit shall not exceed: 25.34 pounds per hour (lbs/hr) of nitrogen oxides (NOx); 6.73 lbs/hr of carbon monoxide (CO); 2.77 lbs/hr of particulate emissions (PE); 4.00 lbs/hr of sulfur dioxide (SO ₂); and 0.65 lb/hr of volatile organic compounds (VOC). The requirements of this rule also include compliance with the requirements of OAC rules 3745-31-05(D), and 3745-17-07(A). See b)(2)(c).
b.	OAC rule 3745-31-05(D)	Emissions from this emissions unit shall not exceed the following limitations, as a 12-month rolling summation: 1.27 tons of NOx; 0.34 ton of CO; 0.20 ton of SO ₂ ; 0.14 ton of PE; and 0.03 ton of VOC See Section c)(2) below.



c.	OAC rule 3745-17-07(A)(1)	Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.
d.	OAC rule 3745-17-11(B)(5)(b)	PE from the engine's exhaust shall not exceed 0.062 lb PE/mmBtu actual heat input.
e.	OAC rule 3745-18-06(G)	Exempt, pursuant to OAC rule 3745-18-06(B) because the rated heat input capacity is less than 10 mmBtu/hr.
f.	40 CFR Part 63, Subpart ZZZZ	See Facility-Wide Terms and Conditions.

(2) Additional Terms and Conditions

- a. The hourly emissions limitations for this emissions unit were established to reflect the potential to emit. Therefore, with the exception of the fuel oil analysis, it is not necessary to develop additional monitoring, record keeping, and/or reporting requirements to ensure compliance with these limits.
- b. In accordance with the 40 CFR Part 63, Subpart ZZZZ final MACT rule for "Stationary Reciprocating Internal Combustion Engines," this emissions unit is considered a "new limited use stationary reciprocating internal combustion engine" and therefore is not required to meet the requirements of the subpart and of 40 CFR 63, Subpart A except for the initial notification requirements of 63.6645(d). It is considered "limited use" because it is operated less than 100 hours per year.
- c. The emissions limitation specified by this rule is less stringent than the emissions limitation specified by OAC rule 3745-17-11(B)(5)(b).

c) Operational Restrictions

- (1) The permittee shall only burn diesel fuel, containing no greater than 0.5% sulfur by weight, in this emissions unit.
- (2) The maximum annual operating hours for this emissions unit shall not exceed 100 hours based upon a 12-month rolling summation. The permittee has existing records of the hours of operation for this emissions unit; therefore, the first year of accumulating monthly hours of operation limitation is not necessary.

d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall obtain and maintain records of the total quantity of oil received and the certification report from the fuel supplier for each shipment of diesel fuel (No. 2 fuel oil) received for burning in this emissions unit. The certification report shall include the most recent sampling results obtained by the fuel supplier preceding the delivery of fuel to the permittee. The SO₂ emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).

Analyses for sulfur content shall be performed in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D4294 and D7039), or equivalent methods as approved by the Director.

- (2) For each day during which the permittee burns a fuel other than diesel fuel in this emissions unit, the permittee shall maintain a record of the type and quantity of fuel burned.
- (3) The permittee shall maintain monthly records of the following information:
 - a. the total number of hours of operation of B418 for each month; and
 - b. the rolling 12-month summation of the hours of operation, calculated by adding the current month's hours of operation to the hours of operation for the preceding eleven calendar months.

e) Reporting Requirements

- (1) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than diesel fuel was burned in this emissions unit. Each report shall include the type and quantity burned and shall be submitted within 30 days after the deviation occurs.
- (2) The permittee shall submit quarterly deviation (excursion) reports which identify the following:
 - a. any exceedance of the rolling 12-month maximum allowable cumulative hours of operation; and
 - b. any exceedance of the sulfur content fuel restriction specified in Section c)(1) above.

These quarterly deviation (excursion) reports shall be submitted in accordance with the reporting requirements of the Standard Terms and Conditions of this permit.

- (3) Unless other arrangements have been approved by the Director, all notifications and reports shall be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal.

f) Testing Requirements

- (1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. Emission Limitations:

25.34 lbsNOx/hr
6.73 lbs CO/hr
2.77 lbs PE/hr*
4.00 lbs SO₂/hr
0.65 lb VOC/hr

Applicable Compliance Method:

The above hourly limitations were established by multiplying the hourly heat input rating for the diesel generator of 7.92 mmBtu/hr by the appropriate emission factor below from U.S. EPA's AP-42, Volume I, Fifth Edition, Section 3.4, "Large Stationary diesel and All Stationary Dual-fuel Engines", Table 3.4-1, October 1996.

<u>Pollutant</u>	<u>Emission Factor</u>
NOx	3.2 lbs/mmBtu
CO	0.85 lb/mmBtu
PE*	0.35 lb/mmBtu
SO ₂	1.01 x (% sulfur content by weight, 0.5) lb/mmBtu
VOC	0.0819 lb/mmBtu

If required, emissions testing shall be conducted using the following test methods: 40 CFR Part 60, Appendix A, Methods 1-4 and Method 5 for PE, Method 7E for NOx, Method 10 for CO, Method 6C for SO₂ and Methods 18, 25, or 25A for VOC. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Central District Office.

*See Section f)(1)c.

b. Emission Limitations:

1.27 tons of NOx per rolling, 12-month period
0.34 tons of CO per rolling, 12-month period
0.20 ton of SO₂ per rolling, 12-month period
0.14 ton of PE per rolling, 12-month period
0.03 ton of VOC per rolling, 12-month period

Applicable Compliance Method:

The annual emission limitations were established by multiplying the maximum hourly emission rate determined in Section f)(1)a. above by the maximum allowable hours of operation of 100 hours per rolling, 12-month period.

c. Emission Limitation:

Particulate emissions from the engine exhaust shall not exceed 0.062 lb/mmBtu actual heat input.

Applicable Compliance Method:

Compliance shall be determined based on the emission factor of 0.062 lb/mmBtu specified in Section b)(1). This limitation reflects the current State Implementation Plan (SIP) for Ohio approved by the U.S. EPA.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).

d. Emission Limitation:

Visible emissions shall not exceed 20% opacity as a six-minute average.

Applicable Compliance Method:

If required, compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A. Method 9 and the procedures are specified in OAC rule 3745-17-03(B)(1).

g) Miscellaneous Requirements

(1) None.



2. B419, BRWP Emergency Generator

Operations, Property and/or Equipment Description:

469 HP stationary diesel emergency generator

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3)	<p>Emissions from this emissions unit shall not exceed:</p> <p>15.41 pounds per hour (lbs/hr) of nitrogen oxides (NO_x); 3.32 lbs/hr of carbon monoxide (CO); 0.87 lbs/hr of particulate emissions (PE); 1.01 lbs/hr of sulfur dioxide (SO₂); and 1.26 lbs/hr of volatile organic compounds (VOC)</p> <p>The requirements of this rule also includes compliance with the requirements of OAC rules 3745-31-05(D) and 3745-17-07(A).</p> <p>See Section b)(2)a.</p>
b.	OAC rule 3745-31-05(D)	<p>Emissions from this emissions unit shall not exceed the following limitations, as a 12 month rolling summation:</p> <p>3.85 tons of NO_x; 0.83 ton of CO; 0.25 ton of SO₂; 0.22 ton of PE; and 0.31 ton of VOC</p> <p>See Section c)(2).</p>



c.	OAC rule 3745-17-07(A)(1)	Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.
d.	OAC rule 3745-17-11(B)(5)(a)	The emissions limitation specified by this rule is less stringent than the emissions limitation specified by OAC rule 3745-31-05(A)(3).
e.	OAC rule 3745-18-06(G)	Exempt, pursuant to OAC rule 3745-18-06(B) because rated heat input capacity is less than 10 mmBtu/hr.

(2) Additional Terms and Conditions

a. The hourly emissions limitations for this emissions unit were established to reflect the potential to emit. Therefore, with the exception of the fuel oil analysis, it is not necessary to develop additional monitoring, record keeping, and/or reporting requirements to ensure compliance with these limits.

c) Operational Restrictions

(1) The permittee shall only burn diesel fuel in this emissions unit.

(2) The maximum annual operating hours for this emissions unit shall not exceed 500 hours, based upon rolling, 12 month summation of the operating hours. The permittee has existing records of the hours of operation for this emissions unit; therefore, the first year of accumulating monthly hours of operation limitation is not necessary.

d) Monitoring and/or Recordkeeping Requirements

(1) For each day during which the permittee burns a fuel other than diesel fuel in this emissions unit, the permittee shall maintain a record of the type and quantity of fuel burned.

(2) The permittee shall maintain monthly records of the following information:

a. the total number of hours of operation of B419 for each month; and

b. the rolling 12-month summation of the hours of operation, calculated by adding the current month's hours of operation to the hours of operation for the preceding eleven calendar months.

e) Reporting Requirements

(1) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than diesel fuel was burned in this emissions unit. Each report shall include the type and quantity burned and shall be submitted within 30 days after the deviation occurs.

- (2) The permittee shall submit quarterly deviation (excursion) reports which identify any exceedance of the rolling 12-month maximum allowable cumulative hours of operation. These quarterly deviation (excursion) reports shall be submitted in accordance with the reporting requirements of the Standard Terms and Conditions of this permit.
 - (3) Unless other arrangements have been approved by the Director, all notifications and reports shall be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal.
- f) Testing Requirements
- (1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emission Limitations:
15.41 lbs of NO_x/hr
3.32 lbs of CO/hr
0.87 lbs of PE/hr*
1.01 lbs of SO₂/hr
1.26 lbs of VOC/hr

Applicable Compliance Method:

The above hourly limitations were established by multiplying the hourly heat input rating for the diesel generator of 3.49 mmBtu/hr by the appropriate emission factor below from U.S. EPA's AP-42, Volume I, Fifth Edition, Section 3.3, "Gasoline and Diesel Industrial Engines", Table 3.3-1, October 1996.

Pollutant Emission Factor

NO_x 4.41 lb/mmBtu
CO 0.95 lb/mmBtu
PE* 0.25 lb/mmBtu
SO₂ 0.29 lb/mmBtu
VOC 0.36 lb/mmBtu

*See Section f)(1)c.

If required, emissions testing shall be conducted using the following test methods: 40 CFR Part 60, Appendix A, Methods 1-4 and Method 5 for PE, Method 7E for NO_x, Method 10 for CO, Method 6C for SO₂ and Methods 18, 25, or 25A for VOC. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Central District Office.
 - b. Emission Limitations:
3.85 tons of NO_x per rolling, 12-month period
0.83 ton of CO per rolling, 12-month period

0.25 ton of SO₂ per rolling, 12-month period
0.22 ton of PE per rolling, 12-month period
0.31 ton of VOC per rolling, 12-month period

Applicable Compliance Method:

The annual emission limitations were established by multiplying the maximum hourly emission rate determined in Section f)(1)a. above by the maximum allowable hours of operation of 500 hours per rolling, 12-month period.

c. Emission Limitation:

Visible emissions shall not exceed 20% opacity as a six-minute average.

Applicable Compliance Method:

If required, compliance shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A. Method 9 and the procedures are specified in OAC rule 3745-17-03(B)(1).

g) Miscellaneous Requirements

(1) None.