



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

12/20/2011

William Patrie
Marathon Petroleum Company LP - Canton Refinery
2408 Gambinus Avenue SW
Canton, OH 44706

RE: FINALAIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 1576002006
Permit Number: P0108808
Permit Type: Initial Installation
County: Stark

Certified Mail

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
Yes	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED
No	MAJOR GHG
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install (PTI) which will allow you to install or modify the described emissions unit(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, we urge you to read it carefully. Please complete a survey at www.epa.ohio.gov/dapc/permitsurvey.aspx and give us feedback on your permitting experience. We value your opinion.

The issuance of this PTI is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. If you have any questions regarding this permit, please contact the Canton City Health Department. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Issued Air Pollution Control Permits" link.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA
Canton; Pennsylvania; West Virginia



FINAL

**Division of Air Pollution Control
Permit-to-Install**

for

Marathon Petroleum Company LP - Canton Refinery

Facility ID:	1576002006
Permit Number:	P0108808
Permit Type:	Initial Installation
Issued:	12/20/2011
Effective:	12/20/2011



Division of Air Pollution Control
Permit-to-Install
for
Marathon Petroleum Company LP - Canton Refinery

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 9
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 10
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 13
1. P083, Diesel Fired Air Compressor 14



Authorization

Facility ID: 1576002006
Facility Description: Petroleum Refinery
Application Number(s): A0042044
Permit Number: P0108808
Permit Description: Permit-to-install a stationary diesel-fired air compressor.
Permit Type: Initial Installation
Permit Fee: \$400.00
Issue Date: 12/20/2011
Effective Date: 12/20/2011

This document constitutes issuance to:

Marathon Petroleum Company LP - Canton Refinery
2408 Gambrinus Avenue SW
Canton, OH 44706

of a Permit-to-Install for the emissions unit(s) identified on the following page.


Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Canton City Health Department
420 Market Avenue
Canton, OH 44702-1544
(330)489-3385

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency



Scott J. Nally
Director



Authorization (continued)

Permit Number: P0108808

Permit Description: Permit-to-install a stationary diesel-fired air compressor.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	P083
Company Equipment ID:	Diesel Fired Air Compressor
Superseded Permit Number:	
General Permit Category and Type:	Not Applicable



A. Standard Terms and Conditions

1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A.2.a), Severability Clause
 - (2) Standard Term and Condition A.3.c) through A. 3.e) General Requirements
 - (3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements
 - (4) Standard Term and Condition A.9., Reporting Requirements
 - (5) Standard Term and Condition A.10., Applicability
 - (6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install
 - (7) Standard Term and Condition A.14., Public Disclosure
 - (8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
 - (9) Standard Term and Condition A.16., Fees
 - (10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

- a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
- b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - (1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Canton City Health Department.

- (2) Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Canton City Health Department. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.
 - (3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the Canton City Health Department every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - (4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Canton City Health Department in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

- a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.
- b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.



- c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- d) The permittee shall submit progress reports to the Canton City Health Department concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Canton City Health Department.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have

been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Canton City Health Department. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

- a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.
- b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.
- c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as "permanently shut down" in Ohio EPA's "Air Services" along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).

- d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

- e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

- a) Completion of initial installation date shall be entered upon completion of construction and prior to start-up.
- b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.



15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the "Owner/Contact Change" functionality in Air Services once the transfer is legally completed. The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.



B. Facility-Wide Terms and Conditions

1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:
 - a) [OAC rule 3745-15-03(A)]
Unless other arrangements have been approved by the Director (the appropriate Ohio EPA District Office or local air agency), all notifications and reports shall be submitted through the Ohio EPA's eBusiness Center: Air Services online web portal.

C. Emissions Unit Terms and Conditions



1. P083, Diesel Fired Air Compressor

Operations, Property and/or Equipment Description:

Non-emergency, back-up diesel fired air compressor, Caterpillar Model C-15 DITA, 475 hp maximum rated power output at 3.42 MMBtu/hr maximum rated heat input. Manufactured after 2007 with displacement less than 10 liters per cylinder, certified to 40 CFR 89.112 Tier 3 exhaust emission standards in Table 1.

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) None.

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	ORC 3704.03(T) [BAT for pollutants greater than 10 tons per year]	Compliance with this rule also includes compliance with 40 CFR Part 60, Subpart IIII for nitrogen oxides (NOx) and carbon monoxide (CO) emissions.
b.	OAC rule 3745-31-05(A)(3), as effective 11/30/01 [BAT for pollutants less than 10 tons per year]	Particulate Matter (PM) shall not exceed 0.70 ton(s) per year. Volatile organic compound (VOC) emissions shall not exceed 3.42 ton(s) per year. Sulfur dioxide (SO ₂) emissions shall not exceed 4.27 ton(s) per year. See b)(2)a.
c.	OAC rule 3745-31-05(A)(3)(a)(ii), as effective 12/01/06 [Less than 10 tons per year BAT exemption]	See b)(2)b.
d.	40 CFR Part 60, Subpart IIII 40 CFR 60.4204(b)	The exhaust emissions from this engine shall not exceed these limits as an average load basis:

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
	40 CFR 60.4201(a) Table 1 to 40 CFR 89.112, Tier 3 See b)(2)c.	0.20 gram of particulate matter per kilowatt-hour (0.20 gram PM/kW-hr) 4.0 grams of nitrogen oxides plus nonmethane hydrocarbons per kilowatt-hour (4.0 grams NOx + NMHC/kW-hr) 3.5 grams of carbon monoxide per kilowatt hour (3.5 grams CO/kW-hr) See b)(2)d through e.
e.	40 CFR 60.4207(b) 40 CFR 80.510(b)	The sulfur content of the diesel fuel burned in this engine shall not exceed 15 ppm or 0.0015% sulfur by weight. See b)(2)f, c(2) and d(1).
f.	40 CFR 89.113(c)	Exempt. See b)(2)g.
h.	OAC rule 3745-17-07(A)(1)	Visible particulate emissions from the exhaust stack serving this engine shall not exceed twenty (20) percent opacity, as a six-minute average, except as specified by rule.
h.	OAC rule 3745-17-11(B)(5)	The emission limitation specified by this rule is less stringent than the emission limitation established for PE pursuant to 40 CFR Part 60, Subpart IIII.
i.	40 CFR 63 Subpart ZZZZ 40 CFR 63.6590(c)(7)	See b)(2)h.

(2) Additional Terms and Conditions

- a. The permittee has satisfied the Best Available Technology (BAT) requirements pursuant to OAC paragraph 3745-31-05(A)(3), as effective November 30, 2001, in this permit. On December 1, 2006, paragraph (A)(3) of OAC rule 3745-31-05 was revised to conform to the Ohio Revised Code (ORC) changes effective August 3, 2006 (Senate Bill 265 changes), such that BAT is no longer required by State regulations for National Ambient Air Quality Standard (NAAQS) pollutant(s) less than ten tons per year. However, that rule revision has not yet been approved by the U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-31-05, the requirement to satisfy BAT still exist as part of the federally-approved SIP for Ohio. Once U.S. EPA approves the

December 1, 2006 version of OAC rule 3745-31-05 these emission limitations/control measures no longer apply.

[OAC rule 3745-31-05(A)(3), as effective 11/30/2001]

- b. This rule paragraph applies once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the SIP.

BAT requirements under OAC rule 3745-31-05(A)(3) do not apply to the PM, VOC and SO₂ from this air contaminant source since the uncontrolled potential to emit for PM, VOC and SO₂ is less than 10 tons/yr.

[OAC rule 3745-31-05(A)(3), as effective 12/01/2006]

- c. This emission unit is a 2007 model year or later non-emergency stationary CI ICE with a maximum engine power less than or equal to 2,237 kilowatt (KW) (3,000 horsepower (HP)) and a displacement of less than 10 liters per cylinder which manufacturers must certify to the certification emission standards for new nonroad CI engines in 40 CFR 89.112, 40 CFR 89.113, 40 CFR 1039.101, 40 CFR 1039.102, 40 CFR 1039.104, 40 CFR 1039.105, 40 CFR 1039.107, and 40 CFR 1039.115, as applicable, for all pollutants, for the same model year and maximum engine power.

[40 CFR 60.4201(a)]

- d. The stationary compression ignition (CI) internal combustion engine (ICE) is subject to and shall be operated in compliance with the requirements of 40 CFR Part 60, Subpart IIII, the standards of performance for stationary CI ICE.

[40 CFR 60.4200(a)]

- e. The stationary CI ICE has been or shall be purchased certified by the manufacturer, to emission standards as stringent as those identified in 40 CFR 60.4201(a) and found in Tier 3 of 40 CFR 89.112, Table 1, for engines greater than or equal to 175 horsepower (130 kilowatt) and less than or equal to 750 horsepower (560 kilowatt).

[40 CFR 60.4204(b)], [40 CFR 60.4201(a)], [40 CFR 60.4203], and [40 CFR 60.4211(c)]

- f. The quality of the diesel fuel burned in this engine shall meet the following specifications on an "as received" basis:

- i. a sulfur content which is sufficient to comply with the allowable sulfur dioxide emission limitation of 0.0015 pound sulfur dioxide/MMBtu actual heat input; and 15 ppm sulfur per gallon of oil or 0.0015% sulfur by weight;
- ii. a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent; and

Compliance with the above-mentioned specifications shall be determined by using the analytical results provided by the permittee or oil supplier for each shipment of oil.

[40 CFR 60.4207(b)] and [40 CFR 80.510(b)]

- g. Pursuant to 40 CFR 89.113(c)(3), this emissions unit is exempt from the opacity requirements specified in this rule, because the air containment source is a constant-speed engine.
- h. The CI reciprocating ICE (RICE), located at a major source for HAPs, is subject to the requirements of the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, Part 63, Subpart ZZZZ. Compliance with the NESHAP shall be demonstrated for the RICE by meeting the requirements of the New Source Performance Standards (NSPS) for Stationary Compression Ignition Internal Combustion Engines, 40 CFR Part 60, Subpart IIII; and the general provisions of the NSPS, 40 CFR Part 60, Subpart A, that apply to the CI RICE, as identifies in Table 8 to Subpart ZZZZ.

[40 CFR 63.6590(c)], [40 CFR 63.6590(a)(2)(iii)], [40 CFR 63.6585], [40 CFR 63.6595(a)(6) or (7)], and [40 CFR 60.4218]

c) Operational Restrictions

- (1) The stationary CI ICE shall be installed, operated, and maintained according to the manufacturer's specifications, written instructions, and procedures, and/or according to procedures developed by the permittee that have been approved by the engine manufacturer in writing, over the entire life of the engine. The CI ICE must also be installed and operated to meet the applicable requirements from 40 CFR Part 89, Control of Emissions from New and In-use Non-road CI ICE and Part 1068, the General Compliance Provisions for Engine Programs. The permittee shall operate and maintain the stationary CI ICE to achieve the Tier 3 emission standards in Table 1 to 40 CFR 89.112, as required per 40 CFR 60.4204.

[40 CFR 60.4206] and [40 CFR 60.4211(a)]

- (2) Diesel fuel burned in the CI, ICE shall not exceed the limit for sulfur as specified by 40 CFR 80.510(b), i.e., the maximum sulfur content of diesel fuel shall not exceed 15 ppm or 0.0015% sulfur by weight.

[40 CFR 60.4207(b)] and [40 CFR 80.510(b)]

d) Monitoring and/or Recordkeeping Requirements

- (1) For each shipment of oil received for burning in this engine, the permittee shall maintain records of the total quantity of the diesel oil received and the oil supplier's (or permittee's) analyses for sulfur content, in parts per million (40 CFR 80.510) or percent by weight. The permittee shall perform or require the supplier to perform the analyses for sulfur content in accordance with 40 CFR 80.580, using the appropriate ASTM

methods. These records shall be retained for a minimum of 5 years and shall be available for inspection by the Director or his/her representative.

[for 40 CFR 60.4207(b)] and [40 CFR 80.410(b)]

- (2) The permittee shall maintain the manufacturer's certification, to the applicable Tier 3 emission standards in Table 1 of 40 CFR 89.112, on site or at a central location for all facility ICE and it shall be made available for review upon request. If the manufacturer's certification is not kept on site, the permittee shall maintain a log for the location of each ICE and it shall identify the agency-assigned emissions unit number, the manufacturer's identification number, and the identification number of the certificate. The manufacturer's operations manual and any written instructions or procedures developed by the permittee and approved by the manufacturer shall be maintained at the same location as the ICE.

[40 CFR 60.4211(c)]

- (3) The permittee shall maintain a record of the diesel fuel burned in this ICE during each calendar year. The fuel oil usage can be calculated at the end of each year using the best method available to estimate the annual throughput which might include, but shall not be limited to: any flow meter installed on the engine, records of the volume of diesel fuel oil received with each delivery, the fuel oil levels recorded from the diesel storage tank, and/or the recorded or estimated hours of operation along with the manufacturer's documentation of the fuel flow rate.

e) Reporting Requirements

- (1) The permittee shall submit quarterly deviation (excursion) reports that identify each day when a fuel containing greater than 0.0015 weight percent sulfur was burned in the emission unit. These deviation reports shall be submitted in accordance with the reporting requirements of the Standard Terms and Conditions of this permit.

f) Testing Requirements

- (1) Compliance with the emission limitations in b)(1) of these terms and conditions shall be determined in accordance with the following methods:

a. Opacity Limitation:

Visible particulate emissions from the exhaust stack serving this engine shall not exceed 20 %opacity, as a six-minute average, except as specified by rule.

Applicable Compliance Method:

If required, compliance shall be determined through visible emission observations performed in accordance with U.S. EPA Reference Method 9 in 40 CFR, Part 60, Appendix A.

[OAC rule 3745-17-07(A)(1)]

b. Emission Limitations:

0.20 gram PM/kW-hr

0.70 tons PM/year

Applicable Compliance Method:

Compliance with the emission limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's specifications. The g/kW-hr limit is the emission limitation from Table 1 of 40 CFR 89.112, the Tier 3 exhaust emission standards for diesel engines between 175 and 750 horsepower (130 and 560 kilowatts).

The ton per year PM emissions limitation was developed using the following equation:

$$0.20 \text{ g PM/kw-hr} \times \text{kw}/1.341 \text{ HP} \times 1 \text{ lb}/453.6 \text{ g} \times 475 \text{ HP} = 0.16 \text{ lb PM/hr}$$

$$0.16 \text{ lbs PM/hr} \times 8760 \text{ hours/year} \times 1 \text{ ton}/2000 \text{ lbs} = 0.70 \text{ tons PM/year}$$

If required, the permittee shall demonstrate compliance with the PM emission limitation through performance tests conducted in accordance with the provisions in term f)(1)h below.

[40 CFR 60.4204(b)], [40 CFR 60.4201(a)], [40 CFR 60.4211(c)], and [40 CFR 60.4212(a) and (c)]

c. Emission Limitations:

4.0 grams NO_x + NMHC/kW-hr

Applicable Compliance Method:

Compliance with the emission limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's specifications. The g/kW-hr limit is the emission limitation from Table 1 of 40 CFR 89.112, the Tier 3 exhaust emission standards for diesel engines between 175 and 750 horsepower (130 and 560 kilowatts).

If required, the permittee shall demonstrate compliance with the NO_x/NMHC emission limitation through performance tests conducted in accordance with the provisions in term f)(1)h below.

[40 CFR 60.4204(b)], [40 CFR 60.4201(a)], [40 CFR 60.4211(c)], and [40 CFR 60.4212(a) and (c)]

d. Emission Limitations:

3.5 grams CO/kW-hr

Applicable Compliance Method:

Compliance with the emission limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's specifications. The g/kW-hr limit is the emission limitation from Table 1 of 40 CFR 89.112, the Tier 3 exhaust emission standards for diesel engines between 175 and 750 horsepower (130 and 560 kilowatts).

If required, the permittee shall demonstrate compliance with the CO emission limitation through performance tests conducted in accordance with the provisions in term f)(1)h below.

[40 CFR 60.4204(b)], [40 CFR 60.4201(a)], [40 CFR 60.4211(c)] and [40 CFR 60.4212(a) and (c)]

e. Emission Limitations:

4.0 grams NO_x + NMHC/kW-hr

3.42 tons VOC/year

Applicable Compliance Method:

Compliance with the emission limitations shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's specifications. The g/kW-hr limit is the emission limitation from Table 1 of 40 CFR 89.112, the Tier 3 exhaust emission standards for diesel engines between 175 and 750 horsepower (130 and 560 kilowatts).

The ton per year limitation was established based on the estimated proportion of NO_x to HC (74.6% NO_x to 25.4% VOC). Other proportion data may be used for compliance demonstration purposes.

$4.0 \text{ g NO}_x + \text{NMHC/kW-hr} \times 25.4\% \text{ NMHC} = 1.0 \text{ gram VOC/kW-hr}$

The ton per year VOC emissions limitation was developed using the following equation:

$1.0 \text{ g VOC/kw-hr} \times \text{kw}/1.341 \text{ HP} \times 1 \text{ lb}/453.6 \text{ g} \times 475 \text{ HP} = 0.78 \text{ lb VOC/hr}$

$0.78 \text{ lb VOC/hr} \times 8760 \text{ hours/year} \times 1 \text{ ton}/2000 \text{ lbs} = 3.42 \text{ tons VOC/year}$

If required, the permittee shall demonstrate compliance with the NO_x/NMHC emission limitation through performance tests conducted in accordance with the provisions in term f)(1)h below.

[40 CFR 60.4204(b)], [40 CFR 60.4201(a)], [40 CFR 60.4211(c)], and [40 CFR 60.4212(a) and (c)]

f. Sulfur Content Limitations for Diesel Fuel:

Sulfur content 15 ppm or \leq 0.0015% by weight sulfur

Applicable Compliance Method:

Compliance shall be demonstrated through the record keeping requirements for the sulfur content of each shipment of diesel oil received. If meeting the standards in 40 CFR 80.510(b), this calculates to approximately 0.0015lb SO₂/MMBtu.

[40 CFR 60.4207(b)] and [40 CFR 80.510(b)]

g. Emission Limitations:

4.27 tons of SO₂/year

Applicable Compliance Method:

Compliance is based upon an emission factor of 0.00205 lb/hp-hr, as specified in the U.S. EPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.3 , Table 3.3-1(10/96).

The ton per year SO₂ emissions limitation was developed using the following equation:

$0.00205 \text{ lb/HP-hr} \times 475 \text{ HP} \times 8760 \text{ hours/year} \times 1 \text{ ton}/2000 \text{ lbs} = 4.27 \text{ tons SO}_2/\text{year}$

h. If it is determined by the Ohio EPA that a compliance demonstration is required through performance testing, it shall be conducted using one of the following test methods or procedures:

- i. in accordance with 40 CFR 60.4212, conduct the exhaust emissions testing using the in-use testing procedures found in 40 CFR Part 1039, Subpart F, measuring the emissions of the regulated pollutants as specified in 40 CFR 1065; or
- ii. in accordance with 40 CFR 60.4213, conduct exhaust emissions testing using the test methods identified in Table 7 to Subpart IIII of Part 60.

If demonstrating compliance through the in-use testing procedures in 40 CFR part 1039, Subpart F, exhaust emissions from the stationary CI ICE shall not exceed the "not to exceed" (NTE) numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112, determined from the following equation:

NTE requirement for each pollutant = 1.25 x STD



Where:

STD = The standard specified for the pollutant in 40 CFR 89.112.

[40 CFR 60.4212(a) and (c)]

g) Miscellaneous Requirements

(1) None.