

August 5, 1998

CERTIFIED MAIL

Re: Modification to Permit to Install No. 01-7342
Franklin County

Mount Carmel Medical Center
793 West State Street
Columbus, OH 43222

Attention: Steven Sims

Enclosed please find a modification to the Ohio EPA Permit to Install referenced above which will modify the terms and conditions.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745-04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Review Appeals Commission within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Board. An appeal may be filed with the Environmental Review Appeals Commission at the following address: Environmental Review Appeals Commission, 236 East Town Street, Room 300, Columbus, Ohio 43215.

Very truly yours,

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

Enclosure

cc: US EPA
CENTRAL DISTRICT OFFICE, DAPC



State of Ohio Environmental Protection Agency

Permit to Install Terms and Conditions

Issuance Date: August 5, 1998
Effective Date: August 5, 1998

OHIO ENVIRONMENTAL PROTECTION AGENCY

MODIFICATION TO PERMIT TO INSTALL

Name of Applicant: Mount Carmel Medical Center
Address: 793 West State Street
City: Columbus, OH
Telephone Number: (614)234-5794

The Ohio EPA has received a request for a modification for the Ohio EPA Permit to Install referenced above.

The Permit to Install issued to **Mount Carmel Medical Center, Permit to Install No. 01-7342** is modified in the following manner:

Terms and Conditions on pages **4 and 10** of Permit to Install issued on **May 13, 1998**.

The reason for the modification is: **to modify the BAT Determination and correct the Emission Limitation for NO_x, of PTI No. 01-7342, issued May 13, 1998.**

The above named entity is hereby granted a modification to the permit to install described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this modification does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

Ohio Environmental Protection Agency

Director

NO_x emissions
shall not
exceed
0.15 pound
NO_x per
million
Btu of
heat input

0.15 pound NO_x/million Btu heat input.