



State of Ohio Environmental Protection Agency

P.O. Box 1049, 1800 WaterMark Dr.
Columbus, Ohio 43266-0149
(614) 644-3020
FAX (614) 644-2329

George V. Voinovich
Governor

T012, T013, T015

October 2, 1991

CERTIFIED MAIL

Re: Modification to Permit to Install No. 17-802
Jefferson County

Marathon Petroleum Company
539 S Main St.
Findlay, OH 45840

Attention: G. D. Sheely

Dear Sir:

Enclosed please find a modification to the Ohio EPA Permit to Install referenced above which will modify the terms and conditions.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Board of Review pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address: Environmental Board of Review, 236 East Town Street, Room 300, Columbus, OH 43215.

Very truly yours,

Thomas G. Rigo, Manager
Field Operations and Permit Section
Division of Air Pollution Control

Enclosure

cc: US EPA
~~NORTH OHIO VALLEY AIR AUTHORITY~~

Issuance Date: October 2, 1991

Effective Date: October 2, 1991

OHIO ENVIRONMENTAL PROTECTION AGENCY

MODIFICATION TO PERMIT TO INSTALL

Name of Applicant: Marathon Petroleum Company
Address: 28371 Kingsdale Road
City: Steubenville, OH
Telephone: (419) 422-2121

The Ohio EPA has received a request for a modification for the Ohio EPA Permit to Install referenced above.

The Permit to Install issued to Marathon Petroleum Company (PTI No. 17-802) is hereby modified in the following manner:


Terms and Conditions on Page 7 of Permit to Install issued August 22, 1990.

The reason for the modification is:

To clarify definition of submerged fill.

The above named entity is hereby granted a modification to the permit to install described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this modification does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

Ohio Environmental Protection Agency



Director

MAINTENANCE OF EQUIPMENT

This source and its associated air pollution control system(s) shall be maintained regularly in accordance with good engineering practices and the recommendations of the respective manufacturers in order to minimize air contaminant emissions.

MALFUNCTION/ABATEMENT

In accordance with OAC Rule 3745-15-06, any malfunction of the source(s) or associated air pollution control system(s) shall be reported immediately to the North Ohio Valley Air Authority, 814 Adams, Steubenville, Ohio 43952.

Except as provided by OAC Rule 3745-15-06(A)(3), scheduled maintenance of air pollution control equipment that requires the shutdown or bypassing of air pollution control system(s) must be accompanied by the shutdown of the associated air pollution sources.

AIR POLLUTION NUISANCES PROHIBITED

The air contaminant source(s) identified in this permit may not cause a public nuisance in violation of OAC Rule 3745-15-07.

NINETY DAY OPERATING PERIOD

The facility will be permitted to operate during a 90 day period in accordance with OAC Rule 3745-31-02(C)(4)(B). The purpose of this period of operation is to fulfill the performance test condition used in the determination of compliance with the provisions of this permit to install or other applicable Ohio EPA rules.

MISCELLANEOUS STORAGE TANKS

Unless otherwise indicated, BAT for any miscellaneous storage tanks identified within this permit consists of the use of submerged fill into the storage tanks. The submerged fill pipe(s) are to be installed within six (6) inches of the bottom of the storage tank.

Submerged fill requirement for storage tanks T012, T013, and T015 shall be accomplished by restricting the minimum tank level allowed to be realized during normal operation to be not less than three inches above the fill nozzle opening. Product removal from the tank is to cease when the level of product is at the minimum stated in the preceding sentence. However, the tank level may be drawn below this level when the tank is taken out of service for inspection, cleaning or maintenance activities and during subsequent refilling for normal operation. Daily records of the minimum tank liquid level shall be maintained in the terminal gauge book in accordance with written procedures.