



**Environmental
Protection Agency**

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

5/30/2012

Certified Mail

Mr. Michael Dae
Carbon Limestone Landfill Gas Power Station
3322 West End Avenue
Suite 115
Nashville, TN 37203

Yes	TOXIC REVIEW
Yes	PSD
Yes	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
Yes	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED

RE: DRAFT AIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 0250050996
Permit Number: P0109811
Permit Type: Administrative Modification
County: Mahoning

Dear Permit Holder:

A draft of the Ohio Administrative Code (OAC) Chapter 3745-31 Air Pollution Permit-to-Install for the referenced facility has been issued for the emissions unit(s) listed in the Authorization section of the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the permit. A public notice will appear in the Ohio EPA Weekly Review and the local newspaper, Youngstown-Vindicator. A copy of the public notice and the draft permit are enclosed. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Issued Air Pollution Control Permits" link. Comments will be accepted as a marked-up copy of the draft permit or in narrative format. Any comments must be sent to the following:

Andrew Hall
Permit Review/Development Section
Ohio EPA, DAPC
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, Ohio 43216-1049

and Ohio EPA DAPC, Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087

Comments and/or a request for a public hearing will be accepted within 30 days of the date the notice is published in the newspaper. You will be notified in writing if a public hearing is scheduled. A decision on issuing a final permit-to-install will be made after consideration of comments received and oral testimony if a public hearing is conducted. Any permit fee that will be due upon issuance of a final Permit-to-Install is indicated in the Authorization section. Please do not submit any payment now. If you have any questions, please contact Ohio EPA DAPC, Northeast District Office at (330)425-9171.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA Region 5 -Via E-Mail Notification
Ohio EPA-NEDO; Pennsylvania; West Virginia



Permit Strategy Write-Up

1. Check all that apply:

Synthetic Minor Determination

Netting Determination

2. Source Description:

Carbon Limestone Landfill Power Station is a landfill gas to energy plant co-located with Carbon Limestone municipal waste landfill. The facility has current Title V operating permit for 14 LFG generator sets, and PTIs for four additional generator sets (P018-P021).

This action is an administrative modification to an initial PTI P0107078 issued July 5, 2011 for P020 and P021, in order to adjust the VOC emissions limitation established under OAC rule 3745-31-05(A)(3), BAT to reflect the results of an initial emissions test. No other emission limitations were changed. The previous permit action for these two engines required BACT for CO.

Emissions units P020 and P021 are Caterpillar (G3520C) - 2,233 hp generator sets that burn landfill gas (LFG) in order to produce electricity.

3. Facility Emissions and Attainment Status:

The facility is located in Mahoning County which is in attainment for all criteria pollutants. Prior to the installation of these two new CAT generator sets, facility actual emissions are as follows: (NO_x - 344 TPY) (CO - 661 TPY) (SO₂ - 15.6 TPY) (PM₁₀ - 26.8 TPY) (OC - 197 TP) (VOC - 5.5 TPY) (HCI - 9.4 TPY). The facility is a major stationary source for NO_x, and CO.

4. Source Emissions:

The previous BAT limitation of 0.167 gram/bhp-hr VOC was estimated based upon the existing Deutz 1400 kW LFG generator sets. Initial installation testing demonstrated that the VOC emission factor was not appropriate for this larger CAT generator sets. The VOC limitation was revised to 0.403 gram/bhp-hr in this permit action, but remains below the NSPS, Subpart JJJ limitation of 1.0 gram/bhp-hr. The facility is not a major source for VOC and this projected was not a major source of VOC. Therefore, no PDS evaluation was required.

Proposed emissions, per generator set were: (NO_x - 12.9 TPY) (CO - 59.2 TPY) (PM₁₀ - 2.1 TPY) (SO₂ - 1.2 TPY) (VOC - 8.67 TPY). When considering the entire project, coupled with the existing emissions from the facility, this is a PSD permit [existing emissions of NO_x and CO are over 250 TPY]. The major modification threshold for CO is 100 TPY and NO_x - 40 TPY. Only CO emissions exceed the major modification threshold; therefore, proposed CO emissions exceed the threshold and must meet BACT. A search was conducted for CO emissions within the BACT Clearinghouse. It was determined that 2.75 g/hp-hr was the emission factor that was the most stringent within the database. NO_x emissions did not exceed the major modification threshold.



- 5. Conclusion: The terms and conditions of this permit continue to provide the same level of BACT for CO emissions and required adequate emission testing to demonstrate compliance with the limitation. The BAT emissions limitations for VOC established in this permit modification reflect the results of the initial compliance test results and are established below the NSPS Subpart JJJ limitation.

- 6. Please provide additional notes or comments as necessary:

- 7. Total Permit Allowable Emissions Summary (for informational purposes only):

<u>Pollutant</u>	<u>Tons Per Year</u>
NO _x	25.84
CO	118.52
SO ₂	2.46
PM/PM ₁₀	4.30
VOC	17.34 (10.16 increase)
OC	251.58
HCl	1.32

PUBLIC NOTICE
5/30/2012 Issuance of Draft Air Pollution Permit-To-Install

Carbon Limestone Landfill Gas Power Station

7960 South Stateline Road,

Lowellville, OH 44436

Mahoning County

FACILITY DESC.: Other Electric Power Generation

PERMIT #: P0109811

PERMIT TYPE: Administrative Modification

PERMIT DESC: Adminstrative modification at the request of the facility in order to adjust the allowable VOC emissions to reflect the results of the inital compliance test.

The Director of the Ohio Environmental Protection Agency issued the draft permit above. The permit and complete instructions for requesting information or submitting comments may be obtained at: <http://epa.ohio.gov/dapc/permitsonline.aspx> by entering the permit # or: Amysue O'Reilly, Ohio EPA DAPC, Northeast District Office, 2110 East Aurora Road, Twinsburg, OH 44087. Ph: (330)425-9171



DRAFT

Division of Air Pollution Control
Permit-to-Install
for
Carbon Limestone Landfill Gas Power Station

Facility ID:	0250050996
Permit Number:	P0109811
Permit Type:	Administrative Modification
Issued:	5/30/2012
Effective:	To be entered upon final issuance



Division of Air Pollution Control
Permit-to-Install
for
Carbon Limestone Landfill Gas Power Station

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 9
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 10
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 14
1. P020 and P021 IC Engine #19 & IC Engine #29 15



Authorization

Facility ID: 0250050996
Facility Description: Landfill gas power station
Application Number(s): A0044071
Permit Number: P0109811
Permit Description: Administrative modification at the request of the facility in order to adjust the allowable VOC emissions to reflect the results of the initial compliance test.
Permit Type: Administrative Modification
Permit Fee: \$400.00 *DO NOT send payment at this time, subject to change before final issuance*
Issue Date: 5/30/2012
Effective Date: To be entered upon final issuance

This document constitutes issuance to:

Carbon Limestone Landfill Gas Power Station
7960 South Stateline Road
Lowellville, OH 44436

of a Permit-to-Install for the emissions unit(s) identified on the following page.

Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Northeast District Office
2110 East Aurora Road
Twinsburg, OH 44087
(330)425-9171

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Scott J. Nally
Director



Authorization (continued)

Permit Number: P0109811

Permit Description: Administrative modification at the request of the facility in order to adjust the allowable VOC emissions to reflect the results of the initial compliance test.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	P020
Company Equipment ID:	IC Engine #19
Superseded Permit Number:	P0107078
General Permit Category and Type:	Not Applicable

Emissions Unit ID:	P021
Company Equipment ID:	IC Engine #29
Superseded Permit Number:	P0107078
General Permit Category and Type:	Not Applicable



A. Standard Terms and Conditions



1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A.2.a), Severability Clause
 - (2) Standard Term and Condition A.3.c) through A. 3.e) General Requirements
 - (3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements
 - (4) Standard Term and Condition A.9., Reporting Requirements
 - (5) Standard Term and Condition A.10., Applicability
 - (6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install
 - (7) Standard Term and Condition A.14., Public Disclosure
 - (8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
 - (9) Standard Term and Condition A.16., Fees
 - (10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

- a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
- b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - (1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Ohio EPA DAPC, Northeast District Office.

- (2) Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Ohio EPA DAPC, Northeast District Office. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.
 - (3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the Ohio EPA DAPC, Northeast District Office every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - (4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Ohio EPA DAPC, Northeast District Office in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

- a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.
- b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.



- c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- d) The permittee shall submit progress reports to the Ohio EPA DAPC, Northeast District Office concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Ohio EPA DAPC, Northeast District Office.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have

been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Ohio EPA DAPC, Northeast District Office. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

- a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.
- b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.
- c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as "permanently shut down" in Ohio EPA's "Air Services" along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).

- d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

- e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

- a) Completion of initial installation date shall be entered upon completion of construction and prior to start-up.
- b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.



15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the "Owner/Contact Change" functionality in Air Services once the transfer is legally completed. The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

B. Facility-Wide Terms and Conditions



1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:

a) None.

2. MACT Subpart AAAAA and Subpart A Requirements

a) Applicable Emissions Limitations and/or Control Requirements

(1) The following emissions units contained in this permit are subject to MACT Subpart AAAAA as control equipment for an existing affected source: P020 and P021. The complete MACT requirements will be established in the Title V Permit for this facility which will encompass these emissions units upon issuance. The applicable sections of the MACT Subpart AAAAA have been cited in the appropriate sections for the emissions units subject to this rule.

b) Operational Restrictions

(1) The permittee shall comply with the applicable compliance standards required under 40 CFR Part 63, Subpart AAAAA including the following sections:

Table with 3 columns: Label, CFR Reference, and Description. Rows include: a. 63.1935(a)(3) Existing Affected Sources; b. 63.1945(f) and 63.1955(b) Compliance requirements for Existing, Area Sources; c. Appendix, Table 1 Applicable General Provisions

c) Monitoring and/or Recordkeeping Requirements

(1) The permittee shall comply with the applicable monitoring and record keeping requirements required under 40 CFR Part 63, Subpart AAAAA, including the following sections:

Table with 3 columns: Label, CFR Reference, and Description. Rows include: a. 63.1945(b) Initial Compliance by January 16, 2004; b. 63.1960 Compliance Methods; c. 63.1965 Deviation Clarifications for SSM Plans and Control Device Operating Parameters; d. 63.1975 Calculating 3-hour Block Average for Control Device Operating Parameters; e. 63.1980(a)(b) Required Records



d) Reporting Requirements

- (1) The permittee shall submit semiannual reports and such other notifications and reports to the Ohio EPA, Northeast District Office as are required pursuant to 40 CFR Part 63, Subpart AAAAA, per the following sections:

a.	63.1980	Semi-Annual Reporting Requirements
----	---------	------------------------------------

C. Emissions Unit Terms and Conditions



1. P020 and P021 IC Engine #19 & IC Engine #29

Operations, Property and/or Equipment Description:

P020	2,233 hp (15.75 mmBtu/hr) Caterpillar Engine (G3520C) to burn LFG to produce electricity
P021	2,233 hp (15.75 mmBtu/hr) Caterpillar Engine (G3520C) to burn LFG to produce electricity

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) e)(5)

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	OAC rule 3745-31-05(A)(3), as effective 11/30/2001	<p>Visible particulate emissions shall not exceed 10% opacity as a 6-minute average.</p> <p>Particulate emissions (PE)/particulate less than 10 microns in diameter (PM₁₀) emissions shall not exceed 0.1 gram per brake horsepower hour, 0.49 pound per hour and 2.15 tons per year.</p> <p>Sulfur dioxide (SO₂) emissions shall not exceed 0.28 pound per hour and 1.23 tons per year.</p> <p>Volatile organic compound (VOC) emissions shall not exceed 0.403 gram per brake horsepower hour and 8.67 tons per year.</p> <p>Hydrogen chloride (HCl) emissions shall not exceed 0.15 pound per hour and 0.66 ton per year.</p>



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		<p>Organic compound (OC) emissions shall not exceed 5.84 grams per brake horsepower hour, 28.72 pounds per hour and 125.79 tons per year.</p> <p>See b)(2)a.</p> <p>Compliance with this rule includes compliance with 40 CFR Part 60, Subpart WWW, 40 CFR Part 60, Subpart JJJJ, 40 CFR Part 63, Subpart AAAA and 40 CFR Part 63, Subpart ZZZZ.</p> <p>Compliance with this rule also includes compliance with the requirements of 40 CFR Part 52, Section 52.21, and OAC rules 3745-31-10 through 20.</p>
b.	OAC rule 3745-31-05(A)(3), as effective 12/1/2006	See b)(2)c.
c.	40 CFR Part 52, Section 52.21 and OAC rules 3745-31-10 through 20	Carbon monoxide (CO) emissions shall not exceed 2.75 grams per brake horsepower hour, 13.53 pounds per hour and 59.26 tons per year.
d.	<p>40 CFR Part 60, Subpart WWW 40 CFR Part 63, Subpart AAAA</p> <p>[The landfill gas fired power station acts as either a control device or a landfill gas treatment system for a landfill subject to these subpart; therefore, the control requirements or treatment requirement of this subpart apply.]</p>	See b)(2)d.
e.	OAC rule 3745-17-11(B)(5)	<p>PE shall not exceed 0.062 pound per million Btu of actual heat input.</p> <p>The emission limitation specified in OAC rule 3745-17-11(B)(5) is currently less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3) as effective November 30, 2001.</p>



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		Once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the Ohio State Implementation Plan, the particulate emission limitation in this rule will apply.
f.	OAC rule 3745-17-07(A)	<p>Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.</p> <p>The visible particulate emission limitation specified in OAC rule 3745-17-07(A) is currently less stringent than the visible particulate emission limitation established pursuant to OAC rule 3745-31-05(A)(3) as effective November 30, 2001.</p> <p>Once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the Ohio State Implementation Plan, the visible particulate emission limitation in this rule will apply.</p>
g.	OAC rule 3745-18-06	<p>SO₂ emissions shall not exceed 0.5 pound per million Btu of actual heat input.</p> <p>The emission limitation specified in OAC rule 3745-18-06 is currently less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3) as effective November 30, 2001.</p> <p>Once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the Ohio State Implementation Plan, the SO₂ emission limitation in this rule will apply.</p>
h.	<p>40 CFR Part 60, Subpart JJJJ (40 CFR 60.4230-4248)</p> <p>[In accordance with 40 CFR 60.4230(a)(4)(i), this emissions unit is a landfill gas fired lean burn stationary spark ignition (SI) internal combustion engine (ICE) constructed after June 12, 2006 and manufactured after July 1, 2007 with a maximum engine power greater than or equal to 500 HP]</p>	<p>Emission standards for landfill gas SI-ICE manufactured after July 1, 2007 as specified in Table 1 of 40 CFR Part 60, Subpart JJJJ.</p> <p>NO_x: 3.0 grams per horsepower-hour or 220 ppmvd at 15% oxygen.</p> <p>CO: 5.0 grams per horsepower-hour or 610 ppmvd at 15% oxygen.</p>



	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		<p>VOC: 1.0 gram per horsepower-hour or 80 ppmvd at 15% oxygen</p> <p>The NO_x emission limitations established in this subpart are less stringent than that established pursuant to OAC rule 3745-31-05(D)(1)(a).</p> <p>The VOC emission limitations established in this subpart are currently less stringent than those established pursuant to OAC rule 3745-31-05(A)(3).</p> <p>The CO emission limitations established in this subpart are less stringent than those established pursuant to OAC rules 3745-31-10 through 20.</p>
i.	<p>40 CFR Part 63, Subpart ZZZZ</p> <p>[In accordance with 40 CFR 63.6590.(a)(2)(i), this emissions unit is a landfill gas fired internal combustion engine (ICE) constructed on or after December 19, 2002 with a maximum engine power greater than or equal to 500 HP located at a major source of HAPs.]</p>	See b)(2)e.
j.	ORC 3704.03(T)	Compliance with this rule also includes compliance with the requirements of 40 CFR Part 52, Section 52.21, and OAC rules 3745-31-10 through 20 and OAC rule 3745-31-05(F).
k.	OAC rule 3745-31-05(D)(1)(a) Voluntary restriction to avoid PSD	Nitrogen oxides (NO _x) emissions shall not exceed 0.6 gram per brake horsepower hour and 12.92 tons per year.

(2) Additional Terms and Conditions

- a. The permittee has satisfied the Best Available Technology (BAT) requirements pursuant to OAC paragraph 3745-31-05(A)(3), as effective November 30, 2001, in this permit. On December 1, 2006, paragraph (A)(3) of OAC rule 3745-31-05 was revised to conform to ORC changes effective August 3, 2006 (S.B. 265 changes), such that BAT is no longer required by State regulations for NAAQS



pollutants less than ten tons per year. However, that rule revision has not yet been approved by U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-31-05, the requirement to satisfy BAT still exists as part of the federally-approved SIP for Ohio.

Once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05, then these emission limits/control measures no longer apply.

- b. The internal combustion engine shall operate using lean burn technology.
- c. This rule paragraph applies once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the State Implementation Plan.

The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the PE/PM₁₀, HCl, SO₂ and VOC emissions from this air contaminant source since the uncontrolled potentials to emit for PE/PM₁₀, HCl, SO₂ and VOC are less than 10 tons per year.

- d. Collected landfill gas shall be treated for sale or additional use per 40 CFR 60.752(b)(2)(iii)(C) or shall be routed to a control system per 40 CFR 60.752(b)(2)(iii)(B). The control system shall be designed and operated to reduce the non-methane organic compound (NMOC) by 98 weight-percent or the outlet NMOC emissions shall be reduced to less than 20 parts per million by volume, dry basis (ppmvd) as hexane at 3 percent oxygen.
- e. In accordance with 40 CFR 63.6590(c), a new or reconstructed stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis must meet the initial notification requirements of §63.6645(f) and the requirements of §§63.6625(c), 63.6650(g), and 63.6655(c). These stationary RICE do not have to meet the emission limitations and operating limitations of this subpart.

The permittee shall comply with the General Provisions specified in 40 CFR Part 63, Subpart ZZZZ including 63.6665 and Table 8 which only include the Initial Notification requirements.

- f. The permittee shall comply with the applicable requirements of 40 CFR Part 60, Subpart JJJJ, including the following sections:

60.4236(b)	Installation deadlines
60.4243(b)	Compliance Requirements

- c) Operational Restrictions
 - (1) This emissions unit shall burn only landfill gas.



- (2) The permittee shall install, maintain and operate according to the manufacturer's specifications a device at the inlet to the internal combustion engine which completely shuts off gas flow to the internal combustion engine when the internal combustion engine is not operating.
(3) When demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(C), the permittee has committed to compressing, filtering for particles up to 10 microns in diameter, and dewatering the landfill gas.

Dewatering shall be defined as a reduction of the dew point of the landfill gas by at least 20 degrees Fahrenheit.

- (4) The allowable gas flow rate to the internal combustion engine's combustion chambers shall not exceed 600 scfm.
(5) When demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(B), the minimum allowable average temperature of the internal combustion engine's combustion chambers, based on 3-hour blocks of time, shall not be lower than the minimum combustion temperature that was established during the most recent compliance test that demonstrated compliance with the applicable requirements.
(6) When demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(B), the maximum allowable gas flow rate to the internal combustion engine's, based on 3-hour blocks of time, shall not be higher than the maximum gas flow rate that was established during the most recent compliance test that demonstrated compliance with the applicable requirements.
(7) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart JJJJ, including the following sections:

Table with 2 columns: Reference Code and Description. Rows include 60.4234 (Duration of compliance with the emissions standards), 60.4243(b) (Maintenance Requirements), and 60.4243(g) (Air-to-Fuel (ATR) controllers).

d) Monitoring and/or Recordkeeping Requirements

- (1) The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving each emissions unit. The presence or absence of any visible emissions shall be noted in an operations log for each unit. If visible emissions are observed, the permittee shall also note the following in the operations log:
a. the color of the emissions;
b. the cause of the visible emissions

- c. the total duration of any visible emissions incident; and,
 - d. any corrective actions taken to eliminate the visible emissions.
- (2) The permittee shall record the dates and times when the landfill gas is treated for sale or additional use and when the internal combustion engines are operated as landfill gas control devices.
 - (3) The permittee shall install, calibrate and maintain a continuous device that monitors and records the temperature of the landfill gas prior to dewatering and after dewatering. When demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(C), the temperature shall be monitored at all times.
 - (4) The permittee shall install, calibrate and maintain a temperature monitoring device equipped with a continuous recorder and having a minimum accuracy of +/- 1 percent of the temperature being measured expressed in degrees Celsius or +/- 0.5 degrees Celsius, whichever is greater, for the exhaust of the internal combustion engines. When demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(B), the temperatures shall be monitored at all times.
 - (5) The permittee shall install, calibrate, and maintain a device that monitors and records gas flow to or bypass of the internal combustion engines. The gas flow rate measuring device shall record the flow to the control device at least every 15 minutes.
 - (6) When attempting to demonstrate compliance with 40 CFR 60.752(b)(2)(iii)(B), the permittee shall collect and record each day all 3-hour blocks of time during which the average combustion chamber temperature within the internal combustion engine was less than the allowable minimum operating temperature as established during the most recent compliance test.
 - (7) When attempting to demonstrate compliance with 40 CFR 60.752(b)(2)(iii)(B), the permittee shall collect and record each day all 3-hour blocks of time during which the average landfill gas flow rate to the internal combustion engine exceeded the maximum allowable gas flow as established during the most recent compliance test.
 - (8) The permittee shall record each day when a fuel other than landfill gas was burned in this emissions unit.
 - (9) The permittee shall collect and record all times the flow rate to the internal combustion engine exceeded 600 scfm. The gas flow rate to the engine shall be determined by dividing the total gas flow into the treatment system(s) by the number of engines operating.
 - (10) The permittee shall record (daily) the operating hours of each engine.
 - (11) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart JJJJ, including the following sections:



60.4243(b)(2)(ii)	Keeping a maintenance plan and records of conducted maintenance
60.4245(a)	Records required

(12) The permittee shall comply with the applicable restrictions of 40 CFR Part 63, Subpart ZZZZ, including the following sections:

63.6655(c)	Monitoring and recording of daily fuel usage and operating of unit to reasonably minimize HAP emissions
63.6660	Record retention and format requirements

e) Reporting Requirements

- (1) The permittee shall submit semiannual written reports that:
 - a. identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit;
 - b. describe any corrective actions taken to eliminate the visible particulate emissions;
 - c. identify the date(s) and duration the gas flow rate to the internal combustion engine exceeded the maximum gas flow rate requirements, as established during the most recent compliance stack test, as a 3-hour average;
 - d. when demonstrating compliance with 40 CFR 60.752 (b)(2)(iii)(C), identify the date(s) and duration when the temperature difference of the landfill gas between pre-dewatering and post-dewatering is less than 20 degrees Fahrenheit; and
 - e. when demonstrating compliance with 40 CFR 60.752(b)(2)(iii)(B), identify the date(s) and duration of each 3-hour block of time when the average temperature within the internal combustion engine did not meet the minimum temperature requirements.

These reports shall be submitted to the Northeast District Office of the Ohio EPA by January 31 and July 31 of each year and shall cover the previous 6-month period.

- (2) The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than landfill gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
- (3) Any breakdown or malfunction resulting in the emission of raw landfill gas emissions to the atmosphere shall be reported by phone to the Northeast District Office of Ohio EPA within one hour after the occurrence, or as soon as reasonably possible, and



immediately remedial measures shall be undertaken to correct the problem and prevent further emissions to the atmosphere. A summary of the breakdown or malfunction, including the date(s) and time(s) and the measure(s) taken to correct the problem shall be included in the semi-annual deviation report.

- (4) The permittee shall submit deviation (excursion) reports that identify each time the gas flow rate to the engine exceeded 600 scfm
(5) The permittee shall include any changes made to a parameter or value used in the dispersion model, that was used to demonstrate compliance with the Toxic Air Contaminant Statute, ORC 3704.03(F), through the predicted 1-hour maximum ground-level concentration, in the quarterly deviation (excursion) reports.
(6) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart JJJJ, including the following sections:

Table with 2 columns: Reference Code, Requirement Description. Rows: 60.4245(c) Initial Notification, 60.4245(d) Performance Test Report

- (7) The permittee shall comply with the applicable restrictions of 40 CFR Part 63, Subpart ZZZZ, including the following sections:

Table with 2 columns: Reference Code, Requirement Description. Rows: 63.6645(f) Initial Notification Requirements, 63.6645(c) Initial Notification Required 120 Days After Subject, 63.6650(g) and Table 7 Annual reporting of fuel flow and heat values, operating limits in permit, problems with meters and any deviations.

f) Testing Requirements

- (1) The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
a. The permittee shall conduct an emission test within 12 months after issuance of the permit and, thereafter, in accordance with the emission test requirements specified in 40 CFR Part 60, Subpart JJJJ.
b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rates for NOx, CO and VOC.

- c. Unless the permittee can demonstrate that all landfill gas burned in the internal combustion engines has been compressed, filtered for particulates up to 10 microns in diameter, and dewatered since the previous compliance test, the emission testing shall be conducted to demonstrate compliance with either the removal of 98 weight-percent of NMOC or the reduction of the outlet concentration of NMOC to less than 20 parts per million by volume, dry basis (ppmvd) as hexane at 3 percent oxygen.
- d. The following test methods shall be employed to demonstrate compliance with the allowable mass emission rates:
- NO_x - Methods 1 through 4 and 7; or 7E of 40 CFR Part 60, Appendix A;
CO - Methods 1 through 4 and 10 of 40 CFR Part 60, Appendix A;
VOC - Methods 1 through 4 and 25 or 25A of 40 CFR Part 60, Appendix A; and
NMOC - If required, methods 1 through 4 and 25 or 25C of 40 CFR Part 60, Appendix A.
- Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA.
- e. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the Ohio EPA Northeast District Office.
- f. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA Northeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA Northeast District Office's refusal to accept the results of the emission test(s).
- g. Personnel from the Ohio EPA Northeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- h. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA Northeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA Northeast District Office.
- (2) Compliance with the emission limitations established in b)(1) and b)(2) of this permit shall be determined in accordance with the following methods:



a. Emission Limitations:

VOC emissions shall not exceed 0.403 gram per brake horsepower hour and 8.67 tons per year.

Applicable Compliance Methods:

Compliance with the VOC hourly emission limitation shall be demonstrated in accordance with the performance test requirement specified in f)(1).

The tpy emission limitation was developed by multiplying the short-term allowable VOC emission limitation by the maximum rated power (2233 bhp-hr) times the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton and 453.59 grams per pound. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

b. Emission Limitation:

Visible particulate emissions shall not exceed 10% opacity as a 6-minute average.

Applicable Compliance Method:

If required, compliance shall be demonstrated based upon visible particulate emission observations performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 9.

c. Emission Limitation:

PE/PM₁₀ emissions shall not exceed 0.1 gram per brake horsepower hour.

Applicable Compliance Method:

If required, compliance shall be demonstrated based upon an emission test performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 5.

d. Emission Limitations:

PE/PM₁₀ emissions shall not exceed 0.49 pound per hour and 2.15 tons per year.

Applicable Compliance Methods:

Compliance with the PE/PM₁₀ hourly emission rate shall be demonstrated by using the following equation:

$$E = EF \times 2233/453.59$$

where:

E = emissions of PE/PM₁₀ (pound per hour);

EF = emission factor provided by manufacturer (0.1 g PM₁₀/bhphr);

2,233 = rating of engine (bhphr); and

453.59 = conversion factor grams per pound.

The tpy emission limitation was developed by multiplying the short-term allowable PE/PM₁₀ emission limitation (0.49 lb/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

e. Emission Limitations:

NO_x emissions shall not exceed 0.6 gram per brake horsepower hour and 12.92 tons per year.

Applicable Compliance Methods:

Compliance with the NO_x hourly emission and technical limitations shall be demonstrated in accordance with the performance test requirement specified in f)(1).

The tpy emission limitation was developed by multiplying the short-term allowable NO_x emission limitation (2.95 lbs/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

f. Emission Limitations:

CO emissions shall not exceed 2.75 grams per brake horsepower hour, 13.53 pounds per hour and 59.26 tons per year.

Applicable Compliance Methods:

Compliance with the CO hourly emission and technical limitations shall be demonstrated in accordance with the performance test requirement specified in f)(1).

The tpy emission limitation was developed by multiplying the short-term allowable CO emission limitation (13.53 lbs/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

g. Emission Limitations:

SO₂ emissions shall not exceed 0.28 pound per hour and 1.23 tons per year.

Applicable Compliance Methods:

Compliance with the SO₂ hourly emission rate shall be demonstrated by using the following equation:

$$E = EF \times (MW/24.45) \times \text{Flow} \times 60 / (35.31 \times 1000 \times 454)$$

where:

E = emissions of SO₂ (pound per hour);

EF = emission factor from AP-42, Section 2.4, Municipal Solid Waste Landfills, version 10/2008 (46.9 ppmv SO₂);

MW = molecular weight of SO₂, 64.06;

24.45 = equation constant;

Flow = average flow of LFG to engine, ft³ per minute;

60 = conversion factor, minutes per hour;

35.31 = conversion factor, ft³ per m³;

1000 = conversion factor, milligrams per gram; and

454 = conversion factor, grams per pound.

The tpy emission limitation was developed by multiplying the short-term allowable SO₂ emission limitation (0.28 lb/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

h. Emission Limitation:

The control system shall be designed and operated to reduce the NMOC by 98 weight-percent or the outlet NMOC emissions shall be reduced to less than 20 parts per million by volume, on a dry basis (ppmvd) as hexane at 3 percent oxygen.

Applicable Compliance Method:

If required, compliance with the control efficiency limitation shall be demonstrated in accordance with the performance test requirement specified in f)(1).

Compliance with this condition is not required if all landfill gas is treated in compliance with 40 CFR 60.752(b)(2)(iii)(C).

i. Emission Limitation:

PE shall not exceed 0.062 pound per million Btu of actual heat input.

Applicable Compliance Method:

If required, compliance with the PE pound per million Btu of actual heat input limitation shall be demonstrated based upon an emission test performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 5.

j. Emission Limitations:

HCl emissions shall not exceed 0.15 pound per hour and 0.66 ton per year.

Applicable Compliance Methods:

If required, compliance with the HCl hourly emission limitation shall be demonstrated based upon an emission test performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 26.

The tpy emission limitation was developed by multiplying the short-term allowable HCl emission limitation (0.15 lb/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.

k. Emission Limitations:

OC emissions shall not exceed 5.84 grams per brake horsepower hour, 28.72 pounds per hour and 125.79 tons per year.

Applicable Compliance Methods:

If required, compliance with the OC hourly emission and technical limitations shall be demonstrated based upon an emission test performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 25.

The tpy emission limitation was developed by multiplying the short-term allowable OC emission limitation (28.72 lbs/hr) by the maximum annual hours of operation (8,760 hours), and then dividing by 2,000 lbs per ton. Therefore, if compliance is shown with the short-term allowable emission limitation, compliance is demonstrated with the annual emission limitation.



I. Emission Limitation:

Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by the rule.

Applicable Compliance Method:

If required, compliance shall be demonstrated based upon visible particulate emission observations performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 9.

m. Emission Limitation:

SO₂ emissions shall not exceed 0.5 pound per million Btu of actual heat input.

Applicable Compliance Method:

If required, compliance with the SO₂ pound per million Btu of actual heat input limitation shall be demonstrated based upon an emission test performed in accordance with the methods and procedures specified in 40 CFR Part 60, Appendix A, Method 8.

(3) The permittee shall comply with the applicable restrictions of 40 CFR Part 60, Subpart JJJJ, including the following sections:

60.4243(b)(1)	Certified engines - Compliance demonstration
60.4243(b)(2)	Non-certified engines - Compliance demonstration
60.4244	Test methods and procedures

g) Miscellaneous Requirements

(1) None.