OhioEPA

State Of Ohio Environmental Protection Agency

P.O. Box 1049, 361 East Broad St., Columbus, Ohio 43216-1049
(614) 466-8565

Richard F. Celeste, Governor

Re: Permit to Install
Stark County

July 2, 1986

CERTIFIED MAIL

BONDED OIL #124 15-318
2525 N. LIMESTONE ST.
SPRINGFIELD, OHIO 45501

ATTN: LOWELL STEVENS

Dear Sir:

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
250 East Town Street, Room 101
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo

Thomas G. Rigo, Manager
Field Operations Section
Division of Air Pollution Control

RECEIVED
JUL 07 1986
CITY OF CANTON
HEALTH DEPT.
AIR POLLUTION CONTROL

TGR/gs

cc: US EPA
Canton Division of Air Pollution Control

OhioEPA

State of Ohio Environmental Protection Agency

Permit to Install
Terms and Conditions

Application No. 15-318
APS Premise No. 1576ØØ1481
Permit Fee: $5Ø.

Name of Facility: BONDED OIL #124

Person to Contact: LOWELL STEVENS

Address: 2525 N LIMESTONE ST
SPRINGFIELD, OHIO 455Ø1

Location of proposed source(s): 2122 NAVARRE RD SW
CANTON, OHIO

Description of proposed source(s): 3 1ØM REPLACEMENT GASOLINE STORAGE TANKS AT GASOLINE DISPENSING FACILITY.

Date of Issuance: JULY 2, 1986

Effective Date: JULY 2, 1986

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Warren W. Tyler

EPA 3156

Substantial construction for installation must take place within eighteen months of the effective date of this permit. This deadline may be extended by up to twelve months, if application is made to the Director no less than sixty days before the expiration of this permit and the party shows good cause for any such extension.

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, examining records or reports pertaining to the construction, modification or installation of the above described source of environmental pollutants.

If the construction of the proposed source has already begun or has been completed prior to the date the Director of the Ohio Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC Rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

The specified permit fee must be remitted within 15 days of the effective date of this permit to install.

This permit shall apply only to the source(s) shown on the application approved by the Ohio Environmental Protection Agency.

The appropriate District Office of the Ohio EPA or Local Air Agency shall be notified, in writing as to (a) the construction starting date (b) the construction completion date and (c) the date the facilities were placed into operation.

Emissions from the source shall not exceed the limits specified below:

Ohio EPA Source No	Source and Identification	BAT Determination	Applicable OAC Rule	Annual Emissions Tons/Year
G001	3 10M Underground Storage Tanks	Vapor Balance System	3745-21-09(R)	0*

*No increase in emissions since old tanks are being replaced by new tanks.

SUMMARY

TOTAL EMISSIONS - SOURCE

Pollutant	Tons/Year
VOC	No increase