



PERMIT TO OPERATE AN AIR CONTAMINANT SOURCE

Date of Issuance 08/28/92 Application No. 1576130018N002

Effective Date 08/28/92 Permit Fee \$210

This document constitutes issuance to:

MASSILLON COMMUNITY HOSPITAL
875-8TH ST NE
MASSILLON

OHIO 44846

of a permit to operate for:

MULTIPLE CHAMBER INCINERATOR PATHOLOGICAL WASTES
PL-0604 KELLOGG/MANN DR-250

The following terms and conditions are hereby expressly incorporated into this permit to operate:

1. This permit to operate shall be effective until 08/27/95. You will be contacted approximately six months prior to this date regarding the renewal of this permit. If you are not contacted, please write to the appropriate Ohio EPA field office.
2. The above-described source is and shall remain in full compliance with all applicable State and federal laws and regulations and the terms and conditions of this permit.
3. Prior to any modification of this source, as defined in rule 3745-31-01 of the Ohio Administrative Code (OAC), a permit to install must be granted by the Ohio EPA pursuant to OAC Chapter 3745-31.
4. The Director of the Ohio EPA or an authorized representative may, subject to the safety requirements of the permit holder, enter upon the premises of this source at any time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State and federal air pollution laws and regulations and the terms and conditions of this permit.
5. A permit fee in the amount specified above must be remitted within 15 days from the issuance date of this permit.
6. Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA field office must be notified in writing of any transfer of this permit.
7. This source and any associated air pollution control system(s) shall be maintained regularly in accordance with good engineering practices in order to minimize air contaminant emissions. Any malfunction of this source or any associated air pollution control system(s) shall be reported immediately to the appropriate Ohio EPA field office in accordance with OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of this source.
8. Any unauthorized or emergency release of an air contaminant from this source which, due to the toxic or hazardous nature of the material, may pose a threat to public health, or otherwise endanger the safety or welfare of the public, shall be reported immediately to the appropriate Ohio EPA field office (during normal business hours) or to the Ohio EPA's Emergency Response Group (1-800-282-9378). (Additional reporting may be required pursuant to the federal Comprehensive Environmental Response, Compensation, and Liability Act.)
9. The appropriate Ohio EPA field office is:

DIV. OF AIR POLLUTION CNTRL CANTON CITY HEALTH DEPT.
THIRD FLOOR, CITY HALL
CANTON, OH 44702 (216) 489-3385

10. If this term and condition is checked, the permit holder is subject to the attached special terms and conditions.

OHIO ENVIRONMENTAL PROTECTION AGENCY

Donald R. Scheyardus

Director

APPLICATION NUMBER: 15 76 13 0018 N002
FACILITY NAME: Massillon Community Hospital
EQUIPMENT DESCRIPTION: Multiple Chamber Incinerator
Pathological Wastes
COMPANY ID: PL-0604 Kellogg/Mann DR-250

SPECIAL TERMS AND CONDITIONS

1. The following rules of the Ohio Administrative Code establish the applicable emission limitations and/or control requirements of this source:

3745-75

(This condition in no way limits the applicability of other requirements of the Ohio Administrative Code to this source.)

2. Pathological wastes shall not be incinerated at a rate higher than 100 lbs/hour. An individual load will not exceed 50 lbs.

3. The incinerator shall not be operated with the afterburner chamber temperature below 1600 degree F.

4. A record will be maintained of when pathological wastes were incinerated and the weight of each load. These records will be maintained for a minimum of two years and will be made available to members of this agency upon request during normal business hours.

5. Afterburner chamber temperatures will be continuously monitored and recorded. These records shall be maintained for a minimum of two years and will be made available to members of this agency upon request during normal business hours. If temperatures below 1600 degrees F are recorded during a burn cycle, this agency will be notified within 24 hours of the event, and the incinerator will not be operated again until repairs have been made that will remedy the problem.

6. This incinerator is being replaced by a new incinerator. As provided in OAC 3745-75-06 (B) (2) (d), this incinerator need not comply with OAC 3745-75-06 if it permanently ceases operation by July 1, 1993 and if a replacement incinerator will be installed.

PREPARED BY: Daniel J. Schiltz
DATE PREPARED: 7-31-92

EPA 3164
02/14/83