



Environmental Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

11/1/2012

Certified Mail

Mr. Harry Wyatt
Ohio University Lausche Heating Plant
49 Factory Street
Athens, OH 45701

RE: FINAL AIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 0605010016
Permit Number: P0110313
Permit Type: OAC Chapter 3745-31 Modification
County: Athens

| | |
|-----|------------------------------------|
| No | TOXIC REVIEW |
| No | PSD |
| No | SYNTHETIC MINOR TO AVOID MAJOR NSR |
| No | CEMS |
| No | MACT/GACT |
| Yes | NSPS |
| No | NESHAPS |
| No | NETTING |
| No | MAJOR NON-ATTAINMENT |
| Yes | MODELING SUBMITTED |
| No | MAJOR GHG |
| No | SYNTHETIC MINOR TO AVOID MAJOR GHG |

Dear Permit Holder:

Enclosed please find a final Air Pollution Permit-to-Install (PTI) which will allow you to install or modify the described emissions unit(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, we urge you to read it carefully. Please complete a survey at www.epa.ohio.gov/dapc/permitsurvey.aspx and give us feedback on your permitting experience. We value your opinion.

The issuance of this PTI is a final action of the Director and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00, made payable to "Ohio Treasurer Josh Mandel," which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

The Ohio EPA is encouraging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Compliance Assistance and Pollution Prevention at (614) 644-3469. If you have any questions regarding this permit, please contact the Ohio EPA DAPC, Southeast District Office. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Issued Air Pollution Control Permits" link.

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA
Ohio EPA-SEDO; West Virginia



FINAL

Division of Air Pollution Control
Permit-to-Install
for
Ohio University Lausche Heating Plant

Facility ID: 0605010016
Permit Number: P0110313
Permit Type: OAC Chapter 3745-31 Modification
Issued: 11/1/2012
Effective: 11/1/2012



Division of Air Pollution Control
Permit-to-Install
for
Ohio University Lausche Heating Plant

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 9
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 9
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 13
1. B058, Boiler #4 - 155 MMBtu/hr Natural Gas fired boiler equipped with Low-NOx burners and flue gas recirculation. 14

Authorization

Facility ID: 0605010016
Facility Description: University Steam Generating Plant
Application Number(s): A0044781
Permit Number: P0110313
Permit Description: This is a Chapter 31 modification of the 155 MMBtu natural gas boiler to allow 8760 hours per year operation. It eliminates the fuel usage restriction of PTI # 06-3816 which was issued Final October 20, 1993.
Permit Type: OAC Chapter 3745-31 Modification
Permit Fee: \$1,000.00
Issue Date: 11/1/2012
Effective Date: 11/1/2012

This document constitutes issuance to:

Ohio University Lausche Heating Plant
Factory Street
Athens, OH 45701

of a Permit-to-Install for the emissions unit(s) identified on the following page.


Ohio EPA District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Southeast District Office
2195 Front Street
Logan, OH 43138
(740)385-8501

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency


Scott J. Nally
Director



Authorization (continued)

Permit Number: P0110313
Permit Description: This is a Chapter 31 modification of the 155 MMBtu natural gas boiler to allow 8760 hours per year operation. It eliminates the fuel usage restriction of PTI # 06-3816 which was issued Final October 20, 1993.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

| | |
|-----------------------------------|-----------------------------------|
| Emissions Unit ID: | B058 |
| Company Equipment ID: | Boiler #4 - 155 MMBtu/hr Nat. Gas |
| Superseded Permit Number: | |
| General Permit Category and Type: | Not Applicable |

A. Standard Terms and Conditions

1. Federally Enforceable Standard Terms and Conditions

- a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:
 - (1) Standard Term and Condition A.2.a), Severability Clause
 - (2) Standard Term and Condition A.3.c) through A. 3.e)General Requirements
 - (3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements
 - (4) Standard Term and Condition A.9., Reporting Requirements
 - (5) Standard Term and Condition A.10., Applicability
 - (6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install
 - (7) Standard Term and Condition A.14., Public Disclosure
 - (8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations
 - (9) Standard Term and Condition A.16., Fees
 - (10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

- a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.
- b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

- a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

- b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d) This permit does not convey any property rights of any sort, or any exclusive privilege.
- e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

- a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - (1) The date, place (as defined in the permit), and time of sampling or measurements.
 - (2) The date(s) analyses were performed.
 - (3) The company or entity that performed the analyses.
 - (4) The analytical techniques or methods used.
 - (5) The results of such analyses.
 - (6) The operating conditions existing at the time of sampling or measurement.
- b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - (1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Ohio EPA DAPC, Southeast District Office.
 - (2) Quarterly written reports of (i) any deviations from federally enforceable emission limitations, and (ii) operational restrictions.

andcontroldeviceoperatingparameterlimitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Ohio EPA DAPC, Southeast District Office. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.

- (3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, andreportingrequirements contained in this permit shall be submitted (i.e., postmarked) to the Ohio EPA DAPC, Southeast District Office every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - (4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Ohio EPA DAPC, Southeast District Office in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

- a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.
- b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:

- (1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - (3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - (4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- d) The permittee shall submit progress reports to the Ohio EPA DAPC, Southeast District Office concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
- (1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - (2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Ohio EPA DAPC, Southeast District Office.
- b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Ohio EPA DAPC, Southeast District Office. If no deviations occurred during a calendar quarter, the permitteeshall

submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

- a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.
- b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.
- c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as "permanently shut down" in Ohio EPA's "Air Services" along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).
- d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All

records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

- e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

- a) Completion of initial installation date shall be entered upon completion of construction and prior to start-up.
- b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the "Owner/Contact Change" functionality in Air Services once the transfer is legally completed. The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

B. Facility-Wide Terms and Conditions

1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:
 - a) None.
2. The following emissions unit contained in this permit are subject to 40 CFR Part 60, Subpart Db: B058. The complete NSPS requirements may be accessed via the internet from the Electronic Code of Federal Regulations (e-CFR) website <http://ecfr.gpoaccess.gov> or by contacting the appropriate Ohio EPA District Office or local air agency.
3. The Ohio EPA has determined that this facility may be applicable to the requirements of an area source MACT/GACT rule that the Ohio EPA does not have the delegated authority to implement. Although Ohio EPA has determined that an area source MACT (also known as the GACT) may apply, at this time Ohio EPA does not have the authority to enforce this standard. Instead, U.S. EPA has the authority to enforce this standard. Please be advised that all requirements associated with these rules are in effect and are enforceable by U.S. EPA. For more information on the area source rules, please refer to the following U.S. EPA website: <http://www.epa.gov/ttn/atw/area/arearules.html>.

C. Emissions Unit Terms and Conditions



1. B058, Boiler #4 - 155 MMBtu/hr Natural Gas fired boiler equipped with Low-NOx burners and flue gas recirculation.

Operations, Property and/or Equipment Description:

Boiler #4 - 155 million Btu/hr natural gas fired boiler with Low-NOx burners and flue gas recirculation.(Chapter 31 modification to PTI # 06-3816 issued Final on October 20, 1993 to increase allowable emissions to reflect potential to emit (PTE)).

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) g)(1)

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

| | Applicable Rules/Requirements | Applicable Emissions Limitations/Control Measures |
|----|---|--|
| a. | ORC 3704.03(T) | Nitrogen oxides (NO _x) emissions shall not exceed 0.10 lb/MMBtu. Carbon monoxide (CO) emissions shall not exceed 0.083lb/MMBtu. |
| b. | OAC rule 3745-31-05(A)(3), as effective 12/01/06 | Particulate emissions (PE) shall not exceed 0.008 lb/MMBtu and 5.43 tons per year. Volatile Organic Compound (VOC) emissions shall not exceed 0.0054 lb/MMBtu and 3.67 tons per year. Sulfur Dioxide (SO _x) emissions shall not exceed 0.0006 lb/MMBtu and 0.40 ton per year. See b)(2)a. |
| c. | OAC rule 3745-31-05(A)(3)(b), as effective 12/01/06 | See b)(2)b. below. |
| d. | OAC rule 3745-31-05(A)(3)(a)(ii), as effective 12/01/06 | See b)(2)c. below. |
| e. | OAC rule 3745-17-07(A) | Visible PE from any stack serving this emissions unit shall not exceed 20 percent opacity as a six-minute average, except as provided by rule. |

| | Applicable Rules/Requirements | Applicable Emissions Limitations/Control Measures |
|----|---|---|
| f. | OAC rule 3745-17-10(B)(1) | The PE limitation established pursuant to this rule is less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3). |
| g. | 40 CFR Part 60, Subpart Db (40 CFR 60.40b – 60.49b) [In accordance with 40 CFR 60.40b(a), this emissions unit is a steam generating unit for which construction, modification, or reconstruction commenced after June 19, 1984 and that has a maximum design heat input capacity of greater than 29 megawatts (MW) (100 million British thermal units per hour (MMBtu/hr))] | See b)(2)c.; b)(2)d.; and d)(2) below. |
| h. | 40 CFR 60.1-19 | See e)(3) below. |

(2) Additional Terms and Conditions

- a. The permittee has satisfied the Best Available Technology (BAT) requirements pursuant to OAC paragraph 3745-31-05(A)(3), as effective November 30, 2001, in this permit. On December 1, 2006, paragraph (A)(3) of OAC rule 3745-31-05 was revised to conform to ORC changes effective August 3, 2006 (S.B.265 changes), such that BAT is no longer required by State regulations for NAAQS pollutants less than ten tons per year. However, that rule revision has not yet been approved by U.S. EPA as a revision to Ohio’s State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-31-05, the requirement to satisfy BAT still exists as part of the federally-approved SIP for Ohio. Once U.S. EPA approves the December 1, 2006 version of 3745-31-05, then these emission limits/control measures for PE, VOC and SOx no longer apply.
- b. This rule paragraph applies once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the SIP.

Permit to Install and Operate P0110313 for this air contaminant source takes into account the following voluntary restriction (including the use of any applicable air pollution control equipment) as proposed by the permittee for the purpose of avoiding Best Available Technology (BAT) requirements under OAC rule 3745-031-05(A)(3):

- i. PE shall not exceed 0.008lb/mmBtu and 5.43 tons per year.
- ii. VOC emissions shall not exceed 0.0054 lb/MMBtu and 3.67 tons per year.



- iii. SOx emissions shall not exceed 0.0006 lb/MMBtu and 0.40 ton per year.
c. This rule paragraph applies once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the SIP.

The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the PE, VOC, and SOx emissions from this air contaminant source since the uncontrolled potential to emit for PE, VOC, and SOx is less than 10 tons/yr.

- d. The only fuel combusted in this emissions unit is natural gas. Thus, this emissions unit is not subject to the SO2 and particulate matter (PM) emissions limitations in 40 CFR 60.42b and 60.43b or the emissions monitoring requirements in 40 CFR 60.47b and 60.48b.

c) Operational Restrictions

- (1) The permittee shall burn only natural gas in this emissions unit.

d) Monitoring and/or Recordkeeping Requirements

- (1) For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
(2) The permittee shall comply with the applicable monitoring and recordkeeping requirements required under 40 CFR Part 60, Subpart Db, including the following sections:

Table with 2 columns: Record Keeping (60.49b(d), (o)) and Maintain records of the amount of each fuel combusted during each calendar month; only natural gas fuel combusted

e) Reporting Requirements

- (1) The permittee shall submit semiannual reports and such other notifications and reports to the appropriate Ohio EPA District office as are required pursuant to 40 CFR part 60, Subpart Db, per the following sections:

Table with 2 columns: Record Keeping (60.49b(a)(1)-(3), 60.49b(q)(1), 60.49b(q)(3)) and Information required to be submitted in the construction notification, Requirement to submit performance test data, Requirement to submit performance test data for NOx along with hours of operation for the reporting period and hours of operation since the last performance test..



| | |
|-----------|--|
| 60.49b(w) | Required reporting periods under this subpart are each six month period. Reports due by the 30 th day following the reporting period. |
|-----------|--|

- (2) Pursuant to the NSPS, the permittee is required to report the following information at the appropriate times (if the information has not already been reported):
- a. Construction date (no later than 30 days after such date);
 - b. Anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
 - c. Actual start-up date (within 15 days after such date); and,
 - d. Date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to the appropriate local air agency or District Office and to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P.O. Box 163669
Columbus, Ohio 43216-3669

f) Testing Requirements

- (1) Compliance with the emission limitations in b)(1) shall be determined in accordance with the following methods:

- a. Emissions Limitation:

NO_x emissions shall not exceed 0.10 lb/MMBtu.

Applicable Compliance Methods:

The emissions limitation is based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/MMBtu emission limitation may be determined by dividing the 100 lbsNO_x/million cubic feet emission factor by 1,020 Btu/scf.

Nitrogen oxides emissions shall be determined according to test Methods 1 - 4, and 7 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

b. Emissions Limitation:

CO emissions shall not exceed 0.083lb/MMBtu.

Applicable Compliance Method:

The emissions limitation is based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-1 (7/98). Compliance with the lb/MMBtu emission limitation may be determined by converting the 84 lbs CO/10⁶ scf emission factor into lb CO/MMBtu by dividing by 1,020 Btu/scf.

If required, the permittee shall demonstrate compliance with the lb/MMBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 10.

c. Emissions Limitations:

PE shall not exceed 0.008 lb/MMBtu and 5.43 tons per year.

Applicable Compliance Methods:

The emissions limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/MMBtu emission limitation may be determined by converting the 7.6lbsPM/10⁶ scf emission factor into lb PM/MMBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lb PE/MMBtu value by the maximum rated heat input capacity of the emissions unit (155MMBtu/hr), then multiplying by 8,760 hrs/yr and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 5.

d. Emissions Limitations:

VOC emissions shall not exceed 0.0054 lb/MMBtu and 3.67 tons per year.

Applicable Compliance Method:

The emissions limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/MMBtu emission limitation may be determined by converting the 5.5lbsVOC/10⁶ scf emission factor into lb VOC/MMBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lbVOC/MMBtu value by the maximum rated heat input capacity of the emissions unit (155MMBtu/hr), then multiplying by 8,760 hrs/yr and dividing by 2,000 lbs/ton.

e. Emissions Limitations:

SOx emissions shall not exceed 0.0006 lb/MMBtu and 0.40 ton per year.

Applicable Compliance Method:

The emissions limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/MMBtu emission limitation may be determined by converting the 0.6 lbSOx/10⁶ scf emission factor into lb SOx/MMBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lbSOx/MMBtu value by the maximum rated heat input capacity of the emissions unit (155MMBtu/hr), then multiplying by 8,760 hrs/yr and dividing by 2,000 lbs/ton.

f. Emissions Limitation:

Visible PE from any stack shall not exceed 20% opacity, as a six-minute average, except as provided by rule.

Applicable Compliance Method:

If required, visible particulate emissions shall be determined according to USEPA Method 9.

(2) The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

- a. The emission testing shall be conducted within 180 days after Final Issuance of this permit.
- b. The emission testing shall be conducted to demonstrate compliance with the lb/MMBtu of NOx emissions limitation.
- c. The following test methods shall be employed to demonstrate compliance with the particulate emission limitation:
 - i. Method 1-4 of 40 CFR Part 60, Appendix A; and
 - ii. Method 7, of 40 CFR Part 60, Appendix A.

Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.

- d. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency. The stack test shall be performed in accordance with the requirements established in 40 CFR 63.11212.
- e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the appropriate Ohio EPA District Office or local air agency. The "Intent to Test" notification shall describe in detail the

proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA District Office's or local air agency's refusal to accept the results of the emission test(s).

- b. Personnel from the appropriate Ohio EPA District Office or local air agency shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
- c. A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the appropriate Ohio EPA District Office or local air agency within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the appropriate Ohio EPA District Office or local air agency.

g) **Miscellaneous Requirements**

- (1) Modeling to demonstrate compliance with the "Toxic Air Contaminant Statute" in ORC 3704.03(F)(4)(b) was not necessary because the emissions unit's maximum annual emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires permittee's to apply for and obtain a new or modified permit to install and operate prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new material, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install and operate.