



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
COSHOCOTON COUNTY**

CERTIFIED MAIL

Street Address:

50 West Town Street, Suite 700

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 06-08121

Fac ID: 0616000000

DATE: 3/13/2007

Conesville Power Plant
Jeff Lytle
1 Riverside Plaza
Columbus, OH 43215

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

Sincerely,

Michael W. Ahern

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

SEDO



**Permit To Install
Terms and Conditions**

**Issue Date: 3/13/2007
Effective Date: 3/13/2007**

FINAL PERMIT TO INSTALL 06-08121

Application Number: 06-08121
Facility ID: 0616000000
Permit Fee: **\$3950**
Name of Facility: Conesville Power Plant
Person to Contact: Jeff Lytle
Address: 1 Riverside Plaza
Columbus, OH 43215

Location of proposed air contaminant source(s) [emissions unit(s)]:
**47201 County Road 273
Conesville, Ohio**

Description of proposed emissions unit(s):
Material Handling Systems.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Permit-To-Install General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.9 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - iv. If this permit is for an emissions unit located at a Title V facility, then each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d. The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

- iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit-To-Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this permit is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

13. Permit-To-Install

A permit-to-install must be obtained pursuant to OAC Chapter 3745-31 prior to "installation" of "any air contaminant source" as defined in OAC rule 3745-31-01, or "modification", as defined in OAC rule 3745-31-01, of any emissions unit included in this permit.

B. State Only Enforceable Permit-To-Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

4. Authorization To Install or Modify

If applicable, authorization to install or modify any new or existing emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

5. Construction of New Sources(s)

This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

8. Construction Compliance Certification

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 0616000000

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the permit-to-install application and the terms and conditions of the permit-to-install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

9. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit-To-Install Summary of Allowable Emissions

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
Particulate	12.5

Conesville Power Plant
PTI Application: 06-08121
Issued: 3/13/2007

Facility ID: 061600000

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F015) - Unit 4 Flue Gas Desulfurization(FGD) Limestone Handling System W/ Enclosures and Baghouses

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
OAC rule 3745-31-05(C) (Synthetic Minor to Avoid PSD)	See section A.I.2.a below. Particulate emissions(PE) shall be less than 10.0 tons per rolling 12-month period.
40 CFR 60.672 (NSPS Subpart OOO)	No owner or operator shall cause to be discharged into the atmosphere from any baghouse that controls emissions from only an individual, enclosed storage bin, stack emissions which exhibit greater than 7 percent opacity. No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affected facility any fugitive emissions which exhibit greater than 10 percent opacity. See section A.I.2.b below.
OAC rule 3745-17-11(A)(2)	PE shall not exceed 66.3 pounds per hour.
OAC rule 3745-17-07(A)	The emissions limit specified by this rule is less stringent than the emission limitation established pursuant to 40 CFR Part 60.672(NSPS Subpart OOO).

2. Additional Terms and Conditions

- 2.a Permit to Install 06-08121 for this air contaminant source takes into account the following voluntary restrictions(including the use of any applicable air pollution control equipment) as proposed by the permittee for the purpose of avoiding Best Available Technology requirements under OAC rule 3745-31-05(A)(3):

Emissions Unit ID: F015

- i. partial enclosure, full enclosure and baghouses, and;
- ii. annual limestone throughput of 346,385 tons per rolling 12-month period limestone throughput limitation.

2.b The material handling operations that are covered by this permit and subject to the requirements of 40 CFR 60.672 (NSPS Subpart OOO) are listed below:

- i. under pile reclaim feeders,
- ii. reclaim conveyor,
- iii. day bin feed conveyors,
- iv. limestone storage day bin vent bag filters,
- v. limestone feeders, and;
- vi. wet ball mills.

II. Operational Restrictions

- 1. The maximum throughput for this emissions unit shall not exceed 346,385 tons of limestone, based upon a rolling, 12-month summation of the throughput rates.

To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the limestone throughput specified in the following table:

<u>Month(s)</u>	<u>Maximum Allowable Limestone Throughput, Tons</u>
1	130,016
1-2	195,024
1-3	260,032
1-4	325,040
1-5	346,385
1-6	346,385
1-7	346,385
1-8	346,385
1-9	346,385
1-10	346,385
1-11	346,385
1-12	346,385

After the first 12 calendar months of operation following the issuance of this permit, compliance with the throughput limitation shall be based upon a rolling, 12-month summation of the limestone throughput.

Issued: 3/13/2007

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain monthly records of the following information for this emissions unit in order to monitor compliance with the applicable material throughput restriction:
 - a. the material throughput for each month; and
 - b. beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling, 12-month summation of the material throughput.

Also during the first 12 calendar months of operation following the issuance of this permit, the permittee shall record the cumulative material throughput for each calendar month.

2. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from any stack and for any visible emissions of fugitive dust from the egress points (i.e., building windows, doors, roof monitors, etc.) serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the location and color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the daily check until the incident has ended. The observer may indicate that the visible emission incident was continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

Emissions Unit ID: F015

IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports which identify all exceedances of the rolling, 12-month material throughput restriction, and for the first 12 calendar months of operation following issuance of this permit, all exceedances of the maximum allowable cumulative throughput levels.
2. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from any stack serving this emissions unit, (b) identify all days during which any visible emissions of fugitive dust were observed from the egress points (i.e., building windows, doors, roof monitors, etc.) serving this emissions unit, and (c) describe any corrective actions taken to minimize or eliminate the visible particulate emissions and/or visible fugitive dust emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month periods.
3. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.
4. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. construction date (no later than 30 days after such date);
 - b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
 - c. actual start-up date (within 15 days after such date); and
 - d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
50 West Town Street, Suite 700
P. O. Box 1049
Columbus, Ohio 43216-1049

and

Southeast District Office of the Ohio EPA
Division of Air Pollution Control
2195 Front Street

Issued: 3/13/2007

Logan, Ohio 43138.

V. Testing Requirements

1. Compliance with the limitations contained in Section A.I.1 of these terms and conditions shall be determined in accordance with the following methods:

Issued: 3/13/2007

a. Emission Limitation:

Particulate emissions(PE) shall be less than 10.0 tons per rolling, 12 month-period.

Applicable Compliance Method:

Compliance with the rolling, 12-month emissions limitation specified above shall be determined by the record keeping requirements specified in Section A.III.1 and the equations contained in AP-42 Chapter 13.2.4 (Aggregate Handling and Storage Piles) and the parameters as listed in Permit to Install application 06-08121, which was submitted to Ohio EPA on March 27, 2006.

b. Emission Limitation:

No owner or operator shall cause to be discharged into the atmosphere from any baghouse that controls emissions from only an individual, enclosed storage bin, stack emissions which exhibit greater than 7 percent opacity

Applicable Compliance Method:

In determining compliance with section 60.672(f) the owner or operator shall use procedures in 40 CFR Part 60.11 and Method 9. The duration of observations shall be 1 hour (ten 6-minute averages).

c. Emission Limitation:

No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affect facility any fugitive emissions which exhibit greater than 10 percent opacity.

Applicable Compliance Method:

In determining compliance with section 60.672(b) the owner or operator shall use procedures in 40 CFR Part 60.11 and Method 9. The duration of observations shall be 3 hours (thirty 6-minute averages). Observations may be reduced to 1 hour (ten 6-minute averages) only if there are no individual readings greater than 10 percent opacity and there are no more than 3 readings of 10 percent for the 1-hour period. The minimum distance between the observer and the emission source shall be 15 feet. The observer shall minimize

Emissions Unit ID: F015

interference from other fugitive emission sources. When a water mist from dust suppression is in use, the observation of emissions is to be made at a point in the plume where the mist is no longer visible.

d. Emission Limitation:

PE shall not exceed 66.3 pounds per hour.

Applicable Compliance Method:

Compliance shall be determined by using the equations contained in AP-42 Chapter 13.2.4 (Aggregate Handling and Storage Piles) and the parameters as listed in Permit to Install application 06-08121, which was submitted to Ohio EPA on March 27, 2006.

2. Compliance with the operational limitation in Section A.II of these terms and conditions shall be determined in accordance with the following method:

Material Throughput Restriction:

346,385 tons of limestone throughput, per rolling, 12-month period.

Applicable Compliance Method:

Compliance with the rolling, 12-month material throughput restriction specified above shall be determined by the record keeping requirements specified in Section A.III.1.

3. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

a. The emission testing shall be conducted within 180 days after the initial startup date.

b. The emission testing shall be conducted to demonstrate compliance with the allowable visible particulate emissions limitations.

c. The following test method(s) shall be employed to demonstrate compliance with the allowable emission rate(s): Method 9 for visible particulate emissions.

d. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Southeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the

Issued: 3/13/2007

emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Southeast District Office's refusal to accept the results of the emission test(s).

Personnel from the Southeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Southeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Southeast District Office.

VI. Miscellaneous Requirements

None

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F015) - Unit 4 Flue Gas Desulfurization(FGD) Limestone Handling System

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F016) - Unit 4 Flue Gas Desulfurization (FGD) Limestone and Gypsum Storage Piles

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
ORC 3704.03(T)(4)	See Section A.I.2.b below.

2. Additional Terms and Conditions

- 2.a The storage piles that are covered by this permit are listed below:

All limestone and gypsum storage piles

- 2.b The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the particulate emissions from this air contaminant source since the uncontrolled potential to emit for particulate emissions is less than ten tons per year.

The annual particulate emissions are based upon the maximum production limitations established for the FGD limestone handling system and the FGD gypsum handling system.

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

Issued: 3/13/2007

IV. Reporting Requirements

None

Issued: 3/13/2007

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F016) - Unit 4 Flue Gas Desulfurization (FGD) Limestone and Gypsum Storage Piles

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F017) - Unit 4 Flue Gas Desulfurization(FGD) Gypsum Handling System

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
ORC 3704.03(T)(4)	See Section A.I.2.a below.

2. Additional Terms and Conditions

- 2.a The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to the particulate emissions from this air contaminant source since the uncontrolled potential to emit for particulate emissions is less than ten tons per year.

The annual particulate emissions are based upon the maximum production limitations established for the FGD limestone handling system.

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

Conesville Power Plant
DTI Application: 06 08121

Facility ID: 061600000

Emissions Unit ID: F017

None

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F017) - Unit 4 Flue Gas Desulfurization(FGD) Gypsum Handling System

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F018) -Urea and Trona Handling and Storage Systems consisting of a Trona silo vented to a bin vent filter and Urea handling and conveying

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
OAC rule 3745-31-05(C)	Particulate emissions shall be less than 10.0 tons per year. See Section A.2.a below.
OAC rule 3745-17-07(A)	Visible particulate emissions from any stack shall not exceed 20 percent opacity as a six-minute average, except as specified by rule.
OAC rule 3745-17-11(A)	Particulate emissions from Trona handling shall not exceed 33.5 pounds per hour. See Section A.2.b below.

2. Additional Terms and Conditions

- 2.a Permit to Install 06-08121 for this air contaminant source takes into account the use of a baghouse system, whenever this air contaminant source is in operation, with a minimum control efficiency of 99%, by weight for particulate emissions, as a voluntary restriction as proposed by the permittee for the purpose of avoiding Best Available Technology requirements under OAC rule 3745-31-05(A)(3).
- 2.b The hourly particulate emissions limitation for Trona handling is based upon Table 1 of OAC 3745-17-11 and the maximum process weight estimation of 23 tons per hour contained in the permit to install application which was submitted to Ohio EPA on March 27, 2006.

II. Operational Restrictions

Issued: 3/13/2007

Emissions Unit ID: F018

None

Issued: 3/13/2007

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall perform weekly checks, when the emissions unit is in operation and when the weather conditions allow, for any visible particulate emissions from the stack serving this emissions unit. The presence or absence of any visible emissions shall be noted in an operations log. If visible emissions are observed, the permittee shall also note the following in the operations log:
 - a. the color of the emissions;
 - b. whether the emissions are representative of normal operations;
 - c. if the emissions are not representative of normal operations, the cause of the abnormal emissions;
 - d. the total duration of any visible emission incident; and
 - e. any corrective actions taken to minimize or eliminate the visible emissions.

If visible emissions are present, a visible emission incident has occurred. The observer does not have to document the exact start and end times for the visible emission incident under item (d) above or continue the weekly check until the incident has ended. The observer may indicate that the visible emission incident was continuous during the observation period (or, if known, continuous during the operation of the emissions unit). With respect to the documentation of corrective actions, the observer may indicate that no corrective actions were taken if the visible emissions were representative of normal operations, or specify the minor corrective actions that were taken to ensure that the emissions unit continued to operate under normal conditions, or specify the corrective actions that were taken to eliminate abnormal visible emissions.

IV. Reporting Requirements

1. The permittee shall submit semiannual written reports that (a) identify all days during which any visible particulate emissions were observed from the stack serving this emissions unit and (b) describe any corrective actions taken to minimize or eliminate the visible particulate emissions. These reports shall be submitted to the Director (the appropriate Ohio EPA District Office or local air agency) by January 31 and July 31 of each year and shall cover the previous 6-month periods.

V. Testing Requirements

1. Compliance with the emission limitations in Section A.I.1. of these terms and conditions shall be determined in accordance with the following methods:

Conesville Power Plant
DTI Application: 06 08424

Facility ID: 061600000

Emissions Unit ID: F018

Emission Limitation

Particulate emissions from Trona Handling shall not exceed 33.5 pounds per hour.

Issued: 3/13/2007

Applicable Compliance Method

If required, the permittee shall demonstrate compliance by emission testing in accordance with the procedures specified in 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures specified in OAC rule 3745-17-03(B)(10).

2. Emission Limitation

Visible particulate emissions from any stack shall not exceed 20 percent opacity as a six-minute average, except as specified by rule.

Applicable Compliance Method

Compliance shall be determined through visible emission observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures specified in OAC rule 3745-17-03(B)(1).

3. Emission Limitation

Particulate emissions shall be less than 10.0 tons per year.

Applicable Compliance Method

The permittee may demonstrate compliance with the annual allowable particulate emissions limitation above by multiplying the maximum hourly controlled particulate emission rate(0.39 pounds per hour) by the maximum annual number of hours of operation(8760), and then dividing by 2000 pounds per ton.

VI. Miscellaneous Requirements

None

Issued: 3/13/2007

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - Urea and Trona Handling and Storage Systems consisting of a Trona silo vented to a bin vent filter and Urea handling and conveying

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. **Additional Terms and Conditions**

- 2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None