



State of Ohio Environmental Protection Agency

**RE: FINAL GENERAL PERMIT TO INSTALL
GALLIA COUNTY**

CERTIFIED MAIL

Street Address:

122 S. Front Street

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 06-07680

DATE: 11/30/2004

Holzer Medical Center
Jeff Harrison
100 Jackson Pike
Gallipolis, OH 45631

Enclosed Please find an Ohio EPA Permit To Install referenced above.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Review Appeals Commission pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed within thirty (30) days after the notice of the Directors action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency within three (3) days of filing with the Commission. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Front Street, Room 222
Columbus, Ohio 43215

Sincerely,

Michael W. Ahern

Permit Issuance and Data Management Section
Ohio EPA, Division of Air Pollution Control

cc: USEPA

SEDO



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

Permit To Install
Terms and Conditions

Issue Date: 11/30/2004
Effective Date: 11/30/2004

FINAL GENERAL PERMIT TO INSTALL 06-07680

Application Number: 06-07680
Facility ID: 0627010000
Permit Fee: \$400
Name of Facility: Holzer Medical Center
Person to Contact: Jeff Harrison
Address: 100 Jackson Pike
Gallipolis, OH 45631



Location of proposed air contaminant source(s) [emissions unit(s)]:

100 Jackson Pike
Gallipolis, Ohio

Emissions Unit ID	Permittee Description	Applicable General Permit Terms (see attached)	Fee
B008	14.65 MMBH natural gas or number 2 fuel oil fired Boiler Number 4	10-15 mmBtu/hr Natural Gas and Oil-Fired Boiler, Post 1989	\$400

The above named entity is hereby granted a permit to install for each emissions unit described above pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of the identified general permit requirements identified above for each emissions unit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans included in the application, the above described source(s) of pollutants will be granted the necessary operating permits.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.8 below if no deviations occurred during the quarter.

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

- iii. If this permit is for an emissions unit located at a Title V facility, then written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - iv. If this permit is for an emissions unit located at a Title V facility, then each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d. The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements.

Holzer Medical Center

Issued: 11/30/2004

Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees

within 30 days after the issuance of any Permit To Install. The permittee shall pay all applicable Permit To Operate fees within thirty days of the issuance of the invoice.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance

were achieved.

- ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit To Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this permit is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

13. Permit To Install

A Permit To Install must be obtained pursuant to OAC Chapter 3745-31 prior to "installation" of "any air contaminant source" as defined in OAC rule 3745-31-01, or "modification", as defined in OAC rule 3745-31-01, of any emissions unit included in this permit.

B. State Only Enforceable Permit To Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

4. Authorization To Install or Modify

If applicable, authorization to install or modify any new or existing emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

5. Construction of New Sources(s)

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

Any proposed emissions unit(s) identified in this permit shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Construction Compliance Certification

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

Holzer Medical Center

Issued: 11/30/2004

8. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

9. Permit Renewal

If applicable, approximately six months prior to the expiration date of this permit, a notice regarding the renewal of this permit will be sent to the permittee's designated facility contact. If you are not contacted, please contact the Ohio EPA District Office or local air agency which has jurisdiction in the area in which the facility is located. It is the permittee's responsibility to renew this permit even if no notice of its expiration is received.

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
10 - 17.9 mmBtu/hr Natural Gas/No. 2 Fuel Oil Boiler	OAC rule 3745-31-05(A)(3) OAC rule 3745-17-07(A)(1) OAC rule 3745-17-10(B)(1) 40 CFR Part 60 Subpart Dc OAC rule 3745-18-06(D) OAC rule 3745-21-08(B) OAC rule 3745-21-07(B) OAC rule 3745-23-06(B)

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP
MGP00101081104

Number:

Applicable Emissions
Limitations/Control
Measures

the requirements of OAC rules 3745-31-05(C), 3745-21-07(B), 3745-21-08(B), and 3745-23-06(B).

Particulate emissions (PE) shall not exceed 0.014 lb/mmBtu and 0.92 ton per year (TPY).

This emissions unit shall not use more than 700,000 gallons of No. 2 fuel oil per year.

Organic compound (OC) emissions shall not exceed 0.011 lb/mmBtu and 0.85 TPY.

The emission limitation specified by these rules are less stringent than the emission limitation established pursuant to OAC rule 3745-31-05(A)(3).

Nitrogen oxides (NO_x) emissions shall not exceed 0.14 lb/mmBtu and 9.88 TPY.

When burning No. 2 fuel oil, the emissions limitation specified by this rule is less stringent than the emissions limitation established pursuant to OAC rule 3745-31-05(A)(3).

Carbon monoxide (CO) emissions shall not exceed 0.082 lb/mmBtu and 6.46 TPY.

See term A.2.e.

Sulfur dioxide (SO₂) emissions shall not exceed 0.50 lb/mmBtu and 24.87 TPY.

See term A.I.2.d.

Visible particulate emissions from any stack shall not exceed 10% opacity, as a six-minute average, except for one 6-minute period per hour of not more than 27% opacity.

The requirements of this rule also include compliance with

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

2. Additional Terms and Conditions

- 2.a** Compliance with OAC rule 3745-31-05(A)(3) shall be demonstrated by the use of natural gas or No. 2 fuel oil, a sulfur content limitation for No. 2 fuel oil, and the emission limitations listed in term A.I.1 above.
- 2.b** The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency (U.S. EPA), 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency (Ohio EPA).
- 2.c** The lb/mmBtu actual heat input and tons per year emission limitations, except for SO₂, are based on the emissions unit's potentials to emit. Therefore, no monitoring, record keeping, and reporting requirements are necessary to ensure ongoing compliance with these emission limitations.
- 2.d** The permittee has satisfied the "latest available control techniques and operating practices" required pursuant to OAC rules 3745-21-07(B) and 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3).
- 2.e** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3).

On November 5, 2002, OAC rule 3745-21-08 was revised to delete paragraph (B); therefore, paragraph (B) is no longer part of the State regulations. However, that rule revision has not yet been submitted to U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revisions occurs and the U.S. EPA approves the revisions to OAC rule 3745-21-08, the requirement to satisfy the "best available control techniques and operating practices" still exists as part of the federally-approved SIP for Ohio.

II. Operational Restrictions

- 1.** The permittee shall burn only natural gas and/or No. 2 fuel oil in this emissions unit.
- 2.** The quality of No. 2 fuel oil received for burning in this emissions unit shall have a combination of sulfur content and heat content sufficient to comply with the allowable sulfur dioxide emission

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

limitation of 0.50 lb/mmBtu of actual heat input and the sulfur content limitation for No. 2 fuel oil of less than or equal to 0.5 weight per cent sulfur.

3. The maximum annual No. 2 fuel oil usage rate for this emissions unit shall not exceed 700,000 gallons per year.

III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)]. A shipment may be comprised of multiple tank truck loads from the same supplier's batch, and the quality of the oil for those loads may be represented by a single batch analysis from the supplier.

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lb/mmBtu). [The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F)].

- c. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240 and D4294), or equivalent methods as approved by the Director.

2. The owner or operator of each affected facility shall record and maintain records of the amounts

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP
MGP00101081104

Number:

of each fuel combusted during each day.

3. The permittee shall maintain monthly records of the following information:
 - a. The total volume of natural gas (mmft³) burned in this emissions unit.
 - b. The total number of gallons of No. 2 fuel oil used in this boiler for each month.
 - c. The total summation of the number of gallons of No. 2 fuel oil used each year.

IV. Reporting Requirements

1. Pursuant to the NSPS, the permittee is required to report the following information at the appropriate times (if the information has not already been reported):
 - a. construction date (no later than 30 days after such date);
 - b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
 - c. actual start-up date (within 15 days after such date); and,
 - d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to the appropriate local air agency or District Office and to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P.O. Box 163669
Columbus, Ohio 43216-3669

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

2. The permittee shall notify the Director (the appropriate local air agency or District Office) in writing of any fuel burned in this emissions unit other than natural gas or No. 2 fuel oil.
3. The permittee shall notify the Director (the appropriate local air agency or District Office) in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation and/or sulfur content limitation based upon the record keeping requirements from term III.1. above.
4. The notifications identified in terms IV.2 and IV.3 shall include a copy of such record and shall be sent to the Director (the appropriate local air agency or District Office) within 45 days after the deviation occurs.
5. The permittee shall submit annual reports that specify the total SO₂ emissions from this emissions unit during the previous calendar year. The reports shall be submitted by January 31 of each year.
6. The permittee shall submit deviation (excursion) reports that identify all exceedances of the annual No. 2 fuel oil usage limitation. These reports are due by the date described in Part 1 - General Terms and Conditions of this permit under Section A.

V. Testing Requirements

1. Compliance with the emission limitations in Section A.I.1. of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emission Limitation(s):
10% opacity, as a six-minute average, except for one 6-minute period per hour of not more than 27% opacity.

Applicable Compliance Method(s):
Compliance shall be determined through visible emission observations performed in accordance with U.S. EPA Reference Method 9 in 40 CFR, Part 60, Appendix A, .
 - b. Emission Limitation(s):
0.14 lb/mmBtu, 9.88 TPY NO_x emissions

Applicable Compliance Method:
The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

20 lbs NO_x/10³ gal emission factor into lb NO_x/mmBtu by dividing by 140 mmBtu/10³ gal. Compliance with the annual emission limitation may be demonstrated by multiplying the lb NO_x/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 7.

- c. Emission Limitation(s):
0.082 lb/mmBtu, 6.46 TPY CO emissions

Applicable Compliance Method:

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-1 (7/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 84 lbs CO/10⁶ scf emission factor into lb CO/mmBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lb CO/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 10.

- d. Emission Limitation(s):
0.011 lb/mmBtu, 0.85 TPY OC emissions

Applicable Compliance Method:

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.4, Table 1.4-2 (7/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 11 lbs TOC/10⁶ scf emission factor into lb TOC/mmBtu by dividing by 1,020 Btu/scf. Compliance with the annual emission limitation may be demonstrated by multiplying the lb TOC/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 25.

- e. Emission Limitation(s):

FINAL GENERAL PERMIT TO INSTALL 06-07680

Holzer Medical Center

Issued: 11/30/2004

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104

0.50 lb/mmBtu, 24.87 TPY SO₂ emissions

Applicable Compliance Method:

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation shall be based upon the record keeping in term III.1. Compliance with the annual emission limitation shall be determined by multiplying the annual average lb SO₂/mmBtu value by the annual average heat content and the total gallons on No. 2 fuel oil burned, and then dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 4, and 6.

- f. Emission Limitation(s):
0.014 lb/mmBtu, 0.92 TPY PE

Applicable Compliance Method:

The emission limitations were based upon the emission factor from AP-42, "Compilation of Air Pollutant Emission Factors", 5th Edition, Section 1.3, Table 1.3-1 (9/98). Compliance with the lb/mmBtu emission limitation may be determined by converting the 2 lbs PE/10³ gal emission factor into lbs PE/mmBtu by dividing by 140 mmBtu/10³ gal. Compliance with the annual emission limitation may be demonstrated by multiplying the lb PE/mmBtu value by the maximum rated heat input capacity of the emissions unit (in mmBtu/hr), then multiplying by 8760 hrs/yr and dividing by 2000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/mmBtu emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1- 5.

- g. Sulfur Content Limitation(s):
≤ 0.5 weight percent sulfur

Applicable Compliance Method:

Compliance shall be demonstrated by the record keeping requirement described in paragraph III.1.

VI. Miscellaneous Requirements

None

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP **Number:**
MGP00101081104

B. State Only Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
10 - 17.9 mmBtu/hr Natural Gas/No. 2 Fuel Oil Boiler	None	None

2. Additional Terms and Conditions

None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Source Description: 10-17.9 mmBtu/hr maximum heat input natural gas and No. 2 oil fired that is constructed, modified or reconstructed after June 9, 1989

MGP

Number:

MGP00101081104