

Facility ID: 0448020006 Issuance type: Title V Draft Permit

This version of facility specific terms and conditions was converted from a database format to an HTML file during an upgrade of the Ohio EPA, Division of Air Pollution Control's permitting software. Every attempt has been made to convert the terms and conditions to look and substantively conform to the permit issued or being drafted in STARS. However, the format of the terms may vary slightly from the original. In addition, although it is not expected, there is a slight possibility that a term and condition may have been inadvertently "left out" of this reproduction during the conversion process. Therefore, if this version is to be used as a starting point in drafting a new version of a permit, it is imperative that the entire set of terms and conditions be reviewed to ensure they substantively mimic the issued permit. The official version of any permit issued final by Ohio EPA is kept in the Agency's Legal section. The Legal section may be contacted at (614) 644-3037.

In addition to the terms and conditions, hyperlinks have been inserted into the document so you may more readily access the section of the document you wish to review.

Finally, the term language under "Part III" and before "I. Applicable Emissions Limitations..." has been added to aid in document conversion, and was not part of the original issued permit.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part II - Specific Facility Terms and Conditions

a State and Federally Enforceable Section

1. Emissions units B001, B002, B003, and B004 are not currently subject to the requirements specified in 40 CFR Part 60, Subparts D and Da, because construction did not commence and modifications were not made after the effective dates of these Subparts.
Emissions units B001, B002, B003, and B004 are not currently subject to the requirements specified in 40 CFR Part 60, Subparts D and Da, because construction did not commence and modifications were not made after the effective dates of these Subparts.
Emissions units B001, B002, B003, and B004 are not currently subject to the requirements specified in 40 CFR Part 60, Subparts D and Da, because construction did not commence and modifications were not made after the effective dates of these Subparts.
Emissions units B001, B002, B003, and B004 are not currently subject to the requirements specified in 40 CFR Part 60, Subparts D and Da, because construction did not commence and modifications were not made after the effective dates of these Subparts.
2. This facility is subject to the applicable requirements specified in OAC Chapter 3745-25. In accordance with Ohio EPA Engineering Guide #64, the emission control action programs, as specified in OAC rule 3745-25-03, shall be developed and submitted within 60 days after receiving notification from the Ohio EPA.
This facility is subject to the applicable requirements specified in OAC Chapter 3745-25. In accordance with Ohio EPA Engineering Guide #64, the emission control action programs, as specified in OAC rule 3745-25-03, shall be developed and submitted within 60 days after receiving notification from the Ohio EPA.
This facility is subject to the applicable requirements specified in OAC Chapter 3745-25. In accordance with Ohio EPA Engineering Guide #64, the emission control action programs, as specified in OAC rule 3745-25-03, shall be developed and submitted within 60 days after receiving notification from the Ohio EPA.
This facility is subject to the applicable requirements specified in OAC Chapter 3745-25. In accordance with Ohio EPA Engineering Guide #64, the emission control action programs, as specified in OAC rule 3745-25-03, shall be developed and submitted within 60 days after receiving notification from the Ohio EPA.
3. All asbestos renovation and demolition activities conducted at this facility shall be performed in accordance with the applicable requirements specified in 40 CFR Part 61 and OAC Chapter 3745-20.
All asbestos renovation and demolition activities conducted at this facility shall be performed in accordance with the applicable requirements specified in 40 CFR Part 61 and OAC Chapter 3745-20.
All asbestos renovation and demolition activities conducted at this facility shall be performed in accordance with the applicable requirements specified in 40 CFR Part 61 and OAC Chapter 3745-20.
All asbestos renovation and demolition activities conducted at this facility shall be performed in accordance with the applicable requirements specified in 40 CFR Part 61 and OAC Chapter 3745-20.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

b State Only Enforceable Section

1. The following insignificant emissions units are located at this facility:
 - F001 - roadways and parking areas;
 - T001 - 50,000-gallon above-ground peaker oil storage tank (Tank #1);
 - T002 - 12,000-gallon above-ground sulfuric acid storage tank (Tank #2);
 - Z001 - 330 HP (2.4 mmBtu/hr) internal combustion diesel engine (Diesel Engine #1);
 - Z002 - 300 HP (2.18 mmBtu/hr) internal combustion diesel engine (Diesel Engine #2);
 - Z003 - 85 kW (0.290 mmBtu/hr) propane generator (Propane Generator #1);
 - Z004 - 75 kW (0.256 mmBtu/hr) propane generator (Propane Generator #2);
 - Z005 - 30kW (0.102 mmBtu/hr) emergency diesel generator (Diesel Generator #3);
 - Z006 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #3);
 - Z007 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #4);
 - Z008 - 3,475-gallon above-ground No. 1 fuel oil bulldozer tank (Tank #5);
 - Z009 - 46,637-gallon above-ground combustion turbine diesel oil tank (Tank #6); and
 - Z010 - 1,000-gallon above-ground No. 2 fuel oil tank (Tank #7).

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a Permit to Install for the

emissions unit.

The following insignificant emissions units are located at this facility:

F001 - roadways and parking areas;
T001 - 50,000-gallon above-ground peaker oil storage tank (Tank #1);
T002 - 12,000-gallon above-ground sulfuric acid storage tank (Tank #2);
Z001 - 330 HP (2.4 mmBtu/hr) internal combustion diesel engine (Diesel Engine #1);
Z002 - 300 HP (2.18 mmBtu/hr) internal combustion diesel engine (Diesel Engine #2);
Z003 - 85 kW (0.290 mmBtu/hr) propane generator (Propane Generator #1);
Z004 - 75 kW (0.256 mmBtu/hr) propane generator (Propane Generator #2);
Z005 - 30kW (0.102 mmBtu/hr) emergency diesel generator (Diesel Generator #3);
Z006 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #3);
Z007 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #4);
Z008 - 3,475-gallon above-ground No. 1 fuel oil bulldozer tank (Tank #5);
Z009 - 46,637-gallon above-ground combustion turbine diesel oil tank (Tank #6); and
Z010 - 1,000-gallon above-ground No. 2 fuel oil tank (Tank #7).

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a Permit to Install for the emissions unit.

The following insignificant emissions units are located at this facility:

F001 - roadways and parking areas;
T001 - 50,000-gallon above-ground peaker oil storage tank (Tank #1);
T002 - 12,000-gallon above-ground sulfuric acid storage tank (Tank #2);
Z001 - 330 HP (2.4 mmBtu/hr) internal combustion diesel engine (Diesel Engine #1);
Z002 - 300 HP (2.18 mmBtu/hr) internal combustion diesel engine (Diesel Engine #2);
Z003 - 85 kW (0.290 mmBtu/hr) propane generator (Propane Generator #1);
Z004 - 75 kW (0.256 mmBtu/hr) propane generator (Propane Generator #2);
Z005 - 30kW (0.102 mmBtu/hr) emergency diesel generator (Diesel Generator #3);
Z006 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #3);
Z007 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #4);
Z008 - 3,475-gallon above-ground No. 1 fuel oil bulldozer tank (Tank #5);
Z009 - 46,637-gallon above-ground combustion turbine diesel oil tank (Tank #6); and
Z010 - 1,000-gallon above-ground No. 2 fuel oil tank (Tank #7).

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a Permit to Install for the emissions unit.

The following insignificant emissions units are located at this facility:

F001 - roadways and parking areas;
T001 - 50,000-gallon above-ground peaker oil storage tank (Tank #1);
T002 - 12,000-gallon above-ground sulfuric acid storage tank (Tank #2);
Z001 - 330 HP (2.4 mmBtu/hr) internal combustion diesel engine (Diesel Engine #1);
Z002 - 300 HP (2.18 mmBtu/hr) internal combustion diesel engine (Diesel Engine #2);
Z003 - 85 kW (0.290 mmBtu/hr) propane generator (Propane Generator #1);
Z004 - 75 kW (0.256 mmBtu/hr) propane generator (Propane Generator #2);
Z005 - 30kW (0.102 mmBtu/hr) emergency diesel generator (Diesel Generator #3);
Z006 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #3);
Z007 - 15,228-gallon above-ground No. 2 fuel oil lighter tank (Tank #4);
Z008 - 3,475-gallon above-ground No. 1 fuel oil bulldozer tank (Tank #5);
Z009 - 46,637-gallon above-ground combustion turbine diesel oil tank (Tank #6); and
Z010 - 1,000-gallon above-ground No. 2 fuel oil tank (Tank #7).

Each insignificant emissions unit at this facility must comply with all applicable State and federal regulations, as well as any emission limitations and/or control requirements contained within a Permit to Install for the emissions unit.

- [Go to Part III for Emissions Unit B001](#)
- [Go to Part III for Emissions Unit B002](#)
- [Go to Part III for Emissions Unit B003](#)
- [Go to Part III for Emissions Unit B004](#)
- [Go to Part III for Emissions Unit B005](#)
- [Go to Part III for Emissions Unit F003](#)
- [Go to Part III for Emissions Unit F004](#)
- [Go to Part III for Emissions Unit F005](#)
- [Go to Part III for Emissions Unit Z011](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B001 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1218 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-07(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-54(V)(1)	Sulfur dioxide emissions shall not exceed 1.94 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks,

and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, the results of the analyses for ash content, sulfur content, and heat content, and the average sulfur dioxide emission rate (lbs/mmBtu). The analyses for ash content, sulfur content and heat content shall be performed in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isooperibol Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Toledo Division of Environmental Services.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

*****THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.*****

IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment

malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1 and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.1. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Toledo Division of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Toledo Division of Environmental Services' refusal to accept the results of the emission test(s).

Personnel from the Toledo Division of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Toledo Division of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Toledo Division of Environmental Services.

2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A)(1) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of sections A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B001 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1218 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		
2. Additional Terms and Conditions		
1. None		

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B002 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1240 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-07(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-54(V)(1)	Sulfur dioxide emissions shall not exceed 1.94 lbs/mmBtu actual heat input.

2. Additional Terms and Conditions

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, the results of the analyses for

ash content, sulfur content, and heat content, and the average sulfur dioxide emission rate (lbs/mmBtu). The analyses for ash content, sulfur content and heat content shall be performed in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isoperibol Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Toledo Division of Environmental Services.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

*****THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.*****

IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1 and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.1. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

*****THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.*****

V. Testing Requirements

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Toledo Division of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Toledo Division of Environmental Services' refusal to accept the results of the emission test(s).

Personnel from the Toledo Division of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Toledo Division of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Toledo Division of Environmental Services.

2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A)(1) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of sections A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B002 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
---	--------------------------------------	--

Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1240 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		
---	--	--

2. **Additional Terms and Conditions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B003 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1217 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

OAC rule 3745-17-07(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
OAC rule 3745-18-54(V)(1)	Sulfur dioxide emissions shall not exceed 1.94 lbs/mmBtu actual heat input.

2. **Additional Terms and Conditions**

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. **Operational Restrictions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. **Monitoring and/or Record Keeping Requirements**

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, the results of the analyses for ash content, sulfur content, and heat content, and the average sulfur dioxide emission rate (lbs/mmBtu). The analyses for ash content, sulfur content and heat content shall be performed in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isoperibol Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Toledo Division of Environmental Services.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1 and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.1. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

*****THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.*****

V. Testing Requirements

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Toledo Division of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Toledo Division of Environmental Services' refusal to accept the results of the emission test(s).

Personnel from the Toledo Division of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Toledo Division of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Toledo Division of Environmental Services.

2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A)(1) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of sections A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B003 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1217 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		

2. Additional Terms and Conditions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.
2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B004 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1862 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-07(C)(1)	Particulate emissions shall not exceed 0.10 lb/mmBtu actual heat input.
	OAC rule 3745-18-54(V)(1)	Sulfur dioxide emissions shall not exceed 1.94 lbs/mmBtu actual heat input.

2. **Additional Terms and Conditions**

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall operate and maintain equipment to continuously monitor and record the opacity of the visible particulate emissions from this emissions unit. Such continuous monitoring and recording equipment

shall comply with the requirements specified in 40 CFR Part 60.13.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain a certification letter from the Ohio EPA documenting that the continuous opacity monitoring system has been certified in accordance with the requirements of 40 CFR Part 60, Appendix B, Performance Specification 1. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous opacity monitoring system: percent opacity on a 6-minute block average basis, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall operate and maintain equipment to continuously monitor and record sulfur dioxide emissions from this emissions unit in units of the applicable standard(s). Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75.

Each continuous monitoring system consists of all the equipment used to acquire data and includes the sample extraction and transport hardware, sample conditioning hardware, analyzers, and data recording/processing hardware and software.

The permittee shall maintain documentation from the USEPA or the Ohio EPA that the continuous sulfur dioxide monitoring system has been certified in accordance with 40 CFR Part 75. The letter of certification shall be made available to the Director upon request.

The permittee shall maintain records of the following data obtained by the continuous sulfur dioxide monitoring system: the average daily and rolling, 30-day average emission rates of sulfur dioxide in lb/mmBtu actual heat input, results of daily zero/span calibration checks, and magnitude of manual calibration adjustments. In addition, the permittee shall maintain daily records of the total actual heat input values as determined through F-Factor and carbon dioxide/oxygen calculations as specified in 40 CFR Part 60, Appendix A, Method 19.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall maintain daily records of the total quantity of coal burned, the results of the analyses for ash content, sulfur content, and heat content, and the average sulfur dioxide emission rate (lbs/mmBtu). The analyses for ash content, sulfur content and heat content shall be performed in accordance with the following:

The permittee shall collect daily composite samples of the coal burned in this emissions unit. A sufficient number of individual samples shall be collected so that each composite sample is representative of the average quality of coal burned in this emissions unit during each calendar day. The coal sampling shall be performed in accordance with the most recent version of ASTM method D2234, Collection of a Gross Sample of Coal.

Each daily composite sample of coal shall be analyzed for ash content (percent), sulfur content (percent), and heat content (Btu/pound of coal). The analytical methods for ash content, sulfur content and heat content shall be the most recent version of: ASTM method D3174, Ash in the Analysis of Coal and Coke; ASTM method D3177, Total Sulfur in the Analysis Sample of Coal and Coke or ASTM method D4239, Sulfur in the Analysis Sample of Coal and Coke Using High Temperature Tube Furnace Combustion Methods; and ASTM method D2015, Gross Calorific Value of Solid Fuel by the Adiabatic Bomb Calorimeter, ASTM method D3286, Gross Calorific Value of Coal and Coke by the Isothermal Bomb Calorimeter, or ASTM method D1989, Standard Test Method for Gross Calorific Value of Coal and Coke by Microprocessor Controlled Isoperibol Calorimeters, respectively. Alternative, equivalent methods may be used upon written approval from the Toledo Division of Environmental Services.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

*****THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.*****

IV. Reporting Requirements

1. The permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting all instances of opacity values in excess of the limitations specified in OAC rule 3745-17-07, detailing the date, commencement and completion times, duration, magnitude (percent opacity), reason (if known), and corrective action(s) taken (if any) of each 6-minute block average above the applicable opacity limitation(s).

The reports shall also identify any excursions of the start-up and shutdown provisions specified in OAC rule 3745-17-07(A)(3) and document any continuous opacity monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason, and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

2. If the continuous sulfur dioxide monitoring system is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit reports (hardcopy or electronic format) within 30 days following the end of each calendar quarter to the Toledo Division of Environmental Services documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of sulfur dioxide values in excess of the applicable rolling, 30-day average sulfur dioxide emission rate (lb/mmBtu). These reports shall also contain average daily sulfur dioxide emission rates (lb/mmBtu) which are greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1.

The reports shall also document any continuous sulfur dioxide monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report.

3. If coal sampling and analysis is used to demonstrate compliance with the sulfur dioxide emission limitation, the permittee shall submit deviation (excursion) reports that document any average daily sulfur dioxide emission rate which was greater than 1.5 times the sulfur dioxide emission limitation specified in Section A.1 and any 30-day rolling, weighted average sulfur dioxide emission rate greater than the sulfur dioxide emission limitation specified in Section A.1. These reports shall be submitted in accordance with Section A.1.c.ii of the General Terms and Conditions.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. The permittee shall conduct, or have conducted, particulate emission testing for this emissions unit to demonstrate compliance with the allowable mass emission rate of 0.10 lb/mmBtu actual heat input in accordance with the following requirements:

The particulate emission testing shall be conducted twice during the term of this permit. Once between years 2 and 3, and once during the last year of the permit.

Compliance with the allowable mass emission rate for particulates shall be determined in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5 and the procedures in OAC rule 3745-17-03(B)(9).

The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Toledo Division of Environmental Services. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Toledo Division of Environmental Services' refusal to accept the results of the emission test(s).

Personnel from the Toledo Division of Environmental Services shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Toledo Division of Environmental Services within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Toledo Division of Environmental Services.

2. Compliance with the visible emission limitations in OAC rule 3745-17-07(A)(1) shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9 and the procedures in OAC rule 3745-17-03(B)(1).
3. Compliance with the sulfur dioxide emission limitation shall be based upon a rolling, 30-day average of the daily sulfur dioxide emission rates, in accordance with the USEPA's policy entitled "Enforcement Policy for Sulfur Dioxide Emission Limitations in Ohio" and dated February 11, 1980 (45 FR 9101). The daily and rolling 30-day sulfur dioxide emission rates shall be determined and reported in accordance with the applicable requirements of sections A.III.2, A.III.3, A.IV.2 and A.IV.3 of this permit. The permittee may be required to perform sulfur dioxide emission tests if warranted by the USEPA's enforcement policy. In such cases, the methods and procedures specified in 40 CFR Part 60.46 shall be employed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B004 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
Babcock & Wilcox pulverized coal-fired, dry bottom boiler, having a nominal capacity of 1862 mmBtu/hr, and controlled with an electrostatic precipitator (ESP).		
2. Additional Terms and Conditions		
<ol style="list-style-type: none"> 1. None 		

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. To obtain an exemption pursuant to OAC rule 3745-17-07(A)(3)(a)(i) or (A)(3)(b)(i), the permittee shall operate and maintain a temperature monitor that measures the temperature of the boiler exhaust gases entering the ESP (a) during all periods of start-up until the ESP is operational or until the inlet temperature of the ESP achieves the temperature level specified in OAC rule 3745-17-07(A)(3)(a)(i) and (b) during all periods of shutdown until the inlet temperature of the ESP drops below the temperature level specified in OAC rule 3745-17-07(A)(3)(b)(i). An electronic or hardcopy record of the temperatures during periods of start-up and shutdown shall be maintained.

The temperature monitor shall be installed, calibrated, operated, and maintained in accordance with manufacturer's recommendations, with any modifications deemed necessary by the permittee, and shall be capable of accurately measuring the temperature of the boiler exhaust gases in units of degrees Fahrenheit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. A logbook documenting activities relating to the continuous opacity monitoring system must be kept on site and available for inspection during regular office hours.

2. A logbook documenting activities relating to the continuous sulfur dioxide monitoring system must be kept on site and available for inspection during regular office hours.

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B005 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
General Electric oil-fired turbine with a nominal capacity of 283.5 mmBtu/hr.	OAC rule 3745-17-07(A)	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
	OAC rule 3745-17-11(B)(4)	Particulate emissions shall not exceed 0.040 lb/mmBtu actual heat input.
	OAC rule 3745-18-54(V)(2)	Sulfur dioxide emissions shall not exceed 0.4 lb/mmBtu actual heat input.

2. Additional Terms and Conditions

- (a) None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. The quality of the oil burned in this emissions unit shall meet a sulfur content that is sufficient to comply with the allowable sulfur dioxide emission limitation specified in Section A.I above.
2. The permittee shall burn only number two fuel oil in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. (The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).) Also, if necessary, the permittee shall maintain monthly records of the calculated sulfur dioxide emission rate based upon a volume-weighted average of the calculated sulfur dioxide emission rates for all of the daily samples during a calendar month.
The permittee shall maintain records of the oil burned in this emissions unit in accordance with either Alternative 1 or Alternative 2 described below.

a. Alternative 1:

For each shipment of oil received for burning in this emissions unit, the permittee shall collect or require the oil supplier to collect a representative grab sample of oil and maintain records of the total quantity of oil received, the permittee's or oil supplier's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu). (The sulfur dioxide emission rate shall be calculated in accordance with the formula specified in OAC rule 3745-18-04(F).) A shipment may be comprised of multiple tank truck loads from the same supplier's batch, and the quality of the oil for those loads may be represented by a single batch analysis from the supplier. Also, if necessary, the permittee shall maintain monthly records of the calculated sulfur dioxide emission rate based upon a volume-weighted average of the calculated sulfur dioxide emission rates for all shipments of oil during a calendar month.

b. Alternative 2:

The permittee shall collect a representative grab sample of oil that is burned in this emissions unit for each day when the emissions unit is in operation. If additional fuel oil is added to the tank serving this emissions

unit on a day when the emissions unit is in operation, the permittee shall collect a sufficient number of grab samples to develop a composite sample representative of the fuel oil burned in this emissions unit. A representative grab sample of oil does not need to be collected on days when this emissions unit is only operated for the purpose of "test-firing." The permittee shall maintain records of the total quantity of oil burned each day, except for the purpose of test-firing, the permittee's analyses for sulfur content and heat content, and the calculated sulfur dioxide emission rate (in lbs/mmBtu).

2. The permittee shall perform or require the supplier to perform the analyses for sulfur content and heat content in accordance with 40 CFR Part 60, Appendix A, Method 19, or the appropriate ASTM methods (such as, ASTM methods D240, D4294, D6010), or equivalent methods as approved by the Director.
3. For each day during which the permittee burns a fuel other than number two fuel oil, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall notify the Toledo Division of Environmental Services in writing of any record which shows a deviation of the allowable sulfur dioxide emission limitation based upon a volume-weighted average of the calculated sulfur dioxide emission rates from Section A.III above. The notification shall include a copy of such record and shall be sent to the Toledo Division of Environmental Services within 45 days after the deviation occurs.
2. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than number two fuel oil was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the emission limitation(s) in Section A.I.1 of these terms and conditions shall be determined in accordance with the following method(s):
 - a. Emission Limitation: Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method: Compliance shall be determined through visible emissions observations performed in accordance with Method 9 of 40 CFR Part 60, Appendix A, and the procedures specified in OAC rule 3745-17-03(B)(1).
 - b. Emission Limitation: Particulate emissions shall not exceed 0.040 lb/mmBtu actual heat input.

Applicable Compliance Method: Compliance shall be based upon an emission factor of 0.038 lb/mmBtu. This emission factor is specified in USEPA reference document AP-42, Fifth Edition, Compilation of Air Pollution Emission Factors, Section 3.1, Table 3.1-1 (10/96). If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in OAC rule 3745-17-03(B)(10).
 - c. Emission Limitation: Sulfur dioxide emissions shall not exceed 0.4 lb/mmBtu actual heat input.

Applicable Compliance Method: Except as provided below, compliance with the allowable sulfur dioxide emission limitation shall be demonstrated by documenting that the sulfur content of each shipment of oil received or each daily sample collected during a calendar month meets the limitation.

If the sulfur content of each shipment of oil received during a calendar month does not comply with the allowable emission limitation on an "as-received" basis or if the sulfur content of each daily sample collected during a calendar month does not comply with the allowable emission limitation on an "as-burned" basis, compliance with the allowable sulfur dioxide emission limitation shall be based upon a volume-weighted average of the calculated sulfur dioxide emission rates for all of the shipments or daily samples of oil during the calendar month.

If required, the permittee shall demonstrate compliance with this emission limitation through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: B005 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
2. Additional Terms and Conditions		
1. None		

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F003 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
load-in or load-out of coal storage piles (see Section A.I.2.a for identification of coal storage piles)	OAC rule 3745-17-07(B)(7)(b)	20% opacity, as a 3-minute average (see Section A.I.2.h)
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.b, A.I.2.c and A.I.2.g)
operation of vehicles on top of coal storage piles, excluding emissions from the combustion of fuels in such vehicles (i.e., pile working)	OAC rule 3745-17-07(B)(7)(c)	20% opacity, as a 3-minute average (see Section A.I.2.h)
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.d, A.I.2.f and A.I.2.g)
wind erosion from coal storage piles	OAC rule 3745-17-07(B)(7)(d)	no visible emissions except for 13 minutes during any 60-minute period (see Section A.I.2.h)
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.d, A.I.2.f and A.I.2.g)
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.e through A.I.2.g)

2. **Additional Terms and Conditions**

- a. The coal storage piles that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:
 - (a) all coal storage piles at the plant.
- b. The permittee shall employ reasonably available control measures on all coal load-in and load-out operations associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to employ precautionary operating practices (i.e., no coal load-in if wind speeds exceed 25 mph, minimize pile disturbance, etc.), use of a variable height stacker, and/or treat the coal load-in and load-out operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- c. The above-mentioned control measures shall be employed for each coal load-in and load-out operation of each storage pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measures shall continue during any such operation until further observation confirms that use of the measures is unnecessary.
- d. The permittee shall employ reasonably available control measures on all pile working operations associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to employ precautionary operating practices and/or treat the pile working operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- e. The permittee shall employ reasonably available control measures for wind erosion from pile surfaces associated with the coal storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to employ precautionary operating practices and/or treat the pile working operations with water and/or any other suitable dust suppression chemicals at sufficient treatment frequencies to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- f. The above-mentioned control measures shall be employed for each pile working operation and wind erosion from each pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Implementation of the control measures shall not be necessary for a coal storage pile that is covered with snow and/or ice or if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements.

- g. Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.
- h. The emission limitation and rule citation reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the limitation and rule citation was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the emission limitation and rule citation as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the limitation and rule citation as a revision to the Ohio SIP for particulate matter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

- 1. Except as otherwise provided in this section, the permittee shall perform inspections of each coal load-in operation at each coal storage pile in accordance with the following frequencies:
 - coal storage pile identification:
all coal storage piles at the plant
 - minimum coal load-in inspection frequency:
daily when in use
- 2. Except as otherwise provided in this section, the permittee shall perform inspections of each coal load-out operation at each coal storage pile in accordance with the following frequencies:
 - coal storage pile identification:
all coal storage piles at the plant
 - minimum coal load-out inspection frequency:
daily when in use
- 3. Except as otherwise provided in this section, the permittee shall perform inspections of each pile working operation associated with each coal storage pile in accordance with the following frequencies:
 - coal storage pile identification:
all coal storage piles at the plant
 - minimum coal pile working inspection frequency:
daily when in use
- 4. Except as otherwise provided in this section, the permittee shall perform inspections of the wind erosion from pile surfaces associated with each coal storage pile in accordance with the following frequencies:
 - coal storage pile identification:
all coal storage piles at the plant
 - minimum wind erosion inspection frequency:
daily
- 5. No inspection shall be necessary for wind erosion from the surface of a pile when the pile is covered with snow and/or ice and for any storage pile activity if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements. Any required inspection that is not performed due to any of the above identified events shall be performed as soon as such event(s) has (have) ended, except if the next required inspection is within one week.
- 6. The purpose of the inspections is to determine the need for implementing the control measures specified in this permit for coal load-in or load-out of a storage pile, pile working operations, and wind erosion from the surface of a coal storage pile. The inspections shall be performed during representative, normal storage pile operating conditions.
- 7. The permittee may, upon receipt of written approval from the Toledo Division of Environmental Services, modify the above-mentioned inspection frequencies if operating experience indicates that less frequent inspections would be sufficient to ensure compliance with the above-mentioned applicable requirements. Such modified inspection frequencies would not be considered a minor or significant modification that would be subject to the Title V permit modification requirements in paragraphs (C)(1) and (C)(3) of OAC rule 3745-77-08.
- 8. The permittee shall maintain records of the following information:
 - a. the date and reason any required inspection was not performed, including those inspections that were not performed due to snow and/or ice cover or precipitation;
 - b. the date of each inspection where it was determined by the permittee that it was necessary to implement

the control measures;

- c. the dates the control measures were implemented; and
- d. on a calendar quarter basis, the total number of days the control measures were implemented and the total number of days where snow and/or ice cover or precipitation were sufficient to not require the control measures.

The information required in 8.d. shall be kept separately for (i) the coal load-in operations, (ii) the coal load-out operations, (iii) the coal pile working operations, and (iv) the coal pile surfaces (wind erosion), and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit deviation reports that identify any of the following occurrences:
 - a. each day during which an inspection was not performed by the required frequency, excluding an inspection which was not performed due to an exemption for snow and/or ice cover or precipitation; and
 - b. each instance when a control measure, that was to be implemented as a result of an inspection, was not implemented.
2. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the visible emission limitations identified above shall be determined in accordance with the following methods:
 - a. Emission Limitation: 20% opacity for coal load-in or load-out of coal storage piles, as a 3-minute average

Applicable Compliance Method: Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03*
 - b. Emission Limitation: 20% opacity for pile working operations on top of coal storage piles, as a 3-minute average

Applicable Compliance Method: Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a), (B)(3)(b) and (B)(3)(e) of OAC rule 3745-17-03*
 - c. Emission Limitation: no visible emissions except for 13 minutes during any 60-minute period for wind erosion from the coal storage pile surfaces

Applicable Compliance Method: Test Method 22 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(4)(a) through (B)(4)(c) of OAC rule 3745-17-03*

*The procedures related to Test Methods 9 and 22 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing these procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F003 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

- 1. None.

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
load-in or load-out of coal storage piles (see Section A.I.2.a for identification of coal storage piles)	none	none
operation of vehicles on top of coal storage piles, excluding emissions from the combustion of fuels in such vehicles (i.e., pile working)	none	none
wind erosion from coal storage piles	none	none

2. Additional Terms and Conditions

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

- 1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

- 1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F004 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

- 1. None.

I. Applicable Emissions Limitations and/or Control Requirements

- 1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
coal unloading from barges, railcars, or trucks (see Section A.I.2.a); coal conveyors (see Section A.I.2.b); coal handling (see Section A.I.2.c); and coal transfer points (see Section A.I.2.d)	OAC rule 3745-17-07(B)(7)(b)	20% opacity, as a 3-minute average
	OAC rule 3745-17-08(B)(6)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.e through A.I.2.g)

2. Additional Terms and Conditions

- a. The coal unloading stations for barges, railcars, or trucks that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:
 - (a) the railcar rotary dumping station
- b. The coal conveyors that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:
 - all coal conveyors at the plant (23)
- c. The coal handling operations that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:
 - rake reclaimer to conveyors
- d. The coal transfer points that are covered by this permit and subject to the requirements of OAC rules 3745-17-07 and 3745-17-08 are listed below:
 - all coal transfer points at the plant
- e. The permittee shall employ reasonably available control measures on all coal unloading stations for railcars, coal conveyors, coal handling operations, and coal transfer points for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to treat the coal unloading stations and coal handling operations with water at sufficient treatment frequencies to ensure compliance. The permittee has committed to use adequate enclosures on coal conveyors and coal transfer points to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- f. For each coal unloading station, coal conveyor, coal handling operation, and coal transfer point that is not adequately enclosed, such unloading station, conveyor, handling operation or transfer point shall be treated with water and/or suitable dust suppression chemicals if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measures are necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measures shall continue during operation of any coal unloading station, coal conveyor, coal handling, or coal transfer point until further observation confirms that use of the control measures is unnecessary.
- g. Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. Except as otherwise provided in this section and for coal unloading stations that are not adequately enclosed, the permittee shall perform inspections of such coal unloading stations with the following frequencies:

coal unloading station identification:
the railcar rotary dumping station

minimum inspection frequency:
daily when in operation
2. Except as otherwise provided in this section and for coal conveyors that are not adequately enclosed, the permittee shall perform inspections of such coal conveyors with the following frequencies:

coal conveyor identification:
all coal conveyors at the plant (23)

minimum inspection frequency:
daily when in operation
3. Except as otherwise provided in this section and for coal handling operations that are not adequately enclosed, the permittee shall perform inspections of such coal handling operations with the following frequencies:

coal handling operation identification:
rake reclaimer to conveyors

minimum inspection frequency:
daily when in operation
4. Except as otherwise provided in this section and for coal transfer points that are not adequately enclosed, the permittee shall perform inspections of such coal transfer points with the following frequencies:

coal transfer point identification:
all coal transfer points at the plant

minimum inspection frequency:
daily when in operation
5. The above-mentioned inspections shall be performed during representative, normal operating conditions.
6. The permittee may, upon receipt of written approval from the Toledo Division of Environmental Services, modify the above-mentioned inspection frequencies if operating experience indicates that less frequent inspections would be sufficient to ensure compliance with the above-mentioned applicable requirements. Such modified inspection frequencies would not be considered a minor or significant modification that would be subject to the Title V permit modification requirements in paragraphs (C)(1) and (C)(3) of OAC rule 3745-77-08.
7. The permittee shall maintain records of the following information:
 - a. the date and reason any required inspection was not performed;
 - b. the date of each inspection where it was determined by the permittee that it was necessary to implement the control measures;
 - c. the dates the control measures were implemented; and
 - d. on a calendar quarter basis, the total number of days the control measures were implemented.The information in 7.d. shall be kept separately for (i) the coal unloading stations, (ii) the coal conveyors, (iii) the coal handling operations, and (iv) the coal transfer points, and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit deviation reports that identify any of the following occurrences:
 - a. each day during which an inspection was not performed by the required frequency; and
 - b. each instance when a control measure, that was to be performed as a result of an inspection, was not implemented.
2. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. **Testing Requirements**

1. Compliance with the emission limitations for coal unloading, conveyors, handling operations, and transfer points identified above shall be determined in accordance with Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03.*

*The procedures related to Test Method 9 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing these procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F004 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
coal unloading from barges, railcars, or trucks (see Section A.I.2.a); coal conveyors (see Section A.I.2.b); coal handling (see Section A.I.2.c); and coal transfer points (see Section A.I.2.d)	none	none

2. **Additional Terms and Conditions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. **Operational Restrictions**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. **Monitoring and/or Record Keeping Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. **Reporting Requirements**

1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. **Testing Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F005 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
fly ash and/or bottom ash pneumatic conveying to silos, and fly ash silo and/or bottom ash load-out into trucks	OAC rule 3745-17-07(B)(7)(b)	20% opacity, as a 3-minute average
	OAC rule 3745-17-08(B)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.a through A.I.2.d)
fly ash and/or bottom ash silo vents (each with baghouse)	OAC rule 3745-17-07(A)	20% opacity, as a 6-minute average, except as provided by rule
	OAC rule 3745-17-08(B)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.a through A.I.2.d)

2. **Additional Terms and Conditions**

- a. The permittee shall employ reasonable available control measures on all fly ash and/or bottom ash pneumatic conveying equipment for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to maintaining total enclosure of such equipment to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- b. The permittee shall employ reasonable available control measures for operations employing the dumping of fly ash and/or bottom ash from storage silos to trucks for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to employ a total enclosure and/or apply sufficient water to the fly ash and/or bottom ash during any load-out from storage silos to trucks to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- c. The permittee shall employ reasonable available control measures for operations employing pneumatic loading of fly ash and/or bottom ash from storage silos to trucks for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to use coaxial spouts or other mechanisms that tightly

fit to the tank hatch of the truck to prevent leaks and vent the displaced air from the tank to the baghouse serving the vent of the storage silo to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.

- d. Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform daily checks, while the equipment is in operation, for any visible emissions of fugitive dust escaping from any fly ash and/or bottom ash pneumatic conveying systems, for any unusual visible emissions from baghouses serving fly ash storage silos, and of the effectiveness of the water addition to the fly ash and/or bottom ash during loadout from storage silos into dump trucks to ensure compliance with the above-mentioned applicable requirements during silo loadout. A record of the necessary and completed corrective actions resulting from the daily checks shall be maintained by the permittee.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit reports in accordance with the reporting requirements of the General Terms and Conditions which identify each day that the observations required under the monitoring section of this permit were not performed and each day that any corrective measures required to be taken pursuant to the monitoring section of this permit were not performed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the visible emission limitations identified above shall be determined in accordance with the following methods:
- a. Emission Limitation: 20% opacity for fly ash and/or bottom ash pneumatic conveying to silos and fly ash and/or bottom ash silo load-out into trucks, as a 3-minute average
- Applicable Compliance Method: Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03*
- *The procedures related to Test Method 9 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.
- b. Emission Limitation: 20% opacity for fly ash silo vents, as a 6-minute average, except as provided by rule
- Applicable Compliance Method: Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: F005 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
fly ash and/or bottom ash pneumatic conveying to silos, and fly ash and/or bottom ash silo load-out into trucks	none	none
fly ash and/or bottom ash silo vents (each with baghouse)	none	none

2. Additional Terms and Conditions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. Miscellaneous Requirements

1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

Part III - Terms and Conditions for Emissions Units

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: Z011 Issuance type: Title V Draft Permit

A. State and Federally Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

1. None.

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
truck unloading of fly ash and/or bottom ash at on-site landfill, and wind erosion at fly ash and/or bottom ash on-site landfill	OAC rule 3745-17-07(B)(7)(b)	20% opacity, as a 3-minute average
	OAC rule 3745-17-08(B)	reasonably available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.a through A.I.2.c)

2. Additional Terms and Conditions

- a. The permittee shall employ reasonably available control measures for the unloading of fly ash and/or bottom ash at the on-site landfill for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to apply sufficient water at the dry ash storage silos during the dumping of fly ash and/or bottom ash into dump trucks to keep the materials moist during unloading from trucks at the on-site landfill to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- b. The permittee shall employ reasonably available control measures for wind erosion of the surface of the on-site landfill for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to apply sufficient water at the dry ash storage silos during the dumping of fly ash and/or bottom ash into trucks to keep the materials moist at the landfill, cover with earth the ash deposited, and plant vegetation on the surface of any filled disposal areas to ensure compliance.
- c. Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-17-08.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. Operational Restrictions

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. Monitoring and/or Record Keeping Requirements

1. The permittee shall perform daily checks, while the equipment is in operation, of the effectiveness of the water addition to the fly ash and/or bottom ash during loadout from storage silos into dump trucks to ensure compliance with the above-mentioned applicable requirements during dumping at the on-site landfill and wind erosion of the surface of the on-site landfill. A record of the necessary and completed corrective actions resulting from the daily checks shall be maintained by the permittee.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. Reporting Requirements

1. The permittee shall submit reports in accordance with the reporting requirements of the General Terms and Conditions of this permit which identify each day that the observations required under the monitoring section of this permit were not performed and each day that any corrective measures required to be taken pursuant to the monitoring section of this permit were not performed.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. Testing Requirements

1. Compliance with the visible emission limitation identified above shall be determined in accordance with the following method:

- a. Emission Limitation: 20% opacity for truck unloading of fly ash and/or bottom ash at on-site landfill and wind erosion at fly ash and/or bottom ash on-site landfill, as a 3-minute average

Applicable Compliance Method: Test Method 9 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 1996, and the modifications listed in paragraphs (B)(3)(a) and (B)(3)(b) of OAC rule 3745-17-03*

*The procedures related to Test Method 9 reflect the settlement agreement reached between Ohio EPA and the Ohio Electric Utilities concerning the Utilities' appeal to the Ohio Environmental Review Appeals Commission of the 1991 revisions and additions to OAC Chapter 3745-17. The revised rule containing the procedures was adopted by the Director of Ohio EPA in December, 1997. The USEPA and the Ohio Electric Utilities have agreed to consider the procedures as federally enforceable during the time from the effective date of this permit to the effective date of USEPA approval of the procedures as a revision to the Ohio SIP for particulate matter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

- 1. None

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION

Facility ID: 0448020006 Issuance type: Title V Draft Permit

[Go to the top of this document](#)

Facility ID: 0448020006 Emissions Unit ID: Z011 Issuance type: Title V Draft Permit

B. State Enforceable Section

The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

- 1. None.

I. **Applicable Emissions Limitations and/or Control Requirements**

- 1. The specific operation(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be employed. Additional applicable emissions limitations and/or control measures (if any) may be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
truck unloading of fly ash and/or bottom ash at on-site landfill, and wind erosion at fly ash and/or bottom ash on-site landfill	none	none

- 2. **Additional Terms and Conditions**

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

II. **Operational Restrictions**

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

III. **Monitoring and/or Record Keeping Requirements**

- 1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

IV. **Reporting Requirements**

- 1. If there are no deviations during a calendar quarter that must be reported pursuant to the reporting requirements of this permit, the permittee shall submit a quarterly report, in accordance with paragraph B.8 of the General Terms and Conditions of this permit, which states that no deviations occurred during that quarter.

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

V. **Testing Requirements**

1. None

[Go to the top of this document](#)

[Go to the top of Part III for this Emissions Unit](#)

THIS IS NOT AN OFFICIAL VERSION OF THE PERMIT. SEE PAGE 1 FOR ADDITIONAL INFORMATION.

VI. **Miscellaneous Requirements**

1. None