State of Ohio Environmental Protection Agency

Street Address: Lazarus Gov. Center **TELE:** (614) 644-3020 **FAX:** (614) 644-2329

Mailing Address: Lazarus Gov. Center

RE: DRAFT PERMIT TO INSTALL **CERTIFIED MAIL**
PERRY COUNTY
Application No: 06-07232

DATE: 8/7/2003

Allied Corp Equipment AG3 A
Larry Shively
PO Box 266 8775 Blackbird Lane
Thornville, OH 43076

You are hereby notified that the Ohio Environmental Protection Agency has made a draft action recommending that the Director issue a Permit to Install for the air contaminant source(s) [emissions unit(s)] shown on the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the proposed installation. A public notice concerning the draft permit will appear in the Ohio EPA Weekly Review and the newspaper in the county where the facility will be located. Public comments will be accepted by the field office within 30 days of the date of publication in the newspaper. Any comments you have on the draft permit should be directed to the appropriate field office within the comment period. A copy of your comments should also be mailed to Robert Hodanbosi, Division of Air Pollution Control, Ohio EPA, P.O. Box 1049, Columbus, OH, 43266-0149.

A Permit to Install may be issued in proposed of final form based on the draft action, any written public comments received within 30 days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting. Upon issuance of a final Permit to Install a fee of **$200** will be due. Please do not submit any payment now.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469. If you have any questions about this draft permit, please contact the field office where you submitted your application, or Mike Ahern, Field Operations & Permit Section at (614) 644-3631.

Very truly yours,

Michael W. Ahern

Michael W. Ahern, Supervisor
Field Operations and Permit Section
Division of Air Pollution Control

cc: **USEPA** **SEDO** **WV**

STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

Permit To Install	**Issue Date: To be entered upon final issuance**
Terms and Conditions	**Effective Date: To be entered upon final issuance**

DRAFT PERMIT TO INSTALL 06-07232

Application Number:	06-07232
APS Premise Number:	0664960003
Permit Fee:	**To be entered upon final issuance**
Name of Facility:	Allied Corp Equipment AG3 A
Person to Contact:	Larry Shively
Address:	PO Box 266 8775 Blackbird Lane Thornville, OH 43076

Location of proposed air contaminant source(s) [emissions unit(s)]:
8775 Blackbird Lane
Thornville, **Ohio**

Description of proposed emissions unit(s):
Portable diesel fired generator.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

_____

Director

Part I - GENERAL TERMS AND CONDITIONS

A. Permit to Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

a. Reports of any required monitoring and/or record keeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.

b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and record keeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any

information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Termination of Permit to Install

This Permit to Install shall terminate within eighteen months of the effective date of the Permit to Install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

9. Construction of New Sources(s)

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may

lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional

facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

10. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

11. Applicability

This Permit To Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate Permit To Install for the installation or modification of any other emissions unit(s) are required for any emissions unit for which a Permit To Install is required.

12. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

13. Source Operation and Operating Permit Requirements After Completion of Construction

a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V

permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

14. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

15. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit to Install fees within 30 days after the issuance of this Permit to Install.

B. Permit to Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

Pollutant	Tons Per Year
SO_2	8.3
NO_x	48.6
VOC	1.5
CO	11.2
PE	0.8

Emissions Unit ID: **P001**

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment	Applicable Rules/Requirements
P001 - Portable 1100 HP Diesel Generator, Equipment No. AG3-A	OAC rule 3745-31-05(A)(3)
	OAC rule 3745-17-11(B)(5)(b)
	OAC rule 3745-17-07(A)(1)
	OAC rule 3745-18-06(B)
	OAC rule 3745-23-06(B)
	OAC rule 3745-35-07(B)

Applicable Emissions Limitations/Control Measures	
Emissions shall not exceed: 4.5 pounds per hour (lb/hr) of sulfur dioxide (SO_2); 26.4 lbs/hr of nitrogen oxides (NO_x); 0.8 lb/hr of volatile organic compounds (VOC); and 6.1 lbs/hr of carbon monoxide (CO). The requirements of this rule also include compliance with the requirements of OAC rules 3745-35-07(B), 3745-17-11(B)(5)(b) and 3745-17-07(A).	See Section A.2.a. below. See Section A.2.b. below.
Emissions shall not exceed, as a rolling 12-month summation: 8.3 tons SO_2 48.6 tons NO_x 1.5 tons VOC 11.2 tons CO 0.8 ton particulate emissions (PE) See Section B.2. below.	
Emissions shall not exceed 0.062 lb PE/million Btu of actual heat input.	
Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule	

2. Additional Terms and Conditions

2.a This emissions unit is exempt from the requirements of OAC rule 3745-18-06 pursuant to OAC rule 3745-18-06(B).

2.b The permittee has satisfied the "latest available control techniques and operating practices required pursuant to OAC rule 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3) in this permit to install.

B. Operational Restrictions

1. The permittee shall only burn low sulfur No. 2 or diesel fuel, containing less than 0.5% sulfur by weight, in this emissions unit.

2. The maximum number of operating hours for emissions unit P001 shall not exceed 3,675 hours based upon a rolling 12-month summation. To ensure enforceability during the first 12 calendar months of operation following the issuance of this permit, the permittee shall not exceed the operating hours specified in the following table:

Month(s)	Maximum Cumulative Operating Hours
1	744
1-2	1,488
1-3	2,232
1-4	2,976
1-5	3,675
1-6	3,675
1-7	3,675
1-8	3,675
1-9	3,675

1-10	3,675
1-11	3,675
1-12	3,675

After the first 12 calendar months of operation following the startup of emissions unit P001, compliance with the annual operating hours limitation shall be based upon a rolling 12-month summation of the operating hours.

C. Monitoring and/or Record keeping Requirements

1. The permittee shall maintain documentation on the sulfur content of all fuels received.

2. For each day during which the permittee burns a fuel other than low sulfur No. 2 or diesel fuel, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

3. The permittee shall maintain monthly records of the following information:

a. The hours of operation for P001 for each month.

b. During the first 12 calendar months of operation following the issuance of this permit, the cumulative hours of operation, calculated by adding the current month's operating hours to the operating hours for each calendar month since the issuance of this permit.

c. Beginning after the first 12 calendar months of operation following the issuance of this permit, the rolling 12-month summation of the hours of operation, calculated by adding the current month's operating hours to the operating hours for the preceding eleven calendar months.

D. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than low sulfur No. 2 or diesel fuel was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.

2. The permittee shall submit quarterly deviation (excursion) reports which identify the following:

a. For the first 12 calendar months of operation following the issuance of this permit, all exceedances of the maximum allowable cumulative hours of operation.

b. Any exceedance of the rolling 12-month hours of operation limitation.

c. Any exceedance of the sulfur content fuel restriction specified in Section B.1.

These deviation (excursion) reports shall be submitted in accordance with Section A.2. of the General Terms and Conditions of this permit.

E. Testing Requirements

1. Compliance with the emissions limitations in Section A.I.1 of these terms and conditions shall be determined in accordance with the following methods:

a. Emissions Limitation:
Emissions shall not exceed 4.5 lbs/hr SO_2.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the emission factor from AP-42, Table 3.4-1, 10/1996 (0.00809S lb/HP-hr) by the maximum allowable sulfur content (0.5%) and the maximum rated capacity of P001 (1100 HP).

Emissions testing, if required, shall be conducted using the following test method: 40 CFR Part 60, Appendix A, Method 8. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Southeast District Office.

b. Emissions Limitation:
Emissions shall not exceed 8.3 tons SO_2 as a rolling 12-month summation.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the hourly SO_2 emission rate by the total number of hours operated per twelve month rolling period, as recorded in Section C.2.c, and dividing by 2000 lbs/ton.

c. Emission Limitation**:**
Emissions shall not exceed 26.4 lbs/hr NO_x.

Applicable Compliance Method**:**
Compliance shall be demonstrated by multiplying the emission factor from AP-42, Table 3.4-1, 10/1996 (0.024 lb/HP-hr) by the maximum rated capacity of P001 (1100 HP).

Emissions testing, if required, shall be conducted using the following test method: 40 CFR Part 60, Appendix A, Method 7. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Southeast District Office.

d. Emissions Limitation:
Emissions shall not exceed 48.6 tons NO_x as a rolling 12-month summation.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the hourly NO_x emission rate by the total number of hours operated per twelve month rolling period, as recorded in Section C.2.c, and dividing by 2000 lbs/ton.

e. Emissions Limitation:
Emissions shall not exceed 0.8 lb/hr VOC.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the emission factor from AP-42, Table 3.4-1, 10/1996 (0.000705 lb/HP-hr) by the maximum rated capacity of P001 (1100 HP).

Emissions testing, if required, shall be conducted using the following test method: 40 CFR Part 60, Appendix A, Method 25A. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Southeast District Office.

f. Emissions Limitation:
Emissions shall not exceed 1.5 tons VOC as a rolling 12-month summation.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the hourly VOC emission rate by the total number of hours operated per twelve month rolling period, as recorded in Section C.2.c, and dividing by 2000 lbs/ton.

g. Emissions Limitation:
Emissions shall not exceed 6.1 lbs/hr CO.

Applicable Compliance Method:
Compliance with the lb/hr emission limitation shall be demonstrated by multiplying the emission factor from AP-42, Table 3.4-1, 10/1996 (0.0055 lb/HP-hr) by the maximum rated capacity of P001 (1100 HP).

Emissions testing, if required, shall be conducted using the following test method: 40 CFR Part 60, Appendix A, Method 10. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA Southeast District Office.

h. Emissions Limitation:
Emissions shall not exceed 11.2 tons CO as a rolling 12-month summation.

Applicable Compliance Method:
Compliance shall be demonstrated by multiplying the hourly CO emission rate by the total number of hours operated per twelve month rolling period, as recorded in Section C.2.c, and dividing by 2000 lbs/ton.

i. Emission Limitation:
Emissions shall not exceed 0.062 lb PE/million Btu of actual heat input.

Applicable Compliance Method:
Compliance shall be determined based on the emission factor of 0.062 lb/mmBtu specified in AP-42, Table 3.4-2, 10/1996.

If required, the permittee shall demonstrate compliance with this emission limitation in accordance with the methods and procedures specified in Methods 1-5 of 40 CFR Part 60, Appendix A.

j. Emission Limitation:
Emissions shall not exceed 0.8 ton PE as a rolling 12-month summation.

Applicable Compliance Method:
Compliance shall be determined by multiplying the PE emission limitation of 0.062 lb/mmBtu of actual heat input by the maximum heat input of P001 (6.22 mmBtu/hr) and by the total number of hours operated per twelve month rolling period, as recorded in Section C.2.c., and dividing by 2000 lbs/ton.

k. Emission Limitation:
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method:
If required, the permittee shall demonstrate compliance with this emission limitation in accordance with Method 9 of 40 CFR Part 60, Appendix A.

2. Compliance with the operational restrictions in Section B of these terms and conditions shall be determined in accordance with the following methods:

a. Operational Limitation:
Sulfur content of fuel restricted to less than 0.5%, by weight

Applicable Compliance Method:
Compliance shall be based on record keeping as specified in Section C.1. of this permit.

b. Operational Limitation:
Maximum of 3,675 hours of operation as a rolling 12-month summation

Applicable Compliance Method:
Compliance shall be based on record keeping as specified in Section C.3. of this permit.

F. Miscellaneous Requirements

1. Pursuant to Ohio Administrative Code (OAC) rule 3745-31-03(A)(1)(p)(i), the permittee of a portable or mobile emissions unit may relocate within the State of Ohio without first obtaining a PTI providing the following criteria are met:

a. The portable emissions unit is equipped with the best available control technology for such portable emissions unit;
b. The portable emissions unit is operating pursuant to a currently effective permit to install, permit to operate or registration;

c. The applicant has provided proper notice of intent to relocate the portable emissions unit to the Southeast District Office (SEDO) and the appropriate field office having jurisdiction over the new site within a minimum of thirty days prior to the scheduled relocation; and,

d. In the SEDO's and the appropriate field office's judgement, the proposed site is acceptable under the rule 3745-15-07 of the Administrative Code.

2. In the alternative, pursuant to OAC rule 3745-31-03(A)(1)(p)(ii), the permittee of a portable or mobile emissions unit may relocate within the State of Ohio without first obtaining a PTI providing the following criteria of OAC rule 3745-31-05(F) are met:

a. The portable emissions unit permittee possesses an Ohio EPA PTI, PTO or registration status;

b. The portable emissions unit is equipped with best available technology;

c. The portable emission unit owner has identified the proposed site to Ohio EPA;

d. Ohio EPA has determined that the portable emissions unit, at the proposed site, will have an acceptable environmental impact;

e. A public notice, consistent with Chapter 3745-47 of the Administrative Code, is published in the county where the proposed site is located;

f. The owner of the proposed site has provided the portable emissions unit owner with approval or equivalent declaration that it is acceptable to the site owner to move the portable emissions unit to the proposed site; and,

g. The portable emissions unit owner has provided the Ohio EPA with fifteen days written notice of the relocation.

Any site approvals issued by the Ohio EPA, pursuant to this section, shall be valid for no longer than three years and are subject to renewal.

3. In order for the SEDO and the appropriate field office having jurisdiction over the new site to determine compliance with all of the above criteria, the owner or operator of the portable or mobile emissions unit must file a "Notice of Intent to Relocate", within the specified time frame (30 or 15 days) prior to the relocation of the emissions unit with the SEDO (2195 Front Street, Logan, Ohio 43138) and the appropriate office having jurisdiction over the new site. Upon receipt of the notice, the SEDO and/or the appropriate field office having jurisdiction over the new site, will evaluate the request in accordance with the above criteria.

4. The permittee should be advised that when portable emission units are located at a stationary source or at a source comprised of portable emission units, potential emissions from the portable emission units are included in the facility potential to emit calculations for Title V and PSD applicability.

The permittee shall include a potential to emit analysis of facility-wide emissions (including the portable sources) for the proposed relocation in the "Notice of Intent to Relocate".

5. Modeling to demonstrate compliance with the Ohio EPA's "Air Toxic Policy" was not necessary because the emissions unit's maximum annual emissions for each toxic compound will be less than 1.0 ton. OAC Chapter 3745-31 requires permittees to apply for and obtain a new or modified permit to install prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any pollutant that has a listed TLV to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new permit to install.

NEW SOURCE REVIEW FORM B

PTI Number: 06-07232 Facility ID: 0664960003

FACILITY NAME Allied Corp Equipment AG3 A

FACILITY DESCRIPTION Portable diesel fired generator. CITY/TWP Thornville

SIC CODE 1422 SCC CODE 20200401 EMISSIONS UNIT ID P001

EMISSIONS UNIT DESCRIPTION Portable 1100 HP Diesel Generator, Equipment No. AG3-A

DATE INSTALLED May 1990

EMISSIONS: (Click on bubble help for Air Quality Descriptions)

Pollutants	Air Quality Description	Actual Emissions Rate		PTI Allowable	
		Short Term Rate	Tons Per Year	Short Term Rate	Tons Per Year
Particulate Matter	attainment	0.4 lb/hr	0.71	0.062 lb/mmBtu	0.8
PM_{10}					
Sulfur Dioxide	attainment	4.5 lb/hr	8.2	4.5	8.3
Organic Compounds	attainment	0.8 lb/hr	1.4	0.8 lb/hr	1.5
Nitrogen Oxides	attainment	26.4 lb/hr	48.5	26.4 lb/hr	48.6
Carbon Monoxide	attainment	6.1 lb/hr	11.1	6.1 lb/hr	11.2
Lead					
Other: Air Toxics					

APPLICABLE FEDERAL RULES:

NSPS? NO NESHAP? NO PSD? NO OFFSET POLICY? NO

WHAT IS THE BAT DETERMINATION, AND WHAT IS THE BASIS FOR THE DETERMINATION?
Compliance with applicable OAC rules and allowable mass emission limitations; use of low sulfur No. 2 or diesel fuel; hours of operation restriction

IS THIS SOURCE SUBJECT TO THE AIR TOXICS POLICY? NO

OPTIONAL: WHAT IS THE CAPITAL COST OF CONTROL EQUIPMENT? $

TOXIC AIR CONTAMINANTS

Ohio EPA's air toxics policy applies to contaiminants for which the American Conference of Governmental Industrial Hygienists (ACGIH) has a listed threshold limit value.

AIR TOXICS MODELING PERFORMED*? _____ YES X NO

IDENTIFY THE AIR CONTAMINANTS: _____