



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
TUSCARAWAS COUNTY**

CERTIFIED MAIL

Street Address:

50 West Town Street, Suite 700

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 06-08384

Fac ID: 0679010013

DATE: 2/5/2008

Arizona Chemical
Richard Baker
875 Harger St.
Dover, OH 44622

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

SEDO



**Permit To Install
Terms and Conditions**

**Issue Date: 2/5/2008
Effective Date: 2/5/2008**

FINAL PERMIT TO INSTALL 06-08384

Application Number: 06-08384
Facility ID: 0679010013
Permit Fee: **\$1200**
Name of Facility: Arizona Chemical
Person to Contact: Richard Baker
Address: 875 Harger St.
Dover, OH 44622

Location of proposed air contaminant source(s) [emissions unit(s)]:
**875 Harger St.
Dover, Ohio**

Description of proposed emissions unit(s):
Three natural gas fired steam generators.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director

Part I - GENERAL TERMS AND CONDITIONS

A. Permit to Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Records Retention Requirements

Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

4. Inspections and Information Requests

The Director of the Ohio EPA, or an authorized representative of the Director, may, subject to the safety requirements of the permittee and without undue delay, enter upon

Arizona Chemical
PTI Application: 06-08384
Issued: 2/5/2008

Facility ID: 0679010013

the premises of this source at any reasonable time for purposes of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants, and determining compliance with any applicable State air pollution laws and regulations and the terms and conditions of this permit. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon verbal or written request, the permittee shall also furnish to the Director of the Ohio EPA, or an authorized representative of the Director, copies of records required to be kept by this permit.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emissions unit(s) that is (are) served by such control system(s).

6. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

7. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

8. Termination of Permit to Install

This Permit to Install shall terminate within eighteen months of the effective date of the Permit to Install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

9. Construction of New Sources(s)

Arizona Chemical
PTI Application: 06-08384
Issued: 2/5/2008

Facility ID: 0679010013

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

10. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

11. Applicability

This Permit To Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate Permit To Install for the installation or modification of any other emissions unit(s) are required for any emissions unit for which a Permit To Install is required.

12. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

Arizona Chemical
 PTI Application: 06-08384
 Issued: 2/5/2008

Facility ID: 0679010013

13. Source Operation and Operating Permit Requirements After Completion of Construction

This facility is permitted to operate each source described by this Permit to Install for a period of up to one year from the date the source commenced operation. This permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the emissions unit(s) covered by this permit.

14. Construction Compliance Certification

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the facility has been constructed in accordance with the Permit to Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

15. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit to Install fees within 30 days after the issuance of this Permit to Install.

B. Permit to Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

SUMMARY (for informational purposes only)
 TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

<u>Pollutant</u>	<u>Tons Per Year</u>
PE	2.88
SO ₂	0.027
NO _x	12.87
CO	26.82
VOC	4.08

7

Arizona Chemical
PTI Application: 06-08384
Issued: 2/5/2008

Facility ID: 0679010013

Issued: 2/5/2008

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment -B031 - 27.895 million BTU per hour natural gas fired water heater number 1 with flue gas recirculation

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
ORC rule 3704.03(T)(4)	See Section A.2.a. below.
OAC rule 3745-31-05(C)	Emissions of nitrogen oxide (NOx) shall not exceed 4.29 tons per year. See Section A.2.b. below.
OAC rule 3745-17-07(A)(1)	Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.
OAC rule 3745-17-10(B)(1)	Particulate emissions (PE) shall not exceed 0.20 lb/million Btu actual heat input.
OAC rule 3745-18-06(B)	Exempt. See Section A.2.c below.
NSPS subpart Dc 40CFR60.40c - 48c	See Sections C.2. and D.2. below.

2. Additional Terms and Conditions

- 2.a The Best Available Technology (BAT) requirements under 3745-31-05(A)(3) do not apply to the carbon monoxide, volatile organic compound, sulfur dioxide, or particulate emissions from this air contaminant source since the uncontrolled potential to emit for carbon monoxide, volatile organic compound, sulfur dioxide, and particulate emissions is each less than ten tons per year.
- 2.b Permit to Install 06-08384 for this air contaminant source takes into account the following voluntary restrictions (including the use of any applicable air pollution control equipment) as proposed by the permittee for the purposes of avoiding Best Available Technology (BAT) requirements under OAC rule

Issued: 2/5/2008

3745-31-05(A)(3): this emissions unit is designed with flue gas recirculation.

- 2.c** This emissions unit is exempt from the requirements of OAC rule 3745-18-06 pursuant to OAC rule 3745-18-06(B).

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

2. 40 CFR 60.48c

(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(g)(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in §60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(g)(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in §60.42C to use fuel certification to demonstrate compliance with the SO₂ standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

Emissions Unit ID: **B031****D. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. construction date (no later than 30 days after such date);
 - b. actual start-up date (within 15 days after such date); and
 - c. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
50 West Town Street, Suite 700
P. O. Box 1049
Columbus, Ohio 43216-1049

and

Southeast District Office of the Ohio EPA
Division of Air Pollution Control
2195 Front Street
Logan, Ohio 43138.

E. Testing Requirements

1. Compliance with the emission limitations specified in section A.1. of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emissions Limitations:

Emissions of nitrogen oxide (NOx) shall not exceed 4.29 tons per year.

Applicable Compliance Method:

Issued: 2/5/2008

Compliance with the NO_x emission limitation may be demonstrated by multiplying the NO_x emissions factor from the manufacturer (0.035 lb/million BTU) by the maximum rated capacity of the emissions unit and by the maximum annual hours of operation (8760 hours), and then dividing by 2,000 lbs per ton as shown in the following equation:

$$(0.035 \text{ lbs/mmBtu})(27.895 \text{ mmBtu/hr})(8760 \text{ hr/yr})/(2000 \text{ lb/ton}) = 4.29 \text{ ton/yr}$$

If required, verification of the NO_x emission factor shall be demonstrated by performing an emission test in accordance with the procedures specified in Methods 1 through 4 and Method 7 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA, Southeast District Office.

- b. Emissions Limitation:
Particulate emissions (PE) shall not exceed 0.20 lb/mmBtu of actual heat input.

Applicable Compliance Method:

Compliance shall be determined based on the manufacturer's emission factor of 0.00777 lb/million Btu.

If required, particulate emissions shall be determined according to test Methods 1 - 5, as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

- c. Emissions Limitation:
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average.

Applicable Compliance Method:

If required, visible particulate emissions shall be determined according to test Method 9 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources" as such appendix existed on July 1, 2002.

F. Miscellaneous Requirements

Issued: 2/5/2008

Emissions Unit ID: **B031**

None

Issued: 2/5/2008

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment -B032 - 27.895 million BTU per hour natural gas fired water heater number 2 with flue gas recirculation

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
ORC rule 3704.03(T)(4)	See Section A.2.a. below.
OAC rule 3745-31-05(C)	Emissions of nitrogen oxide (NOx) shall not exceed 4.29 tons per year. See Section A.2.b. below.
OAC rule 3745-17-07(A)(1)	Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.
OAC rule 3745-17-10(B)(1)	Particulate emissions (PE) shall not exceed 0.20 lb/million Btu actual heat input.
OAC rule 3745-18-06(B)	Exempt. See Section A.2.c below.
NSPS subpart Dc 40CFR60.40c - 48c	See Sections C.2. and D.2. below.

2. Additional Terms and Conditions

- 2.a The Best Available Technology (BAT) requirements under 3745-31-05(A)(3) do not apply to the carbon monoxide, volatile organic compound, sulfur dioxide, or particulate emissions from this air contaminant source since the uncontrolled potential to emit for carbon monoxide, volatile organic compound, sulfur dioxide, and particulate emissions is each less than ten tons per year.
- 2.b Permit to Install 06-08384 for this air contaminant source takes into account the following voluntary restrictions (including the use of any applicable air pollution control equipment) as proposed by the permittee for the purposes of avoiding Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3): this emissions unit is designed with flue gas recirculation.

Emissions Unit ID: B032

- 2.c This emissions unit is exempt from the requirements of OAC rule 3745-18-06 pursuant to OAC rule 3745-18-06(B).

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
2. 40 CFR 60.48c
(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(g)(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in §60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(g)(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in §60.42C to use fuel certification to demonstrate compliance with the SO₂ standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

D. Reporting Requirements

Issued: 2/5/2008

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. construction date (no later than 30 days after such date);
 - b. actual start-up date (within 15 days after such date); and
 - c. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
50 West Town Street, Suite 700
P. O. Box 1049
Columbus, Ohio 43216-1049

and

Southeast District Office of the Ohio EPA
Division of Air Pollution Control
2195 Front Street
Logan, Ohio 43138.

E. Testing Requirements

1. Compliance with the emission limitations specified in section A.1. of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emissions Limitations:

Emissions of nitrogen oxide (NO_x) shall not exceed 4.29 tons per year.

Applicable Compliance Method:

Compliance with the NO_x emission limitation may be demonstrated by

Emissions Unit ID: **B032**

multiplying the NOx emissions factor from the manufacturer (0.035 lb/million BTU) by the maximum rated capacity of the emissions unit and by the maximum annual hours of operation (8760 hours), and then dividing by 2,000 lbs per ton as shown in the following equation:

$$(0.035 \text{ lbs/mmBtu})(27.895 \text{ mmBtu/hr})(8760 \text{ hr/yr})/(2000 \text{ lb/ton}) = 4.29 \text{ ton/yr}$$

If required, verification of the NOx emission factor shall be demonstrated by performing an emission test in accordance with the procedures specified in Methods 1 through 4 and Method 7 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA, Southeast District Office.

- b. Emissions Limitation:
 Particulate emissions (PE) shall not exceed 0.20 lb/mmBtu of actual heat input.

Applicable Compliance Method:

Compliance shall be determined based on the manufacturer's emission factor of 0.00777 lb/million Btu.

If required, particulate emissions shall be determined according to test Methods 1 - 5, as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

- c. Emissions Limitation:
 Visible particulate emissions shall not exceed 20% opacity as a 6-minute average.

Applicable Compliance Method:

If required, visible particulate emissions shall be determined according to test Method 9 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources" as such appendix existed on July 1, 2002.

F. Miscellaneous Requirements

None

Issued: 2/5/2008

PART II - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment -B033 - 27.895 million BTU per hour natural gas fired water heater number 3 with flue gas recirculation

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
ORC rule 3704.03(T)(4)	See Section A.2.a. below.
OAC rule 3745-31-05(C)	Emissions of nitrogen oxide (NOx) shall not exceed 4.29 tons per year. See Section A.2.b. below.
OAC rule 3745-17-07(A)(1)	Visible emissions shall not exceed 20% opacity as a six-minute average, except as provided by rule.
OAC rule 3745-17-10(B)(1)	Particulate emissions (PE) shall not exceed 0.20 lb/million Btu actual heat input.
OAC rule 3745-18-06(B)	Exempt. See Section A.2.c below.
NSPS subpart Dc 40CFR60.40c - 48c	See Sections C.2. and D.2. below.

2. Additional Terms and Conditions

- 2.a The Best Available Technology (BAT) requirements under 3745-31-05(A)(3) do not apply to the carbon monoxide, volatile organic compound, sulfur dioxide, or particulate emissions from this air contaminant source since the uncontrolled potential to emit for carbon monoxide, volatile organic compound, sulfur dioxide, and particulate emissions is each less than ten tons per year.
- 2.b Permit to Install 06-08384 for this air contaminant source takes into account the following voluntary restrictions (including the use of any applicable air pollution control equipment) as proposed by the permittee for the purposes of avoiding Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3): this emissions unit is designed with flue gas recirculation.

Emissions Unit ID: B033

- 2.c This emissions unit is exempt from the requirements of OAC rule 3745-18-06 pursuant to OAC rule 3745-18-06(B).

B. Operational Restrictions

1. The permittee shall burn only natural gas in this emissions unit.

C. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
2. 40 CFR 60.48c
(g)(1) Except as provided under paragraphs (g)(2) and (g)(3) of this section, the owner or operator of each affected facility shall record and maintain records of the amount of each fuel combusted during each operating day.

(g)(2) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility that combusts only natural gas, wood, fuels using fuel certification in §60.48c(f) to demonstrate compliance with the SO₂ standard, fuels not subject to an emissions standard (excluding opacity), or a mixture of these fuels may elect to record and maintain records of the amount of each fuel combusted during each calendar month.

(g)(3) As an alternative to meeting the requirements of paragraph (g)(1) of this section, the owner or operator of an affected facility or multiple affected facilities located on a contiguous property unit where the only fuels combusted in any steam generating unit (including steam generating units not subject to this subpart) at that property are natural gas, wood, distillate oil meeting the most current requirements in §60.42C to use fuel certification to demonstrate compliance with the SO₂ standard, and/or fuels, excluding coal and residual oil, not subject to an emissions standard (excluding opacity) may elect to record and maintain records of the total amount of each steam generating unit fuel delivered to that property during each calendar month.

(i) All records required under this section shall be maintained by the owner or operator of the affected facility for a period of two years following the date of such record.

D. Reporting Requirements

Emissions Unit ID: **B033**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. construction date (no later than 30 days after such date);
 - b. actual start-up date (within 15 days after such date); and
 - c. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
50 West Town Street, Suite 700
P. O. Box 1049
Columbus, Ohio 43216-1049

and

Southeast District Office of the Ohio EPA
Division of Air Pollution Control
2195 Front Street
Logan, Ohio 43138.

E. Testing Requirements

1. Compliance with the emission limitations specified in section A.1. of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emissions Limitations:

Emissions of nitrogen oxide (NO_x) shall not exceed 4.29 tons per year.

Applicable Compliance Method:

Compliance with the NO_x emission limitation may be demonstrated by multiplying the NO_x emissions factor from the manufacturer (0.035 lb/million

Issued: 2/5/2008

BTU) by the maximum rated capacity of the emissions unit and by the maximum annual hours of operation (8760 hours), and then dividing by 2,000 lbs per ton as shown in the following equation:

$$(0.035 \text{ lbs/mmBtu})(27.895 \text{ mmBtu/hr})(8760 \text{ hr/yr})/(2000 \text{ lb/ton}) = 4.29 \text{ ton/yr}$$

If required, verification of the NO_x emission factor shall be demonstrated by performing an emission test in accordance with the procedures specified in Methods 1 through 4 and Method 7 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA-approved test methods may be used with prior approval from the Ohio EPA, Southeast District Office.

- b. Emissions Limitation:
Particulate emissions (PE) shall not exceed 0.20 lb/mmBtu of actual heat input.

Applicable Compliance Method:

Compliance shall be determined based on the manufacturer's emission factor of 0.00777 lb/million Btu.

If required, particulate emissions shall be determined according to test Methods 1 - 5, as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources". Alternative U.S. EPA-approved test methods may be used with prior approval from Ohio EPA, Southeast District Office.

- c. Emissions Limitation:
Visible particulate emissions shall not exceed 20% opacity as a 6-minute average.

Applicable Compliance Method:

If required, visible particulate emissions shall be determined according to test Method 9 as set forth in the "Appendix on Test Methods" in 40 CFR, Part 60 "Standards of Performance for New Stationary Sources" as such appendix existed on July 1, 2002.

F. Miscellaneous Requirements

None