



State of Ohio Environmental Protection Agency

**RE: DRAFT PERMIT TO INSTALL  
WASHINGTON COUNTY**

**CERTIFIED MAIL**

Street Address:

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center

**Application No: 06-06792**

**DATE: 6/6/2002**

Duke Energy Washington County LLC  
William Campbell  
5400 Westheimer Court  
Houston, TX 77056

You are hereby notified that the Ohio Environmental Protection Agency has made a draft action recommending that the Director issue a Permit to Install for the air contaminant source(s) [emissions unit(s)] shown on the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the proposed installation. A public notice concerning the draft permit will appear in the Ohio EPA Weekly Review and the newspaper in the county where the facility will be located. Public comments will be accepted by the field office within 30 days of the date of publication in the newspaper. Any comments you have on the draft permit should be directed to the appropriate field office within the comment period. A copy of your comments should also be mailed to Robert Hodanbosi, Division of Air Pollution Control, Ohio EPA, P.O. Box 1049, Columbus, OH, 43266-0149.

A Permit to Install may be issued in proposed or final form based on the draft action, any written public comments received within 30 days of the public notice, or record of a public meeting if one is held. You will be notified in writing of a scheduled public meeting. Upon issuance of a final Permit to Install a fee of **\$900** will be due. Please do not submit any payment now.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469. If you have any questions about this draft permit, please contact the field office where you submitted your application, or Mike Ahern, Field Operations & Permit Section at (614) 644-3631.

Very truly yours,

Thomas G. Rigo  
Field Operations and Permit Section  
Division of Air Pollution Control

CC: USEPA

SEDO

WV

PA



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

**Permit To Install  
Terms and Conditions**

**Issue Date: To be entered upon final issuance  
Effective Date: To be entered upon final issuance**

**DRAFT PERMIT TO INSTALL 06-06792**

Application Number: 06-06792  
APS Premise Number: 0684000212  
Permit Fee: **To be entered upon final issuance**  
Name of Facility: Duke Energy Washington County LLC  
Person to Contact: William Campbell  
Address: 5400 Westheimer Court  
Houston, TX 77056

Location of proposed air contaminant source(s) [emissions unit(s)]:  
**State Route 83**  
**Beverly, Ohio**

Description of proposed emissions unit(s):  
**Chapter 31 modification of PTI 06-06167, issued January 18, 2001, to increase aux. boiler hours, decrease aux. boiler NOx emission factor, allow fuel flow monitoring, and include a cooling tower.**

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Director

**A. State and Federally Enforceable Permit To Install General Terms and Conditions****1. Monitoring and Related Recordkeeping and Reporting Requirements**

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
  - i. The date, place (as defined in the permit), and time of sampling or measurements.
  - ii. The date(s) analyses were performed.
  - iii. The company or entity that performed the analyses.
  - iv. The analytical techniques or methods used.
  - v. The results of such analyses.
  - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
  - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
  - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See B.10 below if no deviations occurred during the quarter.

Duke Energy Washington County LLC

Facility ID: 0684000212

PTI Application: 06-06792

Issued: To be entered upon final issuance

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted to the appropriate Ohio EPA District Office or local air agency every six months, i.e., by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
- iv. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

## **2. Scheduled Maintenance/Malfunction Reporting**

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

## **3. Risk Management Plans**

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

## **4. Title IV Provisions**

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

## **5. Severability Clause**

**Issued: To be entered upon final issuance**

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

**6. General Requirements**

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and reissuance, or modification, or for denial of a permit renewal application.
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, reopened, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying, reopening or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

**7. Fees**

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable Permit To Install fees within 30 days after the issuance of this Permit To Install.

**8. Federal and State Enforceability**

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA, the State, and citizens under the Act. All other terms and conditions of this permit

**Duke Energy Washington County LLC**

**Facility ID: 0684000212**

**PTI Application: 06-06792**

**Issued: To be entered upon final issuance**

shall not be federally enforceable and shall be enforceable under State law only.

## **9. Compliance Requirements**

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
  - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
  - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
  - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
  - iv. As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.
- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
  - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
  - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

**10. Permit To Operate Application**

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this Permit To Install is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within thirty (30) days after commencing operation of the source(s) covered by this permit.

**11. Best Available Technology**

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

**12. Air Pollution Nuisance**

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

Duke Energy Washington County LLC

Facility ID: 0684000212

PTI Application: 06-06792

Issued: To be entered upon final issuance

**B. State Only Enforceable Permit To Install General Terms and Conditions**

**1. Compliance Requirements**

The emissions unit(s) identified in this Permit to Install shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

**2. Reporting Requirements Related to Monitoring and Recordkeeping Requirements**

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

**3. Permit Transfers**

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

**4. Termination of Permit To Install**

This permit to install shall terminate within eighteen months of the effective date of the permit to install if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may

**Issued: To be entered upon final issuance**

be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

**5. Construction of New Sources(s)**

The proposed emissions unit(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources cannot meet the requirements of this permit or cannot meet applicable standards.

If the construction of the proposed emissions unit(s) has already begun or has been completed prior to the date the Director of the Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

**6. Public Disclosure**

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

**7. Applicability**

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

**8. Construction Compliance Certification**

The applicant shall provide Ohio EPA with a written certification (see enclosed form) that the

Duke Energy Washington County LLC  
 PTI Application: 06-06792

Facility ID: 0684000212

**Issued: To be entered upon final issuance**

facility has been constructed in accordance with the Permit To Install application and the terms and conditions of the Permit to Install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

**9. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)**

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly, i.e., by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

**C. Permit To Install Summary of Allowable Emissions**

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each air contaminant source identified in this permit.

**SUMMARY (for informational purposes only)  
 TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
NO <sub>x</sub>	323.8
SO <sub>2</sub>	113.7
PE	218.7
CO	921.5
VOC	128.0
Ammonia (NH <sub>3</sub> )	269.0
Formaldehyde	7.2
Sulfuric Acid	17.2

Duke Energy Washington County LLC

Facility ID: 0684000212

PTI Application: 06-06792

Issued: To be entered upon final issuance

**Part II - FACILITY SPECIFIC TERMS AND CONDITIONS****A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions**

1. The following emissions units are also being installed as part of this project:

<u>Emissions Unit</u>	<u>BACT</u>	<u>Emissions</u>
600 kW Emergency Diesel Fuel-Fired Generator*	Use of low sulfur fuel; Combustion control	3.1 TPY NO <sub>x</sub> 0.10 TPY SO <sub>2</sub> 0.18 TPY PE 3.8 TPY CO 0.44 TPY VOC
400 HP Emergency Diesel Fuel-Fired Fire Pump Engine*	Use of low sulfur fuel; Combustion control	3.2 TPY NO <sub>x</sub> 0.21 TPY SO <sub>2</sub> 0.22 TPY PE 0.69 TPY CO 0.26 TPY VOC
Four 4-cell Inlet Air Chiller Cooling Towers	Not Applicable	1.6 TPY PE

- \* Subject to OAC rule 3745-31-03(A)(4); restricted to no more than 500 hours per 12-month rolling period.

**B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions**

None

Duke  
PTI A

Emissions Unit ID: **B001**

Issued: **To be entered upon final issuance**

**Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**

**A. State and Federally Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

- 1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>
B001 - 46.6 MMBtu/hr Natural Gas-Fired Boiler	40 CFR Part 60, Subpart Dc OAC rule 3745-18-06(A) OAC rule 3745-17-10(B)(1)
	OAC rule 3745-17-07(A)
	OAC rule 3745-21-08(B) and OAC rule 3745-23-06(B)
	OAC rules 3745-31-10 through 3745-31-20

**Duke**  
**PTI A**

Emissions Unit ID: **B001**

**Issued: To be entered upon final issuance**

Applicable Emissions Limitations/Control Measures	3745-31-20.
Nitrogen oxides (NO <sub>x</sub> ) emissions shall not exceed 0.035 lb/MMBtu actual heat input, 1.72 lbs/hr, and 2.5 tons/yr.	The emission limitations specified by these rules are less stringent than those established pursuant to OAC rule 3745-31-05(A)(3).
Sulfur dioxide (SO <sub>2</sub> ) emissions shall not exceed 0.0057 lb/MMBtu actual heat input, 0.28 lb/hr, and 0.41 ton/yr.	Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.
Particulate emissions (PE) shall not exceed 0.009 lb/MMBtu actual heat input, 0.44 lb/hr, and 0.64 ton/yr.	See A.I.2.a below.
Carbon monoxide (CO) emissions shall not exceed 0.135 lb/MMBtu actual heat input, 6.62 lbs/hr, and 9.6 tons/yr.	NO <sub>x</sub> emissions shall not exceed 2.5 tons per rolling 12-month period.
Volatile organic compounds (VOC) emissions shall not exceed 0.014 lb/MMBtu actual heat input, 0.71 lb/hr, and 1.1 tons/yr.	SO <sub>2</sub> emissions shall not exceed 0.41 ton per rolling 12-month period.
See A.II.1 and A.II.2 below.	PE emissions shall not exceed 0.64 ton per rolling 12-month period.
The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A) and 3745-31-10 through	CO emissions shall not exceed 9.6 tons per rolling 12-month period.
	VOC emissions shall not exceed 1.1 tons per rolling 12-month period.

**Issued: To be entered upon final issuance****2. Additional Terms and Conditions**

- 2.a** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) and the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3) in this Permit to Install.

**II. Operational Restrictions**

1. The permittee shall burn only natural gas in this emissions unit. The maximum sulfur content of the natural gas shall not exceed 2 grains per 100 standard cubic feet.
2. The maximum hourly fuel heat input for this emissions unit shall not exceed 49.0 MMBtu (105% load). The maximum annual fuel heat input for this emissions unit shall not exceed 142,100 MMBtu, based upon a rolling, 12-month summation of the heat input values.

To ensure enforceability during the first 12 calendar months following the start-up of this emissions unit, the permittee shall not exceed the monthly cumulative fuel heat input restrictions specified in the following table:

Duke Energy Washington County LLC

PTI Application: 06-06702

Issued

Facility ID: 0684000212

Emissions Unit ID: B001

Month	Cumulative Fuel Heat Input (MMBtu)
1	86,000
1-2	142,100
1-3	142,100
1-4	142,100
1-5	142,100
1-6	142,100
1-7	142,100
1-8	142,100
1-9	142,100
1-10	142,100
1-11	142,100
1-12	142,100

After the first 12 calendar months following the start-up of this emissions unit, compliance with the annual fuel heat input restriction shall be based on a rolling, 12-month summation of the heat input values.

### III. Monitoring and/or Recordkeeping Requirements

1. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.
2. The permittee shall monitor the sulfur content and gross calorific value of the fuel being fired in the emissions unit. Fuel sampling and analysis shall be conducted according to the procedures and at the frequency specified by 40 CFR Part 75, Appendix D.
3. The permittee shall maintain hourly records of the fuel quantity used (cubic feet) and the heat input (MMBtu/hr) for this emissions unit.
4. The permittee shall maintain monthly records of the following information for this emissions unit:

**Issued: To be entered upon final issuance**

- a. The natural gas usage rate, in standard cubic feet.
- b. Hours of operation.
- c. Monthly fuel heat input (MMBtu).
- d. During the first 12 calendar months of operation, records of the cumulative fuel heat input (MMBtu).
- e. Beginning after the first 12 calendar months of operation, records of the rolling, 12-month summation of fuel heat input (MMBtu).
- f. During the first 12 calendar months of operation, records of the NO<sub>x</sub>, SO<sub>2</sub>, PE, CO, and VOC emissions, in tons.
- g. Beginning after the first 12 calendar months of operation, records of the rolling, 12-month summation of the NO<sub>x</sub>, SO<sub>2</sub>, PE, CO, and VOC emissions, in tons.

**IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurs.
2. The permittee shall submit quarterly deviation (excursion) reports that identify the following:
  - a. Any record which shows that the sulfur content of the natural gas exceeded 2 grains per 100 standard cubic feet.
  - b. All exceedances of the hourly maximum allowable fuel heat input.
  - c. During the first 12 calendar months of operation, all exceedances of the monthly cumulative fuel heat input limitations.
  - d. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month fuel heat input limitation.
  - e. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month emission limitations for NO<sub>x</sub>, SO<sub>2</sub>, PE, CO, and VOC.

The quarterly deviation reports shall be submitted in accordance with General Term and

Duke  
PTI A

Emissions Unit ID: **B001****Issued: To be entered upon final issuance**

Condition A.2.

3. The permittee shall submit annual reports that specify the total NO<sub>x</sub>, SO<sub>2</sub>, PE, CO, and VOC emissions from this emissions unit for the previous calendar year. The annual reports shall be submitted by January 31 of each year.
4. This emissions unit is subject to the applicable provisions of Subpart Dc of the New Source Performance Standards (NSPS) as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60. The application and enforcement of these standards are delegated to the Ohio EPA. The requirements of 40 CFR Part 60 are also federally enforceable.

Pursuant to 40 CFR Part 60.7, the permittee is hereby advised of the requirement to report the following at the appropriate times:

- a. construction date (no later than 30 days after such date);
- b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
- c. actual start-up date (within 15 days after such date); and,
- d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency  
DAPC - Permit Management Unit  
P. O. Box 163669  
Columbus, Ohio 43216-3669

and

Ohio Environmental Protection Agency  
Southeast District Office  
Division of Air Pollution Control  
2195 Front Street  
Logan, Ohio 43138

**V. Testing Requirements**

1. Emission Limitations:

Emissions Unit ID: B001

NO<sub>x</sub> emissions shall not exceed 0.035 lb/MMBtu, 1.72 lbs/hr, and 2.5 tons/yr.

Applicable Compliance Method:

Compliance with the lb/MMBtu emission limitation may be demonstrated using the emission factor supplied by the permittee (0.035 lb NO<sub>x</sub> /MMBtu).

Compliance with the lbs/hr emission limitation may be demonstrated by multiplying the permittee-supplied NO<sub>x</sub> emission factor (0.035 lb NO<sub>x</sub> /MMBtu) by the actual fuel heat input rate (MMBtu/hr).

Compliance with the tons/yr emission limitations shall be demonstrated by multiplying the permittee-supplied NO<sub>x</sub> emission factor (0.035 lb NO<sub>x</sub>/MMBtu) or emissions unit specific NO<sub>x</sub> emission factor established through emission testing by the actual fuel heat input (MMBtu/yr) and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu and lbs/hr emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 7.

2. Emission Limitations:

SO<sub>2</sub> emissions shall not exceed 0.0057 lb/MMBtu, 0.28 lb/hr, and 0.41 ton/yr.

Applicable Compliance Method:

Compliance with the lb/MMBtu emission limitation may be demonstrated using the emission factor supplied by the permittee (0.0057 lb SO<sub>2</sub>/MMBtu).

Compliance with the lb/hr emission limitation may be demonstrated by multiplying the permittee-supplied SO<sub>2</sub> emission factor (0.0057 lb SO<sub>2</sub>/MMBtu) by the actual fuel heat input rate (MMBtu/hr).

Compliance with the ton/yr emission limitation shall be demonstrated by multiplying the permittee-supplied SO<sub>2</sub> emission factor (0.0057 lb SO<sub>2</sub>/MMBtu) or emissions unit specific SO<sub>2</sub> emission factor established through emission testing by the actual fuel heat input (MMBtu/yr) and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu and lb/hr emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

3. Emission Limitations:

**Duke**

**PTI A**

Emissions Unit ID: **B001**

**Issued: To be entered upon final issuance**

CO emissions shall not exceed 0.135 lb/MMBtu, 6.62 lbs/hr, and 9.6 tons/yr.

Applicable Compliance Method:

Compliance with the lb/MMBtu emission limitation may be demonstrated using the emission factor supplied by the permittee (0.135 lb CO/MMBtu).

**Issued: To be entered upon final issuance**

Compliance with the lbs/hr emission limitation may be demonstrated by multiplying the permittee-supplied CO emission factor (0.135 lb CO/MMBtu) by the actual fuel heat input rate (MMBtu/hr).

Compliance with the tons/yr emission limitations shall be demonstrated by multiplying the permittee-supplied CO emission factor (0.135 lb CO/MMBtu) or emissions unit specific CO emission factor established through emission testing by the actual fuel heat input (MMBtu/yr) and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu and lbs/hr emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 10.

4. Emission Limitations:

VOC emissions shall not exceed 0.014 lb/MMBtu, 0.71 lb/hr, and 1.1 tons/yr.

Applicable Compliance Method:

Compliance with the lb/MMBtu emission limitation may be demonstrated using the emission factor supplied by the permittee (0.014 lb VOC/MMBtu).

Compliance with the lb/hr emission limitation may be demonstrated by multiplying the permittee-supplied VOC emission factor (0.014 lb VOC/MMBtu) by the actual fuel heat input rate (MMBtu/hr).

Compliance with the tons/yr emission limitations shall be demonstrated by multiplying the permittee-supplied VOC emission factor (0.014 lb VOC/MMBtu) or emissions unit specific VOC emission factor established through emission testing by the actual fuel heat input (MMBtu/yr) and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu and lb/hr emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 25.

5. Emission Limitations:

PE emissions shall not exceed 0.009 lb/MMBtu, 0.44 lb/hr, and 0.64 ton/yr.

Applicable Compliance Method:

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: **B001**

Compliance with the lb/MMBtu emission limitation may be demonstrated using the emission factor supplied by the permittee (0.009 lb PE/MMBtu).

**Issued: To be entered upon final issuance**

Compliance with the lb/hr emission limitation may be demonstrated by multiplying the permittee-supplied PE emission factor (0.009 lb PE/MMBtu) by the actual fuel heat input rate (MMBtu/hr).

Compliance with the ton/yr emission limitations shall be demonstrated by multiplying the permittee-supplied PE emission factor (0.009 lb PE/MMBtu) or emissions unit specific PE emission factor established through emission testing by the actual fuel heat input (MMBtu/yr) and dividing by 2,000 lbs/ton.

If required, the permittee shall demonstrate compliance with the lb/MMBtu and lb/hr emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 5.

6. Emission Limitations:

NO<sub>x</sub> emissions shall not exceed 2.5 tons per rolling 12-month period.

SO<sub>2</sub> emissions shall not exceed 0.41 ton per rolling 12-month period.

PE emissions shall not exceed 0.64 ton per rolling 12-month period.

CO emissions shall not exceed 9.6 tons per rolling 12-month period.

VOC emissions shall not exceed 1.1 tons per rolling 12-month period.

Applicable Compliance Method:

Compliance with the rolling, 12-month emission limitations shall be demonstrated based upon the records required pursuant to section A.III and the associated emission factors specified in section A.V.

7. Emission Limitation:

Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except as provided by rule.

Applicable Compliance Method:

If required, compliance with this emission limitation shall be demonstrated through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9.

**VI. Miscellaneous Requirements**

1. The terms and conditions for this emissions unit supercede those contained in PTI 06-06167 issued January 18, 2001.

Duke  
PTI A

Emissions Unit ID: **B001**

**Issued: To be entered upon final issuance**

**B. State Only Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
B001 - 46.6 MMBtu/hr Natural Gas-Fired Boiler	None	None

**2. Additional Terms and Conditions**

2.a None

**II. Operational Restrictions**

None

**III. Monitoring and/or Recordkeeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None



3745-31-20

OAC Rule 3745-31-05  
(A)(3)

40 CFR Part 60, Subpart GG

40 CFR Part 60, Subpart Da

OAC rule 3745-18-06(F)

OAC rule 3745-17-11(B)(4)

OAC rule 3745-17-07(A)

OAC rule 3745-21-08(B)

OAC rule 3745-23-06(B)

OAC rules 3745-31-10 through  
3745-31-20

OAC rule 3745-31-05(A)(3)

Duke

PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

<u>Applicable Emissions Limitations/Control Measures</u>		
EMISSION LIMITATIONS WITHOUT DUCT BURNER FIRING	Formaldehyde emissions shall not exceed 0.8 lb/hr and 3.6 tons/yr.	DUCT BURNER FIRING (limited to 4,500 hours per year)
Nitrogen oxides (NO <sub>x</sub> ) emissions shall not exceed 3.5 ppmvd at 15% oxygen, 24.7 lbs/hr, and 157.5 tons/yr, including start-up and shutdown emissions.	Sulfuric acid emissions shall not exceed 1.7 lbs/hr and 8.6 tons/yr.	Nitrogen oxides (NO <sub>x</sub> ) emissions shall not exceed 3.5 ppmvd at 15% oxygen, 32.3 lbs/hr, and 157.5 tons/yr, including start-up and shutdown emissions.
Particulate emissions (PE) shall not exceed 19.0 lbs/hr and 103.5 tons/yr.	Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.  See A.II.1 below.  The requirements of this rule also include compliance with the requirements of 40 CFR Part 60, Subpart GG and OAC rules 3745-31-10 through 3745-31-20.	Particulate emissions (PE) shall not exceed 28.0 lbs/hr and 103.5 tons/yr.  Sulfur dioxide (SO <sub>2</sub> ) emissions shall not exceed 14.5 lbs/hr and 56.5 tons/yr.  Carbon monoxide (CO) emissions shall not exceed 14 ppmvd at 15% oxygen, 78.0 lbs/hr, and 453.7 tons/yr, including start-up and shutdown emissions.
Sulfur dioxide (SO <sub>2</sub> ) emissions shall not exceed 11.2 lbs/hr and 56.5 tons/yr.	See A.I.2.b below.  See A.I.2.a below.	Volatile organic compounds (VOC) emissions shall not exceed 19.6 lbs/hr and 63.1 tons/yr, including start-up and shutdown emissions.
Carbon monoxide (CO) emissions shall not exceed 10 ppmvd at 15% oxygen, 43.0 lbs/hr, and 453.7 tons/yr, including start-up and shutdown emissions.	See A.I.2.d below.  NO <sub>x</sub> emissions shall not exceed 157.5 tons per rolling, 12-month period.	Ammonia (NH <sub>3</sub> ) emissions shall not exceed 34.6 lbs/hr and 134.5 tons/yr.  Formaldehyde emissions shall not exceed 0.82 lb/hr and 3.6 tons/yr.
Volatile organic compounds (VOC) emissions shall not exceed 3.0 lbs/hr and 63.1 tons/yr, including start-up and shutdown emissions.	SO <sub>2</sub> emissions shall not exceed 56.5 tons per rolling, 12-month period. PE emissions shall not exceed 103.5 tons per rolling, 12-month period. CO emissions shall not exceed 453.7 tons per rolling, 12-month period.	Sulfuric acid emissions shall not exceed 2.2 lbs/hr and 8.6 tons/yr.  Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.
Ammonia (NH <sub>3</sub> ) emissions shall not exceed 26.6 lbs/hr and 134.5 tons/yr.	VOC emissions shall not exceed 63.1 tons per rolling, 12-month period.	See A.II.1 and A.II.3 below.
	EMISSION LIMITATIONS WITH	The requirements of this rule also include

Duke

PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

compliance with the requirements of 40 CFR Part 60, Subparts Da and GG, and OAC rules 3745-31-10 through 3745-31-20.

See A.I.2.b below.

See A.I.2.a below.

See A.I.2.d below.

NO<sub>x</sub> emissions shall not exceed 157.5 tons per rolling, 12-month period.

SO<sub>2</sub> emissions shall not exceed 56.5 tons per rolling, 12-month period.

PE emissions shall not exceed 103.5 tons per rolling, 12-month period.

CO emissions shall not exceed 453.7 tons per rolling, 12-month period.

VOC emissions shall not exceed 63.1 tons per rolling, 12-month period.

START-UP AND SHUTDOWN EMISSION LIMITATIONS (See A.II.2 below.)

Nitrogen oxides (NO<sub>x</sub>) emissions shall not exceed 248 lbs/cycle and 32.2 tons/yr.

Carbon monoxide (CO) emissions shall not exceed 1436 lbs/cycle and 186.6 tons/yr.

Volatile organic compounds (VOC) emissions shall not exceed 97 lbs/cycle and 12.6 tons/yr.

Duke Energy Washington County LLC

PTI Application: 06-06702

Issued

Facility ID: 0684000212

Emissions Unit ID: P001

**2. Additional Terms and Conditions**

- 2.a** The emission limitations specified in these applicable rules are equivalent to or less stringent than the emission limitations established pursuant to OAC rule 3745-31-05(A)(3).
- 2.b** The emission limitations specified in this applicable rule are equivalent to or less stringent than the emission limitations established pursuant to OAC rule 3745-31-05(A)(3). Except as provided for in the terms and conditions in this permit, the permittee is not exempt from meeting any additional requirements of 40 CFR Part 60, Subpart GG.
- 2.c** If the permittee is subject to the requirements of OAC Chapter 103 and 40 CFR Parts 72 and 75 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

**Issued: To be entered upon final issuance**

- 2.d** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) and the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3) in this Permit to Install.

**II. Operational Restrictions**

1. The permittee shall burn only natural gas in this emissions unit. The maximum sulfur content of the natural gas shall not exceed 2 grains per 100 standard cubic feet.
2. Start-up shall be defined as the period between when the combined cycle systems are initially started until the combustion turbine achieves combustion operational Mode 6. Shutdown shall be defined as the period beginning when the combustion turbine leaves operational Mode 6 and ending when combustion has ceased. Mode 6 is defined by the manufacturer as the low emissions mode during which all 6 of the burner nozzles are in use, burning a lean premixed gas for steady-state operation (i.e., in compliance with the NO<sub>x</sub> and CO lbs/hr emission limitations listed in term A.I.1.). The continuous emission monitoring system will indicate and record the combustion turbine operational mode, including when the emissions unit is shutdown and when operating in start-up and shutdown modes, and will be used to demonstrate compliance with the NO<sub>x</sub> and CO emission limitations during steady-state operation (Mode 6).

Start-ups shall not exceed 250 minutes in duration and shutdowns shall not exceed 2 hours in duration. The total of all start-ups and shutdowns shall be limited to 260 cycles (each cycle consists of one start-up and one shutdown) per year.

Each cycle shall be limited to the following:

<u>Pollutant</u>	<u>Total lbs/Cycle</u>
NO <sub>x</sub>	248
CO	1436
VOC	97

3. The maximum annual hours of operation of the duct burner for this emissions unit shall not exceed 4,500 hours, based upon a rolling, 12-month summation.

To ensure enforceability during the first 12 calendar months following the start-up of the emissions unit, the permittee shall not exceed the monthly cumulative hours of operation restrictions for the duct burner specified in the following table:

Duke

PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

Month	Cumulative hours of Operation
1	720
1-2	1,440
1-3	2,160
1-4	2,880
1-5	3,600
1-6	4,320
1-7	4,500
1-8	4,500
1-9	4,500
1-10	4,500
1-11	4,500
1-12	4,500

After the first 12 calendar months following the start-up of the emissions unit, compliance with the annual hours of operation restriction for the duct burner shall be based on a rolling, 12-month summation.

#### 4. Continuous NO<sub>x</sub> Monitoring System Certification

Prior to the installation of the continuous NO<sub>x</sub> monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 2 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and 40 CFR Part 75. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to

Emissions Unit ID: P001

the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office. Certification of the continuous NO<sub>x</sub> monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and 40 CFR Part 75.

5. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO<sub>x</sub> monitoring system designed to ensure continuous valid and representative readings of NO<sub>x</sub> emissions in units of the applicable standard. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B. The quality assurance/quality control plan and a logbook dedicated to the continuous NO<sub>x</sub> monitoring system must be kept on site and available for inspection during regular office hours.
6. Continuous CO Monitoring System Certification

Prior to the installation of the continuous CO monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 4 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of the continuous CO monitoring system pursuant to ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office. Certification of the continuous CO monitoring system shall be granted upon determination by the Ohio EPA Central Office that the system meets all requirements of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4.

7. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous CO monitoring system designed to ensure continuous valid and representative readings of CO. The plan shall follow the requirements of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous CO monitoring system must be kept on site and available for inspection during regular office hours.

**Issued: To be entered upon final issuance**8. Continuous O<sub>2</sub> Monitoring System Certification

Prior to the installation of the continuous O<sub>2</sub> monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 3 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 3, and 40 CFR Part 75. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office.

Certification of the continuous O<sub>2</sub> monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 3, and 40 CFR Part 75.

9. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous O<sub>2</sub> monitoring system designed to ensure continuous valid and representative readings of O<sub>2</sub> emissions in units of the applicable standard. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B. The quality assurance/quality control plan and a logbook dedicated to the continuous O<sub>2</sub> monitoring system must be kept on site and available for inspection during regular office hours.

**III. Monitoring and/or Recordkeeping Requirements**

1. The permittee shall maintain monthly records of the following information for this emissions unit:
  - a. The natural gas usage rate, in standard cubic feet.
  - b. Hours of operation of the combustion turbine.
  - c. Hours of operation of the duct burner.

Emissions Unit ID: P001

- d. During the first 12 calendar months of operation, records of the cumulative operating hours of the duct burner.
  - e. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the operating hours of the duct burner.
  - f. Number of start-ups and the duration, in minutes, of each start-up.
  - g. Number of shutdowns, and the duration, in hours, of each shutdown.
  - h. The total number of start-up/shutdown cycles.
  - i. The NO<sub>x</sub>, CO, and VOC emissions, in pounds, for all start-up/shutdown cycles.
  - j. The total NO<sub>x</sub> emissions, in pounds, including start-up/shutdown emissions.
  - k. The total CO emissions, in pounds, including start-up/shutdown emissions.
  - l. The total VOC emissions, in pounds, including start-up/shutdown emissions.
  - m. The total SO<sub>2</sub>, PE, NH<sub>3</sub>, formaldehyde, and sulfuric acid emissions, in pounds.
  - n. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the NO<sub>x</sub> emissions, in tons, including start-up/shutdown emissions.
  - o. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the CO emissions, in tons, including start-up/shutdown emissions.
  - p. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the VOC emissions, in tons, including start-up/shutdown emissions.
  - q. Beginning after the first 12 calendar months of operation, the rolling, 12-month summations of the SO<sub>2</sub> and PE emissions, in tons.
2. The permittee shall install, operate and maintain equipment to continuously monitor and record NO<sub>x</sub> emissions from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements of the appropriate sections specified in 40 CFR Part 60.13 and 40 CFR Part 75.

The permittee shall maintain records of all data obtained by the continuous NO<sub>x</sub> monitoring system including, but not limited to, parts per million NO<sub>x</sub> on an instantaneous (one-minute) basis, emissions of NO<sub>x</sub> in units of the applicable standard in the appropriate averaging period (i.e., ppmvd at 15% oxygen and lbs/hr), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P001

3. The permittee shall install, operate and maintain equipment to continuously monitor and record CO emissions from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13 .

Emissions Unit ID: P001

The permittee shall maintain records of all data obtained by the continuous CO monitoring system including, but not limited to, parts per million CO on an instantaneous (one minute) basis, emissions of CO in units of the applicable standard in the appropriate averaging period (i.e., ppmvd at 15% oxygen and lbs/hr), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. The permittee shall install, operate and maintain equipment to continuously monitor and record O<sub>2</sub> emissions from this emissions unit in percent O<sub>2</sub>. Such continuous monitoring and recording equipment shall comply with the requirements in the appropriate sections specified in 40 CFR Part 60.13 and 40 CFR Part 75.

The permittee shall maintain records of all data obtained by the continuous O<sub>2</sub> monitoring system including, but not limited to, percent O<sub>2</sub> on an instantaneous (one-minute) basis, emissions of O<sub>2</sub> in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

5. The permittee shall install, operate and maintain equipment to continuously monitor and record the fuel flow to this emissions unit when the emissions unit is in operation. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75. If the fuel flow monitoring and/or recording equipment is (are) not in service when the emissions unit is in operation, the permittee shall comply with the appropriate missing data procedures specified in 40 CFR Part 75.
6. The permittee shall monitor the sulfur content and gross calorific value of the fuel being fired in the combustion turbine and duct burner. Fuel sampling and analysis shall be conducted according to the procedures and at the frequency specified by 40 CFR Part 75, Appendix D, section 2.3.3.1.
7. The permittee shall determine the hourly heat input rate to the combustion turbine and duct burner from the fuel flow rate as determined in term A.III.5. and fuel gross calorific value as determined in term A.III.6. The heat input rate shall be calculated in accordance with the procedures in Section 5 of 40 CFR Part 75, Appendix F.
8. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

#### IV. Reporting Requirements

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurred.

**Issued: To be entered upon final issuance**

2. The permittee shall submit quarterly deviation (excursion) reports that identify the following:
  - a. During the first 12 calendar months of operation, all exceedances of the cumulative duct burner operating hours limitations.
  - b. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month duct burner operating hours limitation.
  - c. Any record which shows that the sulfur content of the natural gas exceeded 2 grains per 100 standard cubic feet.
  - d. Any record which shows that the start-up duration exceeded 250 minutes.
  - e. Any record which shows that the shutdown duration exceeded 2 hours.
  - f. Any record which shows that the total number of start-up/shutdown cycles exceeded 260.
  - g. All exceedances of the NO<sub>x</sub>, CO, and/or VOC start-up/shutdown emission limitations during any cycle.
  - h. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month NO<sub>x</sub>, CO, VOC, SO<sub>2</sub>, and/or PE emission limitations.

The quarterly deviation reports shall be submitted in accordance with General Term and Condition A.2.

3. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of NO<sub>x</sub> values in excess of the applicable limitations specified in the terms and conditions of this permit. These reports shall also contain the total NO<sub>x</sub> emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting any continuous NO<sub>x</sub> monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P001

included in the quarterly report.

**Issued: To be entered upon final issuance**

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

4. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of CO values in excess of any applicable limitation(s) specified in the terms and conditions of this permit. These reports shall also contain the total CO emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting any continuous CO monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

5. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting all instances of continuous O<sub>2</sub> monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line

**Issued: To be entered upon final issuance**

shall be included in the quarterly report. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

6. The permittee shall submit annual reports that specify the total NO<sub>x</sub>, CO, PE, SO<sub>2</sub>, VOC, NH<sub>3</sub>, formaldehyde, and sulfuric acid emissions from this emissions unit for the previous calendar year. The reports shall be submitted by January 31 of each year.
7. This emissions unit is subject to the applicable provisions of Subpart Da and GG of the New Source Performance Standards (NSPS) as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60. The application and enforcement of these standards are delegated to the Ohio EPA. The requirements of 40 CFR Part 60 are also federally enforceable.

Pursuant to 40 CFR Part 60.7, the permittee is hereby advised of the requirement to report the following at the appropriate times:

- a. construction date (no later than 30 days after such date);
- b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
- c. actual start-up date (within 15 days after such date); and,
- d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency  
DAPC - Permit Management Unit  
P. O. Box 163669  
Columbus, Ohio 43216-3669

and

Ohio Environmental Protection Agency  
Southeast District Office  
Division of Air Pollution Control  
2195 Front Street  
Logan, Ohio 43138

**V. Testing Requirements**

Emissions Unit ID: P001

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
  - a. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of the emissions unit.
  - b. The emission testing shall be conducted to demonstrate compliance with the NO<sub>x</sub> and CO outlet concentrations, the mass emission limitations for NO<sub>x</sub>, CO, formaldehyde, VOC, and PE, and the visible particulate emission limitations.
  - c. The following test methods shall be employed to demonstrate compliance with the above emission limitations: for NO<sub>x</sub>, Method 20 of 40 CFR Part 60, Appendix A and the procedures required under 40 CFR Part 60.335; for PE, Method 5 of 40 CFR Part 60, Appendix A; for visible particulate emission limitations, Method 9, 40 CFR Part 60 Appendix A; for formaldehyde, SW-846 Method 0011; for VOC, Method 25 of 40 CFR Part 60, Appendix A; and for CO, Method 10 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
  - d. The testing shall be conducted while the emissions unit is operating at or near its maximum capacity with and without the duct burner firing, unless otherwise specified or approved by the Ohio EPA or local air agency.
  - e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Southeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Southeast District Office refusal to accept the results of the emission test(s).
  - f. Personnel from the Ohio EPA, Southeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
  - g. A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Southeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Southeast District Office.
2. Compliance with the allowable emission limitations in this permit shall be determined according to

the following methods:

a. Emission Limitations:

NO<sub>x</sub> emissions shall not exceed 3.5 ppmvd at 15% oxygen, 24.7 lbs/hr without duct burner firing, 32.3 lbs/hr with duct burner firing, and 157.5 tons/yr, which includes 32.2 tons/yr for start-ups and shutdowns.

Applicable Compliance Method:

Initial compliance with the allowable outlet concentration and the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with these emission limitations shall be demonstrated based upon the continuous NO<sub>x</sub> and oxygen monitoring systems data required pursuant to section A.III. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

b. Emission Limitations:

PE emissions shall not exceed 19.0 lbs/hr without duct burner firing, 28.0 lbs/hr with duct burner firing, and 103.5 tons/yr.

Applicable Compliance Method:

Initial compliance with the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific PE emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III.

c. Emission Limitations:

SO<sub>2</sub> emissions shall not exceed 11.2 lbs/hr without duct burner firing, 14.5 lbs/hr with duct burner firing, and 56.5 tons/yr.

Applicable Compliance Method:

Compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied SO<sub>2</sub> emission factor (0.0057 lb SO<sub>2</sub>/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall

Duke

PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

d. Emission Limitations:

VOC emissions shall not exceed 3.0 lbs/hr without duct burner firing, 19.6 lbs/hr with duct burner firing, and 63.1 tons/yr, which includes 12.6 tons/yr for start-ups and shutdowns.

**Issued: To be entered upon final issuance**Applicable Compliance Method:

Initial compliance with the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific VOC emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

e. Emission Limitations:

CO emissions shall not exceed 10 ppmvd at 15% oxygen without duct burner firing, 14 ppmvd at 15% oxygen with duct burner firing, 43.0 lbs/hr without duct burner firing, 78.0 lbs/hr with duct burner firing, and 453.7 tons/yr, which includes 186.6 tons/yr for start-ups and shutdowns.

Applicable Compliance Method:

Initial compliance with the allowable outlet concentrations and the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with these emission limitations shall be demonstrated based upon the continuous CO and oxygen monitoring systems data required pursuant to section A.III. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

f. Emission Limitations:

NH<sub>3</sub> emissions shall not exceed 26.6 lbs/hr without duct burner firing, 34.6 lbs/hr with duct burner firing, and 134.5 tons/yr.

Applicable Compliance Method:

Compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied NH<sub>3</sub> emission factor (0.0136 lb NH<sub>3</sub>/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with U.S. EPA-approved methods.

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**g. Emission Limitations:

Formaldehyde emissions shall not exceed 0.8 lb/hr without duct burner firing, 0.82 lb/hr with duct burner firing, and 3.6 tons/yr.

Applicable Compliance Method:

Initial compliance with the lb/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lb/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific formaldehyde emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III.

h. Emission Limitations:

Sulfuric acid emissions shall not exceed 1.7 lbs/hr without duct burner firing, 2.2 lbs/hr with duct burner firing, and 8.6 tons/yr.

Applicable Compliance Method:

Compliance with the lb/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied sulfuric acid emission factor (0.0009 lb sulfuric acid/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with U.S. EPA-approved methods.

i. Emission Limitations:

Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.

Applicable Compliance Method:

Compliance with this emission limitation shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9.

Duke

PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

**VI. Miscellaneous Requirements**

1. In accordance with good engineering practices, the SCR unit on this emissions unit shall be installed, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee. The permittee shall maintain on site a copy of the operation and maintenance manual, as provided by the manufacturer.
  
2. The terms and conditions for this emissions unit supercede those contained in PTI 06-06167 issued January 18, 2001.

Duke  
PTI A

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

**B. State Only Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P001 - 170 MW GE 7FA natural gas-fired dry low NO <sub>x</sub> (DLN) combustion turbine with duct firing operating in combined cycle mode controlled by Selective Catalytic Reduction (SCR)	None	None

**2. Additional Terms and Conditions**

2.a None

**II. Operational Restrictions**

None

**III. Monitoring and/or Recordkeeping Requirements**

1. The permit to install for this emissions unit (P001) was evaluated based on actual materials (typically coatings and clean up materials) and the design parameters of the emissions unit's exhaust system, as specified by the permittee in the air permit to install application. The Ohio EPA's "Review of New Sources of Air Toxic Emissions" policy ("Air Toxic Policy") was applied for each pollutant emitted by this emissions unit using data from the permit to install application and the SCREEN 3.0 model (or other Ohio EPA approved model). The predicted 1-hour maximum ground-level concentration to the Maximum Acceptable Ground-Level Concentration (MAGLC). The following summarizes the results of the modeling:

Pollutant: Formaldehyde

Duke Energy Washington County LLC

PTI Application: 06-06702

Issued

Facility ID: 0684000212

Emissions Unit ID: P001

TLV (ug/m<sup>3</sup>): 273 (Converted from the STEL)  
 Maximum Hourly Emission Rate (lbs/hr): 1.64\*  
 Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 1.04  
 MAGLC (ug/m<sup>3</sup>): 6.5

Pollutant: Sulfuric Acid  
 TLV (ug/m<sup>3</sup>): 1000  
 Maximum Hourly Emission Rate (lbs/hr): 4.4\*  
 Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 4.07  
 MAGLC (ug/m<sup>3</sup>): 23.8

Pollutant: Ammonia  
 TLV (ug/m<sup>3</sup>): 17000  
 Maximum Hourly Emission Rate (lbs/hr): 69.2\*  
 Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 21.5  
 MAGLC (ug/m<sup>3</sup>): 404.8

\* This was modeled for emissions units P001 and P002 combined.

Physical changes to or changes in the method of operation of the emissions unit after its installation or modification could affect the parameters used to determine whether or not the "Air Toxic Policy" is satisfied. Consequently, prior to making a change that could impact such parameters, the permittee shall conduct an evaluation to determine that the "Air Toxic Policy" will still be still satisfied. If, upon evaluation, the permittee determines that the "Air Toxic Policy" will not be satisfied, the permittee will not make the change. Changes that can affect the parameters used in applying the "Air Toxic Policy" include the following:

- a. changes in the composition of the materials used, or the use of new materials, that would result in the emission of a compound with a lower Threshold Limit Value (TLV), as indicated in the most recent version of the handbook entitled "American Conference of Governmental Industrial Hygienists (ACGIH)," than the lowest TLV value specified in the above table;
  - b. changes in the composition of the materials, or use of new materials, that would result in an increase in emissions of any pollutant with a listed TLV that was proposed in the application and modeled; and
  - c. physical changes to the emissions unit or its exhaust parameters (e.g., increased/ decreased exhaust flow, changes in stack height, changes in stack diameter, etc.).
2. If the permittee determines that the "Air Toxic Policy" will be satisfied for the above changes, the Ohio EPA will not consider the change(s) to be a "modification" under OAC rule 3745-31-01(VV)(1)(a)(ii), and a modification of the existing permit to install will not be required. If the change(s) is (are) defined as a modification under other provisions of the modification

**Duke****PTI A**

Emissions Unit ID: P001

**Issued: To be entered upon final issuance**

definition (other than (VV)(1)(a)(ii)), then the permittee shall obtain a final permit to install prior to the change.

The permittee shall collect, record, and retain the following information when it conducts evaluations to determine that the changed emissions unit will still satisfy the "Air Toxic Policy":

- a. a description of the parameters changed (composition of materials, new pollutants emitted, change in stack/exhaust parameters, etc.);
- b. documentation of its evaluation and determination that the changed emissions unit still satisfies the "Air Toxic Policy"; and
- c. where computer modeling is performed, a copy of the resulting computer model runs that show the results of the application of the "Air Toxic Policy" for the change.

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None



3745-31-20

OAC Rule 3745-31-05  
(A)(3)

40 CFR Part 60, Subpart GG

40 CFR Part 60, Subpart Da

OAC rule 3745-18-06(F)

OAC rule 3745-17-11(B)(4)

OAC rule 3745-17-07(A)

OAC rule 3745-21-08(B)

OAC rule 3745-23-06(B)

OAC rules 3745-31-10 through  
3745-31-20

OAC rule 3745-31-05(A)(3)

Duke

PTI A

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

<u>Applicable Emissions Limitations/Control Measures</u>		
EMISSION LIMITATIONS WITHOUT DUCT BURNER FIRING	Formaldehyde emissions shall not exceed 0.8 lb/hr and 3.6 tons/yr.	DUCT BURNER FIRING (limited to 4,500 hours per year)
Nitrogen oxides (NO <sub>x</sub> ) emissions shall not exceed 3.5 ppmvd at 15% oxygen, 24.7 lbs/hr, and 157.5 tons/yr, including start-up and shutdown emissions.	Sulfuric acid emissions shall not exceed 1.7 lbs/hr and 8.6 tons/yr.	Nitrogen oxides (NO <sub>x</sub> ) emissions shall not exceed 3.5 ppmvd at 15% oxygen, 32.3 lbs/hr, and 157.5 tons/yr, including start-up and shutdown emissions.
Particulate emissions (PE) shall not exceed 19.0 lbs/hr and 103.5 tons/yr.	Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.  See A.II.1 below.  The requirements of this rule also include compliance with the requirements of 40 CFR Part 60, Subpart GG and OAC rules 3745-31-10 through 3745-31-20.	Particulate emissions (PE) shall not exceed 28.0 lbs/hr and 103.5 tons/yr.  Sulfur dioxide (SO <sub>2</sub> ) emissions shall not exceed 14.5 lbs/hr and 56.5 tons/yr.  Carbon monoxide (CO) emissions shall not exceed 14 ppmvd at 15% oxygen, 78.0 lbs/hr, and 453.7 tons/yr, including start-up and shutdown emissions.
Sulfur dioxide (SO <sub>2</sub> ) emissions shall not exceed 11.2 lbs/hr and 56.5 tons/yr.	See A.I.2.b below.  See A.I.2.a below.	Volatile organic compounds (VOC) emissions shall not exceed 19.6 lbs/hr and 63.1 tons/yr, including start-up and shutdown emissions.
Carbon monoxide (CO) emissions shall not exceed 10 ppmvd at 15% oxygen, 43.0 lbs/hr, and 453.7 tons/yr, including start-up and shutdown emissions.	See A.I.2.d below.  NO <sub>x</sub> emissions shall not exceed 157.5 tons per rolling, 12-month period.	Ammonia (NH <sub>3</sub> ) emissions shall not exceed 34.6 lbs/hr and 134.5 tons/yr.  Formaldehyde emissions shall not exceed 0.82 lb/hr and 3.6 tons/yr.
Volatile organic compounds (VOC) emissions shall not exceed 3.0 lbs/hr and 63.1 tons/yr, including start-up and shutdown emissions.	SO <sub>2</sub> emissions shall not exceed 56.5 tons per rolling, 12-month period. PE emissions shall not exceed 103.5 tons per rolling, 12-month period. CO emissions shall not exceed 453.7 tons per rolling, 12-month period.	Sulfuric acid emissions shall not exceed 2.2 lbs/hr and 8.6 tons/yr.  Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.
Ammonia (NH <sub>3</sub> ) emissions shall not exceed 26.6 lbs/hr and 134.5 tons/yr.	VOC emissions shall not exceed 63.1 tons per rolling, 12-month period.	See A.II.1 and A.II.3 below.
	EMISSION LIMITATIONS WITH	The requirements of this rule also include

Duke

PTI A

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

compliance with the requirements of 40 CFR Part 60, Subparts Da and GG, and OAC rules 3745-31-10 through 3745-31-20.

See A.I.2.b below.

See A.I.2.a below.

See A.I.2.d below.

NO<sub>x</sub> emissions shall not exceed 157.5 tons per rolling, 12-month period.

SO<sub>2</sub> emissions shall not exceed 56.5 tons per rolling, 12-month period.

PE emissions shall not exceed 103.5 tons per rolling, 12-month period.

CO emissions shall not exceed 453.7 tons per rolling, 12-month period.

VOC emissions shall not exceed 63.1 tons per rolling, 12-month period.

START-UP AND SHUTDOWN EMISSION LIMITATIONS (See A.II.2 below.)

Nitrogen oxides (NO<sub>x</sub>) emissions shall not exceed 248 lbs/cycle and 32.2 tons/yr.

Carbon monoxide (CO) emissions shall not exceed 1436 lbs/cycle and 186.6 tons/yr.

Volatile organic compounds (VOC) emissions shall not exceed 97 lbs/cycle and 12.6 tons/yr.

**Issued: To be entered upon final issuance****2. Additional Terms and Conditions**

- 2.a** The emission limitations specified in these applicable rules are equivalent to or less stringent than the emission limitations established pursuant to OAC rule 3745-31-05(A)(3).
- 2.b** The emission limitations specified in this applicable rule are equivalent to or less stringent than the emission limitations established pursuant to OAC rule 3745-31-05(A)(3). Except as provided for in the terms and conditions in this permit, the permittee is not exempt from meeting any additional requirements of 40 CFR Part 60, Subpart GG.
- 2.c** If the permittee is subject to the requirements of OAC Chapter 103 and 40 CFR Parts 72 and 75 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

Emissions Unit ID: P002

- 2.d** The permittee has satisfied the "best available control techniques and operating practices" required pursuant to OAC rule 3745-21-08(B) and the "latest available control techniques and operating practices" required pursuant to OAC rule 3745-23-06(B) by committing to comply with the best available technology requirements established pursuant to OAC rule 3745-31-05(A)(3) in this Permit to Install.

## II. Operational Restrictions

- The permittee shall burn only natural gas in this emissions unit. The maximum sulfur content of the natural gas shall not exceed 2 grains per 100 standard cubic feet.
- Start-up shall be defined as the period between when the combined cycle systems are initially started until the combustion turbine achieves combustion operational Mode 6. Shutdown shall be defined as the period beginning when the combustion turbine leaves operational Mode 6 and ending when combustion has ceased. Mode 6 is defined by the manufacturer as the low emissions mode during which all 6 of the burner nozzles are in use, burning a lean premixed gas for steady-state operation (i.e., in compliance with the NO<sub>x</sub> and CO lbs/hr emission limitations listed in term A.I.1.). The continuous emission monitoring system will indicate and record the combustion turbine operational mode, including when the emissions unit is shutdown and when operating in start-up and shutdown modes, and will be used to demonstrate compliance with the NO<sub>x</sub> and CO emission limitations during steady-state operation (Mode 6).

Start-ups shall not exceed 250 minutes in duration and shutdowns shall not exceed 2 hours in duration. The total of all start-ups and shutdowns shall be limited to 260 cycles (each cycle consists of one start-up and one shutdown) per year.

Each cycle shall be limited to the following:

<u>Pollutant</u>	<u>Total lbs/Cycle</u>
NO <sub>x</sub>	248
CO	1436
VOC	97

- The maximum annual hours of operation of the duct burner for this emissions unit shall not exceed 4,500 hours, based upon a rolling, 12-month summation.

To ensure enforceability during the first 12 calendar months following the start-up of the emissions unit, the permittee shall not exceed the monthly cumulative hours of operation restrictions for the duct burner specified in the following table:

Duke

PTI A

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

Month	Cumulative hours of Operation
1	720
1-2	1,440
1-3	2,160
1-4	2,880
1-5	3,600
1-6	4,320
1-7	4,500
1-8	4,500
1-9	4,500
1-10	4,500
1-11	4,500
1-12	4,500

After the first 12 calendar months following the start-up of the emissions unit, compliance with the annual hours of operation restriction for the duct burner shall be based on a rolling, 12-month summation.

#### 4. Continuous NO<sub>x</sub> Monitoring System Certification

Prior to the installation of the continuous NO<sub>x</sub> monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 2 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and 40 CFR Part 75. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to

Emissions Unit ID: P002

the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office. Certification of the continuous NO<sub>x</sub> monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 2, and 40 CFR Part 75.

5. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous NO<sub>x</sub> monitoring system designed to ensure continuous valid and representative readings of NO<sub>x</sub> emissions in units of the applicable standard. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B. The quality assurance/quality control plan and a logbook dedicated to the continuous NO<sub>x</sub> monitoring system must be kept on site and available for inspection during regular office hours.
6. Continuous CO Monitoring System Certification

Prior to the installation of the continuous CO monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 4 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of the continuous CO monitoring system pursuant to ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office. Certification of the continuous CO monitoring system shall be granted upon determination by the Ohio EPA Central Office that the system meets all requirements of ORC section 3704.03(I) and 40 CFR Part 60, Appendix B, Performance Specification 4.

7. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous CO monitoring system designed to ensure continuous valid and representative readings of CO. The plan shall follow the requirements of 40 CFR Part 60, Appendix F. The quality assurance/quality control plan and a logbook dedicated to the continuous CO monitoring system must be kept on site and available for inspection during regular office hours.

8. Continuous O<sub>2</sub> Monitoring System Certification

Prior to the installation of the continuous O<sub>2</sub> monitoring system, the permittee shall submit information detailing the proposed location of the sampling site in accordance with the siting requirements in 40 CFR Part 60, Appendix B, Performance Specification 3 for approval by the Ohio EPA, Central Office.

Within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of such emissions unit, the permittee shall conduct certification tests of such equipment pursuant to the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 3, and 40 CFR Part 75. Personnel from the Ohio EPA, Southeast District Office shall be notified 30 days prior to initiation of the applicable tests and shall be permitted to examine equipment and witness the certification tests. In accordance with OAC rule 3745-15-04, all copies of the test results shall be submitted to the Ohio EPA, Southeast District Office within 30 days after the test is completed. Copies of the test results shall be sent to the Ohio EPA, Southeast District Office and the Ohio EPA, Central Office.

Certification of the continuous O<sub>2</sub> monitoring system shall be granted upon determination by the Ohio EPA, Central Office that the system meets all requirements of the appropriate sections of ORC section 3704.03(I), 40 CFR Part 60, Appendix B, Performance Specification 3, and 40 CFR Part 75.

9. Within 180 days of the effective date of this permit, the permittee shall develop a written quality assurance/quality control plan for the continuous O<sub>2</sub> monitoring system designed to ensure continuous valid and representative readings of O<sub>2</sub> emissions in units of the applicable standard. The plan shall follow the requirements of the appropriate sections of 40 CFR Part 60, Appendix F and 40 CFR Part 75, Appendix B. The quality assurance/quality control plan and a logbook dedicated to the continuous O<sub>2</sub> monitoring system must be kept on site and available for inspection during regular office hours.

### III. Monitoring and/or Recordkeeping Requirements

1. The permittee shall maintain monthly records of the following information for this emissions unit:
  - a. The natural gas usage rate, in standard cubic feet.
  - b. Hours of operation of the combustion turbine.
  - c. Hours of operation of the duct burner.
  - d. During the first 12 calendar months of operation, records of the cumulative operating hours of the duct burner.

Emissions Unit ID: P002

- e. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the operating hours of the duct burner.
  - f. Number of start-ups and the duration, in minutes, of each start-up.
  - g. Number of shutdowns, and the duration, in hours, of each shutdown.
  - h. The total number of start-up/shutdown cycles.
  - i. The NO<sub>x</sub>, CO, and VOC emissions, in pounds, for all start-up/shutdown cycles.
  - j. The total NO<sub>x</sub> emissions, in pounds, including start-up/shutdown emissions.
  - k. The total CO emissions, in pounds, including start-up/shutdown emissions.
  - l. The total VOC emissions, in pounds, including start-up/shutdown emissions.
  - m. The total SO<sub>2</sub>, PE, NH<sub>3</sub>, formaldehyde, and sulfuric acid emissions, in pounds.
  - n. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the NO<sub>x</sub> emissions, in tons, including start-up/shutdown emissions.
  - o. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the CO emissions, in tons, including start-up/shutdown emissions.
  - p. Beginning after the first 12 calendar months of operation, the rolling, 12-month summation of the VOC emissions, in tons, including start-up/shutdown emissions.
  - q. Beginning after the first 12 calendar months of operation, the rolling, 12-month summations of the SO<sub>2</sub> and PE emissions, in tons.
2. The permittee shall install, operate and maintain equipment to continuously monitor and record NO<sub>x</sub> emissions from this emissions unit in units of the applicable standard. Such continuous monitoring and recording equipment shall comply with the requirements of the appropriate sections specified in 40 CFR Part 60.13 and 40 CFR Part 75.  
  
The permittee shall maintain records of all data obtained by the continuous NO<sub>x</sub> monitoring system including, but not limited to, parts per million NO<sub>x</sub> on an instantaneous (one-minute) basis, emissions of NO<sub>x</sub> in units of the applicable standard in the appropriate averaging period (i.e., ppmvd at 15% oxygen and lbs/hr), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.
  3. The permittee shall install, operate and maintain equipment to continuously monitor and record CO emissions from this emissions unit in units of the applicable standard. Such continuous

60

**Duke**

**PTI A**

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 60.13 .

**Issued: To be entered upon final issuance**

The permittee shall maintain records of all data obtained by the continuous CO monitoring system including, but not limited to, parts per million CO on an instantaneous (one minute) basis, emissions of CO in units of the applicable standard in the appropriate averaging period (i.e., ppmvd at 15% oxygen and lbs/hr), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

4. The permittee shall install, operate and maintain equipment to continuously monitor and record O<sub>2</sub> emissions from this emissions unit in percent O<sub>2</sub>. Such continuous monitoring and recording equipment shall comply with the requirements in the appropriate sections specified in 40 CFR Part 60.13 and 40 CFR Part 75.

The permittee shall maintain records of all data obtained by the continuous O<sub>2</sub> monitoring system including, but not limited to, percent O<sub>2</sub> on an instantaneous (one-minute) basis, emissions of O<sub>2</sub> in units of the applicable standard in the appropriate averaging period (e.g., hourly, hourly rolling, 3-hour, daily, 30-day rolling, etc.), results of daily zero/span calibration checks, and magnitude of manual calibration adjustments.

5. The permittee shall install, operate and maintain equipment to continuously monitor and record the fuel flow to this emissions unit when the emissions unit is in operation. Such continuous monitoring and recording equipment shall comply with the requirements specified in 40 CFR Part 75. If the fuel flow monitoring and/or recording equipment is (are) not in service when the emissions unit is in operation, the permittee shall comply with the appropriate missing data procedures specified in 40 CFR Part 75.
6. The permittee shall monitor the sulfur content and gross calorific value of the fuel being fired in the combustion turbine and duct burner. Fuel sampling and analysis shall be conducted according to the procedures and at the frequency specified by 40 CFR Part 75, Appendix D, section 2.3.3.1.
7. The permittee shall determine the hourly heat input rate to the combustion turbine and duct burner from the fuel flow rate as determined in term A.III.5. and fuel gross calorific value as determined in term A.III.6. The heat input rate shall be calculated in accordance with the procedures in Section 5 of 40 CFR Part 75, Appendix F.
8. For each day during which the permittee burns a fuel other than natural gas, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit.

**IV. Reporting Requirements**

1. The permittee shall submit deviation (excursion) reports that identify each day when a fuel other than natural gas was burned in this emissions unit. Each report shall be submitted within 30 days after the deviation occurred.

62

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

2. The permittee shall submit quarterly deviation (excursion) reports that identify the following:
  - a. During the first 12 calendar months of operation, all exceedances of the cumulative duct burner operating hours limitations.
  - b. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month duct burner operating hours limitation.
  - c. Any record which shows that the sulfur content of the natural gas exceeded 2 grains per 100 standard cubic feet.
  - d. Any record which shows that the start-up duration exceeded 250 minutes.
  - e. Any record which shows that the shutdown duration exceeded 2 hours.
  - f. Any record which shows that the total number of start-up/shutdown cycles exceeded 260.
  - g. All exceedances of the NO<sub>x</sub>, CO, and/or VOC start-up/shutdown emission limitations during any cycle.
  - h. Beginning after the first 12 calendar months of operation, all exceedances of the rolling, 12-month NO<sub>x</sub>, CO, VOC, SO<sub>2</sub>, and/or PE emission limitations.

The quarterly deviation reports shall be submitted in accordance with General Term and Condition A.2.

3. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any), of all instances of NO<sub>x</sub> values in excess of the applicable limitations specified in the terms and conditions of this permit. These reports shall also contain the total NO<sub>x</sub> emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting any continuous NO<sub>x</sub> monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be

64

**Duke**

**PTI A**

**Issued: To be entered upon final issuance**  
included in the quarterly report.

Emissions Unit ID: P002

Emissions Unit ID: P002

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line also shall be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

4. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting the date, commencement and completion times, duration, magnitude, reason (if known), and corrective actions taken (if any) of all instances of CO values in excess of any applicable limitation(s) specified in the terms and conditions of this permit. These reports shall also contain the total CO emissions for the calendar quarter (in tons).

The permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting any continuous CO monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit and control equipment malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report.

If there are no excess emissions during the calendar quarter, the permittee shall submit a statement to that effect along with the date, time, reason, and corrective action(s) taken for each time period of monitoring system malfunction. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall also be included in the quarterly report. These quarterly excess emission reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

5. Pursuant to OAC rule 3745-15-04, ORC sections 3704.03(I) and 3704.031, and 40 CFR Parts 60.7 and 60.13(h), the permittee shall submit reports within 30 days following the end of each calendar quarter to the Ohio EPA, Southeast District Office documenting all instances of continuous O<sub>2</sub> monitoring system downtime while the emissions unit was on line (date, time, duration and reason) along with any corrective action(s) taken. The permittee shall provide the emissions unit operating time during the reporting period and the date, time, reason and corrective action(s) taken for each time period of emissions unit malfunctions. The total operating time of the emissions unit and the total operating time of the analyzer while the emissions unit was on line shall be included in the quarterly report. These quarterly reports shall be submitted by January 30, April 30, July 30, and October 30 of each year and shall address the data obtained during the previous calendar quarter.

**Issued: To be entered upon final issuance**

6. The permittee shall submit annual reports that specify the total NO<sub>x</sub>, CO, PE, SO<sub>2</sub>, VOC, NH<sub>3</sub>, formaldehyde, and sulfuric acid emissions from this emissions unit for the previous calendar year. The reports shall be submitted by January 31 of each year.
7. This emissions unit is subject to the applicable provisions of Subpart Da and GG of the New Source Performance Standards (NSPS) as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60. The application and enforcement of these standards are delegated to the Ohio EPA. The requirements of 40 CFR Part 60 are also federally enforceable.

Pursuant to 40 CFR Part 60.7, the permittee is hereby advised of the requirement to report the following at the appropriate times:

- a. construction date (no later than 30 days after such date);
- b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
- c. actual start-up date (within 15 days after such date); and,
- d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency  
DAPC - Permit Management Unit  
P. O. Box 163669  
Columbus, Ohio 43216-3669

and

Ohio Environmental Protection Agency  
Southeast District Office  
Division of Air Pollution Control  
2195 Front Street  
Logan, Ohio 43138

**V. Testing Requirements**

1. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:

Emissions Unit ID: P002

- a. The emission testing shall be conducted within 60 days after achieving the maximum production rate at which the emissions unit will be operated, but not later than 180 days after initial start-up of the emissions unit.
  - b. The emission testing shall be conducted to demonstrate compliance with the NO<sub>x</sub> and CO outlet concentrations, the mass emission limitations for NO<sub>x</sub>, CO, formaldehyde, VOC, and PE, and the visible particulate emission limitations.
  - c. The following test methods shall be employed to demonstrate compliance with the above emission limitations: for NO<sub>x</sub>, Method 20 of 40 CFR Part 60, Appendix A and the procedures required under 40 CFR Part 60.335; for PE, Method 5 of 40 CFR Part 60, Appendix A; for visible particulate emission limitations, Method 9, 40 CFR Part 60 Appendix A; for formaldehyde, SW-846 Method 0011; for VOC, Method 25 of 40 CFR Part 60, Appendix A; and for CO, Method 10 of 40 CFR Part 60, Appendix A. Alternative U.S. EPA approved test methods may be used with prior approval from the Ohio EPA.
  - d. The testing shall be conducted while the emissions unit is operating at or near its maximum capacity with and without the duct burner firing, unless otherwise specified or approved by the Ohio EPA or local air agency.
  - e. Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Ohio EPA, Southeast District Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Ohio EPA, Southeast District Office refusal to accept the results of the emission test(s).
  - f. Personnel from the Ohio EPA, Southeast District Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.
  - g. A comprehensive written report on the results of the emission test(s) shall be signed by the person or persons responsible for the tests and submitted to the Ohio EPA, Southeast District Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Ohio EPA, Southeast District Office.
2. Compliance with the allowable emission limitations in this permit shall be determined according to the following methods:
    - a. Emission Limitations:

**Issued: To be entered upon final issuance**

NO<sub>x</sub> emissions shall not exceed 3.5 ppmvd at 15% oxygen, 24.7 lbs/hr without duct burner firing, 32.3 lbs/hr with duct burner firing, and 157.5 tons/yr, which includes 32.2 tons/yr for start-ups and shutdowns.

Applicable Compliance Method:

Initial compliance with the allowable outlet concentration and the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with these emission limitations shall be demonstrated based upon the continuous NO<sub>x</sub> and oxygen monitoring systems data required pursuant to section A.III. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

b. Emission Limitations:

PE emissions shall not exceed 19.0 lbs/hr without duct burner firing, 28.0 lbs/hr with duct burner firing, and 103.5 tons/yr.

Applicable Compliance Method:

Initial compliance with the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific PE emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III.

c. Emission Limitations:

SO<sub>2</sub> emissions shall not exceed 11.2 lbs/hr without duct burner firing, 14.5 lbs/hr with duct burner firing, and 56.5 tons/yr.

Applicable Compliance Method:

Compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied SO<sub>2</sub> emission factor (0.0057 lb SO<sub>2</sub>/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P002

demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with 40 CFR Part 60, Appendix A, Methods 1 through 4 and 6.

d. Emission Limitations:

VOC emissions shall not exceed 3.0 lbs/hr without duct burner firing, 19.6 lbs/hr with duct burner firing, and 63.1 tons/yr, which includes 12.6 tons/yr for start-ups and shutdowns.

**Issued: To be entered upon final issuance**Applicable Compliance Method:

Initial compliance with the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific VOC emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

e. Emission Limitations:

CO emissions shall not exceed 10 ppmvd at 15% oxygen without duct burner firing, 14 ppmvd at 15% oxygen with duct burner firing, 43.0 lbs/hr without duct burner firing, 78.0 lbs/hr with duct burner firing, and 453.7 tons/yr, which includes 186.6 tons/yr for start-ups and shutdowns.

Applicable Compliance Method:

Initial compliance with the allowable outlet concentrations and the lbs/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with these emission limitations shall be demonstrated based upon the continuous CO and oxygen monitoring systems data required pursuant to section A.III. Compliance with the tons/yr emission limitation, including start-up and shutdown emissions, shall be demonstrated based upon the records required pursuant to section A.III.

f. Emission Limitations:

NH<sub>3</sub> emissions shall not exceed 26.6 lbs/hr without duct burner firing, 34.6 lbs/hr with duct burner firing, and 134.5 tons/yr.

Applicable Compliance Method:

Compliance with the lbs/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied NH<sub>3</sub> emission factor (0.0136 lb NH<sub>3</sub>/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with U.S. EPA-approved methods.

71

**Duke**

**PTI A**

**Issued: To be entered upon final issuance**

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**g. Emission Limitations:

Formaldehyde emissions shall not exceed 0.8 lb/hr without duct burner firing, 0.82 lb/hr with duct burner firing, and 3.6 tons/yr.

Applicable Compliance Method:

Initial compliance with the lb/hr emission limitations shall be demonstrated through emission testing performed in accordance with section A.V.1. Ongoing compliance with the lb/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the emissions unit-specific formaldehyde emission factors established during the emission testing that demonstrated that the emissions unit was in compliance. Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III.

h. Emission Limitations:

Sulfuric acid emissions shall not exceed 1.7 lbs/hr without duct burner firing, 2.2 lbs/hr with duct burner firing, and 8.6 tons/yr.

Applicable Compliance Method:

Compliance with the lb/hr emission limitations may be demonstrated through the records required pursuant to section A.III and the permittee-supplied sulfuric acid emission factor (0.0009 lb sulfuric acid/MMBtu). Compliance with the tons/yr emission limitation shall be demonstrated based upon the records required pursuant to section A.III. If required, the permittee shall demonstrate compliance with the hourly emission limitations through emission tests performed in accordance with U.S. EPA-approved methods.

i. Emission Limitations:

Visible particulate emissions from any stack shall not exceed 10% opacity as a 6-minute average.

Applicable Compliance Method:

Compliance with this emission limitation shall be determined through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9.

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P002

## **VI. Miscellaneous Requirements**

1. In accordance with good engineering practices, the SCR unit on this emissions unit shall be installed, operated and maintained in accordance with the manufacturer's recommendations, with any modifications deemed necessary by the permittee. The permittee shall maintain on site a copy of the operation and maintenance manual, as provided by the manufacturer.
2. The terms and conditions for this emissions unit supercede those contained in PTI 06-06167 issued January 18, 2001.

Duke  
PTI A

Emissions Unit ID: P002

**Issued: To be entered upon final issuance**

**B. State Only Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P002 - 170 MW GE 7FA natural gas-fired dry low NO <sub>x</sub> (DLN) combustion turbine with duct firing operating in combined cycle mode controlled by Selective Catalytic Reduction (SCR)	None	None

**2. Additional Terms and Conditions**

2.a None

**II. Operational Restrictions**

None

**III. Monitoring and/or Recordkeeping Requirements**

1. The permit to install for this emissions unit (P002) was evaluated based on actual materials (typically coatings and clean up materials) and the design parameters of the emissions unit's exhaust system, as specified by the permittee in the air permit to install application. The Ohio EPA's "Review of New Sources of Air Toxic Emissions" policy ("Air Toxic Policy") was applied for each pollutant emitted by this emissions unit using data from the permit to install application and the SCREEN 3.0 model (or other Ohio EPA approved model). The predicted 1-hour maximum ground-level concentration to the Maximum Acceptable Ground-Level Concentration (MAGLC). The following summarizes the results of the modeling:

Pollutant: Formaldehyde

**Issued: To be entered upon final issuance**

TLV (ug/m<sup>3</sup>): 273 (Converted from the STEL)  
Maximum Hourly Emission Rate (lbs/hr): 1.64\*  
Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 1.04  
MAGLC (ug/m<sup>3</sup>): 6.5

Pollutant: Sulfuric Acid  
TLV (ug/m<sup>3</sup>): 1000  
Maximum Hourly Emission Rate (lbs/hr): 4.4\*  
Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 4.07  
MAGLC (ug/m<sup>3</sup>): 23.8

Pollutant: Ammonia  
TLV (ug/m<sup>3</sup>): 17000  
Maximum Hourly Emission Rate (lbs/hr): 69.2\*  
Predicted 1-Hour Maximum Ground-Level Concentration (ug/m<sup>3</sup>): 21.5  
MAGLC (ug/m<sup>3</sup>): 404.8

\* This was modeled for emissions units P001 and P002 combined.

Physical changes to or changes in the method of operation of the emissions unit after its installation or modification could affect the parameters used to determine whether or not the "Air Toxic Policy" is satisfied. Consequently, prior to making a change that could impact such parameters, the permittee shall conduct an evaluation to determine that the "Air Toxic Policy" will still be still satisfied. If, upon evaluation, the permittee determines that the "Air Toxic Policy" will not be satisfied, the permittee will not make the change. Changes that can affect the parameters used in applying the "Air Toxic Policy" include the following:

- a. changes in the composition of the materials used, or the use of new materials, that would result in the emission of a compound with a lower Threshold Limit Value (TLV), as indicated in the most recent version of the handbook entitled "American Conference of Governmental Industrial Hygienists (ACGIH)," than the lowest TLV value specified in the above table;
  - b. changes in the composition of the materials, or use of new materials, that would result in an increase in emissions of any pollutant with a listed TLV that was proposed in the application and modeled; and
  - c. physical changes to the emissions unit or its exhaust parameters (e.g., increased/ decreased exhaust flow, changes in stack height, changes in stack diameter, etc.).
2. If the permittee determines that the "Air Toxic Policy" will be satisfied for the above changes, the

**Duke Energy Washington County LLC**

PTI Application: 06-06702

**Issued****Facility ID: 0684000212**

Emissions Unit ID: P002

Ohio EPA will not consider the change(s) to be a "modification" under OAC rule 3745-31-01(VV)(1)(a)(ii), and a modification of the existing permit to install will not be required. If the change(s) is (are) defined as a modification under other provisions of the modification definition (other than (VV)(1)(a)(ii)), then the permittee shall obtain a final permit to install prior to the change.

The permittee shall collect, record, and retain the following information when it conducts evaluations to determine that the changed emissions unit will still satisfy the "Air Toxic Policy":

- a. a description of the parameters changed (composition of materials, new pollutants emitted, change in stack/exhaust parameters, etc.);
- b. documentation of its evaluation and determination that the changed emissions unit still satisfies the "Air Toxic Policy"; and
- c. where computer modeling is performed, a copy of the resulting computer model runs that show the results of the application of the "Air Toxic Policy" for the change.

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None

Duke

PTI A

Emissions Unit ID: P003

**Issued: To be entered upon final issuance****Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)****A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P003 - 7 Cell Mechanical Draft Cooling Tower	OAC rule 3745-31-05(A)(3)	Particulate emissions (PE) shall not exceed 2.08 lbs/hr and 9.1 tons/yr.  See A.II.1. below.
	OAC rule 3745-17-07(A)	The requirements of this rule also include compliance with the requirements of OAC rules 3745-17-07(A) and 3745-31-10 through 3745-31-20.  Visible particulate emissions shall not exceed 20 percent opacity as a 6-minute average, except as provided by rule.
	OAC rules 3745-31-10 through 3745-31-20	PE emissions shall not exceed 9.1 tons per rolling, 12-month period.

**2. Additional Terms and Conditions**

- 2.a The emission limitation based on this applicable rule is less stringent than the limitation established pursuant to OAC rule 3745-31-05(A)(3).

**II. Operational Restrictions**

Duke

PTI A

Emissions Unit ID: P003

**Issued: To be entered upon final issuance**

1. The permittee shall maintain an average total dissolved solids (TDS) content of 3,000 ppm or less in the circulating cooling water.

**Issued: To be entered upon final issuance****III. Monitoring and/or Recordkeeping Requirements**

1. The permittee shall monitor the TDS content of the circulating cooling water on a monthly basis.
2. The permittee shall maintain monthly records of the following information for this emissions unit:
  - a. The monthly TDS content of the circulating cooling water, in ppm.
  - b. Beginning after the first 12 calendar months of operation, the rolling, 12-month average TDS content of the circulating cooling water, in ppm.

**IV. Reporting Requirements**

1. The permittee shall submit deviation reports in accordance with the general terms and conditions of this permit that identify any exceedances of the average TDS content limitation.

**V. Testing Requirements**

1. Compliance with the allowable emission limitations in this permit shall be determined according to the following methods:

- a. Emission Limitations:

Particulate emissions (PE) shall not exceed 2.08 lbs/hr and 9.1 tons/yr.

Applicable Compliance Method:

Compliance with the lbs/hr emission limitation shall be demonstrated by multiplying the drift loss factor supplied by the permittee (66.7 lbs/million gallons water flow based on 0.0008 percent drift) by the maximum circulating water flow rate (10.38 million gallons per hour) and by the average total dissolved solids content (ppm) of the cooling water and dividing by 1,000,000 (ppm). Compliance with the annual emission limitation shall be determined by multiplying the hourly emission rate by 8,760 hours and dividing by 2,000 lbs/ton.

If required, the permittee shall submit a testing proposal which will demonstrate that the maximum drift loss does not exceed 0.0008 percent.

- b. Emission Limitation:

Visible particulate emissions shall not exceed 20% opacity as a 6-minute average, except

80

**Duke Energy Washington County LLC**

**PTI Application: 06-06702**

**Issued**

**Facility ID: 0684000212**

Emissions Unit ID: P003

as provided by rule.

81

Duke

PTI A

Emissions Unit ID: P003

**Issued: To be entered upon final issuance**

Applicable Compliance Method:

If required, compliance with this emission limitation shall be demonstrated through visible emissions observations performed in accordance with 40 CFR Part 60, Appendix A, Method 9.

**VI. Miscellaneous Requirements**

None

**Issued: To be entered upon final issuance**

**B. State Only Enforceable Section**

**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

<u>Operations, Property, and/or Equipment</u>	<u>Applicable Rules/Requirements</u>	<u>Applicable Emissions Limitations/Control Measures</u>
P003 - 7 Cell Mechanical Draft Cooling Tower	None	None

**2. Additional Terms and Conditions**

- 2.a None

**II. Operational Restrictions**

None

**III. Monitoring and/or Recordkeeping Requirements**

None

**IV. Reporting Requirements**

None

**V. Testing Requirements**

None

**VI. Miscellaneous Requirements**

None