



State of Ohio Environmental Protection Agency

Street Address:
122 S. Front Street

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:
Lazarus Gov. Center
P.O. Box 1049

CERTIFIED MAIL

RE: PERMIT TO INSTALL *CORRECTED COPY 7/24/2007***
ADAMS COUNTY
Application No:07-00583**

DATE: 7/24/2007

Killen Station
David Orme
1065 Woodman Drive
Dayton, OH 45144

Attached please find a corrected copy of PTI 07-00583 issued **6/21/2007**. This corrected copy is being sent due to administrative processing errors and does not affect the enforceability or effective date of the Directors final action. Please note, the appearance of the corrected document may have changed due to changing software or printers (e.g., total number of pages, margins, etc.). Areas of the permit that have been substantively affected by the correction(s) are highlighted in the enclosed "Corrected Copy". I urge you to review these areas in relation to the issued permit document. Please replace the copy provided to you on **6/21/2007** with the attached corrected Permit To Install document. *Please note:* No payment is required for processing this corrected copy.

Very truly yours,

Michael W. Ahern, Supervisor
Field Operations and Permit Section
Division of Air Pollution Control

cc:



State of Ohio Environmental Protection Agency

**RE: FINAL PERMIT TO INSTALL
ADAMS COUNTY**

CERTIFIED MAIL

Street Address:

50 West Town Street, Suite 700

Lazarus Gov. Center TELE: (614) 644-3020 FAX: (614) 644-2329

Mailing Address:

Lazarus Gov. Center
P.O. Box 1049

Application No: 07-00583

Fac ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

DATE: 6/21/2007

Killen Station
JoAnne Rau
1065 Woodman Drive
Dayton, OH 45432

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions, I urge you to read it carefully.

The Ohio EPA is urging companies to investigate pollution prevention and energy conservation. Not only will this reduce pollution and energy consumption, but it can also save you money. If you would like to learn ways you can save money while protecting the environment, please contact our Office of Pollution Prevention at (614) 644-3469.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission
309 South Fourth Street, Room 222
Columbus, OH 43215

Sincerely,

Michael W. Ahern, Manager
Permit Issuance and Data Management Section
Division of Air Pollution Control

CC: USEPA

PCHD



STATE OF OHIO ENVIRONMENTAL PROTECTION AGENCY

**Permit To Install
Terms and Conditions**

**Issue Date: 6/21/2007
Effective Date: 6/21/2007**

**FINAL PERMIT TO INSTALL 07-00583
CORRECTED COPY 7/24/2007**

Application Number: 07-00583
Facility ID: 0701000060
Permit Fee: **\$200**
Name of Facility: Killen Station
Person to Contact: JoAnne Rau
Address: 1065 Woodman Drive
Dayton, OH 45432

Location of proposed air contaminant source(s) [emissions unit(s)]:
**14869 US Highway 52
Manchester, Ohio**

Description of proposed emissions unit(s):
Modification to the expand the material handling gypsum storage area an additional 11.4 acres.

The above named entity is hereby granted a Permit to Install for the above described emissions unit(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Chris Korleski
Director

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

CORRECTED COPY 7/24/2007

Part I - GENERAL TERMS AND CONDITIONS

A. State and Federally Enforceable Permit-To-Install General Terms and Conditions

1. Monitoring and Related Recordkeeping and Reporting Requirements

- a. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:
 - i. The date, place (as defined in the permit), and time of sampling or measurements.
 - ii. The date(s) analyses were performed.
 - iii. The company or entity that performed the analyses.
 - iv. The analytical techniques or methods used.
 - v. The results of such analyses.
 - vi. The operating conditions existing at the time of sampling or measurement.
- b. Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to, all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.
- c. Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:
 - i. Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
 - ii. Quarterly written reports of (i) any deviations from federally enforceable emission limitations, operational restrictions, and control device operating parameter limitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the appropriate Ohio EPA District Office or local air agency. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

previous calendar quarters. See B.9 below if no deviations occurred during the quarter.

- iii. Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, and reporting requirements contained in this permit shall be submitted (i.e., postmarked) to the appropriate Ohio EPA District Office or local air agency every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.
 - iv. If this permit is for an emissions unit located at a Title V facility, then each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
- d. The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

2. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the appropriate Ohio EPA District Office or local air agency in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

3. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

4. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

5. Severability Clause

A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

6. General Requirements

- a. The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification
- b. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.
- c. This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.
- d. This permit does not convey any property rights of any sort, or any exclusive privilege.
- e. The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

7. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

8. Federal and State Enforceability

Only those terms and conditions designated in this permit as federally enforceable, that are required under the Act, or any its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. All other terms and conditions of this permit shall not be federally enforceable and shall be enforceable under State law only.

9. Compliance Requirements

- a. Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.
- b. Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:
 - i. At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.
 - ii. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.
 - iii. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
 - iv. As authorized by the Act, sample or monitor at reasonable times substances or

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

parameters for the purpose of assuring compliance with the permit and applicable requirements.

- c. The permittee shall submit progress reports to the appropriate Ohio EPA District Office or local air agency concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually, or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:
 - i. Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.
 - ii. An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

10. Permit-To-Operate Application

- a. If the permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77, the permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).
- b. If the permittee is required to apply for permit(s) pursuant to OAC Chapter 3745-35, the source(s) identified in this permit is (are) permitted to operate for a period of up to one year from the date the source(s) commenced operation. Permission to operate is granted only if the facility complies with all requirements contained in this permit and all applicable air pollution laws, regulations, and policies. Pursuant to OAC Chapter 3745-35, the permittee shall submit a complete operating permit application within ninety (90) days after commencing operation of the source(s) covered by this permit.

11. Best Available Technology

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

12. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9

Killen Station

PTI Application: 07-00583

Issued: 6/21/2007

Facility ID:

0701000060

*****CORRECTED COPY 7/24/2007*****

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

13. Permit-To-Install

A permit-to-install must be obtained pursuant to OAC Chapter 3745-31 prior to "installation" of "any air contaminant source" as defined in OAC rule 3745-31-01, or "modification", as defined in OAC rule 3745-31-01, of any emissions unit included in this permit.

B. State Only Enforceable Permit-To-Install General Terms and Conditions

1. Compliance Requirements

The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

2. Reporting Requirements

The permittee shall submit required reports in the following manner:

- a. Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the appropriate Ohio EPA District Office or local air agency.
- b. Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the appropriate Ohio EPA District Office or local air agency. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

3. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The appropriate Ohio EPA District Office or local air agency must be notified in writing of any transfer of this permit.

11

Killen Station

PTI Application: 07-00583

Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

4. Authorization To Install or Modify

If applicable, authorization to install or modify any new or existing emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or modification or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation or modification. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

5. Construction of New Sources(s)

This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

6. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

7. Applicability

This Permit to Install is applicable only to the emissions unit(s) identified in the Permit To Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

8. Construction Compliance Certification

If applicable, the applicant shall provide Ohio EPA with a written certification (see enclosed form if applicable) that the facility has been constructed in accordance with the permit-to-install

Killen Station
PTI Application: 07-00583
Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

application and the terms and conditions of the permit-to-install. The certification shall be provided to Ohio EPA upon completion of construction but prior to startup of the source.

9. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations (See Section A of This Permit)

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

C. Permit-To-Install Summary of Allowable Emissions

The following information summarizes the total allowable emissions, by pollutant, based on the individual allowable emissions of each contaminant source identified in this permit.

**SUMMARY (for informational purposes only)
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS**

<u>Pollutant</u>	<u>Tons Per Year</u>
PE	20.40
PM10	10.64

Killen Station

PTI Application: 07-00583

Issued: 6/21/2007

Facility ID: 0701000060

*****CORRECTED COPY 7/24/2007*****

Part II - FACILITY SPECIFIC TERMS AND CONDITIONS

A. State and Federally Enforceable Permit To Install Facility Specific Terms and Conditions

None

B. State Only Enforceable Permit To Install Facility Specific Terms and Conditions

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)

A. State and Federally Enforceable Section

I. Applicable Emissions Limitations and/or Control Requirements

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F001) - flue gas desulfurization (FGD) material handling, transfer, conveying, silos, and wet ball mills - Limestone and gypsum handling system ; The terms and conditions identified in this permit supercede those identified in PTI 07-00559 date 01/12/2006.

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
<p>OAC rule 3745-31-05(A)(3)</p>	<p>PE from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 3.04 pounds per hour.</p> <p>PM₁₀ from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 1.42 pounds per hour.</p> <p>PE from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 13.31 tons per year.</p> <p>PM₁₀ from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 6.26 tons per year.</p> <p>The permittee shall implement best available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.I.2.b through A.I.2.d).</p> <p>See Sections A.I.2.a. through A.I.2.e.</p> <p>The requirements of this rule also include compliance with the requirements of 40 CFR 60.672.</p>

Emissions Unit ID: F001

<p>40 CFR 60.672 (NSPS Subpart OOO)</p>	<p>No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affected facility any stack emission which contains particulate matter in excess of 0.022 gr/dscf.</p> <p>No owner or operator shall cause to be discharged into the atmosphere from any baghouse that controls emissions from only an individual, enclosed storage bin, stack emissions which exhibit greater than 7 percent opacity.</p> <p>No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affected facility any fugitive emissions which exhibit greater than 10 percent opacity.</p> <p>See Section A.I.2.f. and A.I.2.g.</p>
---	---

2. Additional Terms and Conditions

2.a The material handling operation(s) that are covered by this permit and subject to the above-mentioned requirements are listed below:

Limestone handling system, from the barge unloading through the handling process, limestone silos, wet ball mills and screens, as described in the PTI 07-00559 application received on August 10th, 2005.

Gypsum handling system, from reclaim hopper, through the handling process, shuttle conveyor, and barge loading process, as described in the PTI 07-00559 application received on August 10th, 2005.

2.b The permittee shall employ best available control measures for the above-identified material handling operation(s) for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to perform the following control measure(s) to ensure compliance:

<u>material handling operation(s)</u>	<u>control measure(s)</u>
Limestone handling system	a combination of precautionary measures, partial enclosure of conveyor, telescoping chute, and fabric filter;
Gypsum handling system	a combination of precautionary

Emissions Unit ID: F001

measures, partial enclosure of conveyor, maintaining appropriate moisture content, and telescoping chute; and

Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.

- 2.c** For each material handling operation that is not adequately enclosed, the above-identified control measure(s) shall be implemented if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measure(s) is (are) necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measure(s) shall continue during the operation of the material handling operation(s) until further observation confirms that use of the control measure(s) is unnecessary.
- 2.d** Implementation of the above-mentioned control measure(s) in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-31-05.
- 2.e** The hourly emission limitations outlined in term A.I.1. for PE and PM₁₀ are based on the emissions unit's Potential to Emit. Therefore, no hourly records are required to demonstrate compliance with these limits.
- 2.f** The following equipment associated with F001 is subject to 40 CFR 60.672 subpart OOO: limestone reclaim feeder, limestone reclaim conveyor, silo feed conveyors, limestone storage silo bin vent filters, limestone feeders, and wet ball mills.
- 2.g** If any transfer point on a conveyor belt or any other affected facility is enclosed in a building, then each enclosed affect facility must comply with the emission limits in 60.672(a), (b), and (c), or the building enclosing the affected facility or facilities must comply with the following emission limits:
- a. No owner or operator shall cause to be discharged into the atmosphere from any building enclosing any transfer point on a conveyor belt or any other affected facility any visible fugitive emissions except emissions from a vent as defined in 60.671.
 - b. No owner or operator shall cause to be discharged into the atmosphere from any vent of any building enclosing any transfer point on a conveyor belt or any other affected facility emissions which exceed the stack emissions limits in 60.672(a).

II. Operational Restrictions

None

Emissions Unit ID: F001
*****CORRECTED COPY 7/24/2007*****

Issued: 6/21/2007

Issued: 6/21/2007

III. Monitoring and/or Recordkeeping Requirements

1. Except as otherwise provided in this section, for material handling operations that are not adequately enclosed, the permittee shall perform inspections of such operations in accordance with the following minimum frequencies:

<u>material handling operation(s)</u>	<u>minimum inspection frequency</u>
Limestone handling system	weekly
Gypsum handling system	weekly

2. The above-mentioned inspections shall be performed during representative, normal operating conditions.
3. The permittee shall maintain records of the following information:
 - a. the date and reason any required inspection was not performed;
 - b. the date of each inspection where it was determined by the permittee that it was necessary to implement the control measure(s):
 - c. the dates the control measure(s) was (were) implemented; and
 - d. on a calendar quarter basis, the total number of days the control measure(s) was (were) implemented.

The information in 3.d. shall be kept separately for each material handling operation identified above, and shall be updated on a calendar quarter basis within 30 days after the end of each calendar quarter.

IV. Reporting Requirements

1. The permittee shall submit deviation reports that identify any of the following occurrences:
 - a. each day during which an inspection was not performed by the required frequency; and
 - b. each instance when a control measure, that was to be performed as a result of an

Emissions Unit ID: F001

inspection, was not implemented.

2. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.
3. Pursuant to the NSPS, the source owner/operator is hereby advised of the requirement to report the following at the appropriate times:
 - a. construction date (no later than 30 days after such date);
 - b. anticipated start-up date (not more than 60 days or less than 30 days prior to such date);
 - c. actual start-up date (within 15 days after such date); and
 - d. date of performance testing (if required, at least 30 days prior to testing).

Reports are to be sent to:

Ohio Environmental Protection Agency
DAPC - Permit Management Unit
P. O. Box 163669
Columbus, Ohio 43216-3669

and

Portsmouth Local Air Agency
605 Washington Street I
Portsmouth, Ohio 45662

V. Testing Requirements

1. Compliance with the limitations contained in Section A.I. and II of these terms and conditions shall be determined in accordance with the following methods:
 - a. Emissions Limitations:

PE from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 3.04 pounds per hour.

Applicable Compliance Method:

The hourly emission limitations are based upon the emission unit's maximum potential to emit and the emissions data found in PTI 07-00559 submitted August 10th, 2005.

Issued: 6/21/2007

Emissions Unit ID: F001
CORRECTED COPY 7/24/2007

b. Emission Limitation:

PM₁₀ from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 1.42 pounds per hour.

Applicable Compliance Method:

The hourly emission limitations are based upon the emission unit's maximum potential to emit and the emissions data found in PTI 07-00559 submitted August 10th, 2005.

c. Emission Limitation:

PE from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 13.31 tons per year.

Applicable Compliance Method:

Compliance with the annual limitations shall be demonstrated by the emission factors,
and control efficiencies as submitted in PTI application 07-00559, received August 10th, 2005.

d. Emission Limitation:

PM₁₀ from the FGD material handling system, transfer, conveying, silos, wet ball mills and screens shall not exceed 6.26 tons per year.

Applicable Compliance Method:

Compliance with the annual limitations shall be demonstrated by the emission factors,
and control efficiencies as submitted in PTI application 07-00559, received August 10th, 2005.

e. Emission Limitation:

No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affected facility any stack emission which contains particulate matter in excess of 0.022 g/dscf.

Issued: 6/21/2007

Applicable Compliance Method:

In determining compliance with section 60.672(a) the owner or operator shall use Method 5 or Method 17 to determine the particulate matter concentration. The sample volume shall be at least 60 dscf. If Method 5 is used, the gas stream being sampled must be at ambient temperature, the sampling probe and filter may be operated without heaters. If the gas stream is above ambient temperature, the sampling probe and filter may be operated at temperature high enough, but no higher than 250 degree F to prevent water condensation on filter.

f. Emission Limitation:

No owner or operator shall cause to be discharged into the atmosphere from any baghouse that controls emissions from only an individual, enclosed storage bin, stack emissions which exhibit greater than 7 percent opacity

Emissions Unit ID: F001

Applicable Compliance Method:

In determining compliance with section 60.672(f) the owner or operator shall use procedures in 60.11 and Method 9. The duration of observations shall be 1 hour (ten 6-minute averages).

g. Emission Limitation:

No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affect facility any fugitive emissions which exhibit greater than 10 percent opacity.

Applicable Compliance Method:

In determining compliance with section 60.672(b) the owner or operator shall use procedures in 60.11 and Method 9. The duration of observations shall be 3 hours (thirty 6-minute averages). Observations may be reduced to 1 hour (ten 6-minute averages) only if there are no individual readings greater than 10 percent opacity and there are no more than 3 readings of 10 percent for the 1-hour period. The minimum distance between the observer and the emission source shall be 15 feet. The observer shall minimize interference from other fugitive emission sources. When a water mist from dust suppression is in use, the observation of emissions is to be made at a point in the plume where the mist is no longer visible.

2. Compliance with the emission limitation in Section A.I.2.g.a. of these terms and conditions shall be determined by using Method 22 to determine fugitive emissions. The performance test shall be conducted while all affected facilities inside the building are operating. The performance test for each building shall be at least 75 minutes in duration, with each side of the building and the roof being observed for at least 15 minutes.
3. The permittee shall conduct, or have conducted, emission testing for this emissions unit in accordance with the following requirements:
 - a. The emission testing shall be conducted within 180 days after the initial startup date.
 - b. The emission testing shall be conducted to demonstrate compliance with the allowable mass emission rate(s) for particulates.
 - c. The following test method(s) shall be employed to demonstrate compliance with the allowable mass emission rate(s): Methods 1 through 4, 5 or 17, and 9 for particulates.

Issued: 6/21/2007

- d. The test(s) shall be conducted while the emissions unit is operating at or near its maximum capacity, unless otherwise specified or approved by the appropriate Ohio EPA District Office or local air agency.

Not later than 30 days prior to the proposed test date(s), the permittee shall submit an "Intent to Test" notification to the Portsmouth Local Air Agency Office. The "Intent to Test" notification shall describe in detail the proposed test methods and procedures, the emissions unit operating parameters, the time(s) and date(s) of the test(s), and the person(s) who will be conducting the test(s). Failure to submit such notification for review and approval prior to the test(s) may result in the Portsmouth Local Air Agency Office's refusal to accept the results of the emission test(s).

Personnel from the Portsmouth Local Air Agency Office shall be permitted to witness the test(s), examine the testing equipment, and acquire data and information necessary to ensure that the operation of the emissions unit and the testing procedures provide a valid characterization of the emissions from the emissions unit and/or the performance of the control equipment.

A comprehensive written report on the results of the emissions test(s) shall be signed by the person or persons responsible for the tests and submitted to the Portsmouth Local Air Agency Office within 30 days following completion of the test(s). The permittee may request additional time for the submittal of the written report, where warranted, with prior approval from the Portsmouth Local Air Agency.

VI. Miscellaneous Requirements

None

Issued: 6/21/2007

B. State Only Enforceable Section**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F001) -flue gas desulfurization (FGD) material handling, transfer, conveying, silos, and wet ball mills - Limestone and gypsum handling system

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None

Part III - SPECIAL TERMS AND CONDITIONS FOR SPECIFIC EMISSIONS UNIT(S)**A. State and Federally Enforceable Section****I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F002) - Limestone and gypsum storage piles - load-in and load out of storage piles and wind erosion from storage piles; Chapter 31 modification to add one additional storage pile in the original location, plus an additional 11.4 acres of gypsum storage. The terms and conditions identified in this permit supercede those identified in PTI 07-00559 date 01/12/2006.

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
OAC rule 3745-31-05(A)(3)	<p>There shall be no visible particulate emissions except for one minute during any 60-minute period.</p> <p>The permittee shall implement best available control measures that are sufficient to minimize or eliminate visible emissions of fugitive dust (see Sections A.1.2.b through A.1.2.f).</p> <p>PE from the limestone and gypsum storage piles- load-in and load-out of storage piles and wind erosion from storage piles shall not exceed 7.09 tons per year.</p> <p>PM₁₀ from the limestone and gypsum storage piles- load-in and load-out of storage piles and wind erosion from storage piles shall not exceed 4.38 tons per year.</p> <p>See Section A.1.2.g.</p>

2. Additional Terms and Conditions

- 2.a The storage piles that are covered by this permit and subject to the above-mentioned requirements are listed below:

All limestone and gypsum storage piles

- 2.b The permittee shall employ best available control measures on all load-in and load-out operations associated with the storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with

Issued: 6/21/2007

the permittee's permit application, the permittee has committed to the use of a telescoping chute, maintaining material moisture content, and precautionary measures (reduce drop heights) to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.

- 2.c** The above-mentioned control measure(s) shall be employed for each load-in and load-out operation of each storage pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measure(s) are necessary to ensure compliance with the above-mentioned applicable requirements. Any required implementation of the control measure(s) shall continue during any such operation until further observation confirms that use of the measure(s) is unnecessary.
- 2.d** The permittee shall employ best available control measures for wind erosion from the surfaces of all storage piles for the purpose of ensuring compliance with the above-mentioned applicable requirements. In accordance with the permittee's permit application, the permittee has committed to precautionary measures including pile height control, reducing disturbed area, and maintaining moisture content to ensure compliance. Nothing in this paragraph shall prohibit the permittee from employing other control measures to ensure compliance.
- 2.e** The above-mentioned control measure(s) shall be employed for wind erosion from each pile if the permittee determines, as a result of the inspection conducted pursuant to the monitoring section of this permit, that the control measure(s) are necessary to ensure compliance with the above-mentioned applicable requirements. Implementation of the control measure(s) shall not be necessary for a storage pile that is covered with snow and/or ice or if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements.
- 2.f** Implementation of the above-mentioned control measures in accordance with the terms and conditions of this permit is appropriate and sufficient to satisfy the requirements of OAC rule 3745-31-05.
- 2.g** The annual emissions limitations for PE and PM₁₀ outlined are based upon the maximum production limitations established for the FGD material handling, transfer and conveying - Limestone and gypsum handling system.

II. Operational Restrictions

Killen Station

DTI Application: 07 00593

Facility ID:

0701000060

Emissions Unit ID: F002

None

III. Monitoring and/or Recordkeeping Requirements

1. Except as otherwise provided in this section, the permittee shall perform inspections of each load-in operation at each storage pile in accordance with the following frequencies:

Issued: 6/21/2007

<u>storage pile identification</u>	<u>minimum load-in inspection frequency</u>
------------------------------------	---

All limestone storage piles	weekly
All gypsum storage piles	weekly

2. Except as otherwise provided in this section, the permittee shall perform inspections of each load-out operation at each storage pile in accordance with the following frequencies:

<u>storage pile identification</u>	<u>minimum load-out inspection frequency</u>
------------------------------------	--

All limestone storage piles	weekly
All gypsum storage piles	weekly

3. Except as otherwise provided in this section, the permittee shall perform inspections of the wind erosion from pile surfaces associated with each storage pile in accordance with the following frequencies:

<u>storage pile identification</u>	<u>minimum wind erosion inspection frequency</u>
------------------------------------	--

All limestone storage piles	weekly
All gypsum storage piles	weekly

4. No inspection shall be necessary for wind erosion from the surface of a storage pile when the pile is covered with snow and/or ice and for any storage pile activity if precipitation has occurred that is sufficient for that day to ensure compliance with the above-mentioned applicable requirements. Any required inspection that is not performed due to any of the above identified events shall be performed as soon as such event(s) has (have) ended, except if the next required inspection is within one week.
5. The purpose of the inspections is to determine the need for implementing the control measures specified in this permit for load-in and load-out of a storage pile, and wind erosion from the surface of a storage pile. The inspections shall be performed during representative, normal storage pile operating conditions.

Issued: 6/21/2007

6. The permittee shall maintain records of the following information:
 - a. the date and reason any required inspection was not performed, including those inspections that were not performed due to snow and/or ice cover or precipitation;
 - b. the date of each inspection where it was determined by the permittee that it was necessary to implement the control measures;
 - c. the dates the control measures were implemented; and
 - d. on a calendar quarter basis, the total number of days the control measures were implemented and, for wind erosion from pile surfaces, the total number of days where snow and/or ice cover or precipitation were sufficient to not require the control measure(s).

The information required in 6.d. shall be kept separately for (i) the load-in operations, (ii) the load-out operations, and (iii) the pile surfaces (wind erosion), and shall be updated on calendar quarter basis within 30 days after the end of each calendar quarter.

IV. Reporting Requirements

1. The permittee shall submit deviation reports that identify any of the following occurrences:
 - a. each day during which an inspection was not performed by the required frequency, excluding an inspection which was not performed due to an exemption for snow and/or ice cover or precipitation; and
 - b. each instance when a control measure, that was to be implemented as a result of an inspection, was not implemented.
2. The deviation reports shall be submitted in accordance with the reporting requirements of the General Terms and Conditions of this permit.
3. The permittee shall submit annual reports that specify the total PE and PM₁₀ emissions from this emissions unit for the calendar year. These reports shall be submitted by April 15 of each year. This reporting requirement may be satisfied by including and identifying the specific emission data for this emissions unit in the annual Fee Emission Report.

Emissions Unit ID: F002

V. Testing Requirements

1. Compliance with the emissions limitations in Section A.I.1. of these terms and conditions shall be determined in accordance with the following methods:

- a. Emission Limitations:

There shall be no visible particulate emissions except for one minute during any 60-minute period.

Applicable Compliance Method:

If required, compliance with the visible emission limitations for the storage piles identified above shall be determined in accordance with Test Method 22 as set forth in "Appendix on Test Methods" in 40 CFR, Part 60 ("Standards of Performance for New Stationary Sources"), as such Appendix existed on July 1, 2002, and the modifications listed in paragraphs (B)(4)(a) through (B)(4)(c) of OAC rule 3745-17-03.

- b. Emission Limitations:

PE from the limestone and gypsum storage piles- load-in and load-out of storage piles and wind erosion from storage piles shall not exceed 7.09 tons per year.

Applicable Compliance Method:

Compliance with the annual limitations shall be demonstrated by the emission factors, and control efficiencies as submitted in PTI application 07-00583, received May 29th, 2007.

- c. Emission Limitations:

PM₁₀ from the limestone and gypsum storage piles- load-in and load-out of storage piles and wind erosion from storage piles shall not exceed 4.38 tons per year.

Applicable Compliance Method:

Compliance with the annual limitations shall be demonstrated by the emission factors, and control efficiencies as submitted in PTI application 07-00583, received May 29th, 2007.

VI. Miscellaneous Requirements

Emissions Unit ID: F002
*****CORRECTED COPY 7/24/2007*****

Issued: 6/21/2007

None

Issued: 6/21/2007

B. State Only Enforceable Section**I. Applicable Emissions Limitations and/or Control Requirements**

1. The specific operations(s), property, and/or equipment which constitute this emissions unit are listed in the following table along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures. Emissions from this unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

Operations, Property, and/or Equipment - (F002) - Limestone and gypsum storage piles - load-in and load out of storage piles and wind erosion from storage piles; Chapter 31 modification to add one additional storage pile in the original location, plus an additional 11.4 acres of gypsum storage.

Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
None	None

2. Additional Terms and Conditions

2.a None

II. Operational Restrictions

None

III. Monitoring and/or Recordkeeping Requirements

None

IV. Reporting Requirements

None

V. Testing Requirements

None

VI. Miscellaneous Requirements

None