OhioEPA
State of Ohio Environmental Protection Agency

P.O. Box 1049, 1800 WaterMark Dr.
Columbus, Ohio 43266-0149
(614) 644-3020 Fax (614) 644-2329

Richard F. Celeste
Governor

Re: Permit to Install
Stark County
Application No: 15-578
NSPS

CERTIFIED MAIL

October 15, 1990

ASHLAND PETROLEUM COMPANY
TOM WIGGLESWORTH
P O BOX 8170-2408 GAMBRINUS RD
CANTON, OH 44711

Enclosed please find an Ohio EPA Permit to Install which will allow you to install the described source(s) in a manner indicated in the permit. Because this permit contains several conditions and restrictions I urge you to read it carefully.

You are hereby notified that this action by the Director is final and may be appealed to the Ohio Environmental Board of Review pursuant to Chapter 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. It must be filed with the Environmental Board of Review within thirty (30) days after notice of the Director's action. A copy of the appeal must be served on the Director of the Ohio Environmental Protection Agency and the Environmental Law Division of the Office of the Attorney General within three (3) days of filing with the Board. An appeal may be filed with the Environmental Board of Review at the following address:

Environmental Board of Review
236 East Town Street, Room 300
Columbus, Ohio 43215

Very truly yours,

Thomas G. Rigo

Thomas G. Rigo, Manager
Field Operations & Permit Section
Division of Air Pollution Control

cc: US EPA
CANTON AIR POLLUTION CONTROL

RECEIVED
OCT 26 1990
CANTON CITY HEALTH DEPT.
AIR POLLUTION DIVISION

State of Ohio Environmental Protection Agency

Permit to Install
Terms and Conditions

Application No. 15-578
APS Premise No. 1576000301
Permit Fee: $1000.00

Name of Facility: ASHLAND PETROLEUM COMPANY

Person to Contact: TOM WIGGLESWORTH

Address: P O BOX 8170-2408 GAMBRINUS RD
CANTON, OH 44711

Location of proposed source(s): 2408 GAMBRINUS ROAD SW
CANTON TOWNSHIP, OHIO

Description of proposed source(s):
1,260,000 GALLON INTERNAL FLOATING ROOF TANK HOLDING PETROLE UM LIQUID WITH VAPOR PRESSURE < 11.

Date of Issuance: October 15, 1990

Effective Date: October 15, 1990

The above named entity is hereby granted a permit to install for the above described source(s) pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the above described source(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described source(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Richard L. Shank

Director

TERMINATION OF PERMIT TO INSTALL

Substantial construction for installation must take place within 18 months of the effective date of this permit. This deadline may be extended by up to 12 months, if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

NOTICE OF INSPECTION

The Director of the Ohio Environmental Protection Agency, or his authorized representatives, may enter upon the premises of the above-named applicant during construction and operation at any reasonable time for the purpose of making inspections, conducting tests, or to examine records or reports pertaining to the construction, modification or installation of the source(s) of environmental pollutants identified within this permit.

CONSTRUCTION OF NEW SOURCE(S)

The proposed source(s) shall be constructed in strict accordance with the plans and application submitted for this permit to the Director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the Agency. Any deviations from the approved plans or the above conditions may lead to such sanctions and penalties as provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed sources are inadequate or cannot meet applicable standards.

If the construction of the proposed source(s) has already begun or has been completed prior to the date the Director of the Ohio Environmental Protection Agency approves the permit application and plans, the approval does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the approved plans. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of Ohio Administrative Code (OAC) Rule 3745-31-02. Furthermore, issuance of the Permit to Install does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Approval of the plans in any case is not to be construed as an approval of the facility as constructed and/or completed. Moreover, issuance of the Permit to Install is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

PERMIT TO INSTALL FEE

In accordance with Ohio Revised Code 3745.11, the specified Permit to Install fee must be remitted within 15 days of the effective date of this permit to install.

PUBLIC DISCLOSURE

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC Rule 3745-49-03.

APPLICABILITY

This Permit to Install is applicable only to the contaminant sources identified. Separate application must be made to the Director for the installation or modification of any other contaminant sources.

BEST AVAILABLE TECHNOLOGY

As specified in OAC Rule 3745-31-05, all new sources must employ Best Available Technology (BAT). Compliance with the terms and conditions of this permit will fulfill this requirement.

PERMIT TO OPERATE APPLICATION

A Permit to Operate application and a $15 application fee must be submitted to the appropriate field office for each air contaminant source in this Permit to Install. In accordance with OAC Rule 3745-35-02, the application shall be made at least 90 days prior to start-up of the source.

AIR EMISSION SUMMARY

The air contaminant sources listed below comprise the Permit to Install for ASHLAND PETROLEUM COMPANY located in Stark County. The sources listed below shall not exceed the emission limits/control requirements contained in the table. This condition in no way limits the applicability of any other state or federal regulations. Additionally, this condition does not limit the applicability of additional special terms and conditions of this permit.

Ohio EPA Source Number	Source Identification/ Description	BAT Determination	Applicable Federal and OAC Rules	Permit Allowable Mass Emissions and/ or Control & Usage Requirements
T144	1,260,000 Gal IFR Petroleum Liquids ≤11 Vapor Pressure Storage Tank, Tank No. 243	Compliance with NSPS Kb	3745-31-05 3745-21-09 (L)	6 Tons OC/Yr

This tank replaces Tank #70 (T066). That tank had higher emissions.

SUMMARY
TOTAL PERMIT TO INSTALL ALLOWABLE EMISSIONS

Pollutant	Tons/Year
OC	6*

*This figure includes emissions from the tank itself and also the associated pumps, valves, and flanges.

NINETY DAY OPERATING PERIOD

The facility will be permitted to operate during a 90-day period in accordance with OAC Rule 3745-35-02(C)(4)(b). The purpose of this period of operation is to fulfill the performance test conditions used in the determination of compliance with the provisions of this Permit to Install or other applicable Ohio EPA rules.

NEW SOURCE PERFORMANCE STANDARD SUBPART Kb

The application and enforcement of the provisions of the New Source Performance Standards (NSPS), as promulgated by the United States Environmental Protection Agency, 40 CFR Part 60, are delegated to the Ohio Environmental Protection Agency. The requirements of 40 CFR Part 60 are also federally enforceable.

In accordance with 40 CFR 60.116b(a) and (b), the owner and operator of storage vessel T144 shall keep readily accessible records showing the dimension of each storage vessel and an analysis showing the capacity of each storage vessel for the life of each source.

In addition,

A. In accordance with 40 CFR 60.116b(a) and (c), the owner and operator of storage vessel T144 shall maintain a record of the volatile organic liquid (VOL) stored, the period of storage, and the maximum true vapor pressure of that VOL during the respective storage period. Records shall be retained for a minimum of two years.

B. In accordance with 40 CFR 60.116b(a) and (d), the owner and operator of storage vessel T144 shall notify the local field office within 30 days when the maximum true vapor pressure of the liquid exceeds the respective maximum true vapor pressure values for each volume range. Records shall be retained for a minimum of two years.