OhioEPA

State of Ohio Environmental Protection Agency

02

Permit to Operate an Air Contaminant Source
Terms and Conditions

Date of Issuance 04/04/86

Application Number 15760003016025

Effective Date 04/04/86

Permit Fee $210

This document constitutes issuance to: ASHLAND PETROLEUM COMPANY
P.O. BOX 1870, 2408 CAMBRINUS RD. S.W.
CANTON OHIO 44706

of a permit to operate:
50MM BTU REF. GAS/NO.6 OIL BOILER
NO. 2 BOILER 4-16-8-2

The following terms and conditions are hereby expressly incorporated into this permit to operate:

Condition 1

The above described air contaminant source is now operating, and over the period covered by the permit will be operated, in full compliance with all applicable state and federal laws and regulations.

Condition 2

Prior to any physical change in, or change in the method of operation of, this air contaminant source which increases the amount of any air pollutant emitted, or results in the emission of any air pollutant not previously emitted, a permit to install must be granted by the Ohio Environmental Protection Agency (See Chapter 3745-31 of the Ohio Administrative Code).

Condition 3

The Director of the Ohio Environmental Protection Agency, or his authorized representative, may enter upon the premises of the source operation at any reasonable time and subject to safety requirements of the person in control of the premises for the purpose of making inspections, conducting tests, examining records or reports pertaining to any emission of air contaminants and determining compliance with all applicable State and Federal air pollution laws and regulations and the terms and conditions of this permit.

Condition 4 (This condition applicable if checked: ☐)

Upon declaration of an Air Pollution Alert, Warning or Emergency Episode this air contaminant source will follow those emission reduction procedures enumerated in the Emergency Action Plan approved by the Director for this source.

Condition 5

This permit to operate shall be effective until 04/03/89. You will be contacted approximately six months prior to this date regarding the renewal of this permit. If you are not contacted, please write to this agency.

Condition 6

A permit fee in the amount specified above must be remitted within fifteen (15) days of the effective date of this permit.

Condition 7

Any transferee of this permit shall, personally, assume the responsibilities of the original permit holder-transferor. The Ohio EPA must be notified in writing of any transfer of this permit.

Condition 8 (This condition is applicable if checked: ☐)

This permit is subject to the supplementary conditions attached.

RECEIVED
APR 14 1986
CITY OF CANTON
HEALTH DEPT.
AIR POLLUTION CONTROL DIVISION

OHIO ENVIRONMENTAL PROTECTION AGENCY

Director

EPA 3834
4/12/78

APPLICATION NUMBER: 15 76 00 0301 B025

FACILITY NAME: Ashland Petroleum Company

EQUIPMENT DESCRIPTION: 50 MM BTU Ref. Gas/No. 6 Oil Boiler

COMPANY ID: No. 2 Boiler J-16-B-2

SPECIAL TERMS AND CONDITIONS

1. The Ashland Petroleum Co. shall not exceed a maximum emission level of 1.00 lbs. of sulfur dioxide per MM BTU actual heat input on this unit (4-16-B-2) as prescribed in OAC 3745-18-82 (E)(2).

2. The following rules of the Ohio Administrative Code establish the applicable emission limitations and/or control requirements of this source:

   3745-18-82

   (This condition in no way limits the applicability of other requirements of the Ohio Administrative Code to this source.)

PREPARED BY: ANDY PASKO
DATE PREPARED: 2/21/86