John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

3/18/2013

Certified Mail

No	TOXIC REVIEW
No	PSD
No	SYNTHETIC MINOR TO AVOID MAJOR NSR
No	CEMS
Yes	MACT/GACT
Yes	NSPS
No	NESHAPS
No	NETTING
No	MAJOR NON-ATTAINMENT
No	MODELING SUBMITTED
No	MAJOR GHG
No	SYNTHETIC MINOR TO AVOID MAJOR GHG

Mr. Cliff Brannon
POET Biorefining - Marion
1660 Hillman-Ford Road
Marion, OH 43302

RE: DRAFT AIR POLLUTION PERMIT-TO-INSTALL
Facility ID: 0351010207
Permit Number: P0113311
Permit Type: OAC Chapter 3745-31 Modification
County: Marion

Dear Permit Holder:

A draft of the Ohio Administrative Code (OAC) Chapter 3745-31 Air Pollution Permit-to-Install for the referenced facility has been issued for the emissions unit(s) listed in the Authorization section of the enclosed draft permit. This draft action is not an authorization to begin construction or modification of your emissions unit(s). The purpose of this draft is to solicit public comments on the permit. A public notice will appear in the Ohio Environmental Protection Agency (EPA) Weekly Review and the local newspaper, The Marion Star. A copy of the public notice and the draft permit are enclosed. This permit can be accessed electronically on the Division of Air Pollution Control (DAPC) Web page, www.epa.ohio.gov/dapc by clicking the "Search for Permits" link under the Permitting topic on the Programs tab. Comments will be accepted as a marked-up copy of the draft permit or in narrative format. Any comments must be sent to the following:

Andrew Hall
Permit Review/Development Section
Ohio EPA, DAPC
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, Ohio 43216-1049

and

Ohio EPA DAPC, Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402

Comments and/or a request for a public hearing will be accepted within 30 days of the date the notice is published in the newspaper. You will be notified in writing if a public hearing is scheduled. A decision on issuing a final permit-to-install will be made after consideration of comments received and oral testimony if a public hearing is conducted. Any permit fee that will be due upon issuance of a final Permit-to-Install is indicated in the Authorization section. Please do not submit any payment now. If you have any questions, please contact Ohio EPA DAPC, Northwest District Office at (419)352-8461.

Sincerely,

Michael W. Ahern

Michael W. Ahern, Manager
Permit Issuance and Data Management Section, DAPC

Cc: U.S. EPA Region 5 -*Via E-Mail Notification*
Ohio EPA-NWDO

Marion County

PUBLIC NOTICE
Issuance of Draft Air Pollution Permit-To-Install
POET Biorefining - Marion

Issue Date:	3/18/2013
Permit Number:	P0113311
Permit Type:	OAC Chapter 3745-31 Modification
Permit Description:	Chapter 31 modification to a 2000 kW internal combustion engine (P012) to increase the federally-enforceable hours of operation from 100 hours to 400 hours per rolling, 12-month period.
Facility ID:	0351010207
Facility Location:	POET Biorefining - Marion Hillman-Ford Road, Marion, OH 43302
Facility Description:	All Other Basic Organic Chemical Manufacturing

The Director of the Ohio Environmental Protection Agency issued the draft permit above. The permit and complete instructions for requesting information or submitting comments may be obtained at: http://epa.ohio.gov/dapc/permitsonline.aspx by entering the permit # or: Andrea Moore, Ohio EPA DAPC, Northwest District Office, 347 North Dunbridge Road, Bowling Green, OH 43402. Ph: (419)352-8461

Permit Strategy Write-Up

1. Check all that apply:

   _X_ Synthetic Minor Determination

   Netting Determination

2. Source Description:

   POET Biorefining – Marion operates a 79 million gallon per year fuel ethanol production facility in Marion, Ohio (Marion County). The facility produces fuel ethanol by fermenting corn with subsequent distillation. This proposed modification is to increase the hours of operation for a 2000 kW diesel generator.

3. Facility Emissions and Attainment Status:

   The facility is currently a Title V facility but has requested federally-enforceable restrictions to limit the potential to emit from this source. Marion County is designated attainment for all criteria pollutants.

4. Source Emissions:

   POET has requested that the hours of operation are increased from 100 to 400 hours of operation per rolling, 12-month period in order to effectively restrict PTE. This operational restriction will effectively restrict the potential to emit of all criteria pollutants.

5. Conclusion:

   The federally enforceable limitations on the potential to emit for the modified operation will maintain the facility's current status.

6. Please provide additional notes or comments as necessary:

   None

7. Total Permit Allowable Emissions Summary (for informational purposes only):

Pollutant	Tons Per Year
CO	3.09
NOx	4.48
SO2	0.01
PM10	0.18
VOC	1.16

DRAFT

Division of Air Pollution Control
Permit-to-Install
for
POET Biorefining - Marion

Facility ID:	0351010207
Permit Number:	P0113311
Permit Type:	OAC Chapter 3745-31 Modification
Issued:	3/18/2013
Effective:	To be entered upon final issuance

Division of Air Pollution Control
Permit-to-Install
for
POET Biorefining - Marion

Table of Contents

Authorization 1
A. Standard Terms and Conditions 3
1. Federally Enforceable Standard Terms and Conditions 4
2. Severability Clause 4
3. General Requirements 4
4. Monitoring and Related Record Keeping and Reporting Requirements 5
5. Scheduled Maintenance/Malfunction Reporting 6
6. Compliance Requirements 6
7. Best Available Technology 7
8. Air Pollution Nuisance 7
9. Reporting Requirements 7
10. Applicability 8
11. Construction of New Sources(s) and Authorization to Install 8
12. Permit-To-Operate Application 9
13. Construction Compliance Certification 9
14. Public Disclosure 9
15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations 10
16. Fees 10
17. Permit Transfers 10
18. Risk Management Plans 10
19. Title IV Provisions 10
B. Facility-Wide Terms and Conditions 11
C. Emissions Unit Terms and Conditions 13
1. P012, EU037 14

Authorization

Facility ID:	0351010207
Facility Description:	Industrial Organic Chemicals, n.e.c.
Application Number(s):	A0046960
Permit Number:	P0113311
Permit Description:	Chapter 31 modification to a 2000 kW internal combustion engine (P012) to increase the federally-enforceable hours of operation from 100 hours to 400 hours per rolling, 12-month period.
Permit Type:	OAC Chapter 3745-31 Modification
Permit Fee:	$200.00 *DO NOT send payment at this time, subject to change before final issuance*
Issue Date:	3/18/2013
Effective Date:	To be entered upon final issuance

This document constitutes issuance to:

POET Biorefining - Marion
Hillman-Ford Road
Marion, OH 43302

of a Permit-to-Install for the emissions unit(s) identified on the following page.

Ohio Environmental Protection Agency (EPA) District Office or local air agency responsible for processing and administering your permit:

Ohio EPA DAPC, Northwest District Office
347 North Dunbridge Road
Bowling Green, OH 43402
(419)352-8461

The above named entity is hereby granted a Permit-to-Install for the emissions unit(s) listed in this section pursuant to Chapter 3745-31 of the Ohio Administrative Code. Issuance of this permit does not constitute expressed or implied approval or agreement that, if constructed or modified in accordance with the plans included in the application, the emissions unit(s) of environmental pollutants will operate in compliance with applicable State and Federal laws and regulations, and does not constitute expressed or implied assurance that if constructed or modified in accordance with those plans and specifications, the above described emissions unit(s) of pollutants will be granted the necessary permits to operate (air) or NPDES permits as applicable.

This permit is granted subject to the conditions attached hereto.

Ohio Environmental Protection Agency

Scott J. Nally
Director

Authorization (continued)

Permit Number: P0113311
Permit Description: Chapter 31 modification to a 2000 kW internal combustion engine (P012) to increase the federally-enforceable hours of operation from 100 hours to 400 hours per rolling, 12-month period.

Permits for the following Emissions Unit(s) or groups of Emissions Units are in this document as indicated below:

Emissions Unit ID:	**P012**
Company Equipment ID:	EU037
Superseded Permit Number:	P0104476
General Permit Category and Type:	Not Applicable

A. Standard Terms and Conditions

1. Federally Enforceable Standard Terms and Conditions

a) All Standard Terms and Conditions are federally enforceable, with the exception of those listed below which are enforceable under State law only:

(1) Standard Term and Condition A.2.a), Severability Clause

(2) Standard Term and Condition A.3.c) through A. 3.e)General Requirements

(3) Standard Term and Condition A.6.c) and A. 6.d), Compliance Requirements

(4) Standard Term and Condition A.9., Reporting Requirements

(5) Standard Term and Condition A.10., Applicability

(6) Standard Term and Condition A.11.b) through A.11.e), Construction of New Source(s) and Authorization to Install

(7) Standard Term and Condition A.14., Public Disclosure

(8) Standard Term and Condition A.15., Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

(9) Standard Term and Condition A.16., Fees

(10) Standard Term and Condition A.17., Permit Transfers

2. Severability Clause

a) A determination that any term or condition of this permit is invalid shall not invalidate the force or effect of any other term or condition thereof, except to the extent that any other term or condition depends in whole or in part for its operation or implementation upon the term or condition declared invalid.

b) All terms and conditions designated in parts B and C of this permit are federally enforceable as a practical matter, if they are required under the Act, or any of its applicable requirements, including relevant provisions designed to limit the potential to emit of a source, are enforceable by the Administrator of the U.S. EPA and the State and by citizens (to the extent allowed by section 304 of the Act) under the Act. Terms and conditions in parts B and C of this permit shall not be federally enforceable and shall be enforceable under State law only, only if specifically identified in this permit as such.

3. General Requirements

a) The permittee must comply with all terms and conditions of this permit. Any noncompliance with the federally enforceable terms and conditions of this permit constitutes a violation of the Act, and is grounds for enforcement action or for permit revocation, revocation and re-issuance, or modification.

b) It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the federally enforceable terms and conditions of this permit.

c) This permit may be modified, revoked, or revoked and reissued, for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or revocation, or of a notification of planned changes or anticipated noncompliance does not stay any term and condition of this permit.

d) This permit does not convey any property rights of any sort, or any exclusive privilege.

e) The permittee shall furnish to the Director of the Ohio EPA, or an authorized representative of the Director, upon receipt of a written request and within a reasonable time, any information that may be requested to determine whether cause exists for modifying or revoking this permit or to determine compliance with this permit. Upon request, the permittee shall also furnish to the Director or an authorized representative of the Director, copies of records required to be kept by this permit. For information claimed to be confidential in the submittal to the Director, if the Administrator of the U.S. EPA requests such information, the permittee may furnish such records directly to the Administrator along with a claim of confidentiality.

4. Monitoring and Related Record Keeping and Reporting Requirements

a) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall maintain records that include the following, where applicable, for any required monitoring under this permit:

(1) The date, place (as defined in the permit), and time of sampling or measurements.

(2) The date(s) analyses were performed.

(3) The company or entity that performed the analyses.

(4) The analytical techniques or methods used.

(5) The results of such analyses.

(6) The operating conditions existing at the time of sampling or measurement.

b) Each record of any monitoring data, testing data, and support information required pursuant to this permit shall be retained for a period of five years from the date the record was created. Support information shall include, but not be limited to all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. Such records may be maintained in computerized form.

c) Except as may otherwise be provided in the terms and conditions for a specific emissions unit, the permittee shall submit required reports in the following manner:

(1) Reports of any required monitoring and/or recordkeeping of federally enforceable information shall be submitted to the Ohio EPA DAPC, Northwest District Office.

(2) Quarterly written reports of (i) any deviations from federally enforceable emissionlimitations, operationalrestrictions, andcontroldeviceoperatingparameterlimitations, excluding deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06, that have been detected by the testing, monitoring and recordkeeping requirements specified in this permit, (ii) the probable cause of such deviations, and (iii) any corrective actions or preventive measures taken, shall be made to the Ohio EPA DAPC, Northwest District Office. The written reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. See A.15. below if no deviations occurred during the quarter.

(3) Written reports, which identify any deviations from the federally enforceable monitoring, recordkeeping, andreportingrequirements contained in this permit shall be submitted (i.e., postmarked) to the Ohio EPA DAPC, Northwest District Office every six months, by January 31 and July 31 of each year for the previous six calendar months. If no deviations occurred during a six-month period, the permittee shall submit a semi-annual report, which states that no deviations occurred during that period.

(4) This permit is for an emissions unit located at a Title V facility. Each written report shall be signed by a responsible official certifying that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.

d) The permittee shall report actual emissions pursuant to OAC Chapter 3745-78 for the purpose of collecting Air Pollution Control Fees.

5. Scheduled Maintenance/Malfunction Reporting

Any scheduled maintenance of air pollution control equipment shall be performed in accordance with paragraph (A) of OAC rule 3745-15-06. The malfunction, i.e., upset, of any emissions units or any associated air pollution control system(s) shall be reported to the Ohio EPA DAPC, Northwest District Office in accordance with paragraph (B) of OAC rule 3745-15-06. (The definition of an upset condition shall be the same as that used in OAC rule 3745-15-06(B)(1) for a malfunction.) The verbal and written reports shall be submitted pursuant to OAC rule 3745-15-06.

Except as provided in that rule, any scheduled maintenance or malfunction necessitating the shutdown or bypassing of any air pollution control system(s) shall be accompanied by the shutdown of the emission unit(s) that is (are) served by such control system(s).

6. Compliance Requirements

a) The emissions unit(s) identified in this Permit shall remain in full compliance with all applicable State laws and regulations and the terms and conditions of this permit.

b) Any document (including reports) required to be submitted and required by a federally applicable requirement in this permit shall include a certification by a responsible official that, based on information and belief formed after reasonable inquiry, the statements in the document are true, accurate, and complete.

c) Upon presentation of credentials and other documents as may be required by law, the permittee shall allow the Director of the Ohio EPA or an authorized representative of the Director to:

(1) At reasonable times, enter upon the permittee's premises where a source is located or the emissions-related activity is conducted, or where records must be kept under the conditions of this permit.

(2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit, subject to the protection from disclosure to the public of confidential information consistent with ORC section 3704.08.

(3) Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.

(4) As authorized by the Act, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the permit and applicable requirements.

d) The permittee shall submit progress reports to the Ohio EPA DAPC, Northwest District Office concerning any schedule of compliance for meeting an applicable requirement. Progress reports shall be submitted semiannually or more frequently if specified in the applicable requirement or by the Director of the Ohio EPA. Progress reports shall contain the following:

(1) Dates for achieving the activities, milestones, or compliance required in any schedule of compliance, and dates when such activities, milestones, or compliance were achieved.

(2) An explanation of why any dates in any schedule of compliance were not or will not be met, and any preventive or corrective measures adopted.

7. Best Available Technology

As specified in OAC Rule 3745-31-05, new sources that must employ Best Available Technology (BAT) shall comply with the Applicable Emission Limitations/Control Measures identified as BAT for each subject emissions unit.

8. Air Pollution Nuisance

The air contaminants emitted by the emissions units covered by this permit shall not cause a public nuisance, in violation of OAC rule 3745-15-07.

9. Reporting Requirements

The permittee shall submit required reports in the following manner:

a) Reports of any required monitoring and/or recordkeeping of state-only enforceable information shall be submitted to the Ohio EPA DAPC, Northwest District Office.

b) Except as otherwise may be provided in the terms and conditions for a specific emissions unit, quarterly written reports of (a) any deviations (excursions) from state-only required emission limitations, operational restrictions, and control device operating parameter limitations that have

been detected by the testing, monitoring, and recordkeeping requirements specified in this permit, (b) the probable cause of such deviations, and (c) any corrective actions or preventive measures which have been or will be taken, shall be submitted to the Ohio EPA DAPC, Northwest District Office. If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted (i.e., postmarked) quarterly, by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters. (These quarterly reports shall exclude deviations resulting from malfunctions reported in accordance with OAC rule 3745-15-06.)

10. Applicability

This Permit-to-Install is applicable only to the emissions unit(s) identified in the Permit-to-Install. Separate application must be made to the Director for the installation or modification of any other emissions unit(s).

11. Construction of New Sources(s) and Authorization to Install

a) This permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. This permit does not constitute expressed or implied assurance that the proposed facility has been constructed in accordance with the application and terms and conditions of this permit. The action of beginning and/or completing construction prior to obtaining the Director's approval constitutes a violation of OAC rule 3745-31-02. Furthermore, issuance of this permit does not constitute an assurance that the proposed source will operate in compliance with all Ohio laws and regulations. Issuance of this permit is not to be construed as a waiver of any rights that the Ohio Environmental Protection Agency (or other persons) may have against the applicant for starting construction prior to the effective date of the permit. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities cannot meet the requirements of this permit or cannot meet applicable standards.

b) If applicable, authorization to install any new emissions unit included in this permit shall terminate within eighteen months of the effective date of the permit if the owner or operator has not undertaken a continuing program of installation or has not entered into a binding contractual obligation to undertake and complete within a reasonable time a continuing program of installation. This deadline may be extended by up to 12 months if application is made to the Director within a reasonable time before the termination date and the party shows good cause for any such extension.

c) The permittee may notify Ohio EPA of any emissions unit that is permanently shut down (i.e., the emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31) by submitting a certification from the authorized official that identifies the date on which the emissions unit was permanently shut down. Authorization to operate the affected emissions unit shall cease upon the date certified by the authorized official that the emissions unit was permanently shut down. At a minimum, notification of permanent shut down shall be made or confirmed by marking the affected emissions unit(s) as “permanently shut down” in Ohio EPA’s “Air Services” along with the date the emissions unit(s) was permanently removed and/or disabled. Submitting the facility profile update will constitute notifying of the permanent shutdown of the affected emissions unit(s).

d) The provisions of this permit shall cease to be enforceable for each affected emissions unit after the date on which an emissions unit is permanently shut down (i.e., emissions unit has been physically removed from service or has been altered in such a way that it can no longer operate without a subsequent "modification" or "installation" as defined in OAC Chapter 3745-31). All records relating to any permanently shutdown emissions unit, generated while the emissions unit was in operation, must be maintained in accordance with law. All reports required by this permit must be submitted for any period an affected emissions unit operated prior to permanent shut down. At a minimum, the permit requirements must be evaluated as part of the reporting requirements identified in this permit covering the last period the emissions unit operated.

No emissions unit certified by the authorized official as being permanently shut down may resume operation without first applying for and obtaining a permit pursuant to OAC Chapter 3745-31.

e) The permittee shall comply with any residual requirements related to this permit, such as the requirement to submit a deviation report, air fee emission report, or other any reporting required by this permit for the period the operating provisions of this permit were enforceable, or as required by regulation or law. All reports shall be submitted in a form and manner prescribed by the Director. All records relating to this permit must be maintained in accordance with law.

12. Permit-To-Operate Application

The permittee is required to apply for a Title V permit pursuant to OAC Chapter 3745-77. The permittee shall submit a complete Title V permit application or a complete Title V permit modification application within twelve (12) months after commencing operation of the emissions units covered by this permit. However, if the proposed new or modified source(s) would be prohibited by the terms and conditions of an existing Title V permit, a Title V permit modification must be obtained before the operation of such new or modified source(s) pursuant to OAC rule 3745-77-04(D) and OAC rule 3745-77-08(C)(3)(d).

13. Construction Compliance Certification

The applicant shall identify the following dates in the online facility profile for each new emissions unit identified in this permit.

a) Completion of initial installation date shall be enteredupon completion of construction and prior to start-up.

b) Commence operation after installation or latest modification date shall be entered within 90 days after commencing operation of the applicable emissions unit.

14. Public Disclosure

The facility is hereby notified that this permit, and all agency records concerning the operation of this permitted source, are subject to public disclosure in accordance with OAC rule 3745-49-03.

15. Additional Reporting Requirements When There Are No Deviations of Federally Enforceable Emission Limitations, Operational Restrictions, or Control Device Operating Parameter Limitations

If no deviations occurred during a calendar quarter, the permittee shall submit a quarterly report, which states that no deviations occurred during that quarter. The reports shall be submitted quarterly (i.e., postmarked), by January 31, April 30, July 31, and October 31 of each year and shall cover the previous calendar quarters.

16. Fees

The permittee shall pay fees to the Director of the Ohio EPA in accordance with ORC section 3745.11 and OAC Chapter 3745-78. The permittee shall pay all applicable permit-to-install fees within 30 days after the issuance of any permit-to-install. The permittee shall pay all applicable permit-to-operate fees within thirty days of the issuance of the invoice.

17. Permit Transfers

Any transferee of this permit shall assume the responsibilities of the prior permit holder. The new owner must update and submit the ownership information via the “Owner/Contact Change” functionality in Air Services once the transfer is legally completed.The change must be submitted through Air Services within thirty days of the ownership transfer date.

18. Risk Management Plans

If the permittee is required to develop and register a risk management plan pursuant to section 112(r) of the Clean Air Act, as amended, 42 U.S.C. 7401 et seq. ("Act"), the permittee shall comply with the requirement to register such a plan.

19. Title IV Provisions

If the permittee is subject to the requirements of 40 CFR Part 72 concerning acid rain, the permittee shall ensure that any affected emissions unit complies with those requirements. Emissions exceeding any allowances that are lawfully held under Title IV of the Act, or any regulations adopted thereunder, are prohibited.

B. Facility-Wide Terms and Conditions

1. All the following facility-wide terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only:

   a) None.

2. The permittee is subject to the applicable emission limitations and/or control measures, operational restrictions, monitoring and/or record keeping requirements, reporting requirements, testing requirements and the general and/or other requirements specified in 40 CFR Part 63, Subpart ZZZZ, in accordance with 40 CFR Parts 63.6580 through 63.6675 (including the Table(s) and Appendix(ices) referenced in Subpart ZZZZ). The permittee shall meet the requirements of 40 CFR Part 63, Subpart ZZZZ no later than 10/19/2013. The following emissions units in this permit are subject to the aforementioned requirements: P012.

C. Emissions Unit Terms and Conditions

1. P012, EU037

Operations, Property and/or Equipment Description:

2000 kW non-emergency electrical generator

a) The following emissions unit terms and conditions are federally enforceable with the exception of those listed below which are enforceable under state law only.

(1) b)(1)i. and d)(6).

b) Applicable Emissions Limitations and/or Control Requirements

(1) The specific operation(s), property, and/or equipment that constitute each emissions unit along with the applicable rules and/or requirements and with the applicable emissions limitations and/or control measures are identified below. Emissions from each unit shall not exceed the listed limitations, and the listed control measures shall be specified in narrative form following the table.

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
a.	40 CFR Part 60, Subpart IIII 40 CFR 60.4204(b) 40 CFR 60.4201(a) Table 1 to 40 CFR 89.112, Tier 2	The exhaust emissions from this engine shall not exceed: 0.20 gram particulate matter emissions (PM)/kW-hr [see b)(2)k.] 6.4 grams nitrogen oxides (NOx) + non-methane hydrocarbons (NMHC)/kW-hr 3.5 grams carbon monoxide (CO)/kW-hr See terms b)(2)a. through b)(2)c.
b.	40 CFR 60.4207(b) 40 CFR 80.510(b)	The sulfur content of the diesel fuel burned in this emissions unit shall not exceed 15 ppm or 0.0015% sulfur by weight. See terms b)(2)c., c(2), d(3), and e(1).
c.	40 CFR 89.113 (certified by manufacturer)	20% opacity during the acceleration mode 15% opacity during the lugging mode 50% opacity during the peaks in either the acceleration or lugging modes
d.	OAC rule 3745-31-05(D)	3.09 tons CO per rolling, 12-month period 4.48 tons NOx per rolling, 12-month

	Applicable Rules/Requirements	Applicable Emissions Limitations/Control Measures
		period 0.18 ton particulate matter less than or equal to 10 microns in size (PM10) per rolling, 12-month period 1.16 tons VOC per rolling, 12-month period 0.01 ton sulfur dioxide (SO2) per rolling, 12-month period See b)(2)d. and c)(1)
e.	OAC rule 3745-17-07(A)	Visible particulate matter emissions (PE) shall not exceed 20% opacity, as a six-minute average, except as provided by rule
f.	OAC rule 3745-17-11(B)(5)(b)	See b)(2)f.
g.	OAC rule 3745-18-06	See b)(2)g.
h.	OAC rule 3745-114-01 ORC 3704.03(F)	See d)(6)
i.	40 CFR, Part 63, Subpart ZZZZ 40 CFR 63.6590(c)	See b)(2)h.
j.	OAC rule 3745-110-03(F)	See b)(2)i.
k.	OAC rule 3745-31-05(A)(3), as effective 11/30/01	See b)(2)k.
l.	OAC rule 3745-31-05(A)(3, as effective 12/01/06	See b)(2)l.

(2) Additional Terms and Conditions

a. The stationary compression ignition (CI) internal combustion engine (ICE) is subject to and shall be operated in compliance with the requirements of 40 CFR Part 60, Subpart IIII, the standards of performance for stationary CI ICE.

b. The stationary CI ICE has been or shall be purchased certified by the manufacturer, to emission standards as stringent as those identified in 40 CFR 60.4201(a) and found in Tier 2 of 40 CFR 89.112, Table 1, for engines greater than 750 horsepower (560 kilowatt), and to the opacity standards found in 40 CFR 89.113.

c. The quality of the diesel fuel burned in this emissions unit shall meet the following specifications on an “as received”basis:

i. a sulfur content which is sufficient to comply with the allowable sulfur dioxide emission limitation of 0.0015 pound sulfur dioxide/mmBtu actual heat input; and 15 ppm sulfur or 0.0015% sulfur by weight;

ii. a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent; and

iii. a heating value greater than 135,000 Btu/gallon.

Compliance with the above-mentioned specifications shall be determined by using theanalytical results provided by the permittee or oil supplier for each shipment of oil.

d. This permit establishes the following federally enforceable emission limitations based on an hours of operation restriction [See c)(2)] and hourly emission limitations for purposes of limiting the potential to emit:

i. 3.09 tons CO per rolling, 12-month period;

ii. 4.48 tons NOx per rolling, 12-month period;

iii. 0.01 ton SO2 per rolling, 12-month period;

iv. 0.18 ton PM10 per rolling, 12-month period; and

v. 1.16 tons VOC per rolling, 12-month period.

e. The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3), have been determined to be compliance with the limitations established under 40 CFR Part 60, Subpart IIII.

f. The emission limitation specified by this ruleis less stringent than the emission limitation established for particulate matter pursuant to 40 CFR Part 60, Subpart IIII.

g. This emissions unit is exempt from the requirements of OAC rule 3745-18-06 in accordance with OAC rule 3745-18-06(B).

h. A new area source operating in compliance with Part 60 Subpart IIII is the demonstration of compliance for 40 CFR 63 Subpart ZZZZ.

i. This engine is exempt from OAC rule 3745-110-03 per OAC rule 3745-110-03(J)(16).

j. All emissions of particulate matter are PM_{10}.

k. The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3), as effective 11/30/01, have been determined to be compliance with the emission limitations established under OAC rule 3745-31-05(D) and the requirements of 40 CFR Part 60, Subpart IIII.

The permittee has satisfied the Best Available Technology (BAT) requirements pursuant to Ohio Administrative Code (OAC) paragraph 3745-31-05(A)(3), as effective November 30, 2001, in this permit. On December 1, 2006, paragraph (A)(3) of OAC rule 3745-31-05 was revised to conform to the Ohio Revised Code (ORC) changes effective August 3, 2006 (Senate Bill 265 changes), such that BAT is no longer required by State regulations for National Ambient Air Quality Standards (NAAQS) pollutant(s) less than ten tons per year. However, that rule revision has not yet been approved by U.S. EPA as a revision to Ohio's State Implementation Plan (SIP). Therefore, until the SIP revision occurs and the U.S. EPA approves the revisions to OAC rule 3745-31-05, the requirement to satisfy BAT still exists as part of the federally-approved SIP for Ohio. Once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05, then these emission limitations/control measures no longer apply.

l. This rule paragraph applies once U.S. EPA approves the December 1, 2006 version of OAC rule 3745-31-05 as part of the State Implementation Plan.

The Best Available Technology (BAT) requirements under OAC rule 3745-31-05(A)(3) do not apply to NOx, CO, SO2, VOC and PM10 emissions from this air contaminant source since the calculated annual emission rate for NOx, CO, SO2, VOC and PM10 emissions is less than ten tons per year taking into account the federally enforceable restriction on the number of hours of operation under OAC rule 3745-31-05(D).

c) Operational Restrictions

(1) The maximum annual operating hours for this emissions unit shall not exceed 400 hours, based upon a rolling, 12-month summation of the monthly operating hours.

[This emissions unit has been in operation for more than 12 months and, as such, the permittee has existing records to generate the rolling, 12-month summation of the hours of operation, upon issuance of this permit.]

(2) Thestationary CI ICE and any control device shall be installed, operated, and maintained according to the manufacturer's emission-related written instructions and the permittee shall only change those emission–related settings that are allowed by the manufacturer. The CI ICE must also be installed and operated to meet the applicablerequirements from 40 CFR Part 89, Control of Emissions from New and In-use Non-road CI ICE; andPart 1068,the General Compliance Provisions for Engine Programs. The permittee shall operate and maintain the stationary CI ICE to achieve the emissions standards established in 40 CFR 60.4204 over the entire life of the engine(s).

(3) Diesel fuel burned in the CI, ICE shall not exceed the limit for sulfur as specified by 40 CFR 80.510(b), i.e., themaximum sulfur content of diesel fuel shall not exceed 15 ppm or 0.0015% sulfur by weight.

(4) If the stationary CI internal combustion engine is equipped with a diesel particulate filter to comply with the emission standards in 40 CFR 60.4204, the diesel particulate filter must be installed with a backpressure monitor that notifies the permittee when the high backpressure limit of the engine is approached.

d) Monitoring and/or Recordkeeping Requirements

(1) The permittee shall maintain monthly records of the following information for this emissions unit:

a. the number of hours of operation; and

b. the rolling, 12-month summation of the hours of operation.

(2) For each day during which the permittee burns a fuel other than diesel fuel, the permittee shall maintain a record of the type and quantity of fuel burned in this emissions unit. The permittee shall also maintain documentation on the sulfur content of all fuels burned.

(3) The permittee shall maintain documents provided by the oil supplier for each shipment of diesel fuel to demonstrate compliance with the applicable SO_2 emissions standard. These documents must include the following information pursuant to 40 CFR 80.592(a):

a. the name of the oil supplier; and

b. a statement from the oil supplier that the oil complies with the specifications under the definition of ultra-low sulfur diesel.

(4) The permittee shall maintain the manufacturer's certification, to the applicable Tier 2 emission standards in Table 1 of 40 CFR 89.112, on site or at a central location for all facility ICE and it shall be made available for review upon request. If the manufacturer's certification is not kept on site, the permittee shall maintain a log for the location of each ICE and it shall identify the agency-assigned emissions unit number, the manufacturer's identification number, and the identification number of the certificate. The manufacturer's operations manual and any written instructions or procedures developed by the permittee and approved by the manufacturer shall be maintained at the same location as the ICE.

(5) If the stationary CI internal combustion engine is equipped with a diesel particulate filter to comply with the emission standards in 40 CFR 60.4204, the permittee shall keep records of the date, time, and any corrective action(s) taken in response to the notification from the backpressure monitor, that the high backpressure limit of the engine has been approached or exceeded.

e) Reporting Requirements

(1) The permittee shall submit quarterly deviation (excursion) reports which identify the following:

a. All deviations (excursions) of the following emission limitations, operational restrictions and/or control device operating parameter limitations that restrict the potential to emit (PTE) of any regulated air pollutant and have been detected by the monitoring, record keeping and/or testing requirements of this permit:

i. All exceedances of the rolling, 12-month restriction of 400 hours;

ii. any period of time (date and number of hours) that the quality of oil burned in this emissions unit did not meet the requirements established in 40 CFR 80.510(b), based upon the required fuel records;

b. The probable cause of each deviation (excursion);

c. Any corrective actions that were taken to remedy the deviations (excursions) or prevent future deviations (excursions); and

d. The magnitude and duration of each deviation (excursion).

If no deviations (excursions) occurred during a calendar quarter, the permittee shall submit a report that states that no deviations (excursions) occurred during the quarter.

The quarterly reports shall be submitted, electronically through Ohio EPA Air Services, each year by January 31 (covering October to December), April 30 (covering January to March), July 21 (covering April to June), and October 31 (covering July to September), unless an alternative schedule has been established and approved by the Director (the appropriate District Office or local air agency).

(2) If the stationary CI internal combustion engine is equipped with a diesel particulate filter to comply with the emission standards in 40 CFR 60.4204, the permittee shall include in the PER any records of the date, time, and any corrective action(s) taken in response to the notification from the monitor that the backpressure has been approached or exceeded.

f) Testing Requirements

(1) Compliance with the Emissions Limitations and/or Control Requirements specified in section b) of these terms and conditions shall be determined in accordance with the following methods:

a. <u>Opacity Limitations</u>:

20% opacity during the acceleration mode
15% opacity during the lugging mode
50% opacity during the peaks in either the acceleration or lugging modes

<u>Applicable Compliance Method</u>:

The permittee shall demonstrate compliance with the opacity standards of 40 CFR 89.113 based on the standard certification.

[The ICE was purchased certified to the opacity standards of 40 CFR 89.113.]

b. Emission Limitations:

0.18 gram PM/kW-hr
3.5 grams CO/kW-hr
6.4 grams NOx+ NMHC/kW-hr

Applicable Compliance Method:

Compliance with the emission limitationsabove shall be based on the manufacturer's certification and by maintaining the engine according to the manufacturer's specifications. The g/kW-hrlimitis the emission limitation fromTable 1 of 40 CFR 89.112, the Tier 2 exhaust emission standards for diesel engines greater than 750 horsepower (560 kW).

If required, the permittee shall demonstrate compliance with the emission limitations through performance tests conducted in accordance with the provisions in term f)(2) below.

For the purpose of reporting emissions, where the limit is for NOx + NMHC, the NOx and VOC limits shall be calculated using a ratio of 79.4% NOx to 20.6% VOC.*

6.4 g NOx+NMHC/kW-hr x 20.6% NMHC* = 1.3 grams VOC/kW-hr

c. Emission Limitation:

Sulfur content 15 ppm or $\leq$ 0.0015%by weightsulfur

Applicable Compliance Method:

Compliance shall be demonstrated through the record keeping requirements for the sulfur content of each shipment of diesel oil received. If meeting the standards in 40 CFR 80.510(b), this calculates to approximately 0.0015lb SO_2/mmBtu.

d. Emissions Limitations:

4.48 tons NOx per rolling, 12-month period
3.09 tons CO per rolling, 12 month period
1.16 tons VOC per rolling, 12-month period
0.18 ton PM_{10} per rolling, 12-month period

Applicable Compliance Method:

The annual emission limitation above were developed by multiplying the performance standards by the power output of 2000 kW, the maximum annual operating schedule of 400 hours/year, and then dividing by 907,185 grams/ton. Therefore, provided compliance is maintained with the hourly emission limitations and the rolling, 12-month hours of operation restriction, compliance with the annual emission limitations shall also be demonstrated.

e. Emissions Limitation:

0.01 ton SO2 per rolling, 12-month period

Applicable Compliance Method:

The annual emission limitation above was developed by multiplying the emission limit of 0.0015 lb SO2/mmBtu by the power output of 2000 kW, the conversion factors of 0.007 mmBtu/hp-hr, 1.341 hp/kW, the maximum annual operating schedule of 400 hours/year, and then dividing by 2000 lbs/ton. Therefore, provided compliance is maintained with the hourly emission limitation and the rolling, 12-month hours of operation restriction, compliance with the annual emission limitations shall also be demonstrated.

f. Emission Limitation:

Visible PE from the stack serving this emissions unit shall not exceed 20% opacity, as a 6-minute average.

Applicable Compliance Method:

If required, compliance shall be demonstrated in accordance with OAC rule 3745-17-03(B)(1).

(2) If it is determined by the Ohio EPA that a compliance demonstration is required through performance testing, it shall be conducted using one of the following test methods or procedures:

a. in accordance with 40 CFR 60.4212, conduct the exhaust emissions testing using the in-use testing procedures found in 40 CFR Part 1039, Subpart F, measuring the emissions of the regulated pollutants as specified in 40 CFR 1065; or

b. in accordance with 40 CFR 60.4213, conduct exhaust emissions testing using the test methods identified in Table 7 to Subpart IIII of Part 60.

If demonstrating compliance through the in-use testing procedures in 40 CFR part 1039, Subpart F, exhaust emissions from the stationary CI ICE shall not exceed the “not to exceed” (NTE) numerical requirements, rounded to the same number of decimal places as the applicable standard in 40 CFR 89.112, determined from the following equation:

NTE requirement for each pollutant = 1.25 x STD

Where:

STD = The standard specified for the pollutant in 40 CFR 89.112.

g) Miscellaneous Requirements

(1) Modeling to demonstrate compliance with, the “Toxic Air Contaminant Statute”, ORC 3704.03(F)(4)(b), was not necessary because the emissions unit’s maximum annual

emissions for each toxic air contaminant, as defined in OAC rule 3745-114-01, will be less than 1.0 ton per year. OAC Chapter 3745-31 requires a permittee to apply for and obtain a new or modified federally PTI prior to making a "modification" as defined by OAC rule 3745-31-01. The permittee is hereby advised that changes in the composition of the materials, or use of new materials, that would cause the emissions of any toxic air contaminant to increase to above 1.0 ton per year may require the permittee to apply for and obtain a new PTI.