

Appendix A Compliance Table

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Organic Contaminants											
2981	1,1,1-Trichloroethane	0.2	1932	0	0	100.0%				211	179	90.7%
2977	1,1-Dichloroethylene	0.007	1932	0	0	100.0%				211	179	90.7%
2985	1,1,2-Trichloroethane	0.005	1932	0	0	100.0%				211	179	90.7%
2378	1,2,4-Trichlorobenzene	0.07	1932	0	0	100.0%				211	179	90.7%
2931	1,2-Dibromo-3-chloropropane (DBCP)	0.0002	NA	0	0	NA				0	0	NA
2980	1,2-Dichloroethane	0.005	1932	0	0	100.0%				211	179	90.7%
2983	1,2-Dichloropropane	0.005	1932	0	0	100.0%				211	179	90.7%
2063	2,3,7,8-TCDD (Dioxin)	3x10 ⁻⁸	9	0	0	100.0%				1	1	88.9%
2110	2,4,5-TP	0.05	NA	0	0	NA				0	0	NA
2105	2,4-D	0.07	1019	0	0	100.0%				104	104	89.8%
2265	Acrylamide						0	0	100.0%			
2051	Alachlor	0.002	40	0	0	100.0%				5	5	87.5%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
2050	Atrazine	0.003	41	1	1	97.6%				5	5	87.8%
2990	Benzene	0.005	1932	0	0	100.0%				211	179	90.7%
2306	Benzo[a]pyrene	0.0002	781	0	0	100.0%				71	71	90.9%
2046	Carbofuran	0.04	785	0	0	100.0%				69	69	91.2%
2982	Carbon tetrachloride	0.005	1932	0	0	100.0%				211	179	90.7%
2959	Chlordane	0.002	NA	0	0	NA				0	0	NA
2380	cis-1,2-Dichloroethylene	0.07	1932	0	0	100.0%				211	179	90.7%
2031	Dalapon	0.2	NA	0	0	NA				0	0	NA
2035	Di(2-ethylhexyl)adipate	0.4	749	0	0	100.0%				63	63	91.6%
2039	Di(2-ethylhexyl)phthalate	0.006	793	0	0	100.0%				63	63	92.1%
2964	Dichloromethane	0.005	1932	0	0	100.0%				211	179	90.7%
2041	Dinoseb	0.007	NA	0	0	NA				0	0	NA
2032	Diquat	0.02	795	0	0	100.0%				65	65	91.8%
2033	Endothall	0.1	764	0	0	100.0%				67	67	91.2%
2005	Endrin	0.002	NA	0	0	NA				0	0	NA
2257	Epichlorohydrin						0	0	NA			

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
2992	Ethylbenzene	0.7	1932	0	0	100.0%				211	179	90.7%
2946	Ethylene dibromide	0.00005	NA	0	0	NA				0	0	NA
2034	Glyphosate	0.7	960	0	0	100.0%				82	82	91.5%
2065	Heptachlor	0.0004	NA	0	0	NA				0	0	NA
2067	Heptachlor epoxide	0.0002	NA	0	0	NA				0	0	NA
2274	Hexachlorobenzene	0.001	NA	0	0	NA				0	0	NA
2042	Hexachlorocyclopentadiene	0.05	NA	0	0	NA				0	0	NA
2010	Lindane	0.0002	787	0	0	100.0%				67	67	91.5%
2015	Methoxychlor	0.04	780	0	0	100.0%				65	65	91.7%
2989	Monochlorobenzene	0.1	1932	0	0	100.0%				211	179	90.7%
2968	o-Dichlorobenzene	0.6	1932	0	0	100.0%				211	179	90.7%
2969	p-Dichlorobenzene	0.075	1932	0	0	100.0%				211	179	90.7%
2383	Total polychlorinated biphenyls	0.0005	746	0	0	100.0%				62	62	91.7%
2326	Pentachlorophenol	0.001	845	0	0	100.0%				73	73	91.4%
2987	Tetrachloroethylene	0.005	1932	0	0	100.0%				211	179	90.7%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
2984	Trichloroethylene	0.005	1932	1	1	99.9%				211	179	90.7%
2996	Styrene	0.1	1932	0	0	100.0%				211	179	90.7%
2991	Toluene	1	1932	0	0	100.0%				211	179	90.7%
2979	trans-1,2-Dichloroethylene	0.1	1932	0	0	100.0%				211	179	90.7%
2955	Xylenes (total)	10	1932	0	0	100.0%				211	179	90.7%
2020	Toxaphene	0.003	NA	0	0	NA				0	0	NA
2036	Oxamyl (Vydate)	0.2	782	0	0	100.0%				63	63	91.9%
2040	Picloram	0.5	806	0	0	100.0%				64	64	92.1%
2037	Simazine	0.004	40	0	0	100.0%				5	5	87.5%
2976	Vinyl chloride	0.002	1932	0	0	100.0%				211	179	90.7%
2950	Total trihalomethanes	0.10	141	3	2	98.6%				2	2	98.6%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Inorganic Contaminants											
1074	Antimony	0.006	595	0	0	100.0%				67	67	88.7%
1005	Arsenic	0.05	738	0	0	100.0%				78	78	89.4%
1094	Asbestos	7 million fibers/l ≤ 10 μm long	56	0	0	100.0%				9	9	83.9%
1010	Barium	2	738	0	0	100.0%				48	48	93.5%
1075	Beryllium	0.004	596	0	0	100.0%				67	67	88.8%
1015	Cadmium	0.005	347	0	0	100.0%				48	48	86.2%
1020	Chromium	0.1	348	0	0	100.0%				48	48	86.2%
1024	Cyanide (as free cyanide)	0.2	57	0	0	100.0%				10	10	82.5%
1025	Fluoride	4.0	738	0	0	100.0%				61	61	91.7%
1035	Mercury	0.002	348	0	0	100.0%				48	48	86.2%
1040	Nitrate	10 (as Nitrogen)	5865	4	4	99.9%				1408	1402	76.1%
1041	Nitrite	1 (as Nitrogen)	183	0	0	100.0%				75	75	59.0%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
1045	Selenium	0.05	342	0	0	100.0%				48	48	86.0%
1085	Thallium	0.002	595	0	0	100.0%				66	66	88.9%
1038	Total nitrate and nitrite	10 (as Nitrogen)	NA	0	0	NA				0	0	NA

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Radionuclide MCLs											
4000	Gross alpha	15 pCi/l	458	3	1	99.8%				27	27	94.1%
4010	Radium-226 and radium-228	5 pCi/l	458	2	2	99.6%				0	0	100.0%
4100	Gross beta	4 mrem/yr	142	0	0	100.0%				3	3	97.9%
	All Chemical Groups Subtotal		5865	18	13	99.8%				7538	1690	71.2%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Total Coliform Rule											
21	Acute MCL violation	Presence	6137	951	724	88.2%						
22	Non-acute MCL violation	Presence	6137	590	544	91.1%						
23,25	Major routine and follow up monitoring		6137							2141	1371	77.7%
28	Sanitary survey ²									0	0	100.0%
	TCR Subtotal		6137	1541	756	87.7%				2141	1371	77.7%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Surface Water Treatment Rule											
	Filtered systems											
36	Monitoring		142							21	10	93.0%
41	Treatment techniques		165				261	48	70.9%			
	Unfiltered systems											
31	Monitoring		NA							0	0	NA
42	Failure to filter		142				2	2	98.6%			
	SWTR Subtotal						263	50	70.9%	21	10	93.0%

State:	OHIO
Reporting Interval:	JANUARY 1, 1997 - DECEMBER 31, 1997

SDWIS Codes		MCL (mg/l) ¹	Number of Systems Required to Sample during 1997	MCLs			Treatment Techniques			Significant Monitoring/Reporting		
				Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance	Number of Violations	Number of Systems With Violations	Percent of Systems in Compliance
	Lead and Copper Rule											
51	Initial lead and copper tap M/R		347							49	41	88.2%
52	Follow-up or routine lead and copper tap M/R		1339							207	207	84.5%
58,62	Treatment Installation		32				0	0	100.0%			
65	Public education		60				15	15	75.0%			
	Lead & Copper Subbtotal		1686				15	15	75.0%	256	248	85.3%

1. Values are in milligrams per liter (mg/l), unless otherwise specified.
2. Number of major monitoring violations for sanitary survey under the Total Coliform Rule

Definitions for Violations Table

The following definitions apply to the Summary of Violations table.

Filtered Systems: Water systems that have installed filtration treatment [40 CFR 141, Subpart H].

Inorganic Contaminants: Non-carbon-based compounds such as metals, nitrates, and asbestos. These contaminants are naturally-occurring in some water, but can get into water through farming, chemical manufacturing, and other human activities. EPA has established MCLs for 15 inorganic contaminants [40 CFR 141.62].

Lead and Copper Rule: This rule established national limits on lead and copper in drinking water [40 CFR 141.80-91]. Lead and copper corrosion pose various health risks when ingested at any level, and can enter drinking water from household pipes and plumbing fixtures. States report violations of the Lead and Copper Rule in the following six categories:

Initial lead and copper tap M/R: SDWIS Violation Code 51 indicates that a system did not meet initial lead and copper testing requirements, or failed to report the results of those tests to the State.

Follow-up or routine lead and copper tap M/R: SDWIS Violation Code 52 indicates that a system did not meet follow-up or routine lead and copper tap testing requirements, or failed to report the results.

Treatment installation: SDWIS Violation Codes 58 AND 62 indicate a failure to install optimal corrosion control treatment system (58) or source water treatment system (62) which would reduce lead and copper levels in water at the tap. [One number is to be reported for the sum of violations in these two categories].

Public education: SDWIS Violation Code 65 shows that a system did not provide required public education about reducing or avoiding lead intake from water.

Maximum Contaminant Level (MCL): The highest amount of a contaminant that EPA allows in drinking water. MCLs ensure that drinking water does not pose either a short-term or long-term health risk. MCLs are defined in milligrams per liter (parts per million) unless otherwise specified.

Monitoring: EPA specifies which water testing methods the water systems must use, and sets schedules for the frequency of testing. A water system that does not follow EPA's schedule or methodology is in violation [40 CFR 141].

States must report monitoring violations that are significant as determined by the EPA Administrator and in consultation with the States. For purposes of this report, significant monitoring violations are major violations and they occur when no samples are taken or no results are reported during a compliance period. A major monitoring violation for the surface water treatment rule occurs when at least 90% of the required samples are not taken or results are not reported during the compliance period.

Organic Contaminants: Carbon-based compounds, such as industrial solvents and pesticides. These contaminants generally get into water through runoff from cropland or discharge from

factories. EPA has set legal limits on 54 organic contaminants that are to be reported [40 CFR 141.61].

Radionuclides: Radioactive particles which can occur naturally in water or result from human activity. EPA has set legal limits on four types of radionuclides: radium-226, radium-228, gross alpha, and beta particle/photon radioactivity [40 CFR 141]. Violations for these contaminants are to be reported using the following three categories:

Gross alpha: SDWIS Contaminant Code 4000 for alpha radiation above MCL of 15 picocuries/liter. Gross alpha includes radium-226 but excludes radon and uranium.

Combined radium-226 and radium-228: SDWIS Contaminant Code 4010 for combined radiation from these two isotopes above MCL of 5 pCi/L.

Gross beta: SDWIS Contaminant Code 4101 for beta particle and photon radioactivity from man-made radionuclides above 4 millirem/year.

Reporting Interval: The reporting interval for violations to be included in the first PWS Annual Compliance Report, which is to be submitted to EPA by January 1, 1998, is from January 1, 1996 through December 31, 1996. This interval will change for future annual reports. See guidance language for these intervals.

SDWIS Code: Specific numeric codes from the Safe Drinking Water Information System (SDWIS) have been assigned to each violation type included in this report. The violations to be reported include exceeding contaminant MCLs, failure to comply with treatment requirements, and failure to meet monitoring and reporting requirements. Four-digit SDWIS Contaminant Codes have also been included in the chart for specific MCL contaminants.

Surface Water Treatment Rule: The Surface Water Treatment Rule establishes criteria under which water systems supplied by surface water sources, or ground water sources under the direct influence of surface water, must filter and disinfect their water [40 CFR 141, Subpart H]. Violations of the "Surface Water Treatment Rule" are to be reported for the following four categories:

Monitoring, routine/repeat (for filtered systems): SDWIS Violation Code 36 indicates a system's failure to carry out required tests, or to report the results of those tests.

Treatment techniques (for filtered systems): SDWIS Violation Code 41 shows a system's failure to properly treat its water.

Monitoring, routine/repeat (for unfiltered systems): SDWIS Violation Code 31 indicates a system's failure to carry out required water tests, or to report the results of those tests.

Failure to filter (for unfiltered systems): SDWIS Violation Code 42 shows a system's failure to properly treat its water. Data for this violation code will be supplied to the States by EPA.

Total Coliform Rule (TCR): The Total Coliform Rule establishes regulations for microbiological contaminants in drinking water. These contaminants can cause short-term health problems. If no samples are collected during the one month compliance period, a significant monitoring violation occurs. States are to report four categories of violations:

Acute MCL violation: SDWIS Violation Code 21 indicates that the system found fecal coliform or E. coli, potentially harmful bacteria, in its water, thereby violating the rule.

Non-acute MCL violation: SDWIS Violation Code 22 indicates that the system found total coliform in samples of its water at a frequency or at a level that violates the rule. For systems collecting fewer than 40 samples per month, more than one positive sample for total coliform is a violation. For systems collecting 40 or more samples per month, more than 5% of the samples positive for

total coliform is a violation.

Major routine and follow-up monitoring: SDWIS Violation Codes 23 AND 25 show that a system did not perform any monitoring. [One number is to be reported for the sum of violations in these two categories.]

Sanitary Survey: SDWIS Violation Code 28 indicates a major monitoring violation if a system fails to collect 5 routine monthly samples if sanitary survey is not performed.

Treatment Techniques: A water disinfection process that EPA requires instead of an MCL for contaminants that laboratories cannot adequately measure. Failure to meet other operational and system requirements under the Surface Water Treatment and the Lead and Copper Rules have also been included in this category of violation for purposes of this report.

Unfiltered Systems: Water systems that do not need to filter their water before disinfecting it because the source is very clean [40 CFR, Subpart H].

Violation: A failure to meet any state or federal drinking water regulation.