

Application No. OH0049999

Issue Date: June 6, 2016

Effective Date: July 1, 2016

Expiration Date: June 30, 2021

Ohio Environmental Protection Agency
Authorization to Discharge Under the
National Pollutant Discharge Elimination System

In compliance with the provisions of the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et. seq., hereinafter referred to as the "Act"), and the Ohio Water Pollution Control Act (Ohio Revised Code Section 6111),

Eastern Ohio Regional Wastewater Authority

is authorized by the Ohio Environmental Protection Agency, hereinafter referred to as "Ohio EPA," to discharge from authorized overflows and the Eastern Ohio Regional Wastewater Authority wastewater treatment works located at 6000 North Guernsey Street, Bellaire, Ohio, Belmont County and discharging to the Ohio River, McMahan Creek, Indian Run Creek, Pinch Run and Wheeling Creek in accordance with the conditions specified in Parts I, II, and III of this permit.

This permit is conditioned upon payment of applicable fees as required by Section 3745.11 of the Ohio Revised Code.

This permit and the authorization to discharge shall expire at midnight on the expiration date shown above. In order to receive authorization to discharge beyond the above date of expiration, the permittee shall submit such information and forms as are required by the Ohio EPA no later than 180 days prior to the above date of expiration.

Craig W. Butler
Director

Total Pages: 57

Part I, A. - FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements from the following outfall: 0PQ00000001. See Part II, OTHER REQUIREMENTS, for the location of the permitted outfall and the location to sample/monitor the effluent.

Table - Final Outfall - 001 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00010 - Water Temperature - C	-	-	-	-	-	-	-	1/Day	Maximum Indicating Thermometer	All
00045 - Total Precipitation - Inches	-	-	-	-	-	-	-	1/Day	24hr Total	All
00300 - Dissolved Oxygen - mg/l	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
00530 - Total Suspended Solids - mg/l	-	-	45	30	-	852	568	3/Week	24hr Composite	All
00552 - Oil and Grease, Hexane Extr Method - mg/l	10	-	-	-	-	-	-	1 / 2 Weeks	Grab	All
00610 - Nitrogen, Ammonia (NH3) - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All
00625 - Nitrogen Kjeldahl, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00630 - Nitrite Plus Nitrate, Total - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00665 - Phosphorus, Total (P) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00671 - Orthophosphate, Dissolved (as P) - mg/l	-	-	-	-	-	-	-	1/Month	Grab	All
00900 - Hardness, Total (CaCO3) - mg/l	-	-	-	-	-	-	-	1/Month	24hr Composite	All
00978 - Arsenic, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
00981 - Selenium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01129 - Molybdenum, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
31616 - Fecal Coliform - #/100 ml	-	-	400	200	-	-	-	3/Week	Grab	Summer
31616 - Fecal Coliform - #/100 ml	-	-	2000	1000	-	-	-	3/Week	Grab	Winter
50050 - Flow Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
61425 - Acute Toxicity, Ceriodaphnia dubia - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	July
61427 - Acute Toxicity, Pimephales promelas - TUa	-	-	-	-	-	-	-	1/Year	24hr Composite	July
61941 - pH, Maximum - S.U.	9.0	-	-	-	-	-	-	1/Day	Multiple Grab	All
61942 - pH, Minimum - S.U.	-	6.5	-	-	-	-	-	1/Day	Multiple Grab	All
70300 - Residue, Total Filterable - mg/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
80082 - CBOD 5 day - mg/l	-	-	40	25	-	757	473	3/Week	24hr Composite	All

Notes for station 0PQ00000001:

* EFFLUENT LOADINGS - effluent loadings based on average design flow of 5.0 MGD.

a. ORTHOPHOSPHATE MONITORING - See Part II, Item Q.

b. METALS - Nickel, zinc, cadmium, lead, total chromium and copper - See Part II, Item S,1.

c. METALS - Dissolved hexavalent chromium and mercury - see Part II, Item S,2.

d. MERCURY - See Part II, Item R.

e. ACUTE TOXICITY - See Part II, Item V.

f. MULTIPLE GRAB - For Dissolved Oxygen report lowest value; for pH report highest and lowest value; see also Part II, Item L.

g. REPORTING CODES FOR MONITORING/SAMPLING.- See Part II, Item D.

h. FLOW RATE- Flow may be reported using the influent flow meter to be consistent with past practice until such time that an effluent meter may be installed.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

1. CSO Monitoring. The monitoring tables for the 29 Combined Sewer Overflow (CSO) stations listed below are identical to this one, which is for Station Number 0PQ00000 002. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at all of the stations listed below in accordance with the following representative table. The permittee shall report monitoring results for the individual stations to the Ohio EPA as specified below. See Part II, OTHER REQUIREMENTS, for the location to sample and monitor the overflows.

Table - CSO Monitoring - 002 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
82517 - Duration of Discharge - Hours	-	-	-	-	-	-	-	When Disch.	Total	All

NOTES for CSO Station Numbers listed below:

a. APPLICABLE OUTFALLS - The permittee shall monitor at the following CSO outfalls in accordance with the table for outfall 0PQ00000002 above:

- . 0PQ00000002 0PQ00000003 0PQ00000005 0PQ00000006
- . 0PQ00000008 0PQ00000009 0PQ00000010 0PQ00000011
- . 0PQ00000012 0PQ00000013 0PQ00000014 0PQ00000015
- . 0PQ00000016 0PQ00000017 0PQ00000018 0PQ00000023
- . 0PQ00000034 0PQ00000035 0PQ00000036 0PQ00000039
- . 0PQ00000040 0PQ00000041 0PQ00000042 0PQ00000045
- . 0PQ00000047 0PQ00000048 0PQ00000049 0PQ00000050
- . 0PQ00000051

NOTES for CSO Stations (continued):

b. **DISCHARGE AUTHORIZATION** - Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from these stations only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.

c. **DISCHARGE MONITORING REPORTS (DMR)** - A Discharge Monitoring Report (Form 4500) for each of these stations must be submitted every month. If there is no discharge for one of these outfalls during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.

d. **OVERFLOW OCCURRENCE** - Data for Overflow Occurrence may be estimated if a measuring device is not available.

e. **OVERFLOW OCCURRENCES**: If a discharge from one of these stations occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from the station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.

f. **OVERFLOW VOLUME** - Reporting Overflow Volume is not required until a measuring device is installed at a station. Once a measuring device is installed and maintained without complication, Overflow Volume shall be reported on each day there is a discharge through the station.

g. **OVERFLOW DURATION** - Reporting Overflow Duration is not required until a measuring device is installed at a station. Once a device is installed, Overflow Duration shall be measured on each day there is a discharge through the station. Duration of the discharge shall be reported as the total duration for the month. Report total duration for the month on Day 1 of the DMR.

h. **MONITORING/REPORTING REQUIREMENTS AND REPORTING CODES FOR MONITORING/SAMPLING** - See Part II, Item D.

Part I, B. - CSO MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

2. CSO Monitoring. The monitoring tables for the 3 Combined Sewer Overflow (CSO) stations listed below are identical to this one, which is for Station Number 0PQ00000007. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at all of the stations listed below in accordance with the following representative table. The permittee shall report monitoring results for the individual stations to the Ohio EPA as specified below. See Part II, OTHER REQUIREMENTS, for the location to sample and monitor the overflows.

Table - CSO Monitoring - 007 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
	Maximum	Minimum	Weekly	Monthly	Daily				Weekly	Monthly
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly-tox1
31616 - Fecal Coliform - #/100 ml	-	-	-	-	-	-	-	1/Month	Grab	Summer
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	When Disch.	Total	All
74063 - Overflow Volume - Million Gallons	-	-	-	-	-	-	-	When Disch.	24hr Total	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly-tox1
82517 - Duration of Discharge - Hours	-	-	-	-	-	-	-	When Disch.	Total	All

NOTES for CSO Station Numbers 0PQ00000007, 0PQ00000044 and 0PQ00000046:

- a. **APPLICABLE OUTFALLS** - The permittee shall monitor at the following CSO outfalls in accordance with the table for outfall 0PQ00000007 above: 0PQ00000007, 0PQ00000044 and 0PQ00000046.
- b. **DISCHARGE AUTHORIZATION** - Subject to the terms and conditions of this permit, including the General Effluent Limitations in Part III, Item 2, the permittee is authorized to discharge from these stations only during wet weather periods when the flow in the sewer system exceeds the capacity of the sewer system.
- c. **DISCHARGE MONITORING REPORTS (DMR)** - A Discharge Monitoring Report (Form 4500) for each of these stations must be submitted every month. If there is no discharge for one of these outfalls during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.

NOTES for CSO Station Numbers 0PQ00000007, 0PQ00000044 and 0PQ00000046 (continued):

d. OVERFLOW OCCURRENCE, DURATION AND VOLUME - Data for Overflow Occurrence and Overflow Volume and Duration of Discharge may be estimated if a measuring device is not available.

e. OVERFLOW OCCURRENCES: If a discharge from one of these stations occurs intermittently during a day, starting and stopping several times, count "1" occurrence for that day. If a discharge from the station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence. Report total occurrences for the month on Day 1 of the DMR.

f. OVERFLOW VOLUME - Overflow Volume shall be reported on each day there is a discharge through each of these stations.

g. OVERFLOW DURATION - Duration of the discharge shall be reported as the total duration for the month. Report total duration for the month on Day 1 of the DMR.

h. "QUARTERLY-TOX1" monitoring shall be reported in January, April, July, and October. Sample results reported and samples collected shall be done as follows:

. For results reported in:	Samples shall be collected in:
. April	January, February, or March
. July	April, May, or June
. October	July, August, or September
. January	October, November, or December

i. FECAL COLIFORM SAMPLING - Sampling for Fecal Coliform shall be conducted 1/Month during the summer months. The sample shall be collected no later than 90 minutes after a discharge begins.

Part I, B. - SSO MONITORING EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

3. SSO Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor at Station Number 0PQ00000300, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - SSO Monitoring - 300 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly
74062 - Overflow Occurrence - No./Month	-	-	-	-	-	-	-	1/Month	Total	All

Notes for Station Number 0PQ00000300:

- a. **SANITARY SEWER OVERFLOW DEFINITION** - A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. Although the above table indicates that the Measuring Frequency for Overflow Occurrence is 1/Month, the intent of that provision is to specify a reporting frequency for Overflow Occurrence, not a monitoring frequency. The monitoring requirement under this permit is that these overflows shall be monitored on each day when they discharge. Only sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, must be reported under this monitoring station.
- b. **OVERFLOW OCCURENCES** - For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day that enters waters of the state is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, record two occurrences for that day. If overflows from both locations continue on the following day, record two occurrences for the following day. At the end of the month, total the daily occurrences and report this number on Day 1 of the DMR. If there are no overflows during the entire month, report "zero" (0).
- c. **SSOs PROHIBITED** - All sanitary sewer overflows are prohibited.
- d. **SSO ADDITIONAL REQUIREMENTS** - See Part II, Item G.

Part I, B. - SLUDGE MONITORING REQUIREMENTS

4. Sludge Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' final sludge at Station Number 0PQ00000581, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sludge sampling.

Table - Sludge Monitoring - 581 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00611 - Ammonia (NH3) In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00627 - Nitrogen Kjeldahl, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00668 - Phosphorus, Total In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
00938 - Potassium In Sludge - mg/kg	-	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01003 - Arsenic, Total In Sludge - mg/kg	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01028 - Cadmium, Total In Sludge - mg/kg	85	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01043 - Copper, Total In Sludge - mg/kg	4300	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01052 - Lead, Total In Sludge - mg/kg	840	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01068 - Nickel, Total In Sludge - mg/kg	420	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01093 - Zinc, Total In Sludge - mg/kg	7500	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
01148 - Selenium, Total In Sludge - mg/kg	100	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.
51129 - Sludge Fee Weight - dry tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly - Alt.
51131 - Fecal Coliform in Sludge - CFU/gram	2000000	-	-	-	-	-	-	When Disch.	Multiple Grab	Quarterly - Alt.
70316 - Sludge Weight - Dry Tons	-	-	-	-	-	-	-	1/Quarter	Total	Quarterly - Alt.
71921 - Mercury, Total In Sludge - mg/kg	57	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
78465 - Molybdenum In Sludge - mg/kg	75	-	-	-	-	-	-	1/Quarter	Composite	Quarterly - Alt.

Notes for Station Number 0PQ00000581:

a. **MONITORING IS REQUIRED** - Monitoring is required when sewage sludge is removed from the permittee's facility for application to the land. The monitoring data shall be reported on March, June, September, and December Discharge Monitoring Reports (DMR). The monitoring data can be collected at any time during the reporting period.

b. **"QUARTERLY -ALT." SAMPLING** - Quarterly alternate sampling results shall be reported in March, June, September and December. If no discharge occurs during these particular months, data must still be collected and reported if there is a discharge during that calendar quarter period. If sampling data is collected outside the months listed above, report the results on the Monthly Operating Report Form for the month that the data was collected.

c. **METALS** - Metal pollutant analysis must be completed during each reporting period, whether sewage sludge is removed from the facility or not, or the number of composite samples collected and reported shall be increased prior to the next land application event to account for the reporting period(s) in which land application did not occur, unless all previously accumulated sewage sludge has been removed and disposed of via a landfill, through incineration or by transfer to another treatment works.

Notes for Station Number 0PQ00000 581 (continued):

d. **NO SLUDGE REMOVED** - If no sewage sludge is removed from the facility during the reporting period, enter the results for the metal analysis in eDMR or on the 4500 report and enter 0 for sludge weight and sludge fee weight.

- If no sewage sludge is removed from the facility during the reporting period and no metal analysis is completed during the reporting period, select the "No Discharge" check box on the data entry form. PIN the eDMR.

e. **IF METAL ANALYSIS HAS NOT BEEN COMPLETED PREVIOUSLY DURING EACH REPORTING PERIOD** - When sewage sludge is removed from the facility all metal analysis results shall be reported on the applicable DMR by entering the separate results on different days within the DMR. For example, if no sewage sludge has been removed from the facility for a full calendar year, and quarterly monitoring is required by the permit, then five (four from the previous year and one for the current monitoring period) separate composite samples of the sewage sludge are required to be collected and analyzed for metals prior to removal from the facility. The first sample result may be entered on the first day of the DMR, the second result on the second day of the DMR, and so on. A note may then be added to indicate the actual day(s) when the samples were collected.

f. **COMPOSITE SAMPLES** - It is recommended that composite samples of the sewage sludge be collected and analyzed close enough to the time of land application to be reflective of the sludge's current quality, but not so close that the results of the analysis are not available prior to land applying the sludge.

Notes for Station Number 0PQ00000581 (continued):

g. RECORDS FOR VECTOR ATTRACTION AND PATHOGEN REDUCTION - The permittee shall maintain the appropriate records on site to verify that the requirements of Pathogen Reduction and Vector Attraction Reduction have been met.

h. FECAL COLIFORM

(i). "When Discharging" frequency means that IF the Pathogen Reduction Method used is fecal coliform, samples must be taken and reported 1/Quarter (March, June, September and December). If fecal coliform is not the PR method, use the "AH" for this parameter once a quarter.

(ii). To sample for fecal coliform, the treatment plant should collect seven grab samples. Each of the grab samples shall be analyzed independently to determine the CFU/g of fecal coliform in the individual sample. The geometric mean of those seven results shall be reported on the DMR. Each fecal coliform sample must be delivered to the analytical lab within six hours after the sample has been collected, in accordance with the requirements for Part 9222 D., "Standard Methods for the Examination of Water and Wastewater". This process must be completed prior to sewage sludge being removed from the treatment facility.

i. SLUDGE WEIGHT - Sludge weight is a calculated total for the year. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: $\text{dry tons} = \text{gallons} \times 8.34 \text{ (lbs/gallon)} \times 0.0005 \text{ (tons/lb)} \times \text{decimal fraction total solids}$.

j. SLUDGE FEE WEIGHT - Sludge fee weight means sludge weight, in dry U.S. tons, excluding any admixtures such as liming material or bulking agents.

k. UNITS - Units of mg/kg are on a dry weight basis.

l. ADDITIONAL SLUDGE REQUIREMENTS - See Part II, Item P.

Part I, B. - INFLUENT MONITORING REQUIREMENTS

5. Influent Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment works' influent wastewater at Station Number 0PQ00000601, and report to the Ohio EPA in accordance with the following table. Samples of influent used for determination of net values or percent removal must be taken the same day as those samples of effluent used for that determination. See Part II, OTHER REQUIREMENTS, for location of influent sampling.

Table - Influent Monitoring - 601 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months		
Maximum	Minimum	Weekly	Monthly	Daily	Weekly				Monthly	
00530 - Total Suspended Solids - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All
00978 - Arsenic, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
00981 - Selenium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01074 - Nickel, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01094 - Zinc, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01113 - Cadmium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01114 - Lead, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01118 - Chromium, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01119 - Copper, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01129 - Molybdenum, Total Recoverable - ug/l	-	-	-	-	-	-	-	1/Quarter	24hr Composite	Quarterly
01220 - Chromium, Dissolved Hexavalent - ug/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
50047 - Flow, Peak Rate - MGD	-	-	-	-	-	-	-	1/Day	Continuous	All
50092 - Mercury, Total (Low Level) - ng/l	-	-	-	-	-	-	-	1/Quarter	Grab	Quarterly
61941 - pH, Maximum - S.U.	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
61942 - pH, Minimum - S.U.	-	-	-	-	-	-	-	1/Day	Multiple Grab	All
80082 - CBOD 5 day - mg/l	-	-	-	-	-	-	-	3/Week	24hr Composite	All

Notes for Station Number 0PQ00000601:

- a. METALS - Nickel, zinc, cadmium, lead, arsenic, selenium, molybdenum, total chromium and copper - See Part II, Item S,1.
- b. METALS - Dissolved hexavalent chromium and mercury - see Part II, Item S,2 and S,3.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

6. Bypass Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 0PQ00000602, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 602 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	Total	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All

Notes for Station Number 0PQ00000602:

- a. ESTIMATES ARE ACCEPTABLE - Data for 24 hr total volume, bypass occurrence and bypass total hours per day may be estimated if a measuring device is not available.
- b. MONITOR WHEN DISCHARGING - Monitoring shall be conducted and reported on each day that there is a discharge through this station.
- c. BYPASS OCCURENCE - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- d. DISCHARGE MONITORING REPORTS (DMR) - A Discharge Monitoring Report (Form 4500), for this station must be submitted every month. If there are no discharges during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.
- e. BYPASSES ARE PROHIBITED - Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

7. Bypass Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 0PQ00000603, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 603 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	Total	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All

Notes for Station Number 0PQ00000603:

- a. ESTIMATES ARE ACCEPTABLE - Data for 24 hr total volume, bypass occurrence and bypass total hours per day may be estimated if a measuring device is not available.
- b. MONITOR WHEN DISCHARGING - Monitoring shall be conducted and reported on each day that there is a discharge through this station.
- c. BYPASS OCCURENCE - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- d. DISCHARGE MONITORING REPORTS (DMR) - A Discharge Monitoring Report (Form 4500), for this station must be submitted every month. If there are no discharges during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.
- e. BYPASSES ARE PROHIBITED - Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

8. Bypass Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 0PQ00000604, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 604 - Final

Effluent Characteristic Parameter	Discharge Limitations						Monitoring Requirements			
	Concentration Specified Units		Loading* kg/day				Measuring	Sampling	Monitoring	
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly	Frequency	Type	Months
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	Total	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All

Notes for Station Number 0PQ00000604:

- a. ESTIMATES ARE ACCEPTABLE - Data for 24 hr total volume, bypass occurrence and bypass total hours per day may be estimated if a measuring device is not available.
- b. MONITOR WHEN DISCHARGING - Monitoring shall be conducted and reported on each day that there is a discharge through this station.
- c. BYPASS OCCURENCE - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- d. DISCHARGE MONITORING REPORTS (DMR) - A Discharge Monitoring Report (Form 4500), for this station must be submitted every month. If there are no discharges during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.
- e. BYPASSES ARE PROHIBITED - Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - BYPASS MONITORING LIMITATIONS AND MONITORING REQUIREMENTS

9. Bypass Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the treatment plant's bypass when discharging, at Station Number 0PQ00000605, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Bypass Monitoring - 605 - Final

Effluent Characteristic Parameter	Discharge Limitations							Monitoring Requirements		
	Concentration Specified Units				Loading* kg/day			Measuring Frequency	Sampling Type	Monitoring Months
	Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly			
00051 - Bypass Occurrence - No./Day	-	-	-	-	-	-	-	When Disch.	Total	All
00052 - Bypass Total Hours Per Day - Hrs/Day	-	-	-	-	-	-	-	When Disch.	Total	All
51428 - Bypass Volume - MGAL	-	-	-	-	-	-	-	When Disch.	24hr Total	All

Notes for Station Number 0PQ00000605:

- a. ESTIMATES ARE ACCEPTABLE - Data for 24 hr total volume, bypass occurrence and bypass total hours per day may be estimated if a measuring device is not available.
- b. MONITOR WHEN DISCHARGING - Monitoring shall be conducted and reported on each day that there is a discharge through this station.
- c. BYPASS OCCURENCE - If a discharge from this station occurs intermittently during a day, starting and stopping several times, report "1" for that day. If a discharge from this station occurs on more than one day but is the result of a continuing precipitation event, it should be counted as one occurrence: Report "1" on the first day of the discharge.
- d. DISCHARGE MONITORING REPORTS (DMR) - A Discharge Monitoring Report (Form 4500), for this station must be submitted every month. If there are no discharges during the entire month select the "No Discharge" check box on the data entry form. PIN the eDMR.
- e. BYPASSES ARE PROHIBITED - Discharge through this station is prohibited. The Director may take enforcement action for violations of this prohibition unless the three conditions specified at 40 CFR 122.41(m) and in Part III, Item 11.C.1 of this permit are met.

Part I, B. - UPSTREAM MONITORING REQUIREMENTS

10. Upstream Monitoring. During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee shall monitor the receiving stream, upstream of the point of discharge at Station Number 0PQ00000801, and report to the Ohio EPA in accordance with the following table. See Part II, OTHER REQUIREMENTS, for location of sampling.

Table - Upstream Monitoring - 801 - Final

<u>Effluent Characteristic</u> Parameter	<u>Discharge Limitations</u>						<u>Monitoring Requirements</u>			
	Concentration Specified Units		Loading* kg/day				Measuring Frequency	Sampling Type	Monitoring Months	
Maximum	Minimum	Weekly	Monthly	Daily	Weekly	Monthly				
61432 - 48-Hr. Acute Toxicity Ceriodaphnia dubia - % Affected	-	-	-	-	-	-	-	1/Year	Grab	July
61435 - 96-Hr. Acute Toxicity Pimephales promela - % Affected	-	-	-	-	-	-	-	1/Year	Grab	July

Notes for Station Number 0PQ00000801:

a. ACUTE TOXICITY/BIOMONITORING - See Part II, Item V.

Part I, C - Schedule of Compliance

1. COMBINED SEWER OVERFLOW LONG TERM CONTROL PLAN

The permittee shall implement its Long Term Control Plan (LTCP), which was approved by the Director on June 21, 2011 as Plan Approval Number 659884, as expeditiously as possible, but not later than the dates developed in accordance with the following schedule:

The permittee's "Long Term Control Plan" (dated July 2008 and received on July 31, 2008 with final revisions received on June 25, 2010 and amended schedule received on January 14, 2016) includes an acceptable implementation schedule for the Authority to control its combined sewer overflows to four (4) or less during a typical year.

The following projects are to be completed as specified below. (Notification shall be given to Ohio EPA Southeast District Office within 7 days completion of each project)

- a. Optimization of the WWTP to achieve peak hydraulic conditions of 15 MGD no later than February 1, 2017. (event code 04599)
- b. Complete construction of Indian Run Lift Station force main replacement no later than February 1, 2018. This project is needed in order to optimize flow to the WWTP. (event code 04599)
- c. Complete construction of Bridgeport Lift Station force main replacement no later than February 1, 2018. This project is needed in order to optimize flow to the WWTP. (event code 04599)
- d. EORWA shall update through either renewal or modification the permits issued to the Village of Bellaire, City of Martins Ferry, and Village of Bridgeport by no later than July 1, 2016 to include compliance schedules for projects to be completed by each entity on their respective collection system. Copies of the issued permits shall be submitted to the Ohio EPA Southeast District Office by no later than July 1, 2016. (event code 24099)

These modified permits shall require each entity have a capital improvement fund with the following minimum annual revenue:

Village of Bellaire	\$52,000
City of Martins Ferry	\$40,000
Village of Bridgeport	\$16,000

EORWA shall require each entity submit an annual financial statement once every twelve months.

The projects to be included in the updated permits by community are as follows: (Notification shall be given to Ohio EPA Southeast District Office within 7 days completion of each project)

- i. Village of Bellaire

- (a) 49st Street Improvements tributary to outfall 016 to be completed no later than December 31, 2018. (event code 04599)
- (b) Belmont Street Sanitary Improvements tributary to outfalls 005, 006, 007, 008 and 009 to be completed no later than December 31, 2020. (event code 04599)
- (c) Indian Run Creek/Culvert Dredging feasibility study to be completed no later than December 31, 2021.(event code 20099)
- (d) Trumbull Street Improvements tributary to outfall 023 to be completed no later than December 31, 2022. (event code 04599)
- (e) 32nd, 33rd, and 34th Street Improvements tributary to outfalls 011, 012, and 013 to be completed no later than December 31, 2025. (event code 04599)
- (f) 41st, Noble, Trumbull Street and Cherry Alley Improvements tributary to outfalls 017, 018, and 050 to be completed no later than December 31, 2025. (event code 04599)

ii. City of Martins Ferry

- (a) First and Jefferson Street Improvements tributary to outfall 045 to be completed no later than December 31, 2018.(event code 04599)
- (b) First and Avondale Street Improvements tributary to outfall 047 to be completed no later than December 31, 2019. (event code 04599)
- (c) Second Street (Staffilinos) Improvements tributary to outfall 048 to be completed no later than February 1, 2021.(event code 04599)
- (d) First and Monroe Street Improvements tributary to outfall 044 to be completed no later than February 1, 2023. (event code 04599)

iii. Village of Bridgeport

- (a) West Street Improvements tributary to outfall 040 to be completed no later than December 31, 2018. (event code 04599)
- (b) Bennet Street Improvements tributary to outfall 034 to be completed no later than February 1, 2019. (event code 04599)
- (c) Water Street Improvements tributary to outfall 035 to be completed no later than February 1, 2020. (event code 04599)
- (d) West and Howard Street Improvements tributary to outfall 051 to be completed no later than February 1, 2021. (event code 04599)
- (e) Marion Street Improvements tributary to outfall 036 to be completed no later than February 1, 2024. (event code 04599)

e. Annual Combined Sewer Overflow Report

On June 1, 2016, and annually thereafter, the permittee shall submit two copies of a report summarizing its combined sewer overflow (CSO) discharges and CSO control activities during the previous calendar year. One copy of the report shall be sent to the Ohio EPA, Division of Surface Water, Permitting and Compliance Section, P.O. Box 1049, Columbus, Ohio, 43216-1049; and one copy shall be sent to the Ohio EPA Southeast District Office. (Event Code 95999)

The report shall include:

An annual summary of the frequency, volume and duration of CSO discharges. Information shall be provided for each CSO station and WWTP bypass.

A summary of actions taken to implement the nine minimum controls listed in Part II, Item E. This will include an evaluation of the need to modify the operation and maintenance program to reflect changes in the collection system, changes in operation and maintenance procedures, or other changes in activities resulting from Long-Term Control Plan implementation.

A summary of actions taken to implement the permittee's Long-Term Control Plan.

f. Long-Term Control Plan Post-Construction Compliance Monitoring Plan

The permittee shall perform the post-construction compliance monitoring plan to adequately characterize any remaining volumes and occurrences for CSOs and wastewater treatment plant bypasses.

This NPDES permit, Ohio EPA permit number 0PQ00000*OD, expires on June 30, 2021. This Schedule of Compliance includes items that extend beyond the term of the permit. The requirements of these compliance schedule items, including the compliance dates, will be included in permit 0PQ00000*PD when it is renewed.

2. Municipal Pretreatment Schedule

a. The permittee shall evaluate the adequacy of local industrial user limitations to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the POTW in amounts that exceed water quality standard-based limits, be incompatible with the POTW, or limit wastewater or sludge use options. Technical justification for revising local industrial user limitations to attain compliance with final table limits, along with a pretreatment program modification request, or technical justification for retaining existing local industrial user limitations shall be submitted to Ohio EPA, Central Office Pretreatment Unit and to Ohio EPA, Southeast District Office, as soon as possible, but no later than six months from the effective date of this permit. (Event Code 52599)

Technical justification is required for arsenic, cadmium, total chromium, dissolved hexavalent chromium, copper, free cyanide, lead, mercury, molybdenum, nickel, selenium, silver, and zinc unless screening of wastewater and sludge indicate these pollutants are not present in significant amounts. Technical justification is also required for any other pollutants where a local limit may be necessary to protect against pass through, interference or sludge disposal.

To demonstrate technical justification for new local industrial user limits or justification for retaining existing limits, a local limits technical justification report shall be submitted to Ohio EPA. The report shall be consistent with the guidance, procedures and methodologies found in Ohio EPA's and USEPA's local limits guidance documents available at <http://epa.ohio.gov/dsw/pretreatment/guidance.aspx>.

The report shall include the following:

- i. Identification of and justification for pollutants of concern for which local limits will be developed.
- ii. Treatment plant flow and industrial flows to which local limits will be applied. If the POTW is accepting any hauled waste include for each type of hauled waste (e.g. landfill leachate, septage), at least 5 data points detailing the dates and volumes of discharge and sampling results for all the pollutants of concern.]
- iii. Domestic/background concentrations. To determine domestic/background concentrations, the permittee shall, at a minimum, sample at three different locations for five consecutive days or two different locations for seven consecutive days. These locations shall, to the extent possible, convey only domestic wastewater.
- iv. Treatment plant removal efficiencies. Whenever possible, site specific removal efficiencies shall be determined using actual plant data with analytical detection levels that are sensitive enough to provide values above the reporting level (RL) or practical quantification limit (PQL).
- v. A comparison of maximum allowable headworks loadings based on all applicable criteria. Criteria may include sludge disposal, NPDES permit limits, waste load allocation values, and interference with biological processes such as activated sludge, sludge digestion, nitrification, etc. Calculation tables can be found on the Ohio EPA website at is <http://www.epa.ohio.gov/dsw/pretreatment/guidance.aspx>.

- vi. If revised industrial user discharge limits are proposed, the method of allocating available pollutant loads to industrial users.
 - vii. If narrative or best management practices (BMPs) are proposed as local limits, information on how they will be implemented. When appropriate, industrial user discharge limits may include narrative local limits requiring industrial users to develop and implement BMPs. These narrative local limits may be used either alone or as a supplement to numeric limits.
 - viii. Supporting data, assumptions, and methodologies used in establishing the information in item 1.a through 1.g above.
 - ix. The stamp and signature of a licensed Ohio professional engineer.
- b. Revisions. The permittee shall submit a revised local limit technical justification report within 90 days of receiving notification from Ohio EPA of deficiencies in the submitted report.
 - c. If revisions to local industrial user limitations including best management practices are determined to be necessary, the permittee shall incorporate revised local industrial user limitations in all industrial user control documents, as applicable, no later than 4 months after the date of Ohio EPA's approval.
 - d. Sampling Methods
 - i. Mercury: If the permittee uses EPA Method 245.1 or 245.2 to sample domestic background locations and mercury concentrations are below detection, the permittee shall use EPA method 1631 or 245.7 to quantify domestic background contributions of mercury.
 - ii. Free Cyanide: The permittee shall use ASTM D7237 or OIA-1677-09 - flow injection followed by gas diffusion amperometry to quantify domestic background contributions of free cyanide.

Part II, Other Requirements

A. OPERATOR CERTIFICATION REQUIREMENTS

1. Classification

- a. In accordance with Ohio Administrative Code 3745-7-04, the sewage treatment facility at this facility shall be classified as a Class III facility.
- b. All sewerage (collection) systems that are tributary to this treatment works are Class II sewerage systems in accordance with paragraph (B)(1)(a) of rule 3745-7-04 of the Ohio Administrative Code.

2. Operator of Record

- a. The permittee shall designate one or more operator of record to oversee the technical operation of the treatment works and sewerage (collection) system in accordance with paragraph (A)(2) of rule 3745-7-02 of the Ohio Administrative Code.
- b. Each operator of record shall have a valid certification of a class equal to or greater than the classification of the treatment works as defined in Part II, Item A.1 of this NPDES permit.
- c. Within three days of a change in an operator of record, the permittee shall notify the Director of the Ohio EPA of any such change on a form acceptable to Ohio EPA. The appropriate form can be found at the following website:

<http://epa.ohio.gov/dsw/opcert/opcert.aspx>

- d. Within 60 days of the effective date of this permit, the permittee shall notify the Director of Ohio EPA of the operators of record on a form acceptable to Ohio EPA.
- e. The operator of record for a class II, III, or IV treatment works or class II sewerage system may be replaced by a backup operator with a certificate one classification lower than the treatment works or sewerage system for a period of up to thirty consecutive days. The use of this provision does not require notification to the agency.
- f. Upon proper justification, such as military leave or long term illness, the director may authorize the replacement of the operator of record for a class II, III, or IV treatment works or class II sewerage system by a backup operator with a certificate one classification lower than the facility for a period of greater than thirty consecutive days. Such requests shall be made in writing to the appropriate district office.

OPERATOR CERTIFICATION REQUIREMENTS (con't)

3. Minimum Staffing Requirements

- a. The permittee shall ensure that the treatment works operator of record is physically present at the facility in accordance with the minimum staffing requirements per paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code or the requirements from an approved 3745-7-04(C) minimum staffing hour reduction plan.
- b. Sewerage (collection) system Operators of Record are not required to meet minimum staffing requirements in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.
- c. If Ohio EPA approves a reduction in minimum staffing requirements based upon a facility operating plan, any change in the criteria under which the operating plan was approved (such as enforcement status, history of noncompliance, or provisions included in the plan) will require that the treatment works immediately return to the minimum staffing requirements included in paragraph (C)(1) of rule 3745-7-04 of the Ohio Administrative Code.

B. SAMPLING/MONITORING LOCATIONS AND DESCRIPTIONS

Description of the location of the permitted discharge outfalls and required sampling/monitoring stations are as follows:

Permitted Outfall or Effluent Sampling/ Monitoring Station	Description of Permitted Outfall or Effluent Sampling/ Monitoring Location
OPQ00000001 . .	Final effluent. Sample to be taken after disinfection prior to discharge to Ohio River. (Lat: 40 N 02.667'; Long: 80 W 43.900')
OPQ00000581 OPQ00000586 .	Sludge removed from the anaerobic digester for land application. Sludge removed from the anaerobic digester for disposal at an approved landfill.
OPQ00000601 OPQ00000801 OPQ00000300 OPQ00000602 .	Raw influent ahead of grit removal system. Upstream of the OPQ00000 001 discharge, in the Ohio River Any sanitary sewer overflow from EORWA's sewers Internal Bypass - from influent to primary clarification, bypassing preliminary treatment.
OPQ00000603 .	Internal Bypass - from influent to screw pumps, bypassing preliminary and primary treatment.
OPQ00000604 .	Internal Bypass - primary clarification effluent to disinfection, bypassing secondary treatment.
OPQ00000605 .	Internal Bypss - secondary clarification effluent through off line chlorine contact tanks to final outfall.

C. CSO STATION MONITORING - Overflow Occurrences, Duration, and Volume

The following CSO Stations shall be monitored for overflow occurrences, duration, and volume in accordance with the requirements under Part I, B.:

Sampling Station	Description of Location	Receiving Water
Village of Bellaire:		
0PQ00000 002	McMahon Lift Station	McMahon Creek
.	40 N 00.505' W 80-44.572	
0PQ00000 003	Indian Run Lift Station	Indian Run Creek
.	N 40-01.232 W 80-44.389	
0PQ00000 005	Pinch Run Lift Station	Pinch Run
.	N 39-00.632 W 80-44.483	
0PQ00000 006	R-7 Regulator 17th Street & Grape Alley from 17th Street Lift Station	Ohio River
.	N 40-00.191 W 80-44.509	
0PQ00000 007	R-8 Regulator 19th St. & Union St.	Ohio River
.	N 40-00.359 W 80-44.551	
0PQ00000 008	R-9 Regulator 21 St. & Union St.	Ohio River
.	N 40-00.400 W 80-44.554	
0PQ00000 009	R-10 Regulator 25th Street	Ohio River
.	N 40-00.550 W 80-44.535	
0PQ00000 010	R-11 Regulator Crescent St. from Crescent St. Lift Station	Ohio River
.	N 40-00.709 W 80-44.512	
.		

CSO STATION MONITORING (con't)

0PQ00000011	R-12 Regulator 32nd Street N 40-00.791 W 80-44.482	Ohio River
0PQ00000012	R-13 Regulator 33rd Street N 40-00.875 W 80-44.475	Ohio River
0PQ00000013	R-14 Regulator 34th Street N 40-00.942 W 80-44.465	Ohio River
0PQ00000014	R-15 Regulator 46th Street N 40-01.685 W 80-44.248	Ohio River
0PQ00000015	R-16 Regulator 48th Street N 40-01.851 W 80-44.177	Ohio River
0PQ00000016	R-17 Regulator 49th Street Lift Station N 40-01.901 W 80-44.155	Ohio River
0PQ00000017	R-19 Regulator 41st St. & Noble St. N 40-01.314 W 80-44.560	Indian Run Creek
0PQ00000018	R-27 Regulator 41st St. & Trumbull N 40-01.355 W 80-44.699	Indian Run Creek
0PQ00000023	Diversion Manhole-70 N 40-01.362 W 80-44.721	Indian Run Creek
0PQ00000050	R-41 Regulator 41st Street & Chestnut Alley N 40-01.325 W 80-44.585	Indian Run Creek

Village of Bridgeport:

0PQ00000034	R-20 Regulator Bennet Street N 40-04.133 W 80-44.378	Wheeling Creek
0PQ00000035	R-25 Regulator Water Street N 40-04.231 W 80-45.017	Wheeling Creek
0PQ00000036	Diversion Manhole-326 Marion Street N 40-04.254 W 80-44.730	Wheeling Creek
0PQ00000039	Diversion Manhole-293A Water Street N 40-04.233 W 80-45.019	Wheeling Creek
0PQ00000040	Diversion Manhole-285A West Street Regulator N 40-04.176 W 80-45.125	Wheeling Creek

CSO STATION MONITORING (con't)

0PQ00000041	Rhodes Street Lift Station	Wheeling Creek
.	N 40-04.259 W 80-44.895	
0PQ00000042	Bridgeport Lift Station	Ohio River
.	N 40-04.373 W 80-44.379	
0PQ00000051	Diversion Manhole-288A	Wheeling Creek
.	West & Howard Street	
.	N 40-04.115 W 80-45.288	

City of Martins Ferry:

0PQ00000044	R-6 Regulator 1st & Monroe St.	Ohio River
.	N 40-05.359 W 80-43.703	
0PQ00000045	R-2 Regulator 1st & Jefferson St.	Ohio River
.	N 40-05.419 W 80-43.598	
0PQ00000046	R-3 Regulator 1st & Center St.	Ohio River
.	N 40-05.855 W 80-42.833	
0PQ00000047	R-1 Regulator 1st & Avondale St.	Ohio River
.	N 40-05.907 W 80-42.749	
0PQ00000048	R-5 Regulator 2nd Avenue	Ohio River
.	N 40-05.291 W 80-43.800	
0PQ00000049	Martins Ferry Lift Station	Ohio River
.	N 40-05.318 w 80-43.752	

D. MONITORING AND REPORTING REQUIREMENTS AND REPORTING CODES

1. If there is no discharge during the month, DO NOT USE THE "AL" CODE or any other code or report "0" for flow. If no discharge occurred for the full monitoring period, select the "No Discharge" check box at the top of the e-DMR form.
2. If there are no discharges on one or more required monitoring days during the month:
 - a. Enter the required monitoring data for the days when a discharge occurred;
 - b. For each required monitoring day there was no discharge, do not enter "0" for flow. Enter code "AC" for each parameter for each monitoring day the facility was not discharging.
3. If no sample is taken on a required monitoring day, use these codes if applicable:
 - a. Use the "AN" or the "AH" codes. Use the "AN" code to indicate when samples are not collected on days that the facility is not normally staffed. The use of this code is limited to Saturdays, Sundays, and officially recognized municipal holidays if the treatment plant is not normally staffed on those days and staff are needed for sampling. This code is only acceptable for parameters that are sampled daily, but cannot be used if continuous monitoring and recording is used, e.g. flow metering, continuous pH or temperature monitoring. For parameters sampled at a lesser frequency, the sampling date should be moved to a date when the facility is staffed. Enter code "AN" for each parameter for each monitoring day the facility was not staffed.

MONITORING AND REPORTING REQUIREMENTS AND REPORTING CODES (con't)

b. Use the "AH" code when a required sample is not taken for a reason other than one covered by another "A" code. An explanation as to why the sample was not taken must be entered as a Specific Comment for that parameter and date on eDMR or in the Remarks Section of the form 4500. Enter code "AH" for each parameter for each monitoring day a sample was not taken.

c. Data Substitution Codes (a.k.a. "A Codes") used on the Monthly Discharge Monitoring Report form or eDMR are as follows:

AA - Below Detectable Limit

AB - Analytical Data Lost

AC - Facility Not Discharging (or No Sludge Hauled)

AD - Automatic Analyzer Out of Service

AE - Analytical Data Not Valid

AF - Sample Site Inaccessible Due to Flooding or Freezing

AH - Sample Not Taken, Explanation Included

AJ - Above Range of Automatic Analyzer

AK - Biological Sample Too Numerous to Count

AL - No Discharge For the Month

AN - Sample Not Taken, Plant Not Normally Staffed (Saturdays, Sundays, and Holidays)

More detailed information about the A Codes is available at:

<http://www.epa.state.oh.us/LinkClick.aspx?fileticket=5vr4U3Jt65A%3d&tabid=3425&mid=6479>

More information about eDMR is at: <http://www.epa.state.oh.us/dsw/edmr/eDMR.aspx>

E. Nine Minimum Controls

The entire wastewater treatment system shall be operated and maintained so that the total loading of pollutants discharged during wet weather is minimized. To accomplish this, the permittee shall utilize the following technologies:

1) provide proper operation and maintenance for the collection system and the combined sewer overflow points;

2) provide the maximum use of the collection system for storage of wet weather flow prior to allowing overflows;

3) review and modify the pretreatment program to minimize the impact of non-domestic discharges from combined sewer overflows; or if there is no pretreatment program review and modify local programs to minimize the impact of non-domestic discharges from combined sewer overflows;

- 4) maximize the capabilities of the POTW to treat wet weather flows, and maximize the wet weather flow to the wastewater treatment plant within the limits of the plant's capabilities;
- 5) prohibit dry weather overflows;
- 6) control solid and floatable materials in the combined sewer overflow discharge;
- 7) conduct required inspection, monitoring and reporting of CSOs;
- 8) implement pollution prevention programs that focus on reducing the level of contaminants in CSOs; and
- 9) implement a public notification program for areas affected by CSOs, especially beaches and recreation areas.

F. SAMPLING WHEN NOT NORMALLY STAFFED

All parameters, except flow, need not be monitored on days when the plant is not normally staffed (Saturdays, Sundays, and Holidays). On those days, report "AN" on the monthly report form.

G. SANITARY SEWER OVERFLOW (SSO) REPORTING REQUIREMENTS

A sanitary sewer overflow is an overflow, spill, release, or diversion of wastewater from a sanitary sewer system. SSOs do not include wet weather discharges from combined sewer overflows specifically listed in Part II of this NPDES permit (if any). All SSOs are prohibited.

1. Reporting for SSOs That Imminently and Substantially Endanger Human Health

a) Immediate Notification

You must notify Ohio EPA (1-800-282-9378) and the appropriate Board of Health (i.e., city or county) within 24 hours of learning of any SSO from your sewers or from your maintenance contract areas that may imminently and substantially endanger human health. The telephone report must identify the location, estimated volume and receiving water, if any, of the overflow. An SSO that may imminently and substantially endanger human health includes dry weather overflows, major line breaks, overflow events that result in fish kills or other significant harm, overflows that expose the general public to contact with raw sewage, and overflow events that occur in sensitive waters and high exposure areas such as protection areas for public drinking water intakes and waters where primary contact recreation occurs.

b) Follow-Up Written Report

Within 5 days of the time you become aware of any SSO that may imminently and substantially endanger human health, you must provide the appropriate Ohio EPA district office a written report that includes:

- (i) the estimated date and time when the overflow began and stopped or will be stopped (if known);
- (ii) the location of the SSO including an identification number or designation if one exists;
- (iii) the receiving water (if there is one);
- (iv) an estimate of the volume of the SSO (if known);
- (v) a description of the sewer system component from which the release occurred (e.g., manhole, constructed overflow pipe, crack in pipe);
- (vi) the cause or suspected cause of the overflow;
- (vii) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the overflow and a schedule of major milestones for those steps; and
- (viii) steps taken or planned to mitigate the impact(s) of the overflow and a schedule of major milestones for those steps.

An acceptable 5-day follow-up written report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at http://www.epa.ohio.gov/dsw/permits/technical_assistance.aspx .

2. Reporting for All SSOs, Including Those That Imminently and Substantially Endanger Human Health

a) Monthly Operating Reports

Sanitary sewer overflows that enter waters of the state, either directly or through a storm sewer or other conveyance, shall be reported on your monthly operating reports. You must report the system-wide number of occurrences for SSOs that enter waters of the state in accordance with the requirements for station number 300. A monitoring table for this station is included in Part I, B of this NPDES permit. For the purpose of counting occurrences, each location on the sanitary sewer system where there is an overflow, spill, release, or diversion of wastewater on a given day is counted as one occurrence. For example, if on a given day overflows occur from a manhole at one location and from a damaged pipe at another location and they both enter waters of the state, you should record two occurrences for that day. If overflows from both locations continue on the following day, you should record two occurrences for the following day. At the end of the month, total the daily occurrences from all locations on your system and report this number using reporting code 74062 (Overflow Occurrence, No./Month) on the 4500 form for station number 300.

b) Annual Report

You must prepare an annual report of all SSOs in your collection system, including those that do not enter waters of the state. The annual report must be in an acceptable format (see below) and must include:

- (i) A table that lists an identification number, a location description, and the receiving water (if any) for each existing SSO. If an SSO previously included in the list has been eliminated, this shall be noted. Assign each SSO location a unique identification by numbering them consecutively, beginning with 301.
- (ii) A table that lists the date that an overflow occurred, the unique ID of the overflow, the name of affected receiving waters (if any), and the estimated volume of the overflow (in millions of gallons). The annual report may summarize information regarding overflows of less than approximately 1,000 gallons.
- (iii) A table that summarizes the occurrence of water in basements (WIBs) by total number and by sewershed. The report shall include a narrative analysis of WIB patterns by location, frequency and cause. Only WIBs caused by a problem in the publicly-owned collection system must be included.

Not later than March 31 of each year, you must submit one copy of the annual report for the previous calendar year to the appropriate Ohio EPA district office and one copy to: Ohio EPA; Division of Surface Water; NPDES Permit Unit; P.O. Box 1049; Columbus, OH, 43216-1049. You also must provide adequate notice to the public of the availability of the report. Adequate public notice would include: notices posted at the community administration building, the public library and the post office; a public notice in the newspaper; or a notice sent out with all sewer bills.

An acceptable annual SSO report can be filled-in or downloaded from the Ohio EPA Division of Surface Water Permits Program Technical Assistance Web page at http://www.epa.ohio.gov/dsw/permits/technical_assistance.aspx.

H. FACILITY OPERATION AND MAINTENANCE

The permittee shall maintain in good working order and operate as efficiently as possible the "treatment works" and "sewerage system" as defined in ORC 6111.01 to achieve compliance with the terms and conditions of this permit and to prevent discharges to the waters of the state, surface of the ground, basements, homes, buildings, etc.

I. (RESERVED)

J. COMPOSITE SAMPLES

Composite samples shall be comprised of a series of grab samples collected over a 24-hour period and , if capable, proportionate in volume to the wastewater flow rate at the time of sampling. Such samples shall be collected at such times and locations, and in such a fashion, as to be representative of the facility's monitored discharge.

K. GRAB SAMPLES

Grab samples shall be collected at such times and locations, and in such a fashion, as to be representative of the facility's monitored discharge.

L. MULTIPLE GRAB SAMPLES

Multiple grab samples shall be comprised of at least three grab samples collected at intervals of at least three hours during the period that the plant is staffed on each day for sampling. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance. The critical value shall be reported.

M. (Reserved)

N. 85% REMOVAL

The treatment works must obtain at least 85 percent removal of carbonaceous biochemical oxygen demand (five-day) and suspended solids (see Part III, Item 1).

O. HAZARDOUS WASTE

POTWs that accept hazardous wastes by truck, rail, or dedicated pipeline are considered to be hazardous waste treatment, storage, and disposal facilities (TSDFs) and are subject to regulation under the Resource Conservation and Recovery Act (RCRA). Under the "permit-by-rule" regulation found at 40 CFR 270.60(c), a POTW must:

1. comply with all conditions of its NPDES permit,
2. obtain a RCRA ID number and comply with certain manifest and reporting requirements under RCRA,
3. satisfy corrective action requirements, and
4. meet all federal, state, and local pretreatment requirements.

P. SEWAGE SLUDGE

1. All disposal, use, storage, or treatment of sewage sludge by the Permittee shall comply with Chapter 6111. of the Ohio Revised Code, Chapter 3745-40 of the Ohio Administrative Code and any future revisions thereof, any further requirements specified in this NPDES permit, and any other actions of the Director that pertain to the disposal, use, storage, or treatment of sewage sludge by the Permittee.
2. Sewage sludge composite samples shall consist of a minimum of six grab samples collected at such times and locations, and in such fashion, as to be representative of the facility's sewage sludge.
3. No later than March 1 of each calendar year, the Permittee shall submit a report summarizing the sewage sludge disposal, use, storage, or treatment activities of the Permittee during the previous calendar year. The report shall be submitted through the Ohio EPA eBusiness Center, Division of Surface Water NPDES Permit Applications service.
4. Each day when sewage sludge is removed from the wastewater treatment plant for use or disposal, a representative sample of sewage sludge shall be collected and analyzed for percent total solids. This value of percent total solids shall be used to calculate the total Sewage Sludge Weight (Discharge Monitoring Report code 70316) and/or total Sewage Sludge Fee Weight (Discharge Monitoring Report code 51129) removed from the treatment plant on that day. The results of the daily monitoring and the weight calculations shall be maintained on site for a minimum of five years. The test methodology used shall be from Part 2540 G of Standard Methods for the Examination of Water and Wastewater American Public Health Association, American Water Works Association, and Water Environment Federation, using the edition which is current on the issuance date of the permit. To convert from gallons of liquid sewage sludge to dry tons of sewage sludge: $\text{dry tons} = \text{gallons} \times 8.34 \text{ (lbs/gallon)} \times 0.0005 \text{ (tons/lb)} \times \text{decimal fraction total solids}$.
5. The Permittee is authorized to dispose of sewage sludge in a sanitary landfill in an emergency. This station (0PQ00000 586) is included in the authorized list of stations in Part II of this permit, however, a table is not included in Part 1.B for this station. If this station is used in an emergency situation, the Permittee shall report the total amount of sludge taken to landfill on the Permittee's Annual Sludge Report. The permittee does not need to report sewage sludge taken to a landfill in an emergency on their Discharge Monitoring Report (DMR).

Q. Monitoring for Dissolved Orthophosphate (as P)

Beginning no later than three months from the effective date of this permit, the permittee shall begin monitoring for dissolved orthophosphate by grab sample. The permittee shall filter the grab sample within 15 minutes of collection using a 0.45-micron filter. The filtered sample must be analyzed within 48 hours. Samples shall be collected at such times and locations, and in such fashion, as to be representative of the facility's overall performance.

R. MERCURY TESTING METHOD

The permittee shall use either EPA Method 1631 or EPA Method 245.7 promulgated under 40 CFR 136 to comply with the influent and effluent mercury monitoring requirements of this permit.

S. TIMING OF INFLUENT 601 AND EFFLUENT 001 SAMPLING

1. Sampling for these parameters at station 0PQ00000 001 and 0PQ00000 601 shall occur the same day.
2. Sampling at station 0PQ00000 001 for these parameters shall occur one detention time (the time it takes for a volume of water to travel through the treatment plant) after sampling at station 0PQ00000 601 for the same parameters on the same day.
3. Sampling at station 0PQ00000 601 for these parameters shall occur one detention time (the time it takes for a volume of water to travel through the treatment plant) prior to sampling at station 0PQ00000 001 for the same parameters on the same day.

T. OUTFALL SIGNS

The permittee shall maintain a permanent marker on the stream bank at each outfall that is regulated under this NPDES permit and discharges directly to the Ohio River, McMahan Creek, Indian Run Creek, Pinch Run and Wheeling Creek. This includes final outfalls and combined sewer overflows. The marker shall consist at a minimum of the name of the establishment to which the permit was issued, the Ohio EPA permit number, and the outfall number and a contact telephone number. The information shall be printed in letters not less than two inches in height. The marker shall be a minimum of 2 feet by 2 feet and shall be a minimum of 3 feet above ground level. The sign shall be not be obstructed such that persons in boats or persons swimming on the river or someone fishing or walking along the shore cannot read the sign. Vegetation shall be periodically removed to keep the sign visible. If the outfall is normally submerged the sign shall indicate that. If the outfall is a combined sewer outfall, the sign shall indicate that untreated human sewage may be discharged from the outfall during wet weather and that harmful bacteria may be present in the water.

U. NOTIFICATION TO PUBLIC WATER SUPPLY OPERATORS

1. As required by the Ohio Administrative Code 3745-33-08(F), permits for facilities designated by the director as major discharges, in the following locations, shall require the permittee to notify the public water supply operator as soon as practicable after a discharge begins that results from a spill, separate sewer overflow, bypass, upset, or combined sewer overflow that reaches waters of the state:

- a. Discharges within three thousand feet of a public water supply intake located in a lake; or
- b. Discharges within ten stream miles upstream of a public water supply intake located in a reservoir or any other surface water of the state.

NOTIFICATION TO PUBLIC WATER SUPPLY OPERATORS (con't)

2. Public water supply operators meeting the criteria in Part II, Item (U)(1) above for the Eastern Ohio Wastewater Authority are:

WHEELING WATER DEPARTMENT
1305 Richland Ave.
Wheeling, WV 26003-3553
(304) 234-3835

BELLAIRE WATER DEPARTMENT
217 37th Belliare, OH 43906
(740) 676-2664

3. Within 6 months of the effective date of this permit, the permittee shall have developed notification procedures between the wastewater system operator and public water supply operator[s] listed above in Part II, Item (U)(2) that defines the specific notification requirements to the public water supply operator and what constitutes notification "as soon as practicable".

V. BIOMONITORING PROGRAM REQUIREMENTS

General Requirements

All toxicity testing conducted as required by this permit shall be done in accordance with Reporting and Testing Guidance for Biomonitoring Required by the Ohio Environmental Protection Agency (hereinafter, the "biomonitoring guidance"), Ohio EPA, July 1998 (or current revision). The Standard Operating Procedures (SOP) or verification of SOP submittal, as described in Section 1.B. of the biomonitoring guidance, shall be submitted no later than three months after the effective date of this permit. If the laboratory performing the testing has modified its protocols, a new SOP is required.

Testing Requirements

1. Acute Bioassays

For the life of this permit, the permittee shall conduct annual definitive acute toxicity tests using *Ceriodaphnia dubia* and fathead minnows (*Pimephales promelas*) on effluent samples from outfall 0PQ00000 001. These tests shall be conducted as specified in Section 2 of the biomonitoring guidance.

2. Testing of Ambient Water

In conjunction with the acute tests, upstream control water shall be collected at a point outside the zone of effluent and receiving water interaction at station 0PQ00000 801.

3. Data Review

a. Reporting

Following completion of each annual bioassay requirement, the permittee shall report results of the tests in accordance with Sections 2.H.1. and 2.H.2.a. of the biomonitoring guidance, including reporting the results on the monthly DMR and submitting a copy of the complete test report to Ohio EPA, Division of Surface Water, NPDES Permit Unit, P.O. Box 1049, Columbus, OH, 43216-1049.

Based on Ohio EPA's evaluation of the results, this permit may be modified to require additional biomonitoring, require a toxicity reduction evaluation, and/or contain whole effluent toxicity limits.

b. Definitions

TUa = Acute Toxicity Units = 100/LC50

W. PRETREATMENT PROGRAM REQUIREMENTS

The permittee's pretreatment program, initially approved on May 30, 2006, and all subsequent modifications approved before the effective date of this permit, shall be an enforceable term and condition of this permit.

To ensure that the approved program is implemented in accordance with 40 CFR 403, Chapter 3745-3 of Ohio Administrative Code and Chapter 6111 of the Ohio Revised Code, the permittee shall comply with the following conditions:

1. Legal Authority

The permittee shall adopt and maintain legal authority which enables it to fully implement and enforce all aspects of its approved pretreatment program including the identification and characterization of industrial sources, issuance of control documents, compliance monitoring and reporting, and enforcement.

The permittee shall establish agreements with all contributing jurisdictions, as necessary, to enable the permittee to fulfill its requirements with respect to industrial users discharging to its system.

2. Funding

The permittee shall have sufficient resources and qualified personnel to fully implement all aspects of its approved pretreatment program.

3. Industrial User Inventory

The permittee shall identify all industrial users subject to pretreatment standards and requirements and characterize the nature and volume of pollutants in their wastewater. Dischargers determined to be Significant Industrial Users according to OAC 3745-3-01(FF) must be notified of applicable pretreatment standards and requirements within 30 days of making such a determination. This inventory shall be updated at a frequency to ensure proper identification and characterization of industrial users.

4. Slug Load Control Plans for Significant Industrial Users

The permittee shall evaluate the need for a plan, device or structure to control a potential slug discharge at least once during the term of each significant industrial user's control mechanism. Existing significant industrial users shall be evaluated within one year of the effective date of this permit if the users have never been evaluated. New industrial users identified as significant industrial users shall be evaluated within one year of being identified as a significant industrial user.

5. Local Limits

The permittee shall develop and enforce technically based local limits to prevent the introduction of pollutants into the POTW which will interfere with the operation of the POTW, pass through the treatment works, be incompatible with the treatment works, or limit wastewater or sludge use options.

The permittee shall use the following waste load allocation values when evaluating local limits for the following pollutants for which a final effluent limit has not been established:

Arsenic 680 ug/l
Cadmium 34 ug/l
Chromium, hexavalent 31 ug/l
Chromium, total 7,226 ug/l
Copper 85 ug/l
Free Cyanide 44 ug/l
Lead 539 ug/l
Mercury 12 ng/l
Molybdenum 370,000 ug/l
Nickel 2,500 ug/l
Selenium 336 ug/l
Zinc 650 ug/l

For the purpose of periodically reevaluating local limits, the permittee shall implement and maintain a sampling program to characterize pollutant contribution to the POTW from industrial and residential sources and to determine pollutant removal efficiencies through the POTW. The permittee shall continue to review and develop local limits as necessary.

6. Control Mechanisms

The permittee shall issue control mechanisms to all industries determined to be Significant Industrial Users as defined in OAC 3745-3-01(FF). Control mechanisms must meet at least the minimum requirements of OAC-3745-3-03(C)(1)(c).

7. Industrial Compliance Monitoring

The permittee shall sample and inspect industrial users in accordance with the approved program or approved modifications, including inspection and sampling of all significant industrial users at least annually. Sample collection, preservation and analysis must be performed in accordance with procedures in 40 CFR 136 and with sufficient care to produce evidence admissible in judicial enforcement proceedings.

The permittee shall also require, receive, and review self-monitoring and other industrial user reports when necessary to determine compliance with pretreatment standards and requirements. If the permittee performs sampling and analysis in lieu of an industrial user's self-monitoring, the permittee shall perform repeat sampling and analysis within 30 days of becoming aware of a permit violation, unless the permittee notifies the user of the violation and requires the user to perform the repeat analysis and reporting.

8. POTW Priority Pollutant Monitoring

The permittee shall annually monitor priority pollutants, as defined by U.S. EPA, in the POTW's influent, effluent and sludge. Sample collection, preservation, and analysis shall be performed using U.S. EPA approved methods.

a. A sample of the influent and the effluent shall be collected when industrial discharges are occurring at normal to maximum levels. Sampling of the influent shall be done prior to any recycle streams and sampling of the effluent shall be after disinfection. Both samples shall be collected on the same day or, alternately, the effluent sample may be collected following the influent sample by approximately the retention time of the POTW.

Sampling of sludge shall be representative of sludge removed to final disposal. A minimum of one grab sample shall be taken during actual sludge removal and disposal unless the POTW uses more than one disposal option. If multiple disposal options are used, the POTW shall collect a composite of grab samples from all disposal practices which are proportional to the annual flows to each type of disposal.

b. A reasonable attempt shall be made to identify and quantify additional constituents (excluding priority pollutants and unsubstituted aliphatic compounds) at each sample location. Identification of additional peaks more than ten times higher than the adjacent background noise on the total ion plots (reconstructed gas chromatograms) shall be attempted through the use of U.S. EPA/NIH computerized library of mass spectra, with visual confirmation by an experienced analyst. Quantification may be based on an order of magnitude estimate compared with an internal standard.

The results of these samples must be submitted on Ohio EPA Form 4221 with the permittee's annual pretreatment report. Samples may be collected at any time during the 12 months preceding the due date of the annual report and may be used to fulfill other NPDES monitoring requirements where applicable.

9. Enforcement

The permittee shall investigate all instances of noncompliance with pretreatment standards and requirements and take timely, appropriate, and effective enforcement action to resolve the noncompliance in accordance with the permittee's approved enforcement response plan.

On or prior to December 15th of each year, the permittee shall publish, in a newspaper of general circulation that provides meaningful public notice within the jurisdiction served by the permittee, a list of industrial users which, during the previous 12 months, have been in Significant Noncompliance [OAC 3745-3-03(C)(2)(h)] with applicable pretreatment standards or requirements.

10. Reporting

All reports required under this section shall be submitted to the following address in duplicate:

Ohio Environmental Protection Agency
Division of Surface Water
Pretreatment Unit
P.O. Box 1049
Columbus, OH 43216-1049

a. Quarterly Industrial User Violation Report

On or prior to the 15th day of January, April, July and October, the permittee shall report the industrial users that are in violation of applicable pretreatment standards during the previous quarter. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include a description of all industrial user violations and corrective actions taken to resolve the violations.

b. Annual Pretreatment Report

On or prior to January 15th of each year, the permittee shall submit an annual report on the effectiveness of the pretreatment program. The report shall be prepared in accordance with guidance provided by Ohio EPA and shall include, but not be limited to: a discussion of program effectiveness; and industrial user inventory; a description of the permittee's monitoring program; a description of any pass through or interference incidents; a copy of the annual publication of industries in Significant Noncompliance; and, priority pollutant monitoring results.

11. Record Keeping

All records of pretreatment activities including, but not limited to, industrial inventory data, monitoring results, enforcement actions, and reports submitted by industrial users must be maintained for a minimum of three (3) years. This period of retention shall be extended during the course of any unresolved litigation. Records must be made available to Ohio EPA and U.S. EPA upon request.

12. Program Modifications

Any proposed modifications of the approved pretreatment program must be submitted to Ohio EPA for review, on forms available from Ohio EPA and consistent with guidance provided by Ohio EPA. If the modification is deemed to be substantial, prior approval must be obtained before implementation; otherwise, the modification is considered to be effective 45 days after the date of application. Substantial program modifications include, among other things, changes to the POTW's legal authority, industrial user control mechanisms, local limits, confidentiality procedures, or monitoring frequencies.

X. PERMIT MAY BE REISSUED

This permit may be modified or revoked and reissued, as provided pursuant to 40 CFR 122.62 and 124.5 and rule 3745-33-04 of the Ohio Administrative Code, for the following reasons:

- To include new or revised conditions developed to comply with any State or Federal law or regulation that addresses combined sewer overflows or sanitary sewer overflows that is adopted or promulgated after the effective date of this permit.
- To include new or revised conditions if new information, not available at the time of permit issuance, indicates that CSO controls imposed under the permit have failed to ensure the attainment of State water quality standards.
- To include new or revised conditions based on new information generated from development and implementation of the permittee's long-term control plan.

In addition, this permit may be modified or revoked and reissued for any reason specified in 40 CFR 122.62 and rule 3745-33-04 of the Ohio Administrative Code.

Y. RENEWAL OF STORM WATER NO EXPOSURE CERTIFICATION

To comply with industrial storm water regulations, the permittee submitted a form for "No Exposure Certification" on July 23, 2015. Compliance with the industrial storm water regulations must be re-affirmed every five years. No later than July 23, 2020, the permittee must submit a new form for "No Exposure Certification" or make other provisions to comply with the industrial storm water regulations.

PART III - GENERAL CONDITIONS

1. DEFINITIONS

"Daily discharge" means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the day.

"Average weekly" discharge limitation means the highest allowable average of "daily discharges" over a calendar week, calculated as the sum of all "daily discharges" measured during a calendar week divided by the number of "daily discharges" measured during that week. Each of the following 7-day periods is defined as a calendar week: Week 1 is Days 1 - 7 of the month; Week 2 is Days 8 - 14; Week 3 is Days 15 - 21; and Week 4 is Days 22 - 28. If the "daily discharge" on days 29, 30 or 31 exceeds the "average weekly" discharge limitation, Ohio EPA may elect to evaluate the last 7 days of the month as Week 4 instead of Days 22 - 28. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"Average monthly" discharge limitation means the highest allowable average of "daily discharges" over a calendar month, calculated as the sum of all "daily discharges" measured during a calendar month divided by the number of "daily discharges" measured during that month. Compliance with fecal coliform bacteria or E coli bacteria limitations shall be determined using the geometric mean.

"85 percent removal" means the arithmetic mean of the values for effluent samples collected in a period of 30 consecutive days shall not exceed 15 percent of the arithmetic mean of the values for influent samples collected at approximately the same times during the same period.

"Absolute Limitations" Compliance with limitations having descriptions of "shall not be less than," "nor greater than," "shall not exceed," "minimum," or "maximum" shall be determined from any single value for effluent samples and/or measurements collected.

"Net concentration" shall mean the difference between the concentration of a given substance in a sample taken of the discharge and the concentration of the same substances in a sample taken at the intake which supplies water to the given process. For the purpose of this definition, samples that are taken to determine the net concentration shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"Net Load" shall mean the difference between the load of a given substance as calculated from a sample taken of the discharge and the load of the same substance in a sample taken at the intake which supplies water to given process. For purposes of this definition, samples that are taken to determine the net loading shall always be 24-hour composite samples made up of at least six increments taken at regular intervals throughout the plant day.

"MGD" means million gallons per day.

"mg/l" means milligrams per liter.

"ug/l" means micrograms per liter.

"ng/l" means nanograms per liter.

"S.U." means standard pH unit.

"kg/day" means kilograms per day.

"Reporting Code" is a five digit number used by the Ohio EPA in processing reported data. The reporting code does not imply the type of analysis used nor the sampling techniques employed.

"Quarterly (1/Quarter) sampling frequency" means the sampling shall be done in the months of March, June, August, and December, unless specifically identified otherwise in the Effluent Limitations and Monitoring Requirements table.

"Yearly (1/Year) sampling frequency" means the sampling shall be done in the month of September, unless specifically identified otherwise in the effluent limitations and monitoring requirements table.

"Semi-annual (2/Year) sampling frequency" means the sampling shall be done during the months of June and December, unless specifically identified otherwise.

"Winter" shall be considered to be the period from November 1 through April 30.

"Bypass" means the intentional diversion of waste streams from any portion of the treatment facility.

"Summer" shall be considered to be the period from May 1 through October 31.

"Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

"Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

"Sewage sludge" means a solid, semi-solid, or liquid residue generated during the treatment of domestic sewage in a treatment works as defined in section 6111.01 of the Revised Code. "Sewage sludge" includes, but is not limited to, scum or solids removed in primary, secondary, or advanced wastewater treatment processes. "Sewage sludge" does not include ash generated during the firing of sewage sludge in a sewage sludge incinerator, grit and screenings generated during preliminary treatment of domestic sewage in a treatment works, animal manure, residue generated during treatment of animal manure, or domestic septage.

"Sewage sludge weight" means the weight of sewage sludge, in dry U.S. tons, including admixtures such as liming materials or bulking agents. Monitoring frequencies for sewage sludge parameters are based on the reported sludge weight generated in a calendar year (use the most recent calendar year data when the NPDES permit is up for renewal).

"Sewage sludge fee weight" means the weight of sewage sludge, in dry U.S. tons, excluding admixtures such as liming materials or bulking agents. Annual sewage sludge fees, as per section 3745.11(Y) of the Ohio Revised Code, are based on the reported sludge fee weight for the most recent calendar year.

2. GENERAL EFFLUENT LIMITATIONS

The effluent shall, at all times, be free of substances:

- A. In amounts that will settle to form putrescent, or otherwise objectionable, sludge deposits; or that will adversely affect aquatic life or water fowl;
- B. Of an oily, greasy, or surface-active nature, and of other floating debris, in amounts that will form noticeable accumulations of scum, foam or sheen;
- C. In amounts that will alter the natural color or odor of the receiving water to such degree as to create a nuisance;
- D. In amounts that either singly or in combination with other substances are toxic to human, animal, or aquatic life;
- E. In amounts that are conducive to the growth of aquatic weeds or algae to the extent that such growths become inimical to more desirable forms of aquatic life, or create conditions that are unsightly, or constitute a nuisance in any other fashion;
- F. In amounts that will impair designated instream or downstream water uses.

3. FACILITY OPERATION AND QUALITY CONTROL

All wastewater treatment works shall be operated in a manner consistent with the following:

- A. At all times, the permittee shall maintain in good working order and operate as efficiently as possible all treatment or control facilities or systems installed or used by the permittee necessary to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with conditions of the permit.
- B. The permittee shall effectively monitor the operation and efficiency of treatment and control facilities and the quantity and quality of the treated discharge.
- C. Maintenance of wastewater treatment works that results in degradation of effluent quality shall be scheduled during non-critical water quality periods and shall be carried out in a manner approved by Ohio EPA as specified in the Paragraph in the PART III entitled, "UNAUTHORIZED DISCHARGES".

4. REPORTING

A. Monitoring data required by this permit shall be submitted monthly on Ohio EPA 4500 Discharge Monitoring Report (DMR) forms using the electronic DMR (e-DMR) internet application. e-DMR allows permitted facilities to enter, sign, and submit DMRs on the internet. e-DMR information is found on the following web page:

<http://www.epa.ohio.gov/dsw/edmr/eDMR.aspx>

Alternatively, if you are unable to use e-DMR due to a demonstrated hardship, monitoring data may be submitted on paper DMR forms provided by Ohio EPA. Monitoring data shall be typed on the forms. Please contact Ohio EPA, Division of Surface Water at (614) 644-2050 if you wish to receive paper DMR forms.

B. DMRs shall be signed by a facility's Responsible Official or a Delegated Responsible Official (i.e. a person delegated by the Responsible Official). The Responsible Official of a facility is defined as:

1. For corporations - a president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or the manager of one or more manufacturing, production or operating facilities, provided the manager is authorized to make management decisions which govern the operation of the regulated facility including having explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures;
2. For partnerships - a general partner;
3. For a sole proprietorship - the proprietor; or,
4. For a municipality, state or other public facility - a principal executive officer, a ranking elected official or other duly authorized employee.

For e-DMR, the person signing and submitting the DMR will need to obtain an eBusiness Center account and Personal Identification Number (PIN). Additionally, Delegated Responsible Officials must be delegated by the Responsible Official, either on-line using the eBusiness Center's delegation function, or on a paper delegation form provided by Ohio EPA. For more information on the PIN and delegation processes, please view the following web page:

<http://epa.ohio.gov/dsw/edmr/eDMR.aspx>

C. DMRs submitted using e-DMR shall be submitted to Ohio EPA by the 20th day of the month following the month-of-interest. DMRs submitted on paper must include the original signed DMR form and shall be mailed to Ohio EPA at the following address so that they are received no later than the 15th day of the month following the month-of-interest:

Ohio Environmental Protection Agency
Lazarus Government Center
Division of Surface Water - PCU
P.O. Box 1049
Columbus, Ohio 43216-1049

D. Regardless of the submission method, a paper copy of the submitted Ohio EPA 4500 DMR shall be maintained onsite for records retention purposes (see Section 7. RECORDS RETENTION). For e-DMR users, view and print the DMR from the Submission Report Information page after each original or revised DMR is submitted. For submittals on paper, make a copy of the completed paper form after it is signed by a Responsible Official or a Delegated Responsible Official.

E. If the permittee monitors any pollutant at the location(s) designated herein more frequently than required by this permit, using approved analytical methods as specified in Section 5. SAMPLING AND ANALYTICAL METHODS, the results of such monitoring shall be included in the calculation and reporting of the values required in the reports specified above.

F. Analyses of pollutants not required by this permit, except as noted in the preceding paragraph, shall not be reported to the Ohio EPA, but records shall be retained as specified in Section 7. RECORDS RETENTION.

5. SAMPLING AND ANALYTICAL METHOD

Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored flow. Test procedures for the analysis of pollutants shall conform to regulation 40 CFR 136, "Test Procedures For The Analysis of Pollutants" unless other test procedures have been specified in this permit. The permittee shall periodically calibrate and perform maintenance procedures on all monitoring and analytical instrumentation at intervals to insure accuracy of measurements.

6. RECORDING OF RESULTS

For each measurement or sample taken pursuant to the requirements of this permit, the permittee shall record the following information:

- A. The exact place and date of sampling; (time of sampling not required on EPA 4500)
- B. The person(s) who performed the sampling or measurements;
- C. The date the analyses were performed on those samples;
- D. The person(s) who performed the analyses;
- E. The analytical techniques or methods used; and
- F. The results of all analyses and measurements.

7. RECORDS RETENTION

The permittee shall retain all of the following records for the wastewater treatment works for a minimum of three years except those records that pertain to sewage sludge disposal, use, storage, or treatment, which shall be kept for a minimum of five years, including:

- A. All sampling and analytical records (including internal sampling data not reported);
- B. All original recordings for any continuous monitoring instrumentation;
- C. All instrumentation, calibration and maintenance records;
- D. All plant operation and maintenance records;
- E. All reports required by this permit; and
- F. Records of all data used to complete the application for this permit for a period of at least three years, or five years for sewage sludge, from the date of the sample, measurement, report, or application.

These periods will be extended during the course of any unresolved litigation, or when requested by the Regional Administrator or the Ohio EPA. The three year period, or five year period for sewage sludge, for retention of records shall start from the date of sample, measurement, report, or application.

8. AVAILABILITY OF REPORTS

Except for data determined by the Ohio EPA to be entitled to confidential status, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the appropriate district offices of the Ohio EPA. Both the Clean Water Act and Section 6111.05 Ohio Revised Code state that effluent data and receiving water quality data shall not be considered confidential.

9. DUTY TO PROVIDE INFORMATION

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

10. RIGHT OF ENTRY

The permittee shall allow the Director or an authorized representative upon presentation of credentials and other documents as may be required by law to:

- A. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit.
- B. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit.
- C. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit.
- D. Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

11. UNAUTHORIZED DISCHARGES

A. Bypass Not Exceeding Limitations - The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs 11.B and 11.C.

B. Notice

1. Anticipated Bypass - If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

2. Unanticipated Bypass - The permittee shall submit notice of an unanticipated bypass as required in paragraph 12.B (24 hour notice).

C. Prohibition of Bypass

1. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- c. The permittee submitted notices as required under paragraph 11.B.

2. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed above in paragraph 11.C.1.

12. NONCOMPLIANCE NOTIFICATION

A. Exceedance of a Daily Maximum Discharge Limit

1. The permittee shall report noncompliance that is the result of any violation of a daily maximum discharge limit for any of the pollutants listed by the Director in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site under the Monitoring and Reporting - Non-Compliance Notification section:

<http://epa.ohio.gov/dsw/permits/individuals.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
- b. The limit(s) that has been exceeded;
- c. The extent of the exceedance(s);
- d. The cause of the exceedance(s);
- e. The period of the exceedance(s) including exact dates and times;
- f. If uncorrected, the anticipated time the exceedance(s) is expected to continue; and,
- g. Steps taken to reduce, eliminate or prevent occurrence of the exceedance(s).

B. Other Permit Violations

1. The permittee shall report noncompliance that is the result of any unanticipated bypass resulting in an exceedance of any effluent limit in the permit or any upset resulting in an exceedance of any effluent limit in the permit by e-mail or telephone within twenty-four (24) hours of discovery.

The permittee may report to the appropriate Ohio EPA district office e-mail account as follows (this method is preferred):

Southeast District Office: sedo24hournpdes@epa.state.oh.us
Southwest District Office: swdo24hournpdes@epa.state.oh.us
Northwest District Office: nwdo24hournpdes@epa.state.oh.us
Northeast District Office: nedo24hournpdes@epa.state.oh.us
Central District Office: cdo24hournpdes@epa.state.oh.us
Central Office: co24hournpdes@epa.state.oh.us

The permittee shall attach a noncompliance report to the e-mail. A noncompliance report form is available on the following web site:

<http://www.epa.ohio.gov/dsw/permits/permits.aspx>

Or, the permittee may report to the appropriate Ohio EPA district office by telephone toll-free between 8:00 AM and 5:00 PM as follows:

Southeast District Office: (800) 686-7330
Southwest District Office: (800) 686-8930
Northwest District Office: (800) 686-6930
Northeast District Office: (800) 686-6330
Central District Office: (800) 686-2330
Central Office: (614) 644-2001

The permittee shall include the following information in the telephone noncompliance report:

- a. The name of the permittee, and a contact name and telephone number;
 - b. The time(s) at which the discharge occurred, and was discovered;
 - c. The approximate amount and the characteristics of the discharge;
 - d. The stream(s) affected by the discharge;
 - e. The circumstances which created the discharge;
 - f. The name and telephone number of the person(s) who have knowledge of these circumstances;
 - g. What remedial steps are being taken; and,
 - h. The name and telephone number of the person(s) responsible for such remedial steps.
2. The permittee shall report noncompliance that is the result of any spill or discharge which may endanger human health or the environment within thirty (30) minutes of discovery by calling the 24-Hour Emergency Hotline toll-free at (800) 282-9378. The permittee shall also report the spill or discharge by e-mail or telephone within twenty-four (24) hours of discovery in accordance with B.1 above.
- C. When the telephone option is used for the noncompliance reports required by A and B, the permittee shall submit to the appropriate Ohio EPA district office a confirmation letter and a completed noncompliance report within five (5) days of the discovery of the noncompliance. This follow up report is not necessary for the e-mail option which already includes a completed noncompliance report.
- D. If the permittee is unable to meet any date for achieving an event, as specified in a schedule of compliance in their permit, the permittee shall submit a written report to the appropriate Ohio EPA district office within fourteen (14) days of becoming aware of such a situation. The report shall include the following:
1. The compliance event which has been or will be violated;
 2. The cause of the violation;
 3. The remedial action being taken;
 4. The probable date by which compliance will occur; and,
 5. The probability of complying with subsequent and final events as scheduled.
- E. The permittee shall report all other instances of permit noncompliance not reported under paragraphs A or B of this section on their monthly DMR submission. The DMR shall contain comments that include the information listed in paragraphs A or B as appropriate.
- F. If the permittee becomes aware that it failed to submit an application, or submitted incorrect information in an application or in any report to the director, it shall promptly submit such facts or information.

13. RESERVED

14. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

15. AUTHORIZED DISCHARGES

All discharges authorized herein shall be consistent with the terms and conditions of this permit. The discharge of any pollutant identified in this permit more frequently than, or at a level in excess of, that authorized by this permit shall constitute a violation of the terms and conditions of this permit. Such violations may result in the imposition of civil and/or criminal penalties as provided for in Section 309 of the Act and Ohio Revised Code Sections 6111.09 and 6111.99.

16. DISCHARGE CHANGES

The following changes must be reported to the appropriate Ohio EPA district office as soon as practicable:

A. For all treatment works, any significant change in character of the discharge which the permittee knows or has reason to believe has occurred or will occur which would constitute cause for modification or revocation and reissuance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements. Notification of permit changes or anticipated noncompliance does not stay any permit condition.

B. For publicly owned treatment works:

1. Any proposed plant modification, addition, and/or expansion that will change the capacity or efficiency of the plant;
2. The addition of any new significant industrial discharge; and
3. Changes in the quantity or quality of the wastes from existing tributary industrial discharges which will result in significant new or increased discharges of pollutants.

C. For non-publicly owned treatment works, any proposed facility expansions, production increases, or process modifications, which will result in new, different, or increased discharges of pollutants.

Following this notice, modifications to the permit may be made to reflect any necessary changes in permit conditions, including any necessary effluent limitations for any pollutants not identified and limited herein. A determination will also be made as to whether a National Environmental Policy Act (NEPA) review will be required. Sections 6111.44 and 6111.45, Ohio Revised Code, require that plans for treatment works or improvements to such works be approved by the Director of the Ohio EPA prior to initiation of construction.

D. In addition to the reporting requirements under 40 CFR 122.41(l) and per 40 CFR 122.42(a), all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Director as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge on a routine or frequent basis of any toxic pollutant which is not limited in the permit. If that discharge will exceed the highest of the "notification levels" specified in 40 CFR Sections 122.42(a)(1)(i) through 122.42(a)(1)(iv).
2. That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the "notification levels" specified in 122.42(a)(2)(i) through 122.42(a)(2)(iv).

17. TOXIC POLLUTANTS

The permittee shall comply with effluent standards or prohibitions established under Section 307 (a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement. Following establishment of such standards or prohibitions, the Director shall modify this permit and so notify the permittee.

18. PERMIT MODIFICATION OR REVOCATION

A. After notice and opportunity for a hearing, this permit may be modified or revoked, by the Ohio EPA, in whole or in part during its term for cause including, but not limited to, the following:

1. Violation of any terms or conditions of this permit;
2. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts; or
3. Change in any condition that requires either a temporary or permanent reduction or elimination of the permitted discharge.

B. Pursuant to rule 3745-33-04, Ohio Administrative Code, the permittee may at any time apply to the Ohio EPA for modification of any part of this permit. The filing of a request by the permittee for a permit modification or revocation does not stay any permit condition. The application for modification should be received by the appropriate Ohio EPA district office at least ninety days before the date on which it is desired that the modification become effective. The application shall be made only on forms approved by the Ohio EPA.

19. TRANSFER OF OWNERSHIP OR CONTROL

This permit may be transferred or assigned and a new owner or successor can be authorized to discharge from this facility, provided the following requirements are met:

A. The permittee shall notify the succeeding owner or successor of the existence of this permit by a letter, a copy of which shall be forwarded to the appropriate Ohio EPA district office. The copy of that letter will serve as the permittee's notice to the Director of the proposed transfer. The copy of that letter shall be received by the appropriate Ohio EPA district office sixty (60) days prior to the proposed date of transfer;

B. A written agreement containing a specific date for transfer of permit responsibility and coverage between the current and new permittee (including acknowledgement that the existing permittee is liable for violations up to that date, and that the new permittee is liable for violations from that date on) shall be submitted to the appropriate Ohio EPA district office within sixty days after receipt by the district office of the copy of the letter from the permittee to the succeeding owner;

At anytime during the sixty (60) day period between notification of the proposed transfer and the effective date of the transfer, the Director may prevent the transfer if he concludes that such transfer will jeopardize compliance with the terms and conditions of the permit. If the Director does not prevent transfer, he will modify the permit to reflect the new owner.

20. OIL AND HAZARDOUS SUBSTANCE LIABILITY

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Clean Water Act.

21. SOLIDS DISPOSAL

Collected grit and screenings, and other solids other than sewage sludge, shall be disposed of in such a manner as to prevent entry of those wastes into waters of the state, and in accordance with all applicable laws and rules.

22. CONSTRUCTION AFFECTING NAVIGABLE WATERS

This permit does not authorize or approve the construction of any onshore or offshore physical structures or facilities or the undertaking of any work in any navigable waters.

23. CIVIL AND CRIMINAL LIABILITY

Except as exempted in the permit conditions on UNAUTHORIZED DISCHARGES or UPSETS, nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance.

24. STATE LAWS AND REGULATIONS

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by Section 510 of the Clean Water Act.

25. PROPERTY RIGHTS

The issuance of this permit does not convey any property rights in either real or personal property, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations.

26. UPSET

The provisions of 40 CFR Section 122.41(n), relating to "Upset," are specifically incorporated herein by reference in their entirety. For definition of "upset," see Part III, Paragraph 1, DEFINITIONS.

27. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

28. SIGNATORY REQUIREMENTS

All applications submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR 122.22.

All reports submitted to the Director shall be signed and certified in accordance with the requirements of 40 CFR Section 122.22.

29. OTHER INFORMATION

A. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

B. ORC 6111.99 provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

C. ORC 6111.99 states that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit including monitoring reports or reports of compliance or noncompliance shall, upon conviction, be punished by a fine of not more than \$25,000 per violation.

D. ORC 6111.99 provides that any person who violates Sections 6111.04, 6111.042, 6111.05, or division (A) of Section 6111.07 of the Revised Code shall be fined not more than \$25,000 or imprisoned not more than one year, or both.

30. NEED TO HALT OR REDUCE ACTIVITY

40 CFR 122.41(c) states that it shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with conditions of this permit.

31. APPLICABLE FEDERAL RULES

All references to 40 CFR in this permit mean the version of 40 CFR which is effective as of the effective date of this permit.

32. AVAILABILITY OF PUBLIC SEWERS

Notwithstanding the issuance or non-issuance of an NPDES permit to a semi-public disposal system, whenever the sewage system of a publicly owned treatment works becomes available and accessible, the permittee operating any semi-public disposal system shall abandon the semi-public disposal system and connect it into the publicly owned treatment works.